Board of County Commissioners

Eva J. Henry - District #1
Charles "Chaz" Tedesco - District #2
Erik Hansen - District #3
Steve O'Dorisio - District #4
Jan Pawlowski - District #5

PUBLIC HEARING AGENDA

NOTICE TO READERS: The Board of County Commissioners' meeting packets are prepared several days prior to the meeting. This information is reviewed and studied by the Board members to gain a basic understanding, thus eliminating lengthy discussions. Timely action and short discussion on agenda items does not reflect a lack of thought or analysis on the Board's part. An informational packet is available for public inspection in the Board's Office one day prior to the meeting.

THIS AGENDA IS SUBJECT TO CHANGE

Tuesday
November 22, 2016
9:30 AM

1. **ROLL CALL**

2. **PLEDGE OF ALLEGIANCE**

3. **MOTION TO APPROVE AGENDA**

4. **AWARDS AND PRESENTATIONS**

5. **PUBLIC COMMENT**

   A. **Citizen Communication**

   A total of 30 minutes is allocated at this time for public comment and each speaker will be limited to 3 minutes. If there are additional requests from the public to address the Board, time will be allocated at the end of the meeting to complete public comment. The chair requests that there be no public comment on issues for which a prior public hearing has been held before this Board.

   B. **Elected Officials' Communication**

6. **CONSENT CALENDAR**

A.	List of Expenditures Under the Dates of November 7-11, 2016
B.	Minutes of the Commissioners' Proceedings from November 15, 2016
C.	Resolution Approving Change Order #001 for the 2016 Seal Project, Modification of Pay Quantities of Existing Items
D.	Resolution Approving Agreement between Adams County and Clinica Family Health Services to Provide Medicaid Application Processing Services at Clinica Family Health Services Facilities

E. Resolution Supporting and Approving the Sponsorship of a School Yard Grant from the State Board of the Great Outdoors Colorado Trust Fund for the Crawford Elementary School Project

F. Resolution Approving the Provision of Career Services in Alignment with the Workforce Innovation and Opportunity Act of 2014

G. Resolution Approving Ambulance Service License for City of Federal Heights Fire Department

7. NEW BUSINESS

A. COUNTY MANAGER

1. Resolution Approving Amendment One to an Agreement with Cohen Milstein Sellers & Toll, PLLC for Independent Ethics Compliance Officer Services for Adams County

2. Resolution Approving Amendment One to Agreement between Adams County and Almost Home Inc. to Provide Emergency Shelter and Transitional Housing for Temporary Assistance for Needy Families (TANF) in Adams County

B. COUNTY ATTORNEY

1. Resolution Adopting Adams County ADA Transition Plans and Policies

8. Motion to Adjourn into Executive Session Pursuant to C.R.S. 24-6-402(4)(a) and (e) to Discuss the Transfer or Sale of Real Property and to Instruct Negotiators Accordingly

9. ADJOURNMENT

AND SUCH OTHER MATTERS OF PUBLIC BUSINESS WHICH MAY ARISE

County of Adams

Net Warrant by Fund Summary

Fund Number	Fund Description	Amount
1	General Fund	290,669.94
5	Golf Course Enterprise Fund	17,802.48
6	Equipment Service Fund	108,300.56
13	Road & Bridge Fund	54,996.46
19	Insurance Fund	59,211.50
24	Conservation Trust Fund	1,387.50
27	Open Space Projects Fund	7,217.59
28	Open Space Sales Tax Fund	497,934.46
30	Community Dev Block Grant Fund	153,377.24
31	Head Start Fund	28,663.20
35	Workforce & Business Center	15,607.24
43	Front Range Airport	42.00
		1,235,210.17

1 General Fund

Warrant	Supplier No	Supplier Name	Warrant Date	Amount
00701280	45821	BERRY PATCH FARMS	11/07/16	200.00
00701281	293119	BUZEK, VINCE	11/07/16	65.00
00701286	317819	CLUB, RISING SUN 4-H	11/07/16	100.00
00701287	330717	COLO DEPT OF TREASURY	11/07/16	1,702.90
00701288	28639	COLO STATE UNIVERSITY	11/07/16	46.00
00701290	44926	CSU LARIMER COUNTY EXTENSION	11/07/16	226.80
00701294	293118	GARNER, ROSIE	11/07/16	65.00
00701295	152924	GIBNEY HARRY	11/07/16	65.00
00701299	34197	GOURD THADDEUS	11/07/16	306.18
00701300	26333	GRAF TREVOR G	11/07/16	292.00
00701302	49039	I70 PUBLISHING CO INC	11/07/16	44.00
00701312	87014	MOLINARO SAM	11/07/16	65.00
00701313	5026	MOSKO STEW	11/07/16	65.00
00701319	491149	REICHOW RAE-ANNE	11/07/16	76.68
00701320	53054	RICHARDSON SHARON	11/07/16	65.00
00701322	526745	ROMO SONNEMAN, VINCENT	11/07/16	79.00
00701325	385142	THOMPSON GREGORY PAUL	11/07/16	65.00
00701326	1007	UNITED POWER (UNION REA)	11/07/16	84.75
00701327	28975	VERIZON WIRELESS	11/07/16	301.68
00701328	13822	XCEL ENERGY	11/07/16	40.32
00701329	13822	XCEL ENERGY	11/07/16	189.99
00701330	13822	XCEL ENERGY	11/07/16	277.73
00701331	13822	XCEL ENERGY	11/07/16	499.86
00701332	13822	XCEL ENERGY	11/07/16	164.78
00701333	13822	XCEL ENERGY	11/07/16	80.60
00701334	245053	ACCO BRANDS USA LLC	11/07/16	312.00
00701335	30273	ADAMS COUNTY DETENTION FACILIT	11/07/16	144.90
00701336	91631	ADAMSON POLICE PRODUCTS	11/07/16	6,660.00
00701337	385085	ALL STAR HOOD CLEANING	11/07/16	2,995.00
00701338	228213	ARAMARK REFRESHMENT SERVICES	11/07/16	875.19
00701339	2914	BOB BARKER COMPANY	11/07/16	7,175.20
00701340	37266	CENTURY LINK	11/07/16	205.39
00701341	1279	COLO ASSN OF CHIEFS OF POLICE	11/07/16	1,500.00
00701342	435713	COLO DEPT OF CORRECTIONS	11/07/16	28.00
00701344	78873	COMCAST CABLE	11/07/16	1.95
00701345	13049	COMMUNITY REACH CENTER	11/07/16	39,798.60

1 General Fund

Warrant	Supplier No	Supplier Name	Warrant Date	Amount
00701346	13049	COMMUNITY REACH CENTER	11/07/16	300.00
00701347	251244	COMMUNITY REACH CENTER	11/07/16	60.00
00701348	255001	COPYCO QUALITY PRINTING INC	11/07/16	120.00
00701349	255001	COPYCO QUALITY PRINTING INC	11/07/16	435.00
00701350	255001	COPYCO QUALITY PRINTING INC	11/07/16	155.00
00701351	255001	COPYCO QUALITY PRINTING INC	11/07/16	440.00
00701352	255001	COPYCO QUALITY PRINTING INC	11/07/16	310.00
00701353	248103	DS WATERS OF AMERICA INC	11/07/16	162.83
00701355	691812	EXTREME TOWING & RECOVERY SERV	11/07/16	68.00
00701356	346534	FIRST CHOICE COFFEE SERVICES	11/07/16	179.80
00701357	28726	G & K SERVICES	11/07/16	181.30
00701358	12689	GALLS LLC	11/07/16	256.25
00701360	258403	JABARI HOWRIE	11/07/16	75.00
00701361	437558	LANDING PLACE CHURCH	11/07/16	650.00
00701362	36861	LEXIS NEXIS MATTHEW BENDER	11/07/16	2,034.99
00701363	296521	MEAD GLENDA	11/07/16	21.60
00701364	4551	NEVE'S UNIFORMS INC	11/07/16	1,155.09
00701365	6703	NORTH METRO FIRE RESCUE	11/07/16	1,200.00
00701366	36746	PEDRUCCI MARC R	11/07/16	79.38
00701367	163837	PTS OF AMERICA LLC	11/07/16	2,192.58
00701368	53265	SAMS CLUB	11/07/16	836.31
00701369	13538	SHRED IT USA LLC	11/07/16	324.25
00701370	7406	SIERRA DETENTION SYSTEMS	11/07/16	200.00
00701371	37005	TOSHIBA BUSINESS SOLUTIONS	11/07/16	1,691.81
00701372	28617	VERIZON WIRELESS	11/07/16	1,012.26
00701373	319425	WACKER AMBER	11/07/16	75.00
00701374	24560	WIRELESS ADVANCED COMMUNICATIO	11/07/16	360.00
00701375	8158	ZONES INC	11/07/16	504.86
00701376	433987	ADCO DISTRICT ATTORNEY'S OFFIC	11/08/16	922.02
00701377	13060	ADCO HUMAN SERVICES DEPT	11/08/16	13.78
00701381	32273	ALL COPY PRODUCTS INC	11/08/16	92.94
00701383	12012	ALSCO AMERICAN INDUSTRIAL	11/08/16	61.51
00701388	923923	BOSTON DOE LORENA	11/08/16	1,593.00
00701389	13160	BRIGHTON CITY OF (WATER)	11/08/16	702.54
00701390	13160	BRIGHTON CITY OF (WATER)	11/08/16	2,701.05
00701391	13160	BRIGHTON CITY OF (WATER)	11/08/16	12,251.96

1 General Fund

Warrant	Supplier No	Supplier Name	Warrant Date	Amount
00701392	13160	BRIGHTON CITY OF (WATER)	11/08/16	106.32
00701393	13160	BRIGHTON CITY OF (WATER)	11/08/16	17,198.01
00701395	48966	BUEHLER MOVING & STORAGE	11/08/16	1,345.00
00701397	6331	COLO ASSESSORS ASSN	11/08/16	60.00
00701398	209334	COLO NATURAL GAS INC	11/08/16	42.86
00701400	40374	COSTAR REALTY INFORMATION INC	11/08/16	2,808.39
00701402	545111	GUSTAD DAVID	11/08/16	772.00
00701405	545281	MOODY JANET LEA	11/08/16	494.15
00701406	535881	PHOENIX MASONRY INC	11/08/16	3,909.00
00701407	189866	QUINTANA LINDA	11/08/16	21.60
00701408	365736	RACING UNDERGROUND LLC	11/08/16	500.00
00701409	544975	RBA ATTORNEY SERVICES	11/08/16	60.00
00701410	263724	RED HAWK FIRE & SECURITY	11/08/16	393.00
00701412	6125	SUMMIT COUNTY SHERIFF	11/08/16	25.26
00701414	4755	THORNTON CITY OF WATER & SEWER	11/08/16	565.77
00701415	38974	TIARA PRINTING INC	11/08/16	317.78
00701416	3333	U S POSTMASTER	11/08/16	361.65
00701417	545488	VORTEX COLORADO INC	11/08/16	1,086.81
00701418	1038	WAGNER RENTS	11/08/16	250.00
00701419	46796	WESTMINSTER CITY OF	11/08/16	657.88
00701420	46796	WESTMINSTER CITY OF	11/08/16	2,862.97
00701421	13822	XCEL ENERGY	11/08/16	49.78
00701422	13822	XCEL ENERGY	11/08/16	88.42
00701423	13822	XCEL ENERGY	11/08/16	11,466.33
00701424	13822	XCEL ENERGY	11/08/16	5,653.10
00701425	13822	XCEL ENERGY	11/08/16	10,145.97
00701426	13822	XCEL ENERGY	11/08/16	1,616.97
00701427	13822	XCEL ENERGY	11/08/16	868.85
00701428	13822	XCEL ENERGY	11/08/16	85.00
00701429	13822	XCEL ENERGY	11/08/16	277.28
00701430	13822	XCEL ENERGY	11/08/16	242.38
00701431	13822	XCEL ENERGY	11/08/16	142.01
00701433	13040	ADCO DISTRICT ATTORNEY	11/09/16	313.82
00701434	383698	ALLIED BARTON SECURITY SERVICE	11/09/16	1,395.63
00701435	445583	ALVAREZ MEGAN	11/09/16	276.21
00701436	642157	ARELLANO JESSICA	11/09/16	30.24

1 General Fund

Warrant	Supplier No	Supplier Name	Warrant Date	Amount
00701437	322973	ARMORED KNIGHTS INC	11/09/16	1,994.64
00701438	237471	AZZOLINA CAROL	11/09/16	75.33
00701440	134826	CASA OF ADAMS & BROOMFIELD COU	11/09/16	2,500.00
00701443	308324	DELGADO NICOLE	11/09/16	69.66
00701446	438625	GOVERNOR'S OFFICE OF IT	11/09/16	820.70
00701447	278010	HART JULIE	11/09/16	21.00
00701448	486419	HIGH COUNTRY BEVERAGE	11/09/16	534.05
00701449	48322	JACHETTA TINA	11/09/16	28.73
00701450	445584	LAMANNA BARBARA	11/09/16	220.00
00701451	12816	MATTIE BRIAN S	11/09/16	99.00
00701452	51500	MERRICK & COMPANY	11/09/16	2,399.10
00701455	419058	ROBINSON KENNETH	11/09/16	130.68
00701456	455680	RUELAS RAFAEL	11/09/16	85.32
00701458	222147	SHEIKH TARIQ	11/09/16	89.64
00701459	281167	SPECTRA CONTRACT FLOORING SERV	11/09/16	250.00
00701460	281167	SPECTRA CONTRACT FLOORING SERV	11/09/16	275.00
00701461	281167	SPECTRA CONTRACT FLOORING SERV	11/09/16	275.00
00701462	281167	SPECTRA CONTRACT FLOORING SERV	11/09/16	2,400.00
00701464	278011	STUEVE SARA	11/09/16	60.00
00701467	499882	UNGERBOECK SYSTEMS INTERNATION	11/09/16	9,014.00
00701468	7162	WAGNER GEORGIA C	11/09/16	9.00
00701505	42415	AMERICAN INCOME LIFE INS CO	11/10/16	57.00
00701511	463401	BUSH MELVIN E	11/10/16	65.00
00701516	203990	COLORADO STATE UNIVERSITY	11/10/16	661.00
00701519	293123	ELSEROUGI, A J	11/10/16	65.00
00701521	4084	FENCE POST THE	11/10/16	79.04
00701524	293124	HODGE, DICK	11/10/16	65.00
00701533	140397	REAL AUCTION.COM LLC	11/10/16	16,209.00
00701535	10449	SIR SPEEDY	11/10/16	95.30
00701536	315130	STANFIELD THOMSON	11/10/16	65.00
00701537	628772	TUCKER JENNIFER	11/10/16	532.44
00701539	51244	WARD LABORATORIES INC	11/10/16	38.00
00701540	422130	ABL MANAGEMENT INC	11/10/16	28,889.88
00701541	13028	ADAMS COUNTY ASSESSOR	11/10/16	85.86
00701542	13883	ADAMS COUNTY SHERIFF	11/10/16	156.21
00701543	383698	ALLIED BARTON SECURITY SERVICE	11/10/16	14,663.42

1 General Fund

Warrant	Supplier No	Supplier Name	Warrant Date	Amount
00701544	426680	ARISING HOPE INTERNATIONAL	11/10/16	250.00
00701545	37266	CENTURY LINK	11/10/16	88.99
00701546	5556	COLO BUREAU INVESTIGATION-IDEN	11/10/16	1,170.00
00701547	30309	COLO DEPT OF AGRICULTURE/ICS	11/10/16	316.00
00701548	44656	DENVER HEALTH & HOSPITAL AUTHO	11/10/16	6,080.00
00701549	248103	DS WATERS OF AMERICA INC	11/10/16	1,082.22
00701550	169560	FISHER JULIE	11/10/16	196.49
00701551	13545	INTL ASSN OF ASSESSING OFFICE	11/10/16	190.00
00701552	13545	INTL ASSN OF ASSESSING OFFICE	11/10/16	190.00
00701553	40843	LANGUAGE LINE SERVICES	11/10/16	511.68
00701554	16423	LASER TECHNOLOGY INC	11/10/16	7,980.00
00701555	42876	LEXISNEXIS RISK SOLUTIONS	11/10/16	97.85
00701556	13988	LIFE LOC INC	11/10/16	208.00
00701557	311118	LIGHTFIELD LESS LETHAL RESEARC	11/10/16	607.50
00701558	51274	MCDONALD YONG HUI V	11/10/16	5,852.25
00701559	93018	MURPHY RICK	11/10/16	5,054.61
00701560	165772	NORDHOLM MICHELLE K	11/10/16	11.34
00701561	4842	PITNEY BOWES	11/10/16	39.09
00701562	381710	PRAIRIE VIEW HIGH SCHOOL	11/10/16	280.00
00701563	48924	PRO TECH COMPUTER SYSTEMS INC	11/10/16	102.00
00701564	163837	PTS OF AMERICA LLC	11/10/16	2,161.55
00701565	50300	RAMIREZ GABRIELLA	11/10/16	309.00
00701566	3569	ROCKY MTN CONVEYOR & EQUIPT	11/10/16	2,172.91
00701567	339372	ROSS SHIRLEY M	11/10/16	1,035.00
00701568	369706	SANDOVAL DANIELLE	11/10/16	111.24
00701570	98724	SCHAREN DIANNA	11/10/16	11.34
00701571	13538	SHRED IT USA LLC	11/10/16	126.53
00701572	95723	TALLEY LORI	11/10/16	29.00
00701573	98721	TOTAYS TAMSIN	11/10/16	88.56
00701574	28617	VERIZON WIRELESS	11/10/16	1,785.74
00701575	121912	ZOE TRAINING & CONSULTING	11/10/16	4,678.00
			Fund Total	**290,669.94**

5 Golf Course Enterprise Fund

Warrant	Supplier No	Supplier Name	Warrant Date	Amount
00701378	8579	AGFINITY INC	11/08/16	10,103.86
00701379	302764	AGFINITY INC	11/08/16	3,522.58
00701384	12012	ALSCO AMERICAN INDUSTRIAL	11/08/16	40.26
00701394	9822	BUCKEYE WELDING SUPPLY CO INC	11/08/16	26.00
00701401	160270	GOLF & SPORT SOLUTIONS	11/08/16	1,007.49
00701404	11496	L L JOHNSON DIST	11/08/16	3,039.23
00701432	13822	XCEL ENERGY	11/08/16	63.06
			Fund Total	**17,802.48**

6 Equipment Service Fund

Warrant	Supplier No	Supplier Name	Warrant Date	Amount
00701403	491796	HRT ENTERPRISES LLC	11/08/16	130.00
00701454	324769	PRECISE MRM LLC	11/09/16	6,548.13
00701457	16237	SAM HILL OIL INC	11/09/16	13,887.43
00701463	99671	SPRADLEY BARR FORD GREELEY	11/09/16	82,805.00
00701469	24560	WIRELESS ADVANCED COMMUNICATIO	11/09/16	4,930.00
			Fund Total	**108,300.56**

13 Road & Bridge Fund

Warrant	Supplier No	Supplier Name	Warrant Date	Amount
00701380	100083	ALDERMAN BERNSTEIN	11/08/16	2,179.50
00701382	545932	ALPINE WASTE & RECYCLING	11/08/16	1,361.42
00701444	128693	DREXEL BARRELL & CO	11/09/16	48,140.38
00701466	36806	TERRACON	11/09/16	1,448.75
00701506	23969	ASPHALT SPECIALTIES CO INC	11/10/16	142.80
00701507	23969	ASPHALT SPECIALTIES CO INC	11/10/16	170.35
00701508	23969	ASPHALT SPECIALTIES CO INC	11/10/16	1,341.26
00701509	23969	ASPHALT SPECIALTIES CO INC	11/10/16	212.00
			Fund Total	**54,996.46**

19 Insurance Fund

Warrant	Supplier No	Supplier Name	Warrant Date	Amount
00701442	13297	COLO STATE TREASURER	11/09/16	56,556.50
00701445	435111	EXTREME ENGRAVING	11/09/16	2,655.00
			Fund Total	**59,211.50**

24 Conservation Trust Fund

Warrant	Supplier No	Supplier Name	Warrant Date	Amount
00701343	10074	COLO OPEN LANDS	11/07/16	770.00
00701359	229733	GORDON SIGN	11/07/16	617.50
			Fund Total	**1,387.50**

27 Open Space Projects Fund

Warrant	Supplier No	Supplier Name	Warrant Date	Amount
00701354	42542	ERMOLD PARK & RECREATION PROD	11/07/16	2,084.00
00701518	237568	DESIGN WORKSHOP	11/10/16	5,133.59
			Fund Total	**7,217.59**

28 Open Space Sales Tax Fund

Warrant	Supplier No	Supplier Name	Warrant Date	Amount
00701385	1080	AURORA CITY OF	11/08/16	386,000.00
00701386	48132	BENNETT SCHOOLS	11/08/16	89,512.83
00701387	39402	BIRD CONSERVANCY OF THE ROCKIE	11/08/16	20,899.50
00701411	516922	ROCKY MOUNTAIN ARSENAL NATL WI	11/08/16	1,522.13
			Fund Total	**497,934.46**

30 Community Dev Block Grant Fund

Warrant	Supplier No	Supplier Name	Warrant Date	Amount
00701276	419012	ARCHWAY HOUSING AND SERVICES	11/07/16	153,377.24
			Fund Total	**153,377.24**

31 Head Start Fund

Warrant	Supplier No	Supplier Name	Warrant Date	Amount
00701274	90536	ANDREWS PRODUCE INC	11/07/16	10,176.60
00701301	100577	HENDERSON CYNDI	11/07/16	9.52
00701413	13770	SYSCO DENVER	11/08/16	51.00
00701439	245316	CARNATION BUILDING SERVICES IN	11/09/16	2,101.20
00701441	130454	CHILDRENS HOSPITAL COLORADO	11/09/16	2,297.70
00701453	310256	ONE WORLD TRANSLATION & ASSOCI	11/09/16	113.78
00701465	13770	SYSCO DENVER	11/09/16	2,400.14
00701510	45333	BRAGGS- JONES SHONDRELA	11/10/16	104.76
00701512	37266	CENTURY LINK	11/10/16	340.24
00701513	37266	CENTURY LINK	11/10/16	1,117.91
00701514	37266	CENTURY LINK	11/10/16	97.42
00701515	152461	CENTURYLINK	11/10/16	16.70
00701517	248029	COMMUNITY REACH CENTER FOUNDAT	11/10/16	6,190.04
00701520	319944	FARSTER NARLESKY PENNY	11/10/16	72.90
00701522	28726	G & K SERVICES	11/10/16	122.98
00701523	434213	HAGER MICHAEL	11/10/16	53.46
00701525	77611	KD SERVICE GROUP	11/10/16	2,019.35
00701526	342449	LILLIE SHANNON	11/10/16	63.77
00701527	499215	MUDGETTE THERESA	11/10/16	51.84
00701529	55021	NULINX INTERNATIONAL	11/10/16	820.00
00701530	371505	OLIVER LESLIE	11/10/16	84.24
00701531	1463	ORKIN PEST CONTROL	11/10/16	83.80
00701532	129209	RAMIREZ SUSANA	11/10/16	169.09
00701534	537347	SANCHEZ MARITZA	11/10/16	18.36
00701538	354139	WALMSLEY NATASHA	11/10/16	86.40
			Fund Total	**28,663.20**

35 Workforce & Business Center

Warrant	Supplier No	Supplier Name	Warrant Date	Amount
00701275	36820	AGUINIGA CAROL	11/07/16	135.85
00701277	35827	BANKS RACHEL	11/07/16	56.16
00701278	28889	BARRIBO LAURA	11/07/16	17.82
00701279	369657	BERNAL JUAN FELIPE	11/07/16	49.14
00701282	443755	CANAL VALLEJO ATHENAS	11/07/16	94.27
00701283	152461	CENTURYLINK	11/07/16	303.77
00701284	90879	CHAVEZ BELIA P	11/07/16	22.68
00701285	258669	CLARK RYNE	11/07/16	50.44
00701289	255001	COPYCO QUALITY PRINTING INC	11/07/16	49.98
00701291	354196	DUKE STEPHANI	11/07/16	28.62
00701292	38689	ELLIS CHARLES	11/07/16	124.34
00701293	369792	FLORES MICHAEL	11/07/16	76.68
00701296	843241	GLASSER NOELLE	11/07/16	195.48
00701297	68923	GONZALEZ JEANETTE	11/07/16	90.18
00701298	138164	GONZALEZ JESSICA	11/07/16	16.74
00701303	38692	JOHNSON LORRAINE	11/07/16	22.68
00701304	281998	KAMMERZELL JODIE	11/07/16	80.96
00701305	38693	KERR CRISTINE	11/07/16	43.50
00701306	514419	LUNA EVANGELINA S	11/07/16	62.64
00701307	62480	MARTINEZ MARTHA	11/07/16	37.80
00701308	90481	MCDANIEL JENNIFER	11/07/16	36.18
00701309	49485	MCGIRR RITA	11/07/16	57.55
00701310	78254	MEDINA KRISTINA	11/07/16	60.48
00701311	342309	MENDOZA MICHELLE	11/07/16	130.99
00701314	42283	OLSEN KATHRYN	11/07/16	128.10
00701315	481825	PARRA ALDO	11/07/16	144.18
00701316	514882	PEDREGON SYDNEY	11/07/16	102.60
00701317	40920	POST REBECCA	11/07/16	274.86
00701318	460724	REFACTORU LLC	11/07/16	6,000.00
00701323	470649	SANTINO HEATHER	11/07/16	53.46
00701324	13538	SHRED IT USA LLC	11/07/16	60.00
00701396	450030	BUENO MICHELLE ELAINE	11/08/16	1,600.00
00701399	1483	COMPUTER SYSTEMS DESIGN	11/08/16	4,800.00
00701528	143339	NOBLE PHILLIPP	11/10/16	271.56
00701569	357890	SCHAGER BRETT	11/10/16	327.55
			Fund Total	**15,607.24**

43 Front Range Airport

Warrant	Supplier No	Supplier Name	Warrant Date	Amount
00701321	44131	ROGGEN FARMERS ELEVATOR ASSN	11/07/16	42.00
			Fund Total	**42.00**

Grand Total	**1,235,210.17**

4304	Airport Operations/Maintenance	Fund	Voucher	Batch No	GL Date	Amount
	Other Rents & Leases					
	ROGGEN FARMERS ELEVATOR ASSN	00043	879567	263947	10/12/16	42.00
					Account Total	42.00
					Department Total	42.00

99809	All Ofc Shared no SS	Fund	Voucher	Batch No	GL Date	Amount
	Mileage Reimbursements					
	MCDANIEL JENNIFER	00035	881549	265076	10/31/16	15.12
					Account Total	15.12
					Department Total	15.12

99800	All Ofc Shared Direct	Fund	Voucher	Batch No	GL Date	Amount
	Destruction of Records					
	SHRED IT USA LLC	00035	881343	264920	11/01/16	60.00
					Account Total	60.00
	Mileage Reimbursements					
	DUKE STEPHANI	00035	881538	265076	10/31/16	23.76
					Account Total	23.76
					Department Total	83.76

1041	County Assessor	Fund	Voucher	Batch No	GL Date	Amount
	Education & Training					
	COLO ASSESSORS ASSN	00001	881729	265251	11/07/16	60.00
					Account Total	60.00
	Maintenance Contracts					
	COSTAR REALTY INFORMATION INC	00001	881730	265251	11/07/16	2,808.39
					Account Total	2,808.39
	Operating Supplies					
	ALL COPY PRODUCTS INC	00001	881728	265251	11/07/16	92.94
					Account Total	92.94
					Department Total	2,961.33

1013	County Attorney	Fund	Voucher	Batch No	GL Date	Amount
	Mileage Reimbursements					
	BOSTON DOE LORENA	00001	881417	264982	11/02/16	1,593.00
					Account Total	1,593.00
	Other Professional Serv					
	SUMMIT COUNTY SHERIFF	00001	881414	264982	11/02/16	25.26
					Account Total	25.26
					Department Total	1,618.26

1019	Customer Experience Operations	Fund	Voucher	Batch No	GL Date	Amount
	Postage & Freight					
	U S POSTMASTER	00001	881886	265379	11/08/16	361.65
					Account Total	361.65
					Department Total	361.65

1043	CA- Social Services IV-D	Fund	Voucher	Batch No	GL Date	Amount
	Mileage Reimbursements					
	QUINTANA LINDA	00001	881415	264982	11/02/16	21.60
					Account Total	21.60
					Department Total	21.60

1044	CA- SS Dependency/Neglect	Fund	Voucher	Batch No	GL Date	Amount
	Other Professional Serv					
	RBA ATTORNEY SERVICES	00001	881416	264982	11/02/16	60.00
					Account Total	60.00
					Department Total	60.00

1022	CLK Elections	Fund	Voucher	Batch No	GL Date	Amount
	Other Professional Serv					
	BUEHLER MOVING & STORAGE	00001	881712	265200	11/04/16	1,345.00
	VORTEX COLORADO INC	00001	881714	265200	11/04/16	1,086.81
					Account Total	2,431.81
					Department Total	2,431.81

1023	CLK Motor Vehicle	Fund	Voucher	Batch No	GL Date	Amount
	Operating Supplies					
	ALSCO AMERICAN INDUSTRIAL	00001	881709	265200	11/04/16	26.89
	ALSCO AMERICAN INDUSTRIAL	00001	881710	265200	11/04/16	18.41
	ALSCO AMERICAN INDUSTRIAL	00001	881711	265200	11/04/16	16.21
					Account Total	61.51
	Other Professional Serv					
	RED HAWK FIRE & SECURITY	00001	881713	265200	11/04/16	393.00
					Account Total	393.00
					Department Total	454.51

6021	CT- Trails- Plan/Design Const	Fund	Voucher	Batch No	GL Date	Amount
	Consultant Services					
	COLO OPEN LANDS	00024	881420	264986	11/02/16	770.00
					Account Total	770.00
	Repair & Maint Supplies					
	GORDON SIGN	00024	881419	264986	11/02/16	617.50
					Account Total	617.50
					Department Total	1,387.50

1051	District Attorney	Fund	Voucher	Batch No	GL Date	Amount
	Court Reporting Transcripts					
	HART JULIE	00001	881874	265378	11/08/16	21.00
	MATTIE BRIAN S	00001	881876	265378	11/08/16	99.00
	STUEVE SARA	00001	881882	265378	11/08/16	60.00
	WAGNER GEORGIA C	00001	881884	265378	11/08/16	9.00
					Account Total	189.00
	Grants to Other Instit					
	CASA OF ADAMS & BROOMFIELD COU	00001	881870	265378	11/08/16	2,500.00
					Account Total	2,500.00
	Mileage Reimbursements					
	DELGADO NICOLE	00001	881871	265378	11/08/16	69.66
	JACHETTA TINA	00001	881872	265378	11/08/16	28.73
	SHEIKH TARIQ	00001	881880	265378	11/08/16	89.64
					Account Total	188.03
	Other Communications					
	GOVERNOR'S OFFICE OF IT	00001	881873	265378	11/08/16	820.70
					Account Total	820.70
	Other Professional Serv					
	LAMANNA BARBARA	00001	881875	265378	11/08/16	220.00
					Account Total	220.00
	Witness Fees					
	ADCO DISTRICT ATTORNEY	00001	881862	265378	11/08/16	253.82
	ADCO DISTRICT ATTORNEY	00001	881862	265378	11/08/16	60.00
	ADCO DISTRICT ATTORNEY'S OFFIC	00001	881828	265356	11/08/16	1.00
	ADCO DISTRICT ATTORNEY'S OFFIC	00001	881828	265356	11/08/16	124.18
	ADCO DISTRICT ATTORNEY'S OFFIC	00001	881828	265356	11/08/16	294.79
	ADCO DISTRICT ATTORNEY'S OFFIC	00001	881828	265356	11/08/16	186.40
	ADCO DISTRICT ATTORNEY'S OFFIC	00001	881828	265356	11/08/16	13.43
	ADCO DISTRICT ATTORNEY'S OFFIC	00001	881828	265356	11/08/16	302.22
					Account Total	1,235.84
					Department Total	5,153.57

9261	DA- Diversion Project	Fund	Voucher	Batch No	GL Date	Amount
	Mileage Reimbursements					
	ALVAREZ MEGAN	00001	881864	265378	11/08/16	185.54
	ALVAREZ MEGAN	00001	881865	265378	11/08/16	90.67
	ARELLANO JESSICA	00001	881867	265378	11/08/16	30.24
	AZZOLINA CAROL	00001	881868	265378	11/08/16	75.33
	ROBINSON KENNETH	00001	881877	265378	11/08/16	130.68
	RUELAS RAFAEL	00001	881879	265378	11/08/16	85.32
					Account Total	597.78
					Department Total	597.78

99500	Employment First	Fund	Voucher	Batch No	GL Date	Amount
	Mileage Reimbursements					
	BARRIBO LAURA	00035	881533	265076	10/31/16	5.94
	FLORES MICHAEL	00035	881540	265076	10/31/16	76.68
	LUNA EVANGELINA S	00035	881547	265076	10/31/16	62.64
	MEDINA KRISTINA	00035	881551	265076	10/31/16	60.48
	PEDREGON SYDNEY	00035	881555	265076	10/31/16	102.60
					Account Total	308.34
					Department Total	308.34

97802	Employment Support Fund	Fund	Voucher	Batch No	GL Date	Amount
	Mileage Reimbursements					
	AGUINIGA CAROL	00035	881526	265076	10/31/16	16.74
	CHAVEZ BELIA P	00035	881536	265076	10/31/16	6.48
	CLARK RYNE	00035	881537	265076	10/31/16	25.38
	DUKE STEPHANI	00035	881538	265076	10/31/16	4.86
	ELLIS CHARLES	00035	881539	265076	10/31/16	69.12
	MCGIRR RITA	00035	881550	265076	10/31/16	51.30
	MENDOZA MICHELLE	00035	881552	265076	10/31/16	26.46
	POST REBECCA	00035	881556	265076	10/31/16	3.24
					Account Total	203.58
	Travel & Transportation					
	AGUINIGA CAROL	00035	881526	265076	10/31/16	6.25
	CANAL VALLEJO ATHENAS	00035	881535	265076	10/31/16	21.06
	CANAL VALLEJO ATHENAS	00035	881535	265076	10/31/16	6.25
	CLARK RYNE	00035	881537	265076	10/31/16	4.00
	ELLIS CHARLES	00035	881539	265076	10/31/16	5.00
	MCGIRR RITA	00035	881550	265076	10/31/16	6.25
	MENDOZA MICHELLE	00035	881552	265076	10/31/16	6.25
					Account Total	55.06
					Department Total	258.64

6	Equipment Service Fund	Fund	Voucher	Batch No	GL Date	Amount
	Received not Vouchered Clrg					
	PRECISE MRM LLC	00006	881911	265417	11/09/16	2,889.00
	PRECISE MRM LLC	00006	881912	265417	11/09/16	3,659.13
	SAM HILL OIL INC	00006	881914	265417	11/09/16	13,887.43
	SPRADLEY BARR FORD GREELEY	00006	881915	265417	11/09/16	32,501.00
	SPRADLEY BARR FORD GREELEY	00006	881916	265417	11/09/16	50,304.00
	WIRELESS ADVANCED COMMUNICATIO	00006	881913	265417	11/09/16	4,930.00
					Account Total	108,170.56
					Department Total	108,170.56

9243	Extension - Family & Consumer	Fund	Voucher	Batch No	GL Date	Amount
	Other Communications					
	VERIZON WIRELESS	00001	881444	265006	11/02/16	41.15
					Account Total	41.15
					Department Total	41.15

9240	Extension - Horticulture	Fund	Voucher	Batch No	GL Date	Amount
	Operating Supplies					
	CSU LARIMER COUNTY EXTENSION	00001	880749	264686	10/27/16	226.80
					Account Total	226.80
	Other Communications					
	VERIZON WIRELESS	00001	881444	265006	11/02/16	41.15
					Account Total	41.15
					Department Total	267.95

9241	Extension- Administration	Fund	Voucher	Batch No	GL Date	Amount
	Mileage Reimbursements					
	GOURD THADDEUS	00001	880768	264686	10/27/16	306.18
	REICHOW RAE-ANNE	00001	881445	265006	11/02/16	76.68
					Account Total	382.86
	Operating Supplies					
	I70 PUBLISHING CO INC	00001	880744	264686	10/27/16	44.00
					Account Total	44.00
	Other Communications					
	VERIZON WIRELESS	00001	881444	265006	11/02/16	95.93
					Account Total	95.93
					Department Total	522.79

9242	Extension- Agriculture	Fund	Voucher	Batch No	GL Date	Amount
	Operating Supplies					
	BERRY PATCH FARMS	00001	880767	264686	10/27/16	200.00
					Account Total	200.00
					Department Total	200.00

6031	Extension- Soil Conservation	Fund	Voucher	Batch No	GL Date	Amount
	Other Communications					
	COLO STATE UNIVERSITY	00001	880770	264686	10/27/16	46.00
					Account Total	46.00
					Department Total	46.00

9244	Extension- 4-H/Youth	Fund	Voucher	Batch No	GL Date	Amount
	Operating Supplies					
	CLUB, RISING SUN 4-H	00001	881446	265006	11/02/16	100.00
					Account Total	100.00
	Other Communications					
	VERIZON WIRELESS	00001	881444	265006	11/02/16	41.15
	VERIZON WIRELESS	00001	881444	265006	11/02/16	41.15
	VERIZON WIRELESS	00001	881444	265006	11/02/16	41.15
					Account Total	123.45
					Department Total	223.45

9114	Fleet- Commerce	Fund	Voucher	Batch No	GL Date	Amount
	Vehicle Repair & Maint					
	HRT ENTERPRISES LLC	00006	881559	265100	11/13/16	130.00
					Account Total	130.00
					Department Total	130.00

1091	FO - Administration	Fund	Voucher	Batch No	GL Date	Amount
	Gas & Electricity					
	Energy Cap Bill ID=6720	00001	881766	265276	10/19/16	42.86
	Energy Cap Bill ID=6729	00001	881767	265276	10/18/16	868.85
					Account Total	911.71
					Department Total	911.71

1113	FO - Children & Family Service	Fund	Voucher	Batch No	GL Date	Amount
	Water/Sewer/Sanitation					
	Energy Cap Bill ID=6726	00001	881772	265276	10/24/16	565.77
					Account Total	565.77
					Department Total	565.77

1114	FO - District Attorney Bldg.	Fund	Voucher	Batch No	GL Date	Amount
	Gas & Electricity					
	Energy Cap Bill ID=6736	00001	881773	265276	10/21/16	242.38
					Account Total	242.38
					Department Total	242.38

1077	FO - Government Center	Fund	Voucher	Batch No	GL Date	Amount
	Gas & Electricity					
	Energy Cap Bill ID=6738	00001	881765	265276	10/21/16	1,616.97
					Account Total	1,616.97
					Department Total	1,616.97

1067	FO - Human Service Building	Fund	Voucher	Batch No	GL Date	Amount
	Gas & Electricity					
	Energy Cap Bill ID=6737	00001	881760	265276	10/20/16	11,466.33
					Account Total	11,466.33
					Department Total	11,466.33

2009	FO - Sheriff Maintenance	Fund	Voucher	Batch No	GL Date	Amount
	Gas & Electricity					
	Energy Cap Bill ID=6739	00001	881774	265276	10/20/16	142.01
					Account Total	142.01
	Water/Sewer/Sanitation					
	Energy Cap Bill ID=6721	00001	881775	265276	10/21/16	12,251.96
	Energy Cap Bill ID=6722	00001	881776	265276	10/21/16	106.32
	Energy Cap Bill ID=6723	00001	881777	265276	10/21/16	17,198.01
					Account Total	29,556.29
					Department Total	29,698.30

1072	FO - West Service Center	Fund	Voucher	Batch No	GL Date	Amount
	Gas & Electricity					
	Energy Cap Bill ID=6732	00001	881761	265276	10/25/16	5,653.10
					Account Total	5,653.10
	Water/Sewer/Sanitation					
	Energy Cap Bill ID=6727	00001	881762	265276	10/24/16	657.88
	Energy Cap Bill ID=6728	00001	881763	265276	10/24/16	2,862.97
					Account Total	3,520.85
					Department Total	9,173.95

1076	FO-Adams County Service Center	Fund	Voucher	Batch No	GL Date	Amount
	Gas & Electricity					
	Energy Cap Bill ID=6734	00001	881764	265276	10/21/16	10,145.97
					Account Total	10,145.97
					Department Total	10,145.97

1063	FO-Flatrock Training Facility	Fund	Voucher	Batch No	GL Date	Amount
	Gas & Electricity					
	Energy Cap Bill ID=6730	00001	881758	265276	10/21/16	49.78
	Energy Cap Bill ID=6733	00001	881759	265276	10/21/16	88.42
					Account Total	138.20
					Department Total	138.20

1112	FO-Sheriff HQ/Coroner Building	Fund	Voucher	Batch No	GL Date	Amount
	Gas & Electricity					
	Energy Cap Bill ID=6735	00001	881769	265276	10/21/16	277.28
					Account Total	277.28
	Water/Sewer/Sanitation					
	Energy Cap Bill ID=6724	00001	881770	265276	10/21/16	702.54
	Energy Cap Bill ID=6725	00001	881771	265276	10/21/16	2,701.05
					Account Total	3,403.59
					Department Total	3,680.87

1	General Fund	Fund	Voucher	Batch No	GL Date	Amount
	Misc Accounts Payable					
	COLO DEPT OF TREASURY	00001	881779	265263	11/07/16	1,702.90
					Account Total	1,702.90
	Received not Vouchered Clrg					
	ADAMSON POLICE PRODUCTS	00001	881136	264881	11/01/16	845.00
	ADAMSON POLICE PRODUCTS	00001	881137	264881	11/01/16	745.00
	ADAMSON POLICE PRODUCTS	00001	881138	264881	11/01/16	845.00
	ADAMSON POLICE PRODUCTS	00001	881140	264881	11/01/16	845.00
	ADAMSON POLICE PRODUCTS	00001	881142	264881	11/01/16	845.00
	ADAMSON POLICE PRODUCTS	00001	881144	264881	11/01/16	845.00
	ADAMSON POLICE PRODUCTS	00001	881147	264881	11/01/16	845.00
	ADAMSON POLICE PRODUCTS	00001	881149	264881	11/01/16	845.00
	ALLIED BARTON SECURITY SERVICE	00001	881943	265417	11/09/16	1,395.63
	ARMORED KNIGHTS INC	00001	881922	265417	11/09/16	332.44
	ARMORED KNIGHTS INC	00001	881922	265417	11/09/16	332.44
	ARMORED KNIGHTS INC	00001	881922	265417	11/09/16	332.44
	ARMORED KNIGHTS INC	00001	881922	265417	11/09/16	332.44
	ARMORED KNIGHTS INC	00001	881922	265417	11/09/16	332.44
	ARMORED KNIGHTS INC	00001	881922	265417	11/09/16	332.44
	BOB BARKER COMPANY	00001	881152	264881	11/01/16	7,175.20
	COMMUNITY REACH CENTER	00001	881281	264881	11/01/16	39,798.60
	GALLS LLC	00001	881291	264881	11/01/16	32.82
	GALLS LLC	00001	881291	264881	11/01/16	45.98
	GALLS LLC	00001	881291	264881	11/01/16	13.16
	GALLS LLC	00001	881291	264881	11/01/16	118.59
	GALLS LLC	00001	881291	264881	11/01/16	45.70
	HIGH COUNTRY BEVERAGE	00001	881918	265417	11/09/16	237.05
	HIGH COUNTRY BEVERAGE	00001	881919	265417	11/09/16	297.00
	LEXIS NEXIS MATTHEW BENDER	00001	881302	264881	11/01/16	2,034.99
	MERRICK & COMPANY	00001	881960	265425	11/09/16	2,399.10
	NEVE'S UNIFORMS INC	00001	881304	264881	11/01/16	46.95
	NEVE'S UNIFORMS INC	00001	881305	264881	11/01/16	106.80
	NEVE'S UNIFORMS INC	00001	881306	264881	11/01/16	269.95
	NEVE'S UNIFORMS INC	00001	881308	264881	11/01/16	109.90
	NEVE'S UNIFORMS INC	00001	881309	264881	11/01/16	56.94

1	General Fund	Fund	Voucher	Batch No	GL Date	Amount
	NEVE'S UNIFORMS INC	00001	881310	264881	11/01/16	303.75
	NEVE'S UNIFORMS INC	00001	881311	264881	11/01/16	140.85
	NEVE'S UNIFORMS INC	00001	881313	264881	11/01/16	119.95
	PHOENIX MASONRY INC	00001	881890	265382	11/08/16	3,909.00
	PTS OF AMERICA LLC	00001	881316	264881	11/01/16	572.90
	PTS OF AMERICA LLC	00001	881318	264881	11/01/16	429.68
	PTS OF AMERICA LLC	00001	881320	264881	11/01/16	1,190.00
	SPECTRA CONTRACT FLOORING SERV	00001	881900	265417	11/09/16	250.00
	SPECTRA CONTRACT FLOORING SERV	00001	881901	265417	11/09/16	275.00
	SPECTRA CONTRACT FLOORING SERV	00001	881902	265417	11/09/16	275.00
	SPECTRA CONTRACT FLOORING SERV	00001	881903	265417	11/09/16	2,400.00
	UNGERBOECK SYSTEMS INTERNATION	00001	881944	265417	11/09/16	3,600.00
	UNGERBOECK SYSTEMS INTERNATION	00001	881945	265417	11/09/16	5,414.00
	WIRELESS ADVANCED COMMUNICATIO	00001	881323	264881	11/01/16	120.00
	WIRELESS ADVANCED COMMUNICATIO	00001	881327	264881	11/01/16	120.00
	WIRELESS ADVANCED COMMUNICATIO	00001	881328	264881	11/01/16	120.00
					Account Total	82,079.13
					Department Total	83,782.03

5027	Golf Course- CIP	Fund	Voucher	Batch No	GL Date	Amount
	Land Improvements					
	L L JOHNSON DIST	00005	881791	265284	11/07/16	2,925.00
					Account Total	2,925.00
					Department Total	2,925.00

5026	Golf Course- Maintenance	Fund	Voucher	Batch No	GL Date	Amount
	Equipment Rental					
	BUCKEYE WELDING SUPPLY CO INC	00005	881788	265284	11/07/16	26.00
					Account Total	26.00
	Fuel, Gas & Oil					
	AGFINITY INC	00005	881780	265284	11/07/16	1,235.64
	AGFINITY INC	00005	881781	265284	11/07/16	2,286.94
					Account Total	3,522.58
	Gas & Electricity					
	XCEL ENERGY	00005	881792	265284	11/07/16	63.06
					Account Total	63.06
	Grounds Maintenance					
	AGFINITY INC	00005	881782	265284	11/07/16	99.80
	AGFINITY INC	00005	881783	265284	11/07/16	217.38
	AGFINITY INC	00005	881784	265284	11/07/16	463.03
	AGFINITY INC	00005	881785	265284	11/07/16	9,239.65
	GOLF & SPORT SOLUTIONS	00005	881789	265284	11/07/16	1,007.49
					Account Total	11,027.35
	Repair & Maint Supplies					
	AGFINITY INC	00005	881786	265284	11/07/16	84.00
	ALSCO AMERICAN INDUSTRIAL	00005	881787	265284	11/07/16	40.26
					Account Total	124.26
	Vehicle Parts & Supplies					
	L L JOHNSON DIST	00005	881790	265284	11/07/16	114.23
					Account Total	114.23
					Department Total	14,877.48

98600	Governor's Summer Job Hunt	Fund	Voucher	Batch No	GL Date	Amount
	Mileage Reimbursements					
	AGUINIGA CAROL	00035	881526	265076	10/31/16	21.60
	CANAL VALLEJO ATHENAS	00035	881535	265076	10/31/16	23.22
	MENDOZA MICHELLE	00035	881552	265076	10/31/16	27.54
					Account Total	72.36
					Department Total	72.36

31	Head Start Fund	Fund	Voucher	Batch No	GL Date	Amount
	Received not Vouchered Clrg					
	ANDREWS PRODUCE INC	00031	881715	265202	11/04/16	2,888.98
	ANDREWS PRODUCE INC	00031	881715	265202	11/04/16	252.14
	ANDREWS PRODUCE INC	00031	881716	265202	11/04/16	3,230.46
	ANDREWS PRODUCE INC	00031	881716	265202	11/04/16	236.15
	ANDREWS PRODUCE INC	00031	881717	265202	11/04/16	3,551.04
	ANDREWS PRODUCE INC	00031	881717	265202	11/04/16	17.83
	CARNATION BUILDING SERVICES IN	00031	881923	265417	11/09/16	2,101.20
	CHILDRENS HOSPITAL COLORADO	00031	881928	265417	11/09/16	219.70
	CHILDRENS HOSPITAL COLORADO	00031	881929	265417	11/09/16	41.60
	CHILDRENS HOSPITAL COLORADO	00031	881930	265417	11/09/16	109.85
	CHILDRENS HOSPITAL COLORADO	00031	881931	265417	11/09/16	109.85
	CHILDRENS HOSPITAL COLORADO	00031	881932	265417	11/09/16	109.85
	CHILDRENS HOSPITAL COLORADO	00031	881933	265417	11/09/16	109.85
	CHILDRENS HOSPITAL COLORADO	00031	881934	265417	11/09/16	109.85
	CHILDRENS HOSPITAL COLORADO	00031	881935	265417	11/09/16	109.85
	CHILDRENS HOSPITAL COLORADO	00031	881936	265417	11/09/16	718.20
	CHILDRENS HOSPITAL COLORADO	00031	881937	265417	11/09/16	109.85
	CHILDRENS HOSPITAL COLORADO	00031	881938	265417	11/09/16	109.85
	CHILDRENS HOSPITAL COLORADO	00031	881939	265417	11/09/16	109.85
	CHILDRENS HOSPITAL COLORADO	00031	881940	265417	11/09/16	109.85
	CHILDRENS HOSPITAL COLORADO	00031	881941	265417	11/09/16	109.85
	CHILDRENS HOSPITAL COLORADO	00031	881942	265417	11/09/16	109.85
	ONE WORLD TRANSLATION & ASSOCI	00031	881924	265417	11/09/16	47.24
	ONE WORLD TRANSLATION & ASSOCI	00031	881925	265417	11/09/16	66.54
	SYSCO DENVER	00031	881889	265382	11/08/16	51.00
	SYSCO DENVER	00031	881904	265417	11/09/16	65.92
	SYSCO DENVER	00031	881904	265417	11/09/16	490.94
	SYSCO DENVER	00031	881905	265417	11/09/16	107.95
	SYSCO DENVER	00031	881906	265417	11/09/16	55.86
	SYSCO DENVER	00031	881907	265417	11/09/16	304.26
	SYSCO DENVER	00031	881908	265417	11/09/16	958.07
	SYSCO DENVER	00031	881909	265417	11/09/16	132.69
	SYSCO DENVER	00031	881910	265417	11/09/16	137.79
	SYSCO DENVER	00031	881926	265417	11/09/16	88.96
	SYSCO DENVER	00031	881927	265417	11/09/16	57.70

31	Head Start Fund	Fund	Voucher	Batch No	GL Date	Amount
					Account Total	17,140.42
					Department Total	17,140.42

935114	HHS Grant	Fund	Voucher	Batch No	GL Date	Amount
	Mileage Reimbursements					
	HENDERSON CYNDI	00031	881778	265263	11/07/16	9.52
					Account Total	9.52
					Department Total	9.52

961016	HOME	Fund	Voucher	Batch No	GL Date	Amount
	Grants to Other Instit					
	ARCHWAY HOUSING AND SERVICES	00030	881707	265199	11/04/16	153,377.24
					Account Total	153,377.24
					Department Total	153,377.24

19	Insurance Fund	Fund	Voucher	Batch No	GL Date	Amount
	Received not Vouchered Clrg					
	COLO STATE TREASURER	00019	881920	265417	11/09/16	56,556.50
	EXTREME ENGRAVING	00019	881921	265417	11/09/16	2,655.00
					Account Total	59,211.50
					Department Total	59,211.50

97813	MSFW Housing Inspection	Fund	Voucher	Batch No	GL Date	Amount
	Mileage Reimbursements					
	PARRA ALDO	00035	881554	265076	10/31/16	19.44
					Account Total	19.44
					Department Total	19.44

6107	Open Space Projects	Fund	Voucher	Batch No	GL Date	Amount
	Pedestrian Bridge					
	ERMOLD PARK & RECREATION PROD	00027	881418	264986	11/02/16	2,084.00
					Account Total	2,084.00
					Department Total	2,084.00

6202	Open Space Tax- Grants	Fund	Voucher	Batch No	GL Date	Amount
	Grants to Other Instit					
	AURORA CITY OF	00028	881440	265005	11/02/16	386,000.00
	BENNETT SCHOOLS	00028	881441	265005	11/02/16	89,512.83
	BIRD CONSERVANCY OF THE ROCKIE	00028	881442	265005	11/02/16	20,899.50
	ROCKY MOUNTAIN ARSENAL NATL WI	00028	881443	265005	11/02/16	1,522.13
					Account Total	497,934.46
					Department Total	497,934.46

1111	Parks Facilities	Fund	Voucher	Batch No	GL Date	Amount
	Gas & Electricity					
	Energy Cap Bill ID=6731	00001	881768	265276	10/21/16	85.00
					Account Total	85.00
					Department Total	85.00

5010	PKS- Fair & Special Events	Fund	Voucher	Batch No	GL Date	Amount
	Equipment Rental					
	WAGNER RENTS	00001	881706	265196	11/04/16	250.00
					Account Total	250.00
	Fair Expenses-General					
	ROMO SONNEMAN, VINCENT	00001	881755	265263	11/07/16	79.00
					Account Total	79.00
	Liquor Sales					
	GUSTAD DAVID	00001	881703	265196	11/04/16	372.00
					Account Total	372.00
	Regional Park Rentals					
	COMMUNITY REACH CENTER	00001	881421	264986	11/02/16	60.00
	GUSTAD DAVID	00001	881704	265196	11/04/16	400.00
	JABARI HOWRIE	00001	881423	264986	11/02/16	75.00
	LANDING PLACE CHURCH	00001	881424	264986	11/02/16	650.00
	WACKER AMBER	00001	881426	264986	11/02/16	75.00
					Account Total	1,260.00
	Special Events					
	RACING UNDERGROUND LLC	00001	881705	265196	11/04/16	500.00
					Account Total	500.00
	Travel & Transportation					
	GRAF TREVOR G	00001	881756	265263	11/07/16	292.00
					Account Total	292.00
					Department Total	2,753.00

5018	PKS- Natural Resources Program	Fund	Voucher	Batch No	GL Date	Amount
	Mileage Reimbursements					
	PEDRUCCI MARC R	00001	881425	264986	11/02/16	79.38
					Account Total	79.38
					Department Total	79.38

5012	PKS- Regional Complex	Fund	Voucher	Batch No	GL Date	Amount
	Gas & Electricity					
	UNITED POWER (UNION REA)	00001	881427	264994	11/02/16	84.75
	XCEL ENERGY	00001	881428	264994	11/02/16	40.32
	XCEL ENERGY	00001	881429	264994	11/02/16	189.99
	XCEL ENERGY	00001	881430	264994	11/02/16	277.73
	XCEL ENERGY	00001	881431	264994	11/02/16	499.86
	XCEL ENERGY	00001	881432	264994	11/02/16	164.78
	XCEL ENERGY	00001	881433	264994	11/02/16	80.60
					Account Total	1,338.03
	Operating Supplies					
	G & K SERVICES	00001	881422	264986	11/02/16	181.30
					Account Total	181.30
					Department Total	1,519.33

1089	PLN- Boards & Commissions	Fund	Voucher	Batch No	GL Date	Amount
	Other Professional Serv					
	BUZEK, VINCE	00001	881120	264826	10/31/16	65.00
	GARNER, ROSIE	00001	881122	264826	10/31/16	65.00
	GIBNEY HARRY	00001	881121	264826	10/31/16	65.00
	MOLINARO SAM	00001	881123	264826	10/31/16	65.00
	MOSKO STEW	00001	881124	264826	10/31/16	65.00
	RICHARDSON SHARON	00001	881125	264826	10/31/16	65.00
	THOMPSON GREGORY PAUL	00001	881126	264826	10/31/16	65.00
					Account Total	455.00
					Department Total	455.00

13	Road & Bridge Fund	Fund	Voucher	Batch No	GL Date	Amount
	Received not Vouchered Clrg					
	ALDERMAN BERNSTEIN	00013	881720	265213	11/04/16	2,179.50
	DREXEL BARRELL & CO	00013	881917	265417	11/09/16	48,140.38
	TERRACON	00013	881961	265425	11/09/16	1,448.75
					Account Total	51,768.63
					Department Total	51,768.63

2004	Sheriff Training	Fund	Voucher	Batch No	GL Date	Amount
	Operating Supplies					
	TOSHIBA BUSINESS SOLUTIONS	00001	881435	264921	11/02/16	81.26
					Account Total	81.26
					Department Total	81.26

2014	Sheriff-Professional Standards	Fund	Voucher	Batch No	GL Date	Amount
	Printing External					
	COPYCO QUALITY PRINTING INC	00001	881353	264921	11/01/16	230.00
					Account Total	230.00
					Department Total	230.00

2070	SHF - Booking Fee	Fund	Voucher	Batch No	GL Date	Amount
	Education & Training					
	COMMUNITY REACH CENTER	00001	881439	264921	11/02/16	300.00
					Account Total	300.00
					Department Total	300.00

2008	SHF - Training Academy	Fund	Voucher	Batch No	GL Date	Amount
	Operating Supplies					
	NORTH METRO FIRE RESCUE	00001	881404	264921	11/02/16	1,200.00
	SAMS CLUB	00001	881406	264921	11/02/16	275.68
	SAMS CLUB	00001	881406	264921	11/02/16	477.06
	TOSHIBA BUSINESS SOLUTIONS	00001	881435	264921	11/02/16	9.66
					Account Total	1,962.40
					Department Total	1,962.40

2011	SHF- Admin Services Division	Fund	Voucher	Batch No	GL Date	Amount
	Business Meetings					
	SAMS CLUB	00001	881406	264921	11/02/16	64.94
					Account Total	64.94
	Mileage Reimbursements					
	MEAD GLENDA	00001	881402	264921	11/02/16	21.60
					Account Total	21.60
	Office Furniture					
	ZONES INC	00001	881438	264921	11/02/16	504.86
					Account Total	504.86
	Operating Supplies					
	ARAMARK REFRESHMENT SERVICES	00001	881341	264921	11/01/16	502.25
	ARAMARK REFRESHMENT SERVICES	00001	881342	264921	11/01/16	372.94
	DS WATERS OF AMERICA INC	00001	881398	264921	11/02/16	88.48
	SAMS CLUB	00001	881406	264921	11/02/16	18.63
	TOSHIBA BUSINESS SOLUTIONS	00001	881435	264921	11/02/16	235.13
					Account Total	1,217.43
	Other Professional Serv					
	SHRED IT USA LLC	00001	881409	264921	11/02/16	50.00
					Account Total	50.00
	Printing External					
	COPYCO QUALITY PRINTING INC	00001	881351	264921	11/01/16	35.00
					Account Total	35.00
	Public Relations					
	COLO ASSN OF CHIEFS OF POLICE	00001	881345	264921	11/01/16	1,500.00
					Account Total	1,500.00
					Department Total	3,393.83

2015	SHF- Civil Section	Fund	Voucher	Batch No	GL Date	Amount
	Printing External					
	COPYCO QUALITY PRINTING INC	00001	881353	264921	11/01/16	80.00
					Account Total	80.00
					Department Total	80.00

2075	SHF- Commissary Fund	Fund	Voucher	Batch No	GL Date	Amount
	Operating Supplies					
	TOSHIBA BUSINESS SOLUTIONS	00001	881435	264921	11/02/16	154.92
					Account Total	154.92
	Other Communications					
	CENTURY LINK	00001	881344	264921	11/01/16	205.39
					Account Total	205.39
					Department Total	360.31

2016	SHF- Detective Division	Fund	Voucher	Batch No	GL Date	Amount
	Operating Supplies					
	TOSHIBA BUSINESS SOLUTIONS	00001	881435	264921	11/02/16	244.48
					Account Total	244.48
	Other Communications					
	VERIZON WIRELESS	00001	881436	264921	11/02/16	1,012.26
					Account Total	1,012.26
	Other Professional Serv					
	SHRED IT USA LLC	00001	881407	264921	11/02/16	54.00
	SHRED IT USA LLC	00001	881410	264921	11/02/16	40.00
					Account Total	94.00
	Printing External					
	COPYCO QUALITY PRINTING INC	00001	881347	264921	11/01/16	120.00
					Account Total	120.00
	Property/Evidence Dispositions					
	MOODY JANET LEA	00001	881558	265096	11/03/16	494.15
					Account Total	494.15
					Department Total	1,964.89

2071	SHF- Detention Facility	Fund	Voucher	Batch No	GL Date	Amount
	Food Services					
	ALL STAR HOOD CLEANING	00001	881337	264921	11/01/16	2,995.00
					Account Total	2,995.00
	Maintenance Contracts					
	SIERRA DETENTION SYSTEMS	00001	881411	264921	11/02/16	200.00
					Account Total	200.00
	Operating Supplies					
	ADAMS COUNTY DETENTION FACILIT	00001	881334	264921	11/01/16	142.37
	ADAMS COUNTY DETENTION FACILIT	00001	881336	264921	11/01/16	2.53
	TOSHIBA BUSINESS SOLUTIONS	00001	881435	264921	11/02/16	713.25
					Account Total	858.15
					Department Total	4,053.15

2017	SHF- Patrol Division	Fund	Voucher	Batch No	GL Date	Amount
	Operating Supplies					
	TOSHIBA BUSINESS SOLUTIONS	00001	881435	264921	11/02/16	81.42
					Account Total	81.42
	Other Communications					
	COMCAST CABLE	00001	881437	264921	11/02/16	1.95
					Account Total	1.95
	Other Professional Serv					
	SHRED IT USA LLC	00001	881407	264921	11/02/16	54.00
	SHRED IT USA LLC	00001	881410	264921	11/02/16	40.00
					Account Total	94.00
	Printing External					
	COPYCO QUALITY PRINTING INC	00001	881351	264921	11/01/16	120.00
	COPYCO QUALITY PRINTING INC	00001	881352	264921	11/01/16	440.00
	COPYCO QUALITY PRINTING INC	00001	881348	264921	11/01/16	435.00
					Account Total	995.00
	Vehicle Repair & Maint					
	EXTREME TOWING & RECOVERY SERV	00001	881399	264921	11/02/16	68.00
					Account Total	68.00
					Department Total	1,240.37

2018	SHF- Records/Warrants Section	Fund	Voucher	Batch No	GL Date	Amount
	Operating Supplies					
	DS WATERS OF AMERICA INC	00001	881397	264921	11/02/16	74.35
	TOSHIBA BUSINESS SOLUTIONS	00001	881435	264921	11/02/16	132.74
					Account Total	207.09
	Other Professional Serv					
	FIRST CHOICE COFFEE SERVICES	00001	881400	264921	11/02/16	179.80
	SHRED IT USA LLC	00001	881408	264921	11/02/16	86.25
					Account Total	266.05
	Other Repair & Maint					
	ACCO BRANDS USA LLC	00001	881333	264921	11/01/16	312.00
					Account Total	312.00
					Department Total	785.14

2005	SHF- TAC Section	Fund	Voucher	Batch No	GL Date	Amount
	Operating Supplies					
	TOSHIBA BUSINESS SOLUTIONS	00001	881435	264921	11/02/16	38.95
					Account Total	38.95
					Department Total	38.95

2024	SHF- Volunteer Program	Fund	Voucher	Batch No	GL Date	Amount
	Travel & Transportation					
	COLO DEPT OF CORRECTIONS	00001	881346	264921	11/01/16	28.00
					Account Total	28.00
					Department Total	28.00

3031	Transportation Opers & Maint	Fund	Voucher	Batch No	GL Date	Amount
	Community Events					
	ALPINE WASTE & RECYCLING	00013	881757	265270	11/07/16	1,361.42
					Account Total	1,361.42
					Department Total	1,361.42

9291	Veterans Service Office	Fund	Voucher	Batch No	GL Date	Amount
	Postage & Freight					
	ADCO HUMAN SERVICES DEPT	00001	881885	265379	11/08/16	13.78
					Account Total	13.78
	Printing External					
	TIARA PRINTING INC	00001	881887	265379	11/08/16	317.78
					Account Total	317.78
					Department Total	331.56

97800	Wagner-Peyser	Fund	Voucher	Batch No	GL Date	Amount
	Mileage Reimbursements					
	BANKS RACHEL	00035	881529	265076	10/31/16	43.20
	BANKS RACHEL	00035	881529	265076	10/31/16	12.96
	BERNAL JUAN FELIPE	00035	881534	265076	10/31/16	49.14
	GONZALEZ JESSICA	00035	881543	265076	10/31/16	16.74
	JOHNSON LORRAINE	00035	881544	265076	10/31/16	22.68
	KAMMERZELL JODIE	00035	881545	265076	10/31/16	8.10
	MARTINEZ MARTHA	00035	881548	265076	10/31/16	37.80
	MCDANIEL JENNIFER	00035	881549	265076	10/31/16	21.06
	PARRA ALDO	00035	881554	265076	10/31/16	124.74
					Account Total	336.42
	Telephone					
	CENTURYLINK	00035	881335	264920	11/01/16	2.53
	CENTURYLINK	00035	881338	264920	11/01/16	63.21
					Account Total	65.74
					Department Total	402.16

35	Workforce & Business Center	Fund	Voucher	Batch No	GL Date	Amount
	Received not Vouchered Clrg					
	BUENO MICHELLE ELAINE	00035	881827	265355	11/08/16	1,600.00
	COMPUTER SYSTEMS DESIGN	00035	881888	265382	11/08/16	4,800.00
					Account Total	6,400.00
					Department Total	6,400.00

99600	WBC Admin Pool	Fund	Voucher	Batch No	GL Date	Amount
	Mileage Reimbursements					
	BARRIBO LAURA	00035	881533	265076	10/31/16	11.88
	KAMMERZELL JODIE	00035	881545	265076	10/31/16	22.68
	NOBLE PHILLIPP	00035	881825	265312	11/07/16	258.66
					Account Total	293.22
	Printing External					
	COPYCO QUALITY PRINTING INC	00035	881339	264920	11/01/16	49.98
					Account Total	49.98
	Telephone					
	CENTURYLINK	00035	881335	264920	11/01/16	6.74
					Account Total	6.74
	Travel & Transportation					
	NOBLE PHILLIPP	00035	881825	265312	11/07/16	6.00
	NOBLE PHILLIPP	00035	881825	265312	11/07/16	6.90
					Account Total	12.90
					Department Total	362.84

99806	WIA & Wag/Pey Shared Prog Cost	Fund	Voucher	Batch No	GL Date	Amount
	Mileage Reimbursements					
	GLASSER NOELLE	00035	881541	265076	10/31/16	195.48
	POST REBECCA	00035	881556	265076	10/31/16	271.62
					Account Total	467.10
					Department Total	467.10

99802	WIA AD & DLW Shared Pgm Costs	Fund	Voucher	Batch No	GL Date	Amount
	Mileage Reimbursements					
	CHAVEZ BELIA P	00035	881536	265076	10/31/16	16.20
	GONZALEZ JEANETTE	00035	881542	265076	10/31/16	24.30
	OLSEN KATHRYN	00035	881553	265076	10/31/16	116.10
	SANTINO HEATHER	00035	881557	265076	10/31/16	21.60
					Account Total	178.20
	Travel & Transportation					
	OLSEN KATHRYN	00035	881553	265076	10/31/16	12.00
					Account Total	12.00
					Department Total	190.20

97700	WIA DLW PROGRAM	Fund	Voucher	Batch No	GL Date	Amount
	Clnt Trng-Tuition					
	REFACTORU LLC	00035	881340	264920	11/01/16	6,000.00
					Account Total	6,000.00
	Mileage Reimbursements					
	GONZALEZ JEANETTE	00035	881542	265076	10/31/16	65.88
	SANTINO HEATHER	00035	881557	265076	10/31/16	31.86
					Account Total	97.74
					Department Total	6,097.74

99804	WIA Shared Program Direct	Fund	Voucher	Batch No	GL Date	Amount
	Mileage Reimbursements					
	KAMMERZELL JODIE	00035	881545	265076	10/31/16	6.48
					Account Total	6.48
					Department Total	6.48

97500	WIA YOUTH OLDER	Fund	Voucher	Batch No	GL Date	Amount
	Mileage Reimbursements					
	AGUINIGA CAROL	00035	881526	265076	10/31/16	52.38
	CLARK RYNE	00035	881537	265076	10/31/16	21.06
	ELLIS CHARLES	00035	881539	265076	10/31/16	21.06
	KERR CRISTINE	00035	881546	265076	10/31/16	9.18
					Account Total	103.68
					Department Total	103.68

97400	WIA YOUTH YOUNGER	Fund	Voucher	Batch No	GL Date	Amount
	Mileage Reimbursements					
	AGUINIGA CAROL	00035	881526	265076	10/31/16	38.88
	CANAL VALLEJO ATHENAS	00035	881535	265076	10/31/16	16.20
	CANAL VALLEJO ATHENAS	00035	881535	265076	10/31/16	19.44
	ELLIS CHARLES	00035	881539	265076	10/31/16	29.16
	KERR CRISTINE	00035	881546	265076	10/31/16	31.32
	MENDOZA MICHELLE	00035	881552	265076	10/31/16	38.88
	MENDOZA MICHELLE	00035	881552	265076	10/31/16	31.86
					Account Total	205.74
	Travel & Transportation					
	KERR CRISTINE	00035	881546	265076	10/31/16	3.00
					Account Total	3.00
					Department Total	208.74

99700	WIB Expenses	Fund	Voucher	Batch No	GL Date	Amount
	Mileage Reimbursements					
	KAMMERZELL JODIE	00035	881545	265076	10/31/16	9.18
					Account Total	9.18
	Telephone					
	CENTURYLINK	00035	881335	264920	11/01/16	139.26
	CENTURYLINK	00035	881338	264920	11/01/16	92.03
					Account Total	231.29
					Department Total	240.47

99807	Youth Shared Prgrm Direct Cost	Fund	Voucher	Batch No	GL Date	Amount
	Mileage Reimbursements					
	CANAL VALLEJO ATHENAS	00035	881535	265076	10/31/16	8.10
	KAMMERZELL JODIE	00035	881545	265076	10/31/16	20.52
					Account Total	28.62
	Travel & Transportation					
	KAMMERZELL JODIE	00035	881545	265076	10/31/16	14.00
					Account Total	14.00
					Department Total	42.62

Grand Total	**1,111,825.32**

MINUTES OF COMMISSIONERS' PROCEEDINGS FOR TUESDAY, NOVEMBER 15, 2016

1. ROLL CALL
   Present: Steve O'DorisioEva J. Henry and Jan Pawlowski
   Excused: Charles "Chaz" Tedescoand Erik Hansen

2. PLEDGE OF ALLEGIANCE (09:13 AM)

3. MOTION TO APPROVE AGENDA (09:13 AM)
   Motion to Approve 3. MOTION TO APPROVE AGENDA Moved by Jan Pawlowski, seconded by Eva J. Henry, unanimously carried.

4. AWARDS AND PRESENTATIONS (09:13 AM)
   A. 16-798 Open Space Sales Tax Grant Awards Presentation

5. PUBLIC COMMENT (09:23 AM)

A. Citizen Communication

B. Elected Officials' Communication

6. CONSENT CALENDAR (09:25 AM)
   A. 16-799 List of Expenditures Under the Dates of October 21-28, 2016
   B. 16-809 List of Expenditures Under the Dates of October 31-November 4, 2016
   C. 16-802 Minutes of the Commissioners' Proceedings from November 1, 2016
   D. 16-791 Resolution Approving the Award of Open Space Grant Awards and Grant Agreements on November 15, 2016
   E. 16-804 Resolution Establishing Legal Holidays to be Observed by Adams County Offices in 2017
   F. 16-805 Resolution Accepting Deed Conveying Property from Roy J. Marion and Sallie Marion to Adams County for the Dedication of Road Right of Way for Monaghan Road
   G. 16-806 Resolution Accepting Deed Conveying Property from 5810 East 77th Avenue, LLC, to Adams County for the Dedication of Road Right of Way for Kenwood Street and East 77th Avenue
   H. 16-807 Resolution Accepting Deed Conveying Property from HM Rental 1 LLC, to Adams County for the Dedication of Road Right of Way for Lowell Boulevard
   I. 16-811 Resolution Approving an Intergovernmental Agreement for Right-of-Way Maintenance between the City of Brighton and Adams County, Colorado
   J. 16-812 Resolution Approving Quit Claim Deed from Adams County to the City of Commerce City for Street Right-of-Way
   K. 16-815 Resolution Approving the District Attorney's Diversion Program Juvenile Accountability Block Grant Application with the State of Colorado for State Fiscal Year 2017/2018
   L. 16-821 Resolution Continuing Land Use Case #PRC2016-00004 Pomponio Terrace Filing 1 and 2
   M. 16-822 Resolution Approving a Notice of Termination of Development Agreements for Prologis, L.P.

   Motion to Approve 6. CONSENT CALENDAR Moved by Eva J. Henry, seconded by Jan Pawlowski, unanimously carried.

7. NEW BUSINESS (09:25 AM)

A. COUNTY MANAGER

1. 16-823 Resolutions Approving a Bid Award to Multiple Vendors for Janitorial Supples, as noted in the following Agenda Items: (09:25 AM)
   Motion to Approve 1. 16-823 Resolutions Approving a Bid Award to Multiple Vendors for Janitorial Supples, as noted in the following Agenda Items: Moved by Jan Pawlowski, seconded by Eva J. Henry, unanimously carried.

16-770 Resolution Accepting a Bid and Awarding a Pricing Agreement to Hillyard for Janitorial Supplies for Adams County

16-771 Resolution Accepting a Bid and Awarding a Pricing Agreement to EON Office for Janitorial Supplies for Adams County

16-772 Resolution Accepting a Bid and Awarding a Pricing Agreement to Veritiv for Janitorial Supplies for Adams County

16-773 Resolution Accepting a Bid and Awarding a Pricing Agreement to Wrightway Industries for Janitorial Supplies for Adams County

2. 16-789 Resolution Approving Amendment One to an Agreement between Adams County and Colorado Carpet Center for Additional Services (09:28 AM)
   Motion to Approve 2. 16-789 Resolution Approving Amendment One to an Agreement between Adams County and Colorado Carpet Center for Additional Services Moved by Eva J. Henry, seconded by Jan Pawlowski, unanimously carried.
3. 16-793 Resolution Approving First Amendment to the Agreement between Adams County and Allied Barton for Security Services (09:30 AM)
   Motion to Approve 3. 16-793 Resolution Approving First Amendment to the Agreement between Adams County and Allied Barton for Security Services Moved by Jan Pawlowski, seconded by Eva J. Henry, unanimously carried.
4. 16-794 Resolution Approving Agreement between Adams County and Tri-County Health to Provide an Early Crisis Intervention Program (09:35 AM)
   Motion to Approve 4. 16-794 Resolution Approving Agreement between Adams County and Tri-County Health to Provide an Early Crisis Intervention Program Moved by Eva J. Henry, seconded by Jan Pawlowski, unanimously carried.
5. 16-801 Resolution Approving Amendment Number One to an Agreement between Adams County and RNL Design for the Architect & Engineering Services for the Adams County Fleet and Transportation Facility (09:38 AM)
   Motion to Approve 5. 16-801 Resolution Approving Amendment Number One to an Agreement between Adams County and RNL Design for the Architect & Engineering Services for the Adams County Fleet and Transportation Facility Moved by Jan Pawlowski, seconded by Eva J. Henry, unanimously carried.

B. COUNTY ATTORNEY (09:40 AM)

1. 16-800 Second Reading and Adoption of Adams County Ordinance No. 6: Pet Animal Licensing and Control (09:40 AM)
   Motion to Approve 1. 16-800 Second Reading and Adoption of Adams County Ordinance No. 6: Pet Animal Licensing and Control Moved by Eva J. Henry, seconded by Jan Pawlowski, unanimously carried.

8. LAND USE HEARINGS (09:55 AM)

A. Cases to be Heard

1. 16-817 PLN2016-00016 Regulation Amendments (09:55 AM)
   Motion to Approve 1. 16-817 PLN2016-00016 Regulation Amendments Moved by Jan Pawlowski, seconded by Eva J. Henry, unanimously carried.

9. ADJOURNMENT (10:02 AM)

AND SUCH OTHER MATTERS OF PUBLIC BUSINESS WHICH MAY ARISE

PUBLIC HEARING AGENDA ITEM

DATE OF PUBLIC HEARING: November 22, 2016
SUBJECT: 2016 Seal Project Change Order #001, Modification of Pay Quantities of Existing Items
FROM: Jeffery Maxwell, P.E., PTOE, Director of Transportation
AGENCY/DEPARTMENT: Transportation
HEARD AT STUDY SESSION ON
AUTHORIZATION TO MOVE FORWARD: ☐ **YES** ☐ **NO**
RECOMMENDED ACTION: That the Board of County Commissioners Approves

BACKGROUND:

The 2016 Seal Project is a maintenance project that consists of providing chip seal at different locations in unincorporated Adams County. Since these different locations are selected well in advance, it is difficult to estimate the total amount of sealing material that will be required. In the selected neighborhoods additional cracks will need to be sealed.

The Change Order is to document increased quantities needed to complete the roads identified in the 2016 Seal Project.

AGENCIES, DEPARTMENTS OR OTHER OFFICES INVOLVED:

Adams County Transportation Department

ATTACHED DOCUMENTS:

Resolution
Change Order #001
Memo

FISCAL IMPACT:

Please check if there is no fiscal impact ☐. If there is fiscal impact, please fully complete the section below.

Fund: 13

Cost Center: 3055

	Object Account	Subledger	Amount
Current Budgeted Revenue:			
Additional Revenue not included in Current Budget:			
Total Revenues:			

	Object Account	Subledger	Amount
Current Budgeted Operating Expenditure:	7823		$22,089.10
Add'l Operating Expenditure not included in Current Budget:			
Current Budgeted Capital Expenditure:			
Add'l Capital Expenditure not included in Current Budget:			
Total Expenditures:			$22,089.10

New FTEs requested: ☐ **YES** ☐ **NO**

Future Amendment Needed: ☐ **YES** ☐ **NO**

Additional Note:

Draft Resolution

BOARD OF COUNTY COMMISSIONERS FOR ADAMS COUNTY, STATE OF COLORADO

RESOLUTION APPROVING CHANGE ORDER #001 FOR THE 2016 SEAL PROJECT, MODIFICATION OF PAY QUANTITIES OF EXISTING ITEMS

WHEREAS**,** the 2016 Seal Project is a maintenance project that consists of providing chip seal at different locations in unincorporated Adams County; and,

WHEREAS, these type of projects are selected a year or two prior to the actual chip seal placement on the roads; and,

WHEREAS, it is difficult to estimate the total amount of sealing material that will be required to complete the project; and,

WHEREAS, additional cracks have been encountered in selected neighborhoods which require them to be sealed; and,

WHEREAS, Change Order #001 – Modification of Pay Quantities of Existing Items, modifies the plan quantities of the Contract.

NOW, THEREFORE, BE IT RESOLVED by the Board of County Commissioners, County of Adams, State of Colorado, that Change Order #001, Modification of Pay Quantities of Existing Items, a copy of which is attached hereto and incorporated herein by this reference, be approved.

BE IT FURTHER RESOLVED, that the Chairman is authorized to execute said Change Order on behalf of Adams County.

ADAMS COUNTY
COLORADO

ADAMS COUNTY TRANSPORTATION DEPARTMENT
CHANGE ORDER

Project Id No.: 3055.7822	Project Code (SA#): IMP2016-00002
Location: Various Locations in Adams County	
Date: 8/19/16	Project Order No.: 001
Contact: Foothills Paving & Maintenance	Estimated cost to project: Increase X Decrease $22,089.10
Complete Address: 5040 Tabor Street, Wheat Ridge, CO 80033	Total additional days allowed to complete work: 0 / Federal Oversight? Yes No
Modification Title: Change Order #001- Modification of pay quantities of existing items	

Your contract is hereby modified to modify the existing pay items. The following pay items shall be increased: Hot Pour Joint and Crack Sealant and Epoxy Pavement Marking. All work shall be performed per the Project Special Provisions, Standard Special Provisions, Standard Specifications, M&S Standards, Contract, and as directed by the Project Engineer.

This Change Order modifies the plan quantities at the following existing Unit Prices.

Pay Item No.	Item Description	Unit	Quantity	Unit Price	Total
304-06000	Aggregate Base Course (Class 6)	TN	(25.00)	$66.00	-$1,650.00
403-00720	Hot Mix Asphalt (Patching) (Asphalt)	TN	(33.79)	$210.00	-$7,095.90
408-01000	Hot Poured Joint and Crack Sealant	TN	16.8	$3,350.00	$56,280.00
408-01400	Crack Sealant (Special)	TN	(5.00)	$3,850.00	-$19,250.00
627-00005	Epoxy Pavement Marking	GAL	15	$87.00	$1,305.00
700-70010	F/A Minor Contract Revisions	F/A	(1.00)	$7,500.00	($7,500.00)
	Total of Change Order				**$ 22,089.10**

I hereby accept this order, for work to be performed and prices on which payment is to be based.

REQUIRED IN ACCORDANCE WITH INSTRUCTIONS IN THE *CDOT CONSTRUCTION MANUAL*		REQUIRED FOR ALL CHANGE ORDERS	
Approved by FHWA Operations Engineer:	Date:	Authorized by Project Engineer:	Date:
OPTIONAL for additional funding requests		Contractor Representative:	Date:
Approved by Board of County Commissioners:	Date:	Approved by Construction Manager:	Date:
		Participating Non-participating Participation as noted Approved Funding by Transportation Director:	Date:

Change Order Form, ADCO Form 90

APPROVED AS TO FORM
COUNTY ATTORNEY

ADAMS COUNTY
COLORADO

Transportation Department
4430 South Adams County Parkway
1st Floor, Suite W2000B
Brighton, CO 80601-8218
PHONE 720.523.6875
FAX 720.523.6996
www.adcogov.org

August 19, 2016

To: Jeffery Maxwell, PE, PTOE, Director of Transportation

From: Renè Valdez, Infrastructure Manager
Prepared By: Lydia Stegall, Construction Inspector

Project: 2016 Seal Project
Location: Various Locations in unincorporated Adams County
Project No.: 3055.7822
Accela No.: IMP2016-00002

Re: Change Order #001 – Modification of pay quantities of existing items

This project is a maintenance project that consists of providing chip seal at different locations in unincorporated Adams County.

Typically all the cracks on the roads are sealed prior to placement of a chip seal. These type of projects are selected a season or two prior to the actual chip seal placement on the roads. As such it is difficult to estimate the total amount of crack sealing material that will be required. In the selected neighborhoods additional cracks have been encountered which require them to be sealed.

This change order is to document increased quantities needed to complete the roads identified in the 2016 Seal Project.

This Change Order modifies the plan quantities at the following existing Unit Price.

The following existing bid items at the unit price as follows:

Pay Item No.	Item Description	Unit	Quantity	Unit Price	Total
304-06000	Aggregate Base Course (Class 6)	TN	0	$66.00	$0.00
403-00720	Hot Mix Asphalt (Patching) (Asphalt)	TN	6.21	$210.00	$1,304.10
408-01000	Hot Poured Joint and Crack Sealant	TN	21.8	$3,350.00	$73,030.00
408-01400	Crack Sealant (Special)	TN	0	$3,850.00	$0.00
409-01015	Cover Coat Material (Type I)	SY	195,405.00	$2.11	$412,304.55
409-04050	Cover Coat Material (Special)	SY	94,744.00	$2.25	$213,174.00
627-00005	Epoxy Pavement Marking	GAL	835	$87.00	$72,645.00
627-30332	Preformed Plastic Pavement Marking (Xwalk-Stop line)(Type III)	SF	792.00	$14.00	$11,088.00
627-30405	Preformed Thermoplastic Pavement Marking (Word-Symbol)	SF	742.00	$18.00	$13,356.00
630-10005	TRAFFIC CONTROL	LS	1	$6,500.00	$6,500.00
	Total Added Items				**$803,401.65**
	Contract Amount				**$781,312.55**
	Total Amount of Overrun				($22,089.10)

BOARD OF COUNTY COMMISSIONERS

Eva J. Henry — DISTRICT 1
Charles "Chaz" Tedesco — DISTRICT 2
Erik Hansen — DISTRICT 3
Steve O'Dorisio — DISTRICT 4
Jan Pawlowski — DISTRICT 5

This Change Order modifies the plan quantities at the following existing Unit Price.

Pay Item No.	Item Description	Unit	Quantity	Unit Price	Total
304-06000	Aggregate Base Course (Class 6)	TN	(25.00)	$66.00	-$1,650.00
403-00720	Hot Mix Asphalt (Patching) (Asphalt)	TN	(33.79)	$210.00	-$7,095.90
408-01000	Hot Poured Joint and Crack Sealant	TN	16.8	$3,350.00	$56,280.00
408-01400	Crack Sealant (Special)	TN	(5.00)	$3,850.00	-$19,250.00
627-00005	Epoxy Pavement Marking	GAL	15	$87.00	$1,305.00
700-70010	F/A Minor Contract Revisions	F/A	(1.00)	$7,500.00	($7,500.00)
	Total of Change Order				**$ 22,089.10**

Additional funding is being requested:

F/A Minor Contract Revisions	$ 7,500.00
Amount of existing Unit Quantities not used	$ 27,995.90
Amount of Overruns	$ 57,585.00
Total Remaining	$ 22,089.10

The financial status of this project, as of June 21, 2016 is as follows:

Current Purchase Order	$ 781,312.55
Projected Cost to Date	$ 803,401.65
Projected Surplus (Deficit)	$ (22,089.10)

In conclusion, the Adams County Transportation Department, specifically, Russell Nelson P.E. and René Valdez (Storm Water & Infrastructure Manager) agreed with the need for this change order.

Lydia Stegall
Construction Inspector

XC: Liz Estrada, Purchasing
Russell Nelson, P.E.
René Valdez, Storm Water & Infrastructure Manager
Jeff Maxwell, PTOE, PE, Director of Transportation
File

PUBLIC HEARING AGENDA ITEM

DATE OF PUBLIC HEARING: November 22, 2016
SUBJECT: Clinica Family Health Services
FROM: Chris Kline, Director
AGENCY/DEPARTMENT: Human Services Department
HEARD AT STUDY SESSION ON
AUTHORIZATION TO MOVE FORWARD: ☐ **YES** ☐ **NO**
RECOMMENDED ACTION: That the Board of County Commissioners Approves

BACKGROUND:

Adams County Human Services Department contracts with various medical providers to quickly and accurately process medical assistance applications on behalf of their clients. Adams County hires Community Support Specialists who are designated to expedite the medical assistance applications submitted by clients of each of these organizations. Funding to pay for the salaries and benefits of the Adams County employees who work on each of these contracts is as follows:

Twenty five percent (25%) of the salary and benefits for the Adams County employees who works with Clinica Family Health Services is funded by Clinica Family Health Services, and the other seventy five percent (75%) is reimbursed with federal Medicaid funds. In addition, the supervisory costs associated with this contract are funded 25% by Clinica Family Health Services and 75% with Medicaid funds. There is no cost to Adams County for the work done by Adams County employees on this contract.

Adams County Human Services currently has a contract with Clinica Family Health Services for one (1) Community Support Specialist and due to their expansion, Clinica Family Health Services is requesting an additional Community Support Specialist.

Staff's recommendation is to approve this contract to enable timely processing of Medicaid applications. This contract will prevent a negative impact on the delivery of medical services to needy families and will ensure each partner receives timely medical assistance payments for the services rendered to these families.

AGENCIES, DEPARTMENTS OR OTHER OFFICES INVOLVED:

Clinica

ATTACHED DOCUMENTS:

Resolution
Contract between Adams County Human Serivces and Clinica Family Health Services

FISCAL IMPACT:

Please check if there is no fiscal impact ☐. If there is fiscal impact, please fully complete the section below.

Fund: 15

Cost Center: 3060M754015

	Object Account	Subledger	Amount
Current Budgeted Revenue:	5255		47,336.00
Additional Revenue not included in Current Budget:			
Total Revenues:			47,336.00

	Object Account	Subledger	Amount
Current Budgeted Operating Expenditure:	7005		47,336.00
Add'l Operating Expenditure not included in Current Budget:			
Current Budgeted Capital Expenditure:			
Add'l Capital Expenditure not included in Current Budget:			
Total Expenditures:			47,336.00

New FTEs requested: ☒ **YES** ☐ **NO**

Future Amendment Needed: ☐ **YES** ☐ **NO**

Additional Note:

BOARD OF COUNTY COMMISSIONERS FOR
ADAMS COUNTY, STATE OF COLORADO

RESOLUTION APPROVING AGREEMENT BETWEEN ADAMS COUNTY AND CLINICA FAMILY HEALTH SERVICES TO PROVIDE MEDICAID APPLICATION PROCESSING SERVICES AT CLINICA FAMILY HEALTH SERVICES FACILITIES

WHEREAS, Clinica Family Health Services requested to reimburse the Adams County Human Services Department ("ACHSD") to employ two intake specialists to process Medicaid applications; and,

WHEREAS, current satellite intake specialist deployments have resulted in reducing the typical Medicaid application processing time frame from 45-60 days to 2-14 days, significantly improving client services, and facilitating cost savings; and,

WHEREAS, without two on-site specialists, Clinica Family Health Services financial counselors would have to transport application forms to the ACHSD building in Commerce City, which would delay Medicaid eligibility determination, provision of medical services to needy families, and timely payment for those services; and,

WHEREAS, twenty five percent (25%) of the agreement's costs will be funded by Clinica Family Health Services and seventy five percent (75%) will be funded by the Colorado Department of Health Care Policy.

NOW, THEREFORE, BE IT RESOLVED**,** by the Board of County Commissioners, County of Adams, State of Colorado, acting in its capacity as the Board of Human Services, that the Agreement between Adams County and Clinica Family Health Services to provide Medicaid Application Processing Services at Clinica Family Health Services Facilities is approved.

BE IT FURTHER RESOLVED, that the Chair is authorized to execute said Agreement on behalf of Adams County.

AGREEMENT BETWEEN THE COUNTY OF ADAMS, COLORADO AND CLINICA FAMILY HEALTH SERVICES TO PROVIDE MEDICAID APPLICATION PROCESSING AT CLINICA FAMILY HEALTH SERVICES FACILITIES

THIS AGREEMENT is made and entered into between the Adams County Human Services Department, hereinafter referred to as "ACHSD", and **CLINICA FAMILY HEALTH SERVICES**, hereinafter referred to as **CLINICA.**

WITNESSETH:

WHEREAS, Clinica accepts Medicaid applications each month from Adams residents; and

WHEREAS, currently Clinica must transmit said applications to the respective county social/human services locations for processing; and

WHEREAS, the need to convey application forms to county social/human services offices delays Medicaid eligibility determination, provision of medical services to needy individuals and families, and timely payment for those services Clinica; and

WHEREAS, Clinica sometimes provides medical services to indigent patients prior to Medicaid eligibility determination, thus risking non-payment for those services if treated patients are later deemed ineligible; and

WHEREAS, Clinica is willing to pay twenty five percent (25%) the salary and benefits and provide a working space and appropriate office equipment for each Community Support Specialist; and

WHEREAS, ACHSD has agreed to allow two Community Support Specialists, employed by Adams County, to process Clinica Medicaid applications for Adams County.

NOW THEREFORE, FOR AND IN CONSIDERATION of the covenants and agreements below appearing, the parties agree as follows:

A. Scope of Services. Two full time Community Support Specialists employed by ACHSD shall be assigned to work at two different Clinica facilities, one located at 8990 Washington Street, Thornton, CO 80229 and the other at 7101 West 72nd Avenue, Denver, CO 80221. The Community Support Specialists shall be responsible for determining eligibility for Medicaid applicants, and for entering eligibility data into the Colorado Benefits Management System to complete the eligibility determination process. The Community Support Specialists will each process up to 100 applications per

month, will also be responsible for adding "Needy Newborns" and "pregnant women" to ongoing Medicaid cases, and assisting Clinica staff with Medicaid eligibility issues as related to this agreement, including billing back dates and assistance with load letter requests, as time allows. The Community Support Specialists through Clinica will transfer completed processed cases to the respective county departments.

B. ACHSD Responsibilities and Accountability. ACHSD shall be responsible for training and supervising the two Community Support Specialists. ACHSD will oversee the specialist's work to ensure compliance with pertinent federal and state laws and regulations. ACHSD will conduct periodic case reviews to assess the timeliness and accuracy of Medicaid applications processed by the Clinica Community Support Specialists. Further, ACHSD staff will facilitate any audits conducted of the specialist's work.

C. Employment. The two Community Support Specialists shall be employees of ACHSD. The two specialists shall be employed full-time (40 hours per week) by ACHSD. As such, the specialists will be subject to the policies, procedures, rules, regulations, directives, and orders of ACHSD. The Community Support Specialists shall comply with the policies Clinica to the extent that such policies and regulations are not in conflict with those of the ACHSD or are not in conflict with agreements herein contained. If such conflict arises and the policy is material to the role of the Community Support Specialist, the parties shall meet to discuss and determine which policy shall govern. The two Community Support Specialists shall be subject to the supervision of ACHSD, accountable to ACHSD, shall work between the hours of 7:00 a.m. to 5:30 p.m. Monday through Friday, and shall observe the same holidays as Adams County employees.

D. Clinica Financial Responsibility. Twenty-five percent[1] of the average salary costs, employer taxes, retirement contribution, health insurance, and other applicable benefits for each of the Community Support Specialists in accordance with rates specified by ACHSD, shall be paid to ACHSD effective upon the start date of the Community Support Specialist. ACHSD estimates that 25% of the average combined salary and benefits range for two Community Support Specialists will be between $22,500 and $30,000 annually. In addition, a proportionate share of the salary costs, health insurance and other applicable benefits for the supervisory functions of the Community Support Specialists totaling $520 per month effective the Community Support Specialists start date and adjusted annually thereafter shall be paid by Clinica to ACHSD. A memo stating the new average cost of two Community Support Specialists and new average cost of the supervisory

[1] CMS has approved a waiver through 2018 allowing ACHSD to charge seventy-five percent of these costs to Medicaid, with the remaining twenty-five percent chargeable to the contracting entity.

functions salary and benefits will be sent to Clinica within the first quarter of each year.

Notwithstanding the Term (Section J) of this Agreement, financial responsibility for payments owed by Clinica for salary and related expenses shall not commence until the Community Support Specialists have been hired and has started work as an ACHSD employee. In the unlikely event that the Colorado Medicaid program ceases financial support for the Medicaid eligibility function, and if mutually agreed to, the full cost of the Community Support Specialists will be borne by Clinica plus a proportionate share of the supervisor's salary and benefits.

ACHSD shall be responsible for the worker's compensation coverage for the Community Support Specialist and the Supervisor.

Clinica shall reimburse ACHSD for administrative costs, at a fixed rate of Two Hundred Dollars, ($200) per month, incurred by two Community Support Specialists and supervisory staff in carrying out the functions of the Community Support Specialists, such as mileage, continuing education, training and other required meetings. The $200 administrative cost will be submitted on the monthly invoice to Clinica.

Payments will be made in monthly installments, for the total amount invoiced by ACDHS for all salary, benefits, supervisory and additional costs, payable within forty-five (45) days of receipt of the invoice, hereunder beginning the first month the Community Support Specialist has started work at the Clinica facility. To ensure timely payment by Clinica ACHSD shall strive to submit all invoices to Clinica within the first five (5) business days of the month.

Clinica will be responsible for all costs associated with the Community Support Specialists and Supervisor's parking at the Clinica.

E. Coverage for Long-Term Absences. ACHSD shall attempt to provide an on-site replacement staff for the Clinica Community Support Specialist whenever the incumbent is absent for more than ten consecutive work days. In the event the Community Support Specialist will be absent for more than ten consecutive work days, Clinica shall be notified as soon as possible in writing of the extended absence as well as receive a written plan for coverage, including identification of a contact person, to ensure timely application processing until the Community Support Specialist returns.

For periods of absence less than ten consecutive work days, ACHSD shall assume responsibility for timely processing until the incumbent returns. Additionally, ACHSD shall provide a single point of contact in these instances.

F. Workplace and Personal Computer Access Clinica shall provide working space such as an office or cubicle, office equipment and supplies, a desktop computer, and a locking file cabinet for the two Community Support Specialists. ACHSD, with the cooperation of the information technology staff of Clinica, will establish and maintain connectivity to the Colorado Benefits Management System and other automated systems required by the Community Support Specialists.

G. Community Support Specialists Qualifications and Selection. Clinica Community Support Specialists shall be selected by ACHSD in accordance with ACHSD Human Resources specified qualifications for this position.

H. Liability Coverage. Pursuant to the Colorado Governmental Immunity Act, ACHSD agrees to be responsible for injuries or damages caused by or incurred by its respective public employees or agents arising from the performance of their duties and obligations under this Agreement, unless the act is willful and wanton or where sovereign immunity bars the action against the Parties. Nothing in this Agreement is intended to waive the provisions of the Colorado Immunity Act as it applies to ACHSD and its public employees. Clinica agrees to be responsible for injuries with the respective public employees or agents, or damages sustained from any act or omission of its employees or agents arising from the performance of their duties and obligations under this Agreement, unless the act is reckless, willful or wanton.

I. Insurance. ACHSD and Clinica shall exchange evidence of insurance showing general liability coverage for Clinica, and general liability coverage of ACHSD in the minimum amount of the Colorado Governmental Immunity Act for protection from claims for bodily injury, death, property damage, or personal injury which may arise through the execution of this contract. Recipients of such evidence shall be the Adams County Risk Manager and Clinica Vice President of Finance. Such evidence shall be approved by each recipient prior to commencement of this contract.

J. Term. This agreement shall commence on October 1, 2016, for a term of fourteen (14) months ending on December 31, 2017. The agreement shall be automatically renewed for successive one-year terms, unless either party gives sixty (60) days' prior written notice of termination. Additionally, this agreement may be terminated without cause by either ACHSD or Clinica upon thirty (30) days written advance notice, and in the event of such termination, Clinica monthly financial obligation shall cease for all subsequent months.

K. Confidentiality. Each Community Support Specialist shall comply with Clinica confidentiality policies as well as all federal, state, and county administrative rules, laws and regulations governing client confidentiality,

subject only to statutory exceptions applicable to criminal investigations and proceedings. Nothing in this agreement shall constitute ACHSD becoming a HIPAA business associate with Clinica.

L. Evaluation Plan. ACHSD and Clinica will evaluate the project on an annual basis. This will include goals and objectives, workload, performance measures, timelines, milestones, data collection procedures, and other elements agreed to by ACHSD and Clinica for this ongoing evaluation. ACHSD will continue to compile monthly reports and statistics which are presented at Liaison and Stakeholder meetings or whenever requested by Clinica.

M. Contract Amendment. Amendment of this contract may be made only by written agreement and signed by all parties hereto.

N. Electronic Disposition of Document (Scanning and Photocopies). The Parties hereto agree and stipulate that the original of this document, including the signature page, may be scanned and stored in a computer database or similar device, and that any printout or other output readable by sight, the reproduction of which is shown to accurately reproduce the original of this document, may be used for any purpose just as if it were the original, including proof of the content of the original writing.

O. Immediate Termination for Cause. Should Clinica become aware of any serious misconduct by either ACHSD employee such as policy violations or any act or omission that has an adverse impact on or causes damage to patients, staff, Clinica reputation, property, Clinica operations, Clinica must immediately report such information to an ACHSD Superior and/or Management. ACHSD will investigate such allegations and take appropriate disciplinary action according to its policies and procedures, including terminating the employee if appropriate.

P. Access to Records. ACHSD, for itself and for its agents and employees, agrees to provide to the Controller General of the United States or the Department of Health and Human Services ("HHS"), and their duly authorized representatives, upon written request, reasonable access to this Agreement, books, documents and records until the expiration of four (4) years after the Services are furnished under the Agreement for the purpose of evaluating the nature and extent or the costs and Services provided. ACHSD also agrees that if ACHSD subcontracts for any of the duties under this Agreement at a value or cost of Ten Thousand Dollars ($10,000) or more over a twelve (12) month period, with a related organization, the subcontract shall contain a clause to the effect that the related organization must make available, upon written request, to HHS, the Controller General, or their duly authorized representatives, the subcontract, and the books, documents, and records of the related organization that are necessary to verify the nature and

extent of the costs until the expiration of four (4) years after the Services are furnished under the subcontract.

IN WITNESS WHEREOF, the parties hereto have caused their names to be affixed hereto.

BOARD OF COUNTY COMMISSIONERS
ADAMS COUNTY, COLORADO

_____ _____
Chair Date

ATTEST:
STAN MARTIN
CLERK AND RECORDER

APPROVED AS TO FORM:

Adams County Attorney's Office

_____
Deputy Clerk

CONTRACTOR:

_____
Name: Simon Smith
Title: Present and CEO
Clinica Campesina/Family Health Services

Subscribed and sworn to before me this 6th day of October 2016, by Simon Smith.

_____
Notary Public

My commission expires: _____

SUSAN M WORTMAN KEENAN
NOTARY PUBLIC
STATE OF COLORADO
NOTARY ID 19954014138
MY COMMISSION EXPIRES 01/04/2020

PUBLIC HEARING AGENDA ITEM

DATE OF PUBLIC HEARING: November 22, 2016
SUBJECT: Sponsor Aurora Public Schools for a Great Outdoors Colorado grant
FROM: Shannon McDowell and Nathan Mosley
AGENCY/DEPARTMENT: Parks and Open Space
HEARD AT STUDY SESSION ON October 21, 2016
AUTHORIZATION TO MOVE FORWARD: ☒ YES ☐ NO
RECOMMENDED ACTION: That the Board of County Commissioners approves the resolution supporting and approving the sponsorship of a school yard grant from the State Board of the Great Outdoors Colorado Trust Fund for the Crawford Elementary School project.

BACKGROUND:

Aurora Public Schools (APS) has requested sponsorship from Adams County to apply for Great Outdoors Colorado (GOCO) grant funding to renovate the playground associated with Crawford Elementary School, located at 1600 Florence Street in Aurora. According to GOCO's policies, the school district is not an eligible grantee. However, they could seek an eligible grantee, such as Adams County, to apply on their behalf. The school district intends to apply through the School Yard Initiative, which aims to create school grounds that inspire more active, physical play and enhance learning about nature and the environment.

Crawford Elementary has approximately 640 students in kindergarten through fifth grades. The neighborhood that this school serves is very affordable and is the first place many refugees and immigrants settle when they migrate to the United States. Students at the school hail from countries such as Nepal, Burma/Myanmar, Cambodia, Iraq, Somalia, Kenya, The Congo, Ethiopia, Sudan, Mexico, and other Latin American countries. Almost seventy-five percent of the students are English Language Learners and eighty-eight percent of the students receive free or reduced lunch each day.

APS plans to request the full amount possible from GOCO, $110,000, and has the necessary matching funds toward the project. Right now, APS anticipates targeting renovation of the preschool playground and replacing the oldest play equipment at the school. APS has been successful with two of these grants in the past (at other schools) with the City of Aurora as their sponsor. When asked why the city would not sponsor this application, APS staff indicated

Aurora has chosen to share their support with all school districts within the city boundaries by sponsoring Cherry Creek School District with an application in this round.

Adams County's role in sponsoring this application will include approving a resolution to sponsor the application. If a grant is awarded, the County will then need to execute a grant agreement with GOCO, execute an agreement with Aurora Public Schools to establish proper use of these funds, ensure the project is constructed as described in the GOCO application, and submit closeout paperwork (prepared by APS) to GOCO. Parks staff will participate in the design process by attending design meetings. Adams County will also serve as a pass-through agency for GOCO funds once the project is completed. Staff anticipates spending no more than forty hours of time on the above tasks.

Adams County is currently working on two additional grant applications to GOCO. The Willow Bay acquisition application is being submitted through GOCO's Protect Initiative and an application for planning assistance to design a nature play experience at the 88th Avenue Open Space is being submitted in the Planning Grant cycle. GOCO treats each different application category as a separate process, so none of these applications is in direct competition with the other.

The school district intends to provide the required match, which cannot be less than $37,000 and intends to request the maximum grant of $110,000 from GOCO. This creates a total project cost of $147,000. Applications are due to GOCO on January 10, 2017. The GOCO Board will make their funding decision in April of 2017.

AGENCIES, DEPARTMENTS OR OTHER OFFICES INVOLVED:

Aurora Public School District, Great Outdoors Colorado

ATTACHED DOCUMENTS:

Resolution

FISCAL IMPACT:

Please check if there is no fiscal impact ☒. If there is fiscal impact, please fully complete the section below.

Fund:	
Cost Center:	

	Object Account	Subledger	Amount
Current Budgeted Revenue:			
Additional Revenue not included in Current Budget:			
Total Revenues:			

	Object Account	Subledger	Amount
Current Budgeted Operating Expenditure:			
Add'l Operating Expenditure not included in Current Budget:			
Current Budgeted Capital Expenditure:			
Add'l Capital Expenditure not included in Current Budget:			
Total Expenditures:			

New FTEs requested: ☐ **YES** ☒ **NO**

Future Amendment Needed: ☐ **YES** ☒ **NO**

Additional Note:

Aurora Public School District will provide all matching funds. Adams County will serve as the pass through agency to transfer funds from Great Outdoors Colorado to Aurora Public Schools.

RESOLUTION SUPPORTING AND APPROVING THE SPONSORSHIP OF A SCHOOL YARD GRANT FROM THE STATE BOARD OF THE GREAT OUTDOORS COLORADO TRUST FUND FOR THE CRAWFORD ELEMENTARY SCHOOL PROJECT

Resolution 2016-

WHEREAS, Adams County supports the Great Outdoors Colorado grant application for the Playground Renovation at Crawford Elementary School, and, if the grant is awarded, Adams County supports the completion of the project; and,

WHEREAS, Adams County is partnering with the Aurora Public School District to request $110,000 from Great Outdoors Colorado to enhance the playground at Crawford Elementary School.

NOW, THEREFORE, BE IT RESOLVED, by the Board of County Commissioners of the County of Adams, State of Colorado, that:

Section 1: The Board of County Commissioners of Adams County strongly supports the application to Great Outdoors Colorado.

Section 2: If the grant is awarded, the Board of County Commissioners of Adams County strongly supports the completion of the project.

Section 3: The Board of County Commissioners of Adams County will endeavor to enter into an intergovernmental agreement with Aurora Public School District to confirm the funding necessary to meet the terms and obligations of any Grant awarded.

Section 4: The Board of County Commissioners of Adams County will endeavor to enter into an intergovernmental agreement with Aurora Public School District to ensure the maintenance of the Playground Renovation at Crawford Elementary project in a high quality condition for its useful life. As stated in the Intergovernmental Agreement, Aurora Public School District will appropriate funds for maintenance in its annual budget.

Section 5: If the grant is awarded and the parties are able to reach mutually agreeable terms, the Board of County Commissioners of Adams County hereby authorizes the Chair of the Board of County Commissioners to sign the grant agreement with Great Outdoors Colorado after approval to form by the County Attorney's Office.

Section 6: This resolution shall be in full force and effect from and after its passage and approval.

PUBLIC HEARING AGENDA ITEM

DATE OF PUBLIC HEARING: November 22, 2016
SUBJECT: Adams County Workforce Development Board Provision of Career Services in Alignment with the Workforce Innovation and Opportunity Act of 2014
FROM: Chris Kline, Director
AGENCY/DEPARTMENT: Human services Department
HEARD AT STUDY SESSION ON
AUTHORIZATION TO MOVE FORWARD: ☐ YES ☐ NO
RECOMMENDED ACTION: That the Board of County Commissioners Approves

BACKGROUND:

The Adams County Workforce Development Board is requesting permission to provide career services and allow the board to pursue consent from the Governor in alignment with federal & state regulations and the Workforce Innovation and Opportunity Act of 2014. The Adams County Workforce and Business Center has been providing career services for over 20 years and this will allow that practice and continued benefit for the citizens of Adams County.

AGENCIES, DEPARTMENTS OR OTHER OFFICES INVOLVED:

Workforce and Business Center

ATTACHED DOCUMENTS:

Resolution

FISCAL IMPACT:

Please check if there is no fiscal impact ☒. If there is fiscal impact, please fully complete the section below.

Fund:	
Cost Center:	

	Object Account	Subledger	Amount
Current Budgeted Revenue:			
Additional Revenue not included in Current Budget:			
Total Revenues:			

	Object Account	Subledger	Amount
Current Budgeted Operating Expenditure:			
Add'l Operating Expenditure not included in Current Budget:			
Current Budgeted Capital Expenditure:			
Add'l Capital Expenditure not included in Current Budget:			
Total Expenditures:			

New FTEs requested: ☐ **YES** ☒ **NO**

Future Amendment Needed: ☐ **YES** ☒ **NO**

Additional Note:

BOARD OF COUNTY COMMISSIONERS FOR
ADAMS COUNTY, STATE OF COLORADO
RESOLUTION APPROVING THE PROVISION OF CAREER SERVICES IN ALIGNMENT WITH THE WORKFORCE INNOVATION AND OPPORTUNITY ACT OF 2014

Resolution No.

WHEREAS, in 2014, the Congress of the United States enacted the Workforce Innovation and Opportunity Act ("WIOA"), replacing the Workforce Investment Act of 1998 ("WIA") and the Rehabilitation Act of 1973, and the U.S. Department of Labor promulgated regulations thereunder; and,

WHEREAS, Adams County is a workforce investment area designated under WIOA; and,

WHEREAS, the Adams County Workforce Development Board ("WDB") maintains WIOA required representation; and,

WHEREAS, 20 CFR 679.410(b) provides that the local board may provide career services with the agreement of the local Workforce Development Board, Chief Elected Official and the Governor; and,

WHEREAS, pursuant to 20 CFR 679.380, the WDB hereby determines that career services are best performed by the local board through the Adams County Workforce and Business Center ("WBC"), specifically the WBC satisfies the consumer choice requirement by:

a. providing sufficient access to services for individuals with disabilities, including opportunities that lead to integrated, competitive employment for individuals with disabilities both internally and through its Memoranda of Understanding ("MOUs") with one-stop partners;
b. providing sufficient access for adult education and literacy activities both internally and through its MOUs with one-stop partners.

NOW, THEREFORE, BE IT RESOLVED, by the Board of County Commissioners, County of Adams, State of Colorado, that the provision of career services shall be performed in alignment with the Workforce Innovation and Opportunity Act of 2014.

BE IT FURTHER RESOLVED that Tricia Allen, Chair of the WDB, and Dr. Dirk Schmidt, Vice Chair, are hereby appointed and authorized to execute all reasonable and necessary non-contractual documents on behalf of the WDB in order to request the Governor's approval for WBC to provide career services.

PUBLIC HEARING AGENDA ITEM

DATE OF PUBLIC HEARING: November 22, 2016
SUBJECT: Ambulance License Renewal
FROM: Brandan Slattery
AGENCY/DEPARTMENT: Licensing/Community and Economic Development
HEARD AT STUDY SESSION ON: N/A
AUTHORIZATION TO MOVE FORWARD: ☐ YES ☐ NO
RECOMMENDED ACTION: That the Board of County Commissioners approve one ambulance license renewal for The City of Federal Heights Fire Department

BACKGROUND:

Annually the Office of Community and Economic development is responsible for the application review and licensing of all ambulances in the county according to the Multi-County Ambulance Committee Intergovernmental Agreement. The following ambulance agency has submitted their application packet in full and is subject to BOCC approval.

The City of Federal Heights Fire Department

AGENCIES, DEPARTMENTS OR OTHER OFFICES INVOLVED:

Community and Economic Development

ATTACHED DOCUMENTS:

Please reference the attached Resolutions and Licenses for this ambulance agency.

FISCAL IMPACT:

Please check if there is no fiscal impact ☒. If there is fiscal impact, please fully complete the section below.

Fund: 0001
Cost Center: 2053.6180

	Object Account	Subledger	Amount
Current Budgeted Revenue:			
Additional Revenue not included in Current Budget:			
Total Revenues:			

	Object Account	Subledger	Amount
Current Budgeted Operating Expenditure:			
Add'l Operating Expenditure not included in Current Budget:			
Current Budgeted Capital Expenditure:			
Add'l Capital Expenditure not included in Current Budget:			
Total Expenditures:			

New FTEs requested: ☐ **YES** ☒ **NO**

Future Amendment Needed: ☐ **YES** ☒ **NO**

Additional Note:

RESOLUTION APPROVING AMBULANCE SERVICE LICENSE FOR THE CITY OF FEDERAL HEIGHTS FIRE DEPARTMENT

WHEREAS, the General Assembly of the State of Colorado has enacted the Colorado Medical and Trauma Services Act, Section 25-3.5-101 et seq. C.R.S. ("Act"); and,

WHEREAS, the Act requires the Board of County Commissioners for each County to administer licensure of ambulance services; and,

WHEREAS, under the provisions of the Act, each ambulance operated by a licensed ambulance service in the State of Colorado must be issued a license and permit evidencing that the ambulance and its equipment meets applicable state requirements; and,

WHEREAS, Adams County has entered into an intergovernmental agreement with the City and County of Broomfield and the counties of Arapahoe, Douglas, Denver, Elbert, and Jefferson to establish a licensing program that provides for reciprocal inspection, licensing, and permitting that may be used by all parties, creating efficiency and cost saving to the parties and to the ambulance service providers; and,

WHEREAS, The City of Federal Heights Fire Department, 2400 W. 90th Ave., Federal Heights, CO 80260, has applied for an Ambulance Service License through Adams County; and,

WHEREAS, Adams County has reviewed the inspection performed through the intergovernmental agreement and the application of The City of Federal Heights Fire Department and has found that the ambulances meet the standards set forth in the March 2011 Adams County Ambulance Services Regulations; and,

WHEREAS, The City of Federal Heights Fire Department has complied with all regulations set forth in the March 2011 Adams County Ambulance Services Regulations.

NOW, THEREFORE, BE IT RESOLVED, by the Board of County Commissioners, County of Adams, State of Colorado, that the Ambulance Service License for The City of Federal Heights Fire Department is hereby approved to provide ambulance services in the County of Adams.

BE IT FURTHER RESOLVED, that the Chairman is authorized to sign said license on behalf of Adams County.

County of Adams, State of Colorado

No. ADCO 11/16 Licensing Fee: $230

Ambulance Service License

This is to Certify, that **The City of Federal Heights Fire Department, 2400 W. 90TH Ave., Federal Heights, CO,80260,** having applied for a license to provide **Advanced Life Support** ambulance services, and having paid to the Treasurer of Adams County the required fees therefore, the above named applicant is hereby licensed to provide ambulance services within and without the County of Adams, State of Colorado, for one year from the **30TH of November 2017**, unless this license be sooner revoked or suspended as provided by law.

This license is subject to the laws of the State of Colorado, and the Resolutions of the Board of County Commissioners of the County of Adams, passed pursuant thereto.

In Testimony Whereof, the Board of County Commissioners of the County of Adams has hereunto subscribed its name by its officers duly authorized, this _____ day of _____, _____.

Board of County Commissioners of the County of Adams,
State of Colorado

Attest:

_____
Chairman

_____
Clerk

PUBLIC HEARING AGENDA ITEM

DATE OF PUBLIC HEARING: November 22, 2016
SUBJECT: Independent Ethics Compliance Officer Agreement
FROM: Todd Leopold, County Manager; Bryan Ostler, Interim Deputy County Manager; Benjamin Dahlman, Finance Director; Kim Roland, Purchasing Manager
AGENCY/DEPARTMENT: County Attorney's Office
HEARD AT STUDY SESSION ON: October 11, 2016
AUTHORIZATION TO MOVE FORWARD: ☒ **YES** ☐ **NO**
RECOMMENDED ACTION: That the Board of County Commissioners approves Amendment One to the agreement with Cohen Milstein Sellers & Toll, PLLC, for independent ethics compliance services.

BACKGROUND:

Adams County requires the services of an experienced professional consultant to provide an objective and independent analysis regarding the interpretation and application of the Adams County Code of Ethics and applicable Colorado Law. Some of the duties of this professional include; receiving, evaluating, and investigating complaints of unethical conduct within Adams County Government.

A Request for Proposal (RFP) process was performed in 2015. The Board of County Commissioners approved the award of the agreement to Cohen Milstein Sellers & Toll, PLLC, for the initial term of one year, with two, one-year renewal options.

Cohen Milstein Sellers & Toll, PLLC, has performed their services well and continues to meet the expectations of the agreement. Staff is requesting the approval of the first option year renewal, in an estimated annual amount of $25,000.00, depending on required services.

AGENCIES, DEPARTMENTS OR OTHER OFFICES INVOLVED:

County Attorney's Office
County Manager's Office
Human Resources Department

ATTACHED DOCUMENTS:

Resolution

FISCAL IMPACT:

Please check if there is no fiscal impact ☐. If there is fiscal impact, please fully complete the section below.

Fund: 1

Cost Center: 1013

	Object Account	Subledger	Amount
Current Budgeted Revenue:			
Additional Revenue not included in Current Budget:			
Total Revenues:			

	Object Account	Subledger	Amount
Current Budgeted Operating Expenditure:	7635		$25,000.00
Add'l Operating Expenditure not included in Current Budget:			
Current Budgeted Capital Expenditure:			
Add'l Capital Expenditure not included in Current Budget:			
Total Expenditures:			$25,000.00

New FTEs requested: ☐ **YES** ☒ **NO**

Future Amendment Needed: ☐ **YES** ☒ **NO**

Additional Note:

BOARD OF COUNTY COMMISSIONERS FOR
ADAMS COUNTY, STATE OF COLORADO

RESOLUTION APPROVING AMENDMENT ONE TO AN AGREEMENT WITH COHEN MILSTEIN SELLERS & TOLL, PLLC, FOR INDEPENDENT ETHICS COMPLIANCE OFFICER SERVICES FOR ADAMS COUNTY

WHEREAS, on November 9, 2015, Adams County entered into an agreement with Cohen Milstein Sellers & Toll, PLLC, to provide independent ethics compliance officer services for Adams County; and,

WHEREAS, the agreement allows for two, one-year renewals, of which this is the first renewal to be exercised; and,

WHEREAS, Cohen Milstein Sellers & Toll, PLLC, agrees to provide the independent ethics compliance services at the previously established rates, in the estimated annual amount of $25,000.00; and,

WHEREAS, by means of the attached Amendment One, the parties wish to amend the agreement to reflect the above changes.

NOW, THEREFORE, BE IT RESOLVED, by the Board of County Commissioners, County of Adams, State of Colorado, that Amendment One to the Agreement between Adams County and Cohen Milstein Sellers & Toll, PLLC, to provide independent ethics compliance officer services for Adams County be approved.

BE IT FURTHER RESOLVED that the Chair is hereby authorized to sign the agreement with Cohen Milstein Sellers & Toll, PLLC, after negotiation and approval as to form is completed by the County Attorney's Office.

PUBLIC HEARING AGENDA ITEM

DATE OF PUBLIC HEARING: November 22, 2016
SUBJECT: Human Services Workforce and Business Center (TANF) Funded Program
FROM: Todd Leopold, County Manager; Bryan Ostler, Interim Deputy County Manager; Benjamin Dahlman, Finance Director; Kim Roland, Purchasing Manager
AGENCY/DEPARTMENT: Adams County Human Services Department Workforce and Business Center (TANF)
HEARD AT STUDY SESSION ON: N/A
AUTHORIZATION TO MOVE FORWARD: ☐ **YES** ☐ **NO**
RECOMMENDED ACTION: That the Board of County Commissioners approves Amendment One to renew the agreement with Almost Home Inc., to provide Emergency Shelter and Transitional Housing for Temporary Assistance to Needy Families (TANF) in Adams County.

BACKGROUND:

Adams County's Human Services Department received a Temporary Assistance for Needy Families (TANF) Block Grant from the State to assist with the goals of the Human Services Department Workforce and Business Center program services. The program services provide emergency shelter, transitional housing, case management and referrals, education, and advocacy services to eligible Adams County families.

The County awarded the original Agreement on December 29, 2015. At this time, the Human Services Department Workforce and Business Center is requesting the renewal of the agreement with Almost Home Inc., to provide emergency shelter, transitional housing, case management and referrals, education, and advocacy services for families who are eligible for TANF in Adams County. These services include providing funds directly to families for rent, utilities, and other housing-related expenses.

Almost Home Inc., has met the Human Services Department's expectations for the initial term of the Agreement. They assisted 86 families with rent, 125 families with utilities, and 28 families with other needs. Thirty-nine (39) families received funded assistance from this agreement.

The Almost Home Inc., program serves an average of five (5) families a month with forty-five (45) families having stayed in the homeless shelter this year. In addition, Almost Home, Inc., collaborates

with Aims Community College to provide GED classes, tutoring, and testing; the program has provided 308 classes.

The grant awarded will provide eighty-five (85%) funding by the State, with Adams County responsible for the remaining fifteen (15%) percent. The total cost for the renewal will be in the amount of eighty-six thousand, one hundred eighty-one dollars and no cents ($86,181.00).

The service effective date will begin January 1, 2017 through December 31, 2017.

AGENCIES, DEPARTMENTS OR OTHER OFFICES INVOLVED:

Human Services Department Workforce and Business Center

ATTACHED DOCUMENTS:

Resolution

FISCAL IMPACT:
Please check if there is no fiscal impact ☐. If there is fiscal impact, please fully complete the section below.

Fund: 15

Cost Center: 3070I8614195

	Object Account	Subledger	Amount
Current Budgeted Revenue:	5755		$73,254.00
Additional Revenue not included in Current Budget:			
Total Revenues:			$73,254.00

	Object Account	Subledger	Amount
Current Budgeted Operating Expenditure:	7645		$86,181.00
Add'l Operating Expenditure not included in Current Budget:			
Current Budgeted Capital Expenditure:			
Add'l Capital Expenditure not included in Current Budget:			
Total Expenditures:			$86,181.00

New FTEs requested: ☐ **YES** **X NO**

Future Amendment Needed: ☐ **YES** ☐ **NO**

Additional Note:

These expenditures are based on 2017 budget approval.

BOARD OF COUNTY COMMISSIONERS FOR
ADAMS COUNTY, STATE OF COLORADO

RESOLUTION APPROVING AMENDMENT ONE TO AGREEMENT BETWEEN ADAMS COUNTY AND ALMOST HOME INC., TO PROVIDE EMERGENCY SHELTER AND TRANSITIONAL HOUSING FOR TEMPORARY ASSISTANCE FOR NEEDY FAMILIES (TANF) IN ADAMS COUNTY

WHEREAS, Almost Home Inc., is currently providing emergency shelter, transitional housing, case management and referrals, education, and advocacy services for Temporary Assistance to Needy Families (TANF) in Adams County; and,

WHEREAS, this Human Services Department program is being funded eighty-five (85%) by the State, with Adams County responsible for the remaining fifteen (15%) percent; and,

WHEREAS, Almost Home Inc., agrees to provide the services for a total amount of $86,181.00 for the first year renewal; and,

WHEREAS, the Human Services Department is pleased with services provided by Almost Home Inc., under the current agreement, believes the renewal fees are fair and reasonable, and wishes to exercise the renewal of the existing agreement with Almost Home Inc., by means of the attached Amendment One.

NOW, THEREFORE, BE IT RESOLVED, by the Board of County Commissioners, County of Adams, State of Colorado, that Amendment One to the Agreement between Adams County and Almost Home Inc., be and hereby is approved.

BE IT FURTHER RESOLVED that the Chair is hereby authorized to sign Amendment One with Almost Home Inc., after approval as to form is completed by the County Attorney's Office.

PUBLIC HEARING AGENDA ITEM

DATE OF PUBLIC HEARING: November 22, 2016
SUBJECT: ADA Policies and Procedures and Transition Plans
FROM: Michelle Tyler Michel, Assistant County Attorney, Lorena Doe Boston, ADA Coordinator
AGENCY/DEPARTMENT: County Attorney's Office
HEARD AT STUDY SESSION ON: N/A
AUTHORIZATION TO MOVE FORWARD: ☐ YES ☐ NO
RECOMMENDED ACTION: That the Board of County Commissioners Approves the County's ADA Public Accommodation Policies, Master Transition Plan, Facilities Transition Plan, and Transportation Transition Plan.

BACKGROUND:

The Americans with Disabilities Act ("ADA") requires public entities to evaluate their current services, policies, and practices, and the effects thereof, to determine whether they meet the requirements of the ADA. To the extent modification of any such services, policies, and practices is required, the public entity must make the necessary modifications. This process is known as a self-evaluation.

Because it is a Title II entity, Adams County hired Meeting the Challenge, Inc. ("MTC") to perform the self-evaluation; it was completed in 2014. Since that time, several County departments have been working to make the necessary modifications. To that end, County staff has drafted Transition Plans and ADA Public Accommodation Policies to ensure the County's comply with Title II of the ADA. We are now asking that these Transition Plans and Policies be approved and adopted by the BOCC.

AGENCIES, DEPARTMENTS OR OTHER OFFICES INVOLVED:

County Attorney's Office
Facilities Department
Parks Department
Transportation Department

ATTACHED DOCUMENTS:

Resolution Adopting Adams County ADA Transition Plans and Policies
ADA Public Accommodation Policies
Master Transition Plan
Facilities Transition Plan
Transportation Transition Plan

FISCAL IMPACT:

Please check if there is no fiscal impact ☒. If there is fiscal impact, please fully complete the section below.

Fund:	
Cost Center:	

	Object Account	Subledger	Amount
Current Budgeted Revenue:			
Additional Revenue not included in Current Budget:			
Total Revenues:			

	Object Account	Subledger	Amount
Current Budgeted Operating Expenditure:			
Add'l Operating Expenditure not included in Current Budget:			
Current Budgeted Capital Expenditure:			
Add'l Capital Expenditure not included in Current Budget:			
Total Expenditures:			

New FTEs requested: ☐ **YES** ☒ **NO**

Future Amendment Needed: ☒ **YES** ☐ **NO**

Additional Note:
As the Transition Plans and Policies will need to be updated on an ongoing basis, the County Attorney's Office requests that the it be delegated the authority to alter or amend the Plans and Policies as needed.

RESOLUTION ADOPTING ADAMS COUNTY ADA TRANSITION PLANS AND POLICIES

WHEREAS, the Board of County Commissioners is committed to complying with federal and state laws governing a public entity's services to citizens with disabilities, including, Title II of the Americans with Disabilities Act of 1990 ("ADA" or "Title II") and Section 504 of the Rehabilitation Act of 1973 ("Section 504"); and,

WHEREAS, Adams County ("Adams County" or "County") previously contracted with Meeting the Challenge, Inc. ("MTC") to conduct a self-evaluation of the County's services, policies, and practices and County staff has reviewed that self-evaluation to identify necessary modifications; and,

WHEREAS, Adams County is committed to providing reasonable policy modifications, which provide equitable access to and participation in our programs and services, when viewed in their entirety, for all citizens; and,

WHEREAS, formal ADA Transition Plans and Policies are an essential part of ensuring compliance with applicable laws and the recommendations of the self-evaluation; and,

WHEREAS, Adams County has prepared formal ADA Transition Plans and Policies, copies of which are on file with the Adams County Attorney's Office and on the County's internet site, and are incorporated herein by reference as Exhibit A; and,

WHEREAS, the Board of County Commissioners has reviewed the County's ADA Transition Plans and Policies and has determined that they are reasonable and necessary to achieve the goals set out in this resolution; and,

WHEREAS, the Board of County Commissioners wishes to formally adopt the County's ADA Transition Plans and Policies, including:

- Adams County Master ADA Transition Plan
- Facilities Department Transition Plan
- Transportation Department Transition Plan
- Adams County ADA Public Accommodation Policies; and,

WHEREAS, the Board of County Commissioners recognizes the need to update the County's ADA Transition Plans and Policies on an ongoing basis and as such, delegates the authority to alter or amend the Plans and Policies to the Adams County Attorney's Office.

NOW, THEREFORE, BE IT RESOLVED by the Board of County Commissioners, County of Adams, State of Colorado that the County's ADA Transition Plans and Policies, which are on file with the Adams County Attorney's Office and on the County's

internet site and incorporated herein by reference as Exhibit A, are hereby approved and adopted.

BE IT FURTHER RESOLVED that the Adams County Attorney's Office has the right and authority to alter and amend the ADA Transition Plans and Policies as needed.

1. DISABILITY RIGHTS PUBLIC NOTICE

PURPOSE:
In accordance with the requirements of Title II of the Americans with Disabilities Act of 1990 ("ADA" or "Title II"), Section 504 of the Rehabilitation Act of 1973 ("Section 504"), and Section 1557 of the Patient Protection and Affordable Care Act of 2010 ("Section 1557"), Adams County ("Adams County" or "County") will not discriminate against qualified individuals with disabilities on the basis of disability in employment, admission or access to, treatment or participation in, or receipt of its services, programs, or activities. Adams County is committed to providing reasonable policy modifications, which ensure equitable access to and participation in our programs and services, when viewed in their entirety, for all citizens.

SCOPE:
Adams County's ADA policies apply to members of the public accessing County programs and services.

Effective Communication: Adams County will generally, upon request, provide appropriate aids and services leading to effective communication for qualified persons with disabilities so they can participate equally in County programs, services, and activities, including qualified sign language interpreters, documents in Braille, and other ways of making information and communications accessible to people who have speech, hearing, vision, or manual impairments.

Modifications to Policies and Procedures: Adams County will make all reasonable modifications to policies and programs to ensure that people with disabilities have an equal opportunity to enjoy all County programs, services, and activities. Anyone who requires an auxiliary aid or service for effective communication, or a modification of policies or procedures to participate in a County program, service, or activity, should contact the **ADA Coordinator** no later than forty-eight (48) business hours before the scheduled event. Title II does not require the County to take any action that would fundamentally alter the nature of its programs or services, or impose an undue financial or administrative burden.

The County will not place a surcharge on a particular individual with a disability or any group of individuals with disabilities to cover the cost of providing auxiliary aids/services or reasonable modifications of policy, such as retrieving items from locations that are open to the public but are not accessible to persons who use wheelchairs. Adams County has a procedure for complaints alleging disability discrimination or violations of Title II of the ADA, Section 504, or Section 1557.

Employment: Adams County does not discriminate on the basis of disability in its hiring or employment practices and complies with all regulations promulgated by the U.S. Equal Employment Opportunity Commission under Title I of the ADA.

1. DISABILITY RIGHTS PUBLIC NOTICE (CONTINUED)

Complaints that a County program, service, or activity is not accessible to persons with disabilities should be made to the ADA Coordinator. The ADA Coordinator handles complaints of discrimination made by the public under Title II, Section 504, or Section 1557.

For more information or to submit a request or complaint please contact:

Adams County ADA/504/1557 Coordinator
4430 South Adams County Parkway, Suite C5000B
Brighton, CO 80601-8206
Phone: (720) 523-6882 or (720) 523-6116
Fax: (720) 523-6114
Email: ADA504@adcogov.org
Adams County TTY: (720) 523-6044
Website: www.adcogov.org/americans-disabilities

If you wish to file a complaint with the U.S. Department of Health and Human Services, please contact:

U.S. Department of Health and Human Services
Office for Civil Rights
Centralized Case Management Operations
200 Independence Avenue, S.W.
Suite 515F, HHH Building
Washington, D.C. 20201
Customer Response Center: (800) 368-1019
Fax: (202) 619-3818
TDD: (800) 537-7697
Email: ocrmail@hhs.gov
Website: www.hhs.com/ocr

2. COMPLAINT PROCEDURE

ADA/SECTION 504 COMPLAINT PROCEDURE:
If you feel that you have not been able to access an Adams County program or service because of a lack of accessibility, or that you have been discriminated against because of your disability, please fill out a written ADA Complaint Form.

Step 1: An ADA Complaint Form should be filed in writing to:

Adams County ADA/504/1557 Coordinator
4430 South Adams County Parkway, Suite C5000B
Brighton, CO 80601-8206
Phone: (720) 523-6882 or (720) 523-6116
Fax: (720) 523-6114
Email: ADA504@adcogov.org
Adams County TTY: (720) 523-6044
Website: www.adcogov.org/americans-disabilities

Complaints should contain the name and address of the person filing the complaint and describe the alleged violation of Title II of the Americans with Disabilities Act or Section 504 of the Rehabilitation Act, if appropriate, and the remedy the person believes is appropriate. A complaint must be filed within thirty (30) calendar days after the complainant becomes aware, or should have become aware, of the alleged violation. Assistance with and/or a modification to filling out the ADA Complaint Form will be provided to those persons with disabilities requesting such assistance and/or modification.

Step 2: An investigation will follow the filing of a complaint. The ADA Coordinator shall conduct or administer the investigation unless such complaint alleges misconduct on the part of the ADA Coordinator.

Step 3: Upon conclusion of the investigation, and within forty-five (45) working days of the filing of the ADA Complaint Form, the ADA Coordinator shall issue a written determination regarding the validity of the complaint and describing the resolution. A copy of the written determination will be forwarded to the complainant and the affected department director, or elected official.

Filed Complaints:
The ADA Coordinator shall maintain the confidentiality of all files and records of any complaint, unless disclosure is authorized or required by law. The entire record shall be maintained for a period of three years.

Filing a complaint with the ADA Coordinator does not preclude a complainant from filing a complaint or seeking relief from any other federal or state agency with jurisdiction over such matters. If you wish to file a complaint with the U.S. Department of Health and Human Services, please contact:

U.S. Department of Health and Human Services
Office for Civil Rights
Centralized Case Management Operations
200 Independence Avenue, S.W.
Suite 515F, HHH Building
Washington, D.C. 20201
Customer Response Center: (800) 368-1019
Fax: (202) 619-3818
TDD: (800) 537-7697
Email: ocrmail@hhs.gov
Website: www.hhs.com/ocr

3. NONDISCRIMINATION POLICY

POLICY:
It is the policy of Adams County that all programs and services, viewed in their entirety, are accessible to and usable by individuals with disabilities, unless providing access results in undue financial or administrative burden to Adams County or causes fundamental alteration of the programs and services. It is also Adams County's policy that members of the public not experience discrimination, retaliation, or harassment based upon a disability when accessing County programs and services.

Adams County complies with applicable federal and state civil rights laws and does not exclude, deny benefits to, or otherwise discriminate against any individual on the basis of race, color, ethnic or national origin, ancestry, age, sex, gender, sexual orientation, gender identity and expression, religion, creed, political beliefs, or disability in employment, admission or access to, treatment or participation in, or receipt of the services and benefits under any of its programs, services and activities, whether carried out by the County directly or through a contractor or any other entity with which it arranges to carry out its programs, services and activities.

4. ANTI-RETALIATION POLICY

POLICY:
Adams County shall not discriminate against any individual because that individual has opposed any act or practice made unlawful by the ADA, or because that individual made a charge, testified, assisted, or participated in any manner in an investigation, proceeding, or hearing under the ADA.

Adams County and its staff shall not coerce, intimidate, threaten, or interfere with any individual in the exercise or enjoyment of, or on account of his or her having aided or encouraged any other individual in the exercise or enjoyment of, any right granted or protected by the ADA.

5. DIRECT THREAT POLICY/PROCEDURE

POLICY:
Adams County's ADA Nondiscrimination Policy does not require a public accommodation or modification that would permit an individual to participate in or benefit from the goods, services, privileges, advantages and accommodations of that public accommodation when that individual poses a direct threat to the health or safety of themselves or others. Direct threat means a significant risk to the health or safety of others that cannot be eliminated by a modification of policies, practices, or procedures, or by the provision of auxiliary aids or services. The County may impose legitimate safety requirements necessary for the safe operation of its services, programs, or activities.

In determining whether a direct threat exists, County staff should perform an individualized assessment that relies on current medical evidence, or on the best available objective evidence, to assess:

- The nature, duration, and severity of the risk;
- The probability that the potential injury will actually occur; and,
- Whether reasonable modifications of policies, practices, or procedures or the provision of auxiliary aids or services will mitigate or eliminate the risk.

Making this assessment will not usually require the services of a physician. Medical guidance may be obtained from public health authorities.

If an employee believes that an individual may pose a direct threat, the employee should immediately contact the County's ADA Coordinator. If the direct threat situation constitutes an emergency, the employee should dial 911.

6. EFFECTIVE COMMUNICATIONS POLICY

POLICY:
It is the intent of Adams County to ensure that communications with individuals with disabilities in its programs, services, and activities are as effective as communications with individuals without disabilities. Upon request, the County will provide, free of charge, appropriate and reasonable auxiliary aids and services to ensure that individuals with disabilities have an equal opportunity to participate in, and benefit from, the County's programs, services, and activities. The County will not place a surcharge on a particular individual with a disability or any group of individuals with disabilities to cover the cost of providing auxiliary aids/services or reasonable modifications of policy. All notifications, including approvals or denials of requests for effective communication referenced in this policy, will be provided in an alternate format, upon request.

Auxiliary Aids and Services:
Auxiliary aids and services include a wide range of services and devices that promote effective communication for people with disabilities. The type of auxiliary aid or service necessary to ensure effective communication will vary in accordance with the length and complexity of the communication involved.

- **For people who are deaf, have hearing loss or are deaf-blind**, examples of appropriate auxiliary aids and services may include, but are not limited to, a qualified sign language interpreter, oral interpreter, cued-speech interpreter, tactile interpreter, note-takers, computer-aided transcription services, written materials, telephone handset amplifiers, assistive listening systems, telephones compatible with hearing aids, real-time captioning, closed caption decoders, open and closed captioning, videophones, captioned telephones, telecommunications devices for deaf persons (TTYs), videotext displays, and exchange of written notes.
- **For people who are blind, have vision loss, or are deaf-blind**, examples of appropriate auxiliary aids and services may include, but are not limited to, a qualified reader, taped texts, optical readers, audio recordings, printed information in Braille, large print materials, screen reader software or text magnification software to make computer displays accessible, or assistance in locating items.
- **For people who have speech disabilities, examples of appropriate auxiliary aids and services may** include, but are not limited to, a qualified speech-to-speech transliterator (a person trained to recognize unclear speech and repeat it clearly), computer terminals, speech synthesizers, and communication boards.

Qualified interpreters:
The term "qualified interpreter" means an interpreter who, via an on-site appearance or a video remote interpreting (VRI) service, is able to interpret effectively, accurately, and impartially, both receptively and expressively, using any specialized terminology necessary for effective communication with an individual who is deaf or hard of hearing or who has a speech impairment. The term "qualified interpreter" includes, for example, sign language interpreters, oral translators, or cued-language translators.

6. EFFECTIVE COMMUNICATIONS POLICY (CONTINUED)

Telephone communications:
Departments and offices that have regular and direct contact with the general public via the telephone should ensure communication is equally accessible and effective to people who are deaf, hard of hearing and/or speech impaired by providing telecommunication access. If telephone relay services are used (i.e., TTY), County staff should respond to all telephone calls from a telecommunications relay service, in the same manner that they respond to other telephone calls in the normal course of business.

The TTY number for the Adams County Government Center is: (720) 523-6044.

Requests for Effective Communication:
All requests for auxiliary aids and services must be submitted in writing to the Adams County ADA Coordinator using the "Auxiliary Aids and Service Request Form." and must be received by the ADA Coordinator a minimum of two (2) weeks prior to the date the service is needed. If, in emergency circumstances, an auxiliary aid or services is requested less than two (2) weeks prior to the date the service is needed, the County will take reasonable steps to secure the requested auxiliary aid or service to the extent possible.

The "Auxiliary Aids and Service Request Form" is available on the County website. Individuals may contact the Adams County ADA Coordinator directly to discuss alternate methods for completing the request.

In determining which type(s) of auxiliary aids and/or services to provide, the County will give "primary consideration" to the request of the individual with a disability. "Primary consideration" means that the County will honor the individual's request unless it can demonstrate that another equally effective means of communication is available, or that use of the means chosen would result in a fundamental alteration in the service, program, or activity or in undue financial and administrative burdens.

Upon notification of a request, County staff may consult with the individual with a disability to determine the most appropriate auxiliary aid or service to meet their needs. The County will endeavor to respond promptly to requests for auxiliary aids and services so that delays in responding do not deny individuals with disabilities an equal opportunity to participate in, and benefit from, the County's programs, services and activities.

Personal Devices
The County will not provide individuals with disabilities with personal or individually prescribed devices, such as: wheelchairs; individually prescribed devices, such as prescription eyeglasses or hearing aids; readers for personal use or study; or services of a personal nature including assistance in eating, toileting, or dressing.

6. EFFECTIVE COMMUNICATIONS POLICY (CONTINUED)

Effective Communication FAQs:

Must public service announcements or other television programming produced by public entities be captioned?
Audio portions of television and videotape programming produced by public entities are subject to the requirement to provide equally effective communication for individuals with hearing impairments. Closed captioning of such programs is sufficient to meet this requirement.

Must tax bills from public entities be available in Braille and/or large print? What about other documents?
Tax bills and other written communications provided by public entities are subject to the requirement for effective communication. Thus, where a public entity provides information in written form, it must, when requested, make that information available to individuals with vision impairments in a form that is usable by them. "Large print" versions of written documents may be produced on a copier with enlargement capacities. Braille versions of documents produced by computers may be produced with a Braille printer, or audio tapes may be provided for individuals who are unable to read large print or do not use Braille.

May friends or relatives be asked to interpret?
Often, friends or relatives of the individual can provide interpreting services, but the County may not require the individual to provide his or her own interpreter. A family member or friend may not be qualified to render the necessary interpretation or other services. Also, in many situations, requiring a friend or family member to interpret may not be appropriate, because his or her presence at the transaction may violate the individual's right to confidentiality, or because the friend or family member may have an interest in the transaction. The obligation to provide "impartial" interpreting services requires that, upon request, the County provide an interpreter who does not have a personal relationship to the individual with a disability.

Are certified interpreters considered to be more qualified than interpreters without certification?
Certification is not required in order for an interpreter to be considered to have the skills necessary to facilitate communication. Regardless of the professionalism or skills that a certified interpreter may possess, that particular individual may not feel comfortable or possess the proper vocabulary necessary for interpreting for a subject that involves specialized knowledge. Another equally skilled, but noncertified interpreter might have the necessary vocabulary, thus making the noncertified person the qualified interpreter for that particular situation.

Can the County use a staff member who signs "pretty well" as an interpreter for meetings with individuals who use sign language to communicate?
Signing and interpreting are not the same thing. Being able to sign does not mean that a person can process spoken communication into the proper signs, nor does it mean that he or she possesses the proper skills to observe someone signing and change their signed or finger spelled communication into spoken words. The interpreter must be able to interpret both receptively and expressively.

7. TELECOMMUNICATIONS POLICY

POLICY:
It is the policy of Adams County that all departments and offices that have regular and direct contact with the general public via the telephone shall ensure communication is equally accessible and effective to people who are deaf, hard of hearing and/or speech impaired by providing telecommunication access. If telephone relay services are used, County staff shall respond to all telephone calls from a telecommunications relay service, in the same manner that they respond to other telephone calls in the normal course of business.

For departments and offices that communicate by telephone with applicants and beneficiaries, text telephones (TTYs) or equally effective telecommunications systems shall be used to communicate with individuals who are deaf or hard of hearing or have speech impairments.

For departments and offices that use an automated-attendant system, including, but not limited to, voice mail and messaging, or an interactive voice response system, for receiving and directing incoming telephone calls, that system must provide effective real-time communication with individuals using auxiliary aids and services, including TTYs and all forms of FCC-approved telecommunications relay system, including Internet-based relay systems.

Adams County TTY number (Government Center): (720) 523-6044

In the event that County staff require relay services, these services are available by contacting the Colorado Relay Service at:

- TTY: 7-1-1 or 1 (800) 659-2656
- Voice: 7-1-1 or 1 (800) 659-3656
- Spanish Calls: 1 (800) 337-3242
- Spanish Translation: 1 (844) 409-2451
- VCO Calls*: 1 (877) 659-8260
- ASCII Calls: 1 (800) 659-4656
- Speech-to-Speech Calls: 1 (877) 659-4279
- Telebraille: 1 (800) 659-2656

** Voice carry-over or VCO calls allow a deaf or hard-of-hearing person to use their voice to speak directly to a hearing person.*

For customer service or technical assistance, staff can contact the Colorado Relay Customer Care Center 24 hours 7 days a week at:

- Voice: 1 (800) 676-3777
- Speech-to-Speech: 1 (877) 787-1989
- TTY: 1 (800) 676-3777
- Spanish: 1 (800) 676-4290

7. TELECOMMUNICATIONS POLICY (CONTINUED)

- E-mail: Sprint.TRSCustServ@sprint.com
- Fax: 1 (877) 877-3291

8. SERVICE ANIMAL POLICY

POLICY:
Adams County allows service animals to accompany individuals with disabilities in all areas where members of the public are allowed to go, subject to the requirements and limitations noted below. If the County properly excludes a service animal it will give the individual with a disability the opportunity to participate in the service, program, or activity without having the service animal on the premises.

Service Animals:
Service animals are dogs or miniature horses that are individually trained to do work or perform tasks for a person with a disability. Service animals are working animals, not pets. Dogs whose sole function is to provide comfort or emotional support do not qualify as service animals under Title II. The work or task a dog has been trained to provide must be directly related to the individual's disability. Examples of such work or tasks may include the following:

- Guiding people who are blind;
- Alerting people who are deaf;
- Pulling a wheelchair;
- Alerting and Protecting a person who is having a seizure;
- Reminding a person with mental illness to take prescribed medications;
- Calming a person with Post Traumatic Stress Disorder (PTSD) during an anxiety attack;
- Fetching or retrieving items; or
- Performing other special tasks or duties.

Miniature horses that have been individually trained to do work or perform tasks for people with disabilities will be accommodated at County facilities where reasonable. Miniature horses generally range in height from 24 to 34 inches as measured to the shoulders and generally weigh between 70 and 100 pounds. The following four assessment factors will be used by the County in order to determine whether a miniature horse can be accommodated at a particular County facility:

1) Whether the miniature horse is housebroken;
2) Whether the miniature horse is under the individual owner's control;
3) Whether the facility can accommodate the miniature horse's type, size and weight; and
4) Whether the miniature horse's presence will not compromise legitimate safety requirements necessary for the safe operation of that facility.

8. SERVICE ANIMAL POLICY (CONTINUED)

Handler Requirements and Limitations:

- **Control:** Service animals must be harnessed, leashed, or tethered, unless these devices interfere with the service animal's work or the individual's disability prevents the use of these devices. In such cases, the individual must maintain control of the animal through voice, signal, or other effective controls.
- **Removal:** An individual with a disability may be asked to remove their service animal from a County facility if the animal is out of control and the individual does not take effective action to regain control, or if the service animal is not housebroken. When there is a legitimate reason to ask that a service animal be removed, County staff must offer the individual with the disability the opportunity to obtain goods or services without the animal's presence.
- **Licensure:** There is no requirement that a dog be licensed or certified as a service animal.
- **Maintenance**: County staff is not responsible for the care and supervision of a service animal. It is the responsibility of the individual to make or arrange for any cleaning necessary due to the presence of the Service Animal.

Permissible Inquiry

When it is not obvious what service an animal provides, only limited inquiries are allowed. County staff may only ask two questions:

1) "Is the service animal required because of a disability?"
2) "What work or task has the animal been trained to perform?"

County staff may not ask about the individual's disability, require a showing of medical documentation, require a special identification card or training certificate for the animal, or ask that the animal demonstrate its ability to perform the work or task. County staff may not make these inquiries about a service animal when it is readily apparent that an animal is trained to do work or perform tasks for an individual with a disability (e.g., the dog is observed guiding an individual who is blind or has low vision, pulling a person's wheelchair, or providing assistance with stability or balance to an individual with an observable disability). Allergies and fear of dogs are not valid reasons for denying access or refusing service to people using service animals.

Charges and Requirements

The County should not ask or require an individual with a disability to pay a surcharge, even if people accompanied by pets are required to pay fees, or to comply with other requirements generally not applicable to people without pets. If the County normally charges individuals for the damage they cause, an individual with a disability may be charged for damage caused by his or her service animal.

9. MOBILITY DEVICE POLICY

POLICY:
Adams County allows people with disabilities who use wheelchairs, manually-powered mobility aids and other types of power-driven mobility devices ("OPDMD") into all areas of a County owned facility where members of the public are permitted to go, unless a particular type of device cannot be accommodated because of legitimate safety requirements. The County will ensure that its safety requirements are based on actual risks, not on mere speculation, stereotypes, or generalizations about individuals with disabilities.

In addition, the County strives to provide an equal opportunity to all visitors to experience programs, events, facilities, and natural and cultural resources at County facilities. Due to the broad range of devices and vehicles that meet the above definition of an OPDMD, the County will assess the use of such devices using the below noted assessment factors. The County will allow use of OPDMDs that meet the following criteria:

- Limited by the intended use of the device or vehicle, based upon the manufacturer's recommendation and the type of activity the device or vehicle is designed and used for.
- If powered by an internal combustion engine, the engine shall have a four-stroke cycle, be equipped with an approved spark arrestor muffler, and meet Clean Air standards in effect at the time of its manufacture. Two-stroke cycle engines are not allowed.
- If powered by an internal combustion engine, OPDMDs are not allowed inside structures whether the internal combustion engine is used or not while indoors.
- Used in accordance with normal operating hours for that facility or site and in compliance with current regulations and policy governing public use of County programs and sites.
- Used only on designated trails and paved surfaces.
- When using an OPDMD, it must not exceed a maximum speed limit of 15 mph.

The County reserves the right to modify this criteria regarding use of OPDMDs in order to provide greater clarity of use and to establish additional safety requirements as necessary.

Other Power-Driven Mobility Device Assessment Factors:
In determining whether an OPDMD will be allowed in a specific facility as a reasonable modification, the County shall consider the following assessment factors:

- The type, size, weight, dimensions, and speed of the device;
- The facility's volume of pedestrian traffic (which may vary at different times of the day, week, month, or year);
- The facility's design and operational characteristics (e.g., whether its service, program, or activity is conducted indoors, its square footage, the density and placement of stationary devices, and the availability of storage for the device, if requested by the user);
- Whether legitimate safety requirements can be established to permit the safe operation of the OPDMD in the specific facility; and

9. MOBILITY DEVICE POLICY (CONTINUED)

- Whether the use of the OPDMD creates a substantial risk of serious harm to the immediate environment or natural or cultural resources, or poses a conflict with all applicable land management laws and regulations.

Permissible Inquiry:
County staff should not ask an individual using a wheelchair or other power-driven mobility device questions about the nature and extent of the individual's disability. County staff may ask a person using an OPDMD to provide a credible assurance that the mobility device is required because of the person's qualified disability. When the use of an OPDMD is permitted by the County in accordance with the established policy, the County shall accept the presentation of a valid, state-issued, disability parking placard, or other state-issued proof of disability as a credible assurance that the use of the OPDMD is for the individual's mobility disability. In lieu of a valid, state-issued disability parking placard, or state-issued proof of disability, the County shall accept a verbal representation, not contradicted by observable fact, as a credible assurance that the OPDMD is being used for a mobility disability. A "valid" disability placard is one that is presented by the individual to whom it was issued and is otherwise in compliance with the state of issuance's requirements for disability placards.

DEFINITIONS:

- **Manually-powered mobility aid:** any manually-operated device such a walker, crutches cane, brace or similar device.
- **Wheelchair**: a manually operated or power driven device designed primarily for use by an individual with a mobility disability for the main purpose of indoor or of both indoor and outdoor locomotion.
- **Other Power-Driven Mobility Devices (OPDMD)**: any mobility device powered by batteries, fuel or other engines that is used by individuals with mobility disabilities for the purpose of locomotion. This definition includes golf carts, electronic personal assistance mobility devices (EPAMDs) such as Segways ®, or any mobility device designed to operate in areas without defined pedestrian routes, but that is not a wheelchair. When an OPDMD is being used by a person with a mobility disability, different rules apply under the ADA than when it is being used by a person without a disability.

10. INFORMATIONAL SIGNAGE

POLICY:
The County shall endeavor to ensure that interested persons, including individuals with disabilities, can obtain information as to the existence and location of accessible services, activities, and facilities. Requests for information can be made to the Adams County ADA Coordinator.

The County provides signage at inaccessible entrances to each of its facilities, directing users to an accessible entrance or to a location at which they can obtain information about accessible facilities. The international symbol for accessibility shall be used at each accessible entrance of a facility.

11. FUNDAMENTAL ALTERATION/UNDUE BURDEN

POLICY:
All programs, services and activities, viewed in their entirety, should be accessible to and usable by individuals with disabilities, unless providing access results in undue financial or administrative burden to Adams County or causes fundamental alteration of the programs and services. An undue burden is defined as significant difficulty or expense relative to the operation of a public entity's program. Undue burden is determined on a case-by-case basis and is based on the nature and cost of the requested modification/accommodation in relation to the size, resources, and structure of the specific operation.

All decisions denying the provision of a requested modification, auxiliary aid or service on the grounds that doing so would result in a fundamental alteration or impose undue financial or administrative burdens must be made by the County Manager, or his/her designee, after considering all resources available to the County for the use in the funding and operation of the County's services, programs and activities, and should be accompanied by a written statement of the reasons for reaching that conclusion. If an action would result in such an alteration or such burdens, the County shall take any other action that would not result in such an alteration or such burdens but would nevertheless ensure that individuals with disabilities receive the benefits or services provided by the public entity.

12. ILLEGAL USE OF DRUGS POLICY

POLICY:
It is the policy of Adams County to not discriminate against members of the public on the basis of illegal use of drugs for an individual who is not engaging in the current illegal use of drugs who:

- Has successfully completed a supervised drug rehabilitation program or has otherwise been rehabilitated successfully;
- Is participating in a supervised rehabilitation program; or
- Is erroneously regarded as engaging in such use.

Adams County will also not deny services to an individual on the basis of that individual's current illegal use of drugs, if the individual is otherwise entitled to such services. This policy does not prohibit the County from adopting or administering reasonable polices or procedures, including but not limited to drug testing, designed to ensure that an individual who formerly engaged in the illegal use of drugs is not now engaging in current illegal use of drugs. Nothing in this policy shall be construed to encourage, prohibit, restrict, or authorize the conduct of testing for the illegal use of drugs.

13. MAINTENANCE OF ACCESSIBLE FEATURES POLICY

POLICY:
All Adams County departments and offices will maintain, in operable working condition, the features of County facilities and equipment that are required to be readily accessible to and usable by individuals with disabilities.

Temporary access interruptions for maintenance, repair, or operational activities (such as mechanical failures in equipment including elevators or automatic doors) are permitted, but will be remedied as soon as possible and may not extend beyond a reasonable period of time. Repairs will be made promptly and adequately so as not to cause repeated or persistent failures. Adams County employees will be prepared to assist individuals with disabilities during these interruptions. Accessible doors will be unlocked and operable when the County is open for business. No new barriers will be created that impede access by people with disabilities. For all accessible public routes, the route will remain accessible and not blocked by obstacles such as furniture, filing cabinets, potted plants, etc. Isolated instance of placement of an object on an accessible route is permissible when necessary provided that the object is promptly removed.

14. EXISTING FACILITIES POLICY

POLICY:
Adams County will maintain, in operable working condition, the features of facilities and equipment that are required to be readily accessible to and usable by persons with disabilities.

ADA Requirements:
All public facilities designed, constructed, or altered must be readily accessible and usable by individuals with disabilities, if the construction or alteration began after January 26, 1992. Title II regulations and the ADA Standards for Accessible Design, originally published in 1991, set the minimum standard for what makes a facility accessible.

The County is not required to make structural changes in existing facilities where other methods are effective in achieving compliance under Title II. In making alterations to existing buildings, the County shall meet the accessibility requirements of Title II. In choosing among available methods for meeting the requirements of this section, the County will give priority to those methods that offer services, programs, and activities to qualified individuals with disabilities in the most integrated setting appropriate.

The County is not required to make each of its existing facilities accessible. **Elements that have not been altered in existing facilities on or after March 15, 2012, and that comply with the corresponding technical and scoping specifications for those elements in either the 1991 Standards or in the Uniform Federal Accessibility Standards (UFAS), are not required to be modified in order to comply with the requirements set forth in the 2010 Standards.** This provision is referred to as the "safe harbor." It applies on an element-by-element basis and remains in effect until a public entity decides to alter a facility for reasons other than the ADA. . The safe harbor does not apply to those elements in existing facilities that are subject to supplemental requirements.

The County is not required to take any action that would threaten or destroy the historical significance of a historic property or require the County to take any action that would result in a fundamental alteration in the nature of service, program, or activity or would cause an undue financial and administrative burden. In meeting the requirements of Title II in historic preservation programs, the County will give priority to methods that provide physical access to individuals with disabilities. The decision that compliance would result in such alteration or burdens will be made in compliance with the established County policy on "Fundamental Alteration/Undue Burden."

Transition Plan:
Adams County has a Transition Plan that identifies the required structural changes in order to be compliant with Title II of the Americans with Disabilities Act. Requests for a copy of the transition plan are available to the public by contacting the Adams County ADA Coordinator.

15. NEW CONSTRUCTION AND ALTERATIONS POLICY

POLICY:
All new construction or qualifying facility alterations for the use by Adams County will be designed and constructed in such a manner that the facility, or part of the facility, is readily accessible to and usable by individuals with disabilities. The design, construction, or other determinations such as the sites and locations of facilities will not have the effect of excluding individuals with disabilities from programs, denying them the benefits of the programs, or otherwise subjecting them to discrimination.

ADA Requirements:
All public facilities designed, constructed, or altered must be readily accessible and usable by individuals with disabilities, if the construction or alteration began after January 26, 1992. Title II regulations and the ADA Standards for Accessible Design, originally published in 1991, set the minimum standard for what makes a facility accessible. For new construction or alterations on or after March 15, 2012, public entities must comply with the 2010 Standards for public accessibility.

When part of a building has been altered on or after March 15, 2012, the alterations must be made in strict compliance with architectural standards, including creating an accessible path of travel to the altered area. New and altered facilities must be built in compliance with the 2010 Standards regardless of what, if any, programs are located in them. Even if new or altered facilities are not open to the public, they must be accessible to people with disabilities. In the case of a building built before 1992 that has altered elements, the County can provide program access for the programs housed in the non-altered portion of the building by making them available in the parts of the building that have been altered.

16. CORRECTIONAL FACILITY POLICY

POLICY:
Please refer to the Sheriff's Office Correctional Facility policy.

17. Alterations or Modifications of Assets within Public Right-Of-Way Policy

POLICY:
An overall plan to transition the non-compliant existing County assets within public right-of-way shall be developed, implemented, monitored and amended by Adams County as needed to successfully implement ADA. Adams County may designate a Department Director and/or their assigns to manage the technical aspects related to the self-evaluation activities of the assets within the public right-of-way, and ADA Transition Plan updates as it pertains to the existing assets within public right-of-way.

Adams County, when altering or modifying County assets within public right-of-way, shall bring non-compliant assets within the specific project limits into compliance or file an exception for the specific asset with the ADA Coordinator.

ADA Requirements:
In accordance with Title II of the ADA, Adams County must assess County assets within the right-of-way for their compliancy to ADA and to prepare a plan to transition the non compliant existing assets within public right-of-way to full compliancy.

The County is not required to make specific physical changes in the public right-of-way where other methods are effective in achieving compliance under Title II. In making alterations to existing County assets within public right-of-way, the County shall meet the accessibility requirements of Title II. In choosing among available methods for meeting the requirements of this section, the County will implement and phase the transition of existing county assets within the public right-of-way based on current work priorities, project types, funding, process, and training.

In many circumstances, existing County assets within public right-of-way fall under the existing facilities policy.

The County is not required to correct non-compliant areas within and/or immediately adjacent to work being done when the cost of the corrections will cause a disproportionality in overall project costs.

Adams County Master ADA Transition Plan

	Expected Completion Date	Actual Completion Date	Task Description
	5/2/2015	5/2/2015	Perform self-evaluation audit (Meeting the Challenge)
	12/31/2015	8/14/2015	Complete ADA Compliant Emergency Management Operations & Recovery Plan
	11/25/2015	11/12/2015	Develop Disability Rights Notice, Complaint Procedure & Form, Non-discrimination Policy, Anti-Retaliation Policy, Reasonable Modifications Request Form, Auxiliary Aids & Services Request Form
	11/25/2015	11/12/2015	Create ADA page on County website (ADA Coordinator contact info, Disability Rights Public Notice, Complaint Procedure & Form, Non-discrimination Policy, Anti-retaliation Policy, and forms on website (Complaint, Auxiliary Aids & Services, and Reasonable Modifications Request)
	11/25/2015	11/13/2015	Provide TTY phone instructions for reception desk
	12/9/2015	12/9/2015	Public Meeting for citizen comment & input on Transportation ADA transition plan
	12/31/2015	12/4/2015	Closed captioning for public hearings & all county videos completed
	12/31/2015	12/30/2015	Draft ADA policies and procedures: 1. Disability Rights Public Notice 2. Complaint Procedure 3. Nondiscrimination Policy 4. Anti-retaliation Policy 5. Direct Threat Policy/Procedure 6. Effective Communication Policy 7. Telecommunications Policy 8. Service Animals Policy 9. Mobility Devices Policy 10. Informational Signage Policy 11. Fundamental Alteration/Undue Burden Policy 12. Illegal Use of Drugs Policy 13. Maintain Accessible Features Policy 14. Existing Facilities Policy 15. New Construction & Alterations Policy 16. Correctional Facility Policy
	12/31/2015	1/4/2016	Facilities Department draft transition plan based on self-evaluation audit results
	12/31/2015	12/3/2015	Post instructions on public hearing room lift
	12/31/2015	11/9/2015	Transportation Department complete transition plan based on audit results (Plan prepared by Alfred Benesch & Company in partnership with the Adams County Transportation Department)
	3/31/2016	3/25/2016	Parks Department complete transition plan based on self-evaluation audit results
	7/31/2016	11/9/2016	Trasportation Department draft policy regarding new construction and rights of way
	10/31/2016	10/31/2016	Develop ADA compliant website (PIO/Communications)
	9/30/2016	11/7/2016	Revise and finalize ADA policies and procedures
	11/22/2016		ADA Policies and Procedures approved & adopted by BOCC
	11/22/2016		Adams County Master transition plan approved & adopted by BOCC
	11/22/2016		Transportation Department transition plan approved & adopted by BOCC
	11/22/2016		Facilities Department transition plan (including Parks) approved & adopted by BOCC
	2/28/2017		Develop training for County staff: Policies & procedures, and disability sensitivity/awareness training
	TBD		Train frontline staff on policies & procedures

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00003	Adams County Detention Center	Existing Jail	Interior	Owned	Assembly Area		3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F00011	Adams County Detention Center	F Module	2nd Floor	Owned	Assembly Area	Training - F Adm	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F00279	Adams County Detention Center	Existing Jail	Interior	Owned	Break Room	Medical Employee Area	3-Employee Common	Counter		Approach type	S	N/A					n/a	$ -	
F02959	Adams County Detention Center	Existing Jail	Interior	Owned	Detention Facility	Inmates	3-Employee Common	Cell Specifications		Number, classification levels	3	N/A					n/a	$ -	
F02960	Adams County Detention Center	Existing Jail	Interior	Owned	Detention Facility	Inmates	3-Employee Common	Cell Specifications		Number, communication access by type	No info available	N/A					n/a	$ -	
F02961	Adams County Detention Center	Existing Jail	Interior	Owned	Detention Facility	Inmates	3-Employee Common	Cell Specifications		Number, communication access cells	No info available	N/A					n/a	$ -	
F02962	Adams County Detention Center	Existing Jail	Interior	Owned	Detention Facility	Inmates	3-Employee Common	Cell Specifications		Number, total cells	480	N/A					n/a	$ -	
F02964	Adams County Detention Center	F Module	Interior	Owned	Detention Facility		3-Employee Common	Cell Specifications	Housing Dorm F 2nd For	Number, total cells	No info available	N/A					n/a	$ -	
F02965	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Elevator Door		Location	Center	N/A					n/a	$ -	
F03638	Adams County Detention Center	Existing Jail	Interior	Owned	Hallway	From lobby to video phone bank	1-Public Unsupervised	Handrail		Cross section type	Round	N/A					n/a	$ -	
F03651	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Handrail	Ramp	Cross section type	Round	N/A					n/a	$ -	
F04221	Adams County Detention Center	F Module	Interior	Owned	Housing Cell		3-Employee Common	Bed		Number, beds	64	N/A					n/a	$ -	
F04285	Adams County Detention Center	Existing Jail	Interior	Owned	Lobby Reception	From parking lot to Main entrance	2-Public Supervised	Counter		Approach type	S	N/A					n/a	$ -	
F04286	Adams County Detention Center	Existing Jail	Interior	Owned	Lobby Reception	From parking lot to Main entrance	2-Public Supervised	Alarm System		Dimension from ceiling	14	N/A					n/a	$ -	
F04589	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Men's	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F04591	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F04592	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F04593	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F04594	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F04595	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F04596	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F04597	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Alarm System		Dimension from ceiling	19	N/A					n/a	$ -	
F04598	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Protrusion	Fire extinguisher	Height	28	N/A					n/a	$ -	
F04599	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Shower Compartment		Height, shower control	None	N/A					n/a	$ -	
F04600	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F04601	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F04602	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Latch?	N	N/A					n/a	$ -	
F04603	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F04604	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Signage		Other attribute	Changing type now	N/A					n/a	$ -	
F04605	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Shower Compartment		Seat location	None Provided	N/A					n/a	$ -	
F04606	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Shower Compartment		Shower type	Transfer	N/A					n/a	$ -	
F04638	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Shower Compartment		Threshold beveled?	Y	N/A					n/a	$ -	
F04869	Adams County Detention Center	Existing Jail	Interior	Owned	Other Room	Library	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F04870	Adams County Detention Center	Existing Jail	Interior	Owned	Other Room	Library	3-Employee Common	Door Gate		Height, peep-hole	Window	N/A					n/a	$ -	
F04871	Adams County Detention Center	Existing Jail	Interior	Owned	Other Room	Library	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05190	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Facility Specifications		Number, total spaces	307	N/A					n/a	$ -	
F05242	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Adjacent pathway?	N	N/A					n/a	$ -	
F05243	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Adjacent pathway?	N	N/A					n/a	$ -	
F05244	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #6 & #7	Adjacent pathway?	N	N/A					n/a	$ -	
F05245	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #8 & #9	Adjacent pathway?	N	N/A					n/a	$ -	
F05246	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, total spaces	152	N/A					n/a	$ -	
F05247	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Type	STD	N/A					n/a	$ -	
F05248	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Type	STD	N/A					n/a	$ -	
F05249	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Type	STD	N/A					n/a	$ -	
F05250	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Type	STD	N/A					n/a	$ -	
F05251	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#6	Type	STD	N/A					n/a	$ -	
F05252	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#8	Type	STD	N/A					n/a	$ -	
F05253	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#9	Type	STD	N/A					n/a	$ -	
F05254	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Type	STD	N/A					n/a	$ -	
F05345	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Facility Specifications		Number, total spaces	281	N/A					n/a	$ -	
F05346	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#1	Type	STD	N/A					n/a	$ -	
F05347	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#2	Type	STD	N/A					n/a	$ -	
F05348	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#3	Type	STD	N/A					n/a	$ -	
F05349	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#5	Type	STD	N/A					n/a	$ -	
F05350	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#6	Type	STD	N/A					n/a	$ -	
F07449	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F07450	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F07451	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F07452	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F07453	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Alarm System		Dimension from ceiling	14	N/A					n/a	$ -	
F07454	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F07455	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Changing Station		Height	49	N/A					n/a	$ -	
F07456	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F07457	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F07458	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	N/A					n/a	$ -	
F07459	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Fixture Count		Number, toilet compartments	2	N/A					n/a	$ -	
F07460	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Fixture Count		Number, urinals	2	N/A					n/a	$ -	
F07461	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F07462	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F07463	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F07464	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07473	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	2-Public Supervised	Signage		ISA?	N	N/A					n/a	$ -	
F07527	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Medical Wing	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F07548	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F07549	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F07550	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Coat Hook		Over obstruction?	N	N/A					n/a	$ -	
F07551	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F07574	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - East hallway	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F07589	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - Staff library	3-Employee Common	Mirror		Over lavatory?	N	N/A					n/a	$ -	
F07590	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - Staff library	3-Employee Common	Coat Hook		Over obstruction?	N	N/A					n/a	$ -	
F07611	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F07612	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F07613	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F07614	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F07615	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Alarm System		Dimension from ceiling	13.5	N/A					n/a	$ -	
F07616	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Toilet Compartment		Door location	F	N/A					n/a	$ -	
F07617	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Changing Station		Height	47	N/A					n/a	$ -	
F07618	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F07619	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F07620	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F07621	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F07622	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F07623	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F07624	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F07625	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F07632	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Signage		ISA?	N	N/A					n/a	$ -	
F07687	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F07688	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F07715	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F07716	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Door Gate		Latch?	N	N/A					n/a	$ -	
F07717	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Signage		Other attribute	N/A	N/A					n/a	$ -	
F07718	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F07719	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Dispenser	Feminine products	Over obstruction?	N	N/A					n/a	$ -	
F07741	Adams County Detention Center	F Module	Interior	Owned	Restroom	Men's - F Adm locker room	3-Employee Common	Toilet Compartment		Door location	F	N/A					n/a	$ -	
F07761	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - #F1100 Housing Dorm	3-Employee Common	Shower Compartment	Stainless steel unit	Seat location	Rear	N/A					n/a	$ -	
F07762	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - #F1100 Housing Dorm	3-Employee Common	Shower Compartment	Stainless steel unit	Seat?	Y	N/A					n/a	$ -	
F07763	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - #F1100 Housing Dorm	3-Employee Common	Shower Compartment	Stainless steel unit	Shower type	Roll-in	N/A					n/a	$ -	
F07779	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07780	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F07817	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Alarm System		Dimension from ceiling	26	N/A					n/a	$ -	
F07818	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Toilet Compartment		Door location	F	N/A					n/a	$ -	
F07819	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Fixture Count		Number, toilet compartments	3	N/A					n/a	$ -	
F07820	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Fixture Count		Number, urinals	0	N/A					n/a	$ -	
F07821	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F07822	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F07823	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F07824	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Dispenser	Soap	Over obstruction?	N	N/A					n/a	$ -	
F07825	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Grab Bar	Continuous	Vertical grab bar?	N	N/A					n/a	$ -	
F07826	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F07827	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F07828	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F07829	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F15700	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway	From parking lot	1-Public Unsupervised	Curb Ramp		Are detectable warnings present?	N	N/A					n/a	$ -	
F00016	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F00017	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Height, peep-hole	W	N/A					n/a	$ -	
F00026	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F00036	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F00037	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F00038	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F00039	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Height, threshold	None	N/A					n/a	$ -	
F00045	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Threshold beveled?	N	N/A					n/a	$ -	
F00050	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #1	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F00051	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #1	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F00052	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #1	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F00069	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #2 & #3	1-Public Unsupervised	Other Element		Other attribute	Same as Rendezvous #1	N/A					n/a	$ -	
F00081	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #1	1-Public Unsupervised	Door Gate		Threshold beveled?	N	N/A					n/a	$ -	
F00082	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #2	1-Public Unsupervised	Door Gate		Threshold beveled?	N	N/A					n/a	$ -	
F00083	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #3	1-Public Unsupervised	Door Gate		Threshold beveled?	N	N/A					n/a	$ -	
F00288	Adams County Fair Grounds		Interior	Owned	Break Room	Rendezvous #1	1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F00289	Adams County Fair Grounds		Interior	Owned	Break Room	Rendezvous #1	1-Public Unsupervised	Counter		Dimension, knee clearance	0	N/A					n/a	$ -	
F00290	Adams County Fair Grounds		Interior	Owned	Break Room	Rendezvous #1	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F00291	Adams County Fair Grounds		Interior	Owned	Break Room	Rendezvous #1	1-Public Unsupervised	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F00908	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Concessions		1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F00909	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Concessions		1-Public Unsupervised	Counter		Dimension, knee clearance	0	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00921	Adams County Fair Grounds		Exterior	Owned	Concessions	Exterior of indoor arena	1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F00927	Adams County Fair Grounds		Exterior	Owned	Concessions		1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F00928	Adams County Fair Grounds		Exterior	Owned	Concessions		1-Public Unsupervised	Counter		Dimension, knee clearance	0	N/A					n/a	$ -	
F03513	Adams County Fair Grounds		Exterior	Owned	Fishing Pier	#1	1-Public Unsupervised	Clear Space		Clearance, perpendicular	99	N/A					n/a	$ -	
F03521	Adams County Fair Grounds		Exterior	Owned	Fishing Pier	#2 - Under construction	1-Public Unsupervised	Other Element		Other attribute	Under construction	N/A					n/a	$ -	
F04239	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Kitchen		1-Public Unsupervised	Kitchen Clearance		Appliance at base of U	Y	N/A					n/a	$ -	
F04240	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Kitchen		1-Public Unsupervised	Counter		Dimension, knee clearance	0	N/A					n/a	$ -	
F04241	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Kitchen		1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	0	N/A					n/a	$ -	
F04242	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Kitchen		1-Public Unsupervised	Lavatory Sink		Other attribute	Pipes in cabinet	N/A					n/a	$ -	
F05413	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, total spaces	50	N/A					n/a	$ -	
F05414	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Type	STD	N/A					n/a	$ -	
F05415	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Type	STD	N/A					n/a	$ -	
F05435	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Type	STD	N/A					n/a	$ -	
F05444	Adams County Fair Grounds	Waymire Dome	Exterior	Owned	Parking Facility	North parking lot - includes S.E. of grandstand	1-Public Unsupervised	Facility Specifications	Lot has no markings - being repainted	Number, total spaces	799	N/A					n/a	$ -	
F05445	Adams County Fair Grounds	Waymire Dome	Exterior	Owned	Parking Facility	North parking lot - includes S.E. of grandstand	1-Public Unsupervised	Facility Specifications	Lot has no markings - being repainted	Other attribute	Trevor will supply	N/A					n/a	$ -	
F05446	Adams County Fair Grounds		Exterior	Owned	Parking Facility	At play area	1-Public Unsupervised	Facility Specifications		Number, total spaces	50	N/A					n/a	$ -	
F05447	Adams County Fair Grounds		Exterior	Owned	Parking Facility	At play area	1-Public Unsupervised	Parking Space	#1	Type	STD	N/A					n/a	$ -	
F05448	Adams County Fair Grounds		Exterior	Owned	Parking Facility	At play area	1-Public Unsupervised	Parking Space	#2	Type	STD	N/A					n/a	$ -	
F05462	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Access Aisle	#1	Adjacent pathway?	N	N/A					n/a	$ -	
F05463	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Facility Specifications		Number, total spaces	Trevor will supply	N/A					n/a	$ -	
F05464	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Parking Space	#1 - Row 1	Type	STD	N/A					n/a	$ -	
F05475	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Parking Space		Other attribute	#2 - #12 typical of #1	N/A					n/a	$ -	
F05490	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Facility Specifications		Number, total spaces	25	N/A					n/a	$ -	
F05491	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Parking Space	#1	Type	STD	N/A					n/a	$ -	
F05492	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Parking Space	#2	Type	STD	N/A					n/a	$ -	
F05520	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle		Adjacent pathway?	N	N/A					n/a	$ -	
F05521	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle		Adjacent pathway?	N	N/A					n/a	$ -	
F05522	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Adjacent pathway?	N	N/A					n/a	$ -	
F05523	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Facility Specifications		Number, total spaces	203	N/A					n/a	$ -	
F05524	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#1	Type	Van	N/A					n/a	$ -	
F05525	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#2	Type	STD	N/A					n/a	$ -	
F05526	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#3	Type	STD	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05527	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#4	Type	STD	N/A					n/a	$ -	
F05528	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#5	Type	STD	N/A					n/a	$ -	
F05529	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space		Type	Van	N/A					n/a	$ -	
F05535	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space		Other attribute	Space #2 thru #4 same as #1	N/A					n/a	$ -	
F07319	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Area Specifications		Number, elevated components	15	N/A					n/a	$ -	
F07320	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Area Specifications		Number, ground types on accessible route	0	N/A					n/a	$ -	
F07321	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Walking Surface		Surface material	Rubberized wood chips	N/A					n/a	$ -	
F07354	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Play Table	Under play components	Height	64	N/A					n/a	$ -	
F07355	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Area Specifications		Number, elevated components	18	N/A					n/a	$ -	
F07356	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Area Specifications		Number, elevated components connected by ramp	0	N/A					n/a	$ -	
F07357	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Area Specifications		Number, elevated types connected by ramp	0	N/A					n/a	$ -	
F07358	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Area Specifications		Number, ground components on accessible route	0	N/A					n/a	$ -	
F07359	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Area Specifications		Number, ground types	2	N/A					n/a	$ -	
F07360	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Area Specifications		Number, ground types on accessible route	0	N/A					n/a	$ -	
F07878	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F07879	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	#1	Door location	F	N/A					n/a	$ -	
F07880	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	#2	Door location	F	N/A					n/a	$ -	
F07881	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet	Ambulatory	Location, flush control	W	N/A					n/a	$ -	
F07882	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F07883	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F07884	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F07885	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side - #1 stall	Vertical grab bar?	N	N/A					n/a	$ -	
F07886	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side - #2 stall	Vertical grab bar?	N	N/A					n/a	$ -	
F07887	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear - #1 stall	Vertical grab bar?	N	N/A					n/a	$ -	
F07888	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear - #2 stall	Vertical grab bar?	N	N/A					n/a	$ -	
F07889	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Ambulatory	Vertical grab bar?	N	N/A					n/a	$ -	
F07890	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	#1	Water closet type	F	N/A					n/a	$ -	
F07891	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	#2	Water closet type	F	N/A					n/a	$ -	
F07892	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	Ambulatory	Water closet type	F	N/A					n/a	$ -	
F07908	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		ISA?	N	N/A					n/a	$ -	
F07994	Adams County Fair Grounds	Exhibit Hall	Exterior	Owned	Restroom	Men's - Back side	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F07995	Adams County Fair Grounds	Exhibit Hall	Exterior	Owned	Restroom	Men's - Back side	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07996	Adams County Fair Grounds	Exhibit Hall	Exterior	Owned	Restroom	Men's - Back side	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F07997	Adams County Fair Grounds	Exhibit Hall	Exterior	Owned	Restroom	Men's - Back side	1-Public Unsupervised	Door Gate		Latch?	N	N/A					n/a	$ -	
F08001	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Door Gate	Partition into shower & urinal	Hardware type	None	N/A					n/a	$ -	
F08003	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F08004	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment	#1	Door location	F	N/A					n/a	$ -	
F08005	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment	#2	Door location	F	N/A					n/a	$ -	
F08006	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet	Ambulatory	Location, flush control	Narrow	N/A					n/a	$ -	
F08007	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F08008	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F08009	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F08010	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Feminine products	Over obstruction?	N	N/A					n/a	$ -	
F08011	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side - #1 stall	Vertical grab bar?	N	N/A					n/a	$ -	
F08012	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear - #1 stall	Vertical grab bar?	N	N/A					n/a	$ -	
F08013	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear - #2 stall	Vertical grab bar?	N	N/A					n/a	$ -	
F08014	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side - #2 stall	Vertical grab bar?	N	N/A					n/a	$ -	
F08015	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Amb - Side #1	Vertical grab bar?	Y	N/A					n/a	$ -	
F08016	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Amb - Side #2	Vertical grab bar?	Y	N/A					n/a	$ -	
F08017	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment	#2	Water closet type	F	N/A					n/a	$ -	
F08035	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		ISA?	N	N/A					n/a	$ -	
F08119	Adams County Fair Grounds	Exhibit Hall	Exterior	Owned	Restroom	Women's - Back side	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F08120	Adams County Fair Grounds	Exhibit Hall	Exterior	Owned	Restroom	Women's - Back side	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F08121	Adams County Fair Grounds	Exhibit Hall	Exterior	Owned	Restroom	Women's - Back side	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F08122	Adams County Fair Grounds	Exhibit Hall	Exterior	Owned	Restroom	Women's - Back side	1-Public Unsupervised	Door Gate		Latch?	N	N/A					n/a	$ -	
F08131	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Approach type, pull	F	N/A					n/a	$ -	
F08132	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Approach type, push	F	N/A					n/a	$ -	
F08133	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Closer?	Y	N/A					n/a	$ -	
F08134	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Door location	F	N/A					n/a	$ -	
F08135	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Latch?	N	N/A					n/a	$ -	
F08136	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Mirror		Over lavatory?	N	N/A					n/a	$ -	
F08137	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F08138	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	N	N/A					n/a	$ -	
F08139	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F08140	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F08141	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Water closet type	F	N/A					n/a	$ -	
F08202	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F08203	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F08204	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08205	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Door location	F	N/A					n/a	$ -	
F08206	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Latch?	N	N/A					n/a	$ -	
F08207	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Mirror		Over lavatory?	N	N/A					n/a	$ -	
F08208	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Coat Hook		Over obstruction?	N	N/A					n/a	$ -	
F08209	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F08210	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F08211	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F08212	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F08213	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F08214	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Water closet type	F	N/A					n/a	$ -	
F08271	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F08272	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Approach type, pull	L	N/A					n/a	$ -	
F08273	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Interior access	Approach type, pull	F	N/A					n/a	$ -	
F08274	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Approach type, push	F	N/A					n/a	$ -	
F08275	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Interior access	Approach type, push	F	N/A					n/a	$ -	
F08276	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Closer?	Y	N/A					n/a	$ -	
F08277	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Interior access	Closer?	Y	N/A					n/a	$ -	
F08278	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Door location	F	N/A					n/a	$ -	
F08279	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Is a peep-hole provided?	N	N/A					n/a	$ -	
F08280	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Latch?	Y	N/A					n/a	$ -	
F08281	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Interior access	Latch?	N	N/A					n/a	$ -	
F08282	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F08283	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F08284	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F08285	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F08286	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Water closet type	F	N/A					n/a	$ -	
F08303	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		ISA?	N	N/A					n/a	$ -	
F08364	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F08365	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Interior access	Approach type, pull	L	N/A					n/a	$ -	
F08366	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Exterior access	Approach type, pull	L	N/A					n/a	$ -	
F08367	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Interior access	Approach type, push	F	N/A					n/a	$ -	
F08368	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Exterior access	Approach type, push	F	N/A					n/a	$ -	
F08369	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Interior access	Closer?	Y	N/A					n/a	$ -	
F08370	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Exterior access	Closer?	Y	N/A					n/a	$ -	
F08371	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Door location	F	N/A					n/a	$ -	
F08372	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Soap	Height	46	N/A					n/a	$ -	
F08373	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Interior access	Is a peep-hole provided?	N	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08374	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Exterior access	Is a peep-hole provided?	N	N/A					n/a	$ -	
F08375	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Interior access	Latch?	N	N/A					n/a	$ -	
F08376	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Exterior access	Latch?	Y	N/A					n/a	$ -	
F08377	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F08378	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F08379	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F08380	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F08381	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F08382	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Water closet type	F	N/A					n/a	$ -	
F08399	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage	Interior access	ISA?	N	N/A					n/a	$ -	
F08457	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	Y	N/A					n/a	$ -	
F08470	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F08471	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F08480	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		ISA?	N	N/A					n/a	$ -	
F08505	Adams County Fair Grounds	Mann-Nyholt Lake Parking	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Other attribute	No plumbing	N/A					n/a	$ -	
F08506	Adams County Fair Grounds	Mann-Nyholt Lake Parking	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F08509	Adams County Fair Grounds	Mann-Nyholt Lake Parking	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Other attribute	All same as Site B	N/A					n/a	$ -	
F08519	Adams County Fair Grounds	Mann-Nyholt Lake Parking	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Other attribute	OK	N/A					n/a	$ -	
F08520	Adams County Fair Grounds	Mann-Nyholt Lake Parking	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Other attribute	OK	N/A					n/a	$ -	
F08522	Adams County Fair Grounds	Mann-Nyholt Lake Parking	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Other attribute	Same as site B	N/A					n/a	$ -	
F08526	Adams County Fair Grounds	Mann-Nyholt Lake Parking	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Threshold beveled?	N	N/A					n/a	$ -	
F08527	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F08528	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	0	N/A					n/a	$ -	
F08529	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Latch?	N	N/A					n/a	$ -	
F08530	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Other attribute	Pipes in cabinet	N/A					n/a	$ -	
F08531	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F08532	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F08533	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F08561	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Height, flush control	None	N/A					n/a	$ -	
F08562	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Location, flush control	None	N/A					n/a	$ -	
F08563	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Other attribute	No plumbing	N/A					n/a	$ -	
F08564	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar		Vertical grab bar?	N	N/A					n/a	$ -	
F08565	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F08579	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F08580	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F08581	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F08582	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08583	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Alarm System		Dimension from ceiling	10	N/A					n/a	$ -	
F08584	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Latch?	N	N/A					n/a	$ -	
F08585	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F08586	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F08587	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F08588	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F08589	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F08590	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F08591	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F08656	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F08657	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Approach type, pull	L	N/A					n/a	$ -	
F08658	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F08659	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F08660	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Alarm System		Dimension from ceiling	18	N/A					n/a	$ -	
F08661	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Door location	F	N/A					n/a	$ -	
F08662	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Changing Station		Height	49	N/A					n/a	$ -	
F08663	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Protrusion	Feminine product dispenser	Height	33	N/A					n/a	$ -	
F08664	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F08665	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Other attribute	Door stop present	N/A					n/a	$ -	
F08666	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F08667	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F08668	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F08669	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F08670	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F08671	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F08672	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F08743	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F08744	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Door Gate		Approach type, push	H	N/A					n/a	$ -	
F08745	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F08746	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Shower Compartment		Dimension, entry to back wall	92	N/A					n/a	$ -	
F08747	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	0	N/A					n/a	$ -	
F08748	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Lavatory Sink		Other attribute	Drain in cabinet	N/A					n/a	$ -	
F08749	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F08750	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Dispenser	TP	Over obstruction?	Y	N/A					n/a	$ -	
F08751	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F08752	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F08753	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Toilet Compartment		Water closet type	F	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08784	Adams County Fair Grounds		Exterior	Owned	Restroom	Men's - Picnic Site B	1-Public Unsupervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F08787	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F08788	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Approach type, push	L	N/A					n/a	$ -	
F08789	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	0	N/A					n/a	$ -	
F08790	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Door location	F	N/A					n/a	$ -	
F08791	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Latch?	N	N/A					n/a	$ -	
F08792	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Other attribute	Pipes in cabinet	N/A					n/a	$ -	
F08793	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F08794	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F08795	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F08796	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F08811	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Other attribute	On door	N/A					n/a	$ -	
F08833	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F08834	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F08835	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	0	N/A					n/a	$ -	
F08836	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Changing Station		Height	55.5	N/A					n/a	$ -	
F08837	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Door Gate		Latch?	N	N/A					n/a	$ -	
F08838	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Shower Compartment		Length, hose	None	N/A					n/a	$ -	
F08839	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Door Gate		Other attribute	OK	N/A					n/a	$ -	
F08840	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Lavatory Sink		Other attribute	Pipes in cabinet	N/A					n/a	$ -	
F08841	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F08842	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F08872	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's - Picnic Site B	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F08873	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's - Picnic Site B	1-Public Unsupervised	Water Closet		Location, flush control	No plumbing	N/A					n/a	$ -	
F08874	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's - Picnic Site B	1-Public Unsupervised	Signage		Other attribute	OK	N/A					n/a	$ -	
F08875	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's - Picnic Site B	1-Public Unsupervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F08876	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's - Picnic Site B	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F08877	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's - Picnic Site B	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F15608	Adams County Fair Grounds		Exterior	Owned	Sport Area	Open rodeo grandstand	1-Public Unsupervised	Seating Area	Grandstands	Amplified sound?	Y	N/A					n/a	$ -	
F15609	Adams County Fair Grounds		Exterior	Owned	Sport Area	Open rodeo grandstand	1-Public Unsupervised	Wheelchair Space	Typical for all 20	Approach type	F	N/A					n/a	$ -	
F15610	Adams County Fair Grounds		Exterior	Owned	Sport Area	Open rodeo grandstand	1-Public Unsupervised	Aisle Seat		Folding/removable armrest?	N/A	N/A					n/a	$ -	
F15611	Adams County Fair Grounds		Exterior	Owned	Sport Area	Open rodeo grandstand	1-Public Unsupervised	Aisle Seat		ISA?	N	N/A					n/a	$ -	
F15612	Adams County Fair Grounds		Exterior	Owned	Sport Area	Open rodeo grandstand	1-Public Unsupervised	Seating Area	Grandstands	Number, aisle seats	20	N/A					n/a	$ -	
F15613	Adams County Fair Grounds		Exterior	Owned	Sport Area	Open rodeo grandstand	1-Public Unsupervised	Seating Area	Grandstands	Number, marked aisle seats	0	N/A					n/a	$ -	
F15614	Adams County Fair Grounds		Exterior	Owned	Sport Area	Open rodeo grandstand	1-Public Unsupervised	Seating Area	Grandstands	Number, seats	2000	N/A					n/a	$ -	
F15800	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Ramp	Section #2	Length	124	N/A					n/a	$ -	
F03537	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		2-Public Supervised	Golf Specifications		Number, holes	18	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F03538	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#1	Number, teeing grounds	3	N/A					n/a	$ -	
F03579	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Golf Specifications		Number, holes	18	N/A					n/a	$ -	
F03580	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Golf Specifications		Number, practice greens	4	N/A					n/a	$ -	
F03581	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#1	Number, teeing grounds	3	N/A					n/a	$ -	
F03582	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#2	Number, teeing grounds	3	N/A					n/a	$ -	
F03583	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#3	Number, teeing grounds	3	N/A					n/a	$ -	
F03584	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Golf Specifications		Number, teeing stations	1	N/A					n/a	$ -	
F03698	Adams County Golf Course		Interior	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Between men's & women's restrooms	High-low fountain?	Y	N/A					n/a	$ -	
F04879	Adams County Golf Course		Interior	Owned	Other Room	Pro shop	1-Public Unsupervised	Counter		Approach type	S	N/A					n/a	$ -	
F04880	Adams County Golf Course		Interior	Owned	Other Room	Pro shop	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F04881	Adams County Golf Course		Interior	Owned	Other Room	Pro shop	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F04882	Adams County Golf Course		Interior	Owned	Other Room	Pro shop	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F04883	Adams County Golf Course		Interior	Owned	Other Room	Pro shop	1-Public Unsupervised	Alarm System		Dimension from ceiling	17	N/A					n/a	$ -	
F04893	Adams County Golf Course		Interior	Owned	Other Room	Pub/dining room	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F04894	Adams County Golf Course		Interior	Owned	Other Room	Pub/dining room	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F04895	Adams County Golf Course		Interior	Owned	Other Room	Pub/dining room	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F04898	Adams County Golf Course		Interior	Owned	Other Room	Public use computer room	1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F04899	Adams County Golf Course		Interior	Owned	Other Room	Public use computer room	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F04900	Adams County Golf Course		Interior	Owned	Other Room	Public use computer room	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F04901	Adams County Golf Course		Interior	Owned	Other Room	Public use computer room	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F04902	Adams County Golf Course		Interior	Owned	Other Room	Public use computer room	1-Public Unsupervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F04903	Adams County Golf Course		Interior	Owned	Other Room	Public use computer room	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F05600	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, total spaces	297	N/A					n/a	$ -	
F05601	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Other attribute	OK	N/A					n/a	$ -	
F05602	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Type	STD	N/A					n/a	$ -	
F05603	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Type	STD	N/A					n/a	$ -	
F05604	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Type	STD	N/A					n/a	$ -	
F05605	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Type	STD	N/A					n/a	$ -	
F05606	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#6	Type	STD	N/A					n/a	$ -	
F05607	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#7	Type	STD	N/A					n/a	$ -	
F05608	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Type	STD	N/A					n/a	$ -	
F05617	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Other attribute	No van signs	N/A					n/a	$ -	
F08896	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Door Gate		Approach type, pull	H	N/A					n/a	$ -	
F08897	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F08898	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F08899	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08900	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Water Closet		Location, flush control	None	N/A					n/a	$ -	
F08901	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F08902	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F08931	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F08932	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F08933	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F08934	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F08935	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F08936	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F08947	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Signage		ISA?	N	N/A					n/a	$ -	
F08974	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Threshold beveled?	Y	N/A					n/a	$ -	
F08975	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F08976	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F08977	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F08978	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F08979	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F08980	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F08981	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F08982	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F09015	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex - Near #10 teeing grounds	1-Public Unsupervised	Water Closet		Location, flush control	None	N/A					n/a	$ -	
F09034	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F09035	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F09036	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F09037	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F09038	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F09039	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F09040	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F09041	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F09081	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F09082	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F09083	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F09084	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F09085	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F09086	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F09087	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F09088	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F09089	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09125	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F09126	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F09127	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Door Gate		Approach type, pull	L	N/A					n/a	$ -	
F09128	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F09129	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F09130	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Alarm System		Dimension from ceiling	26	N/A					n/a	$ -	
F09131	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Toilet Compartment		Door location	F	N/A					n/a	$ -	
F09132	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Door Gate		Latch?	N	N/A					n/a	$ -	
F09133	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F09134	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F09135	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F09136	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Shower Compartment		Seat?	Y	N/A					n/a	$ -	
F09137	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Shower Compartment		Shower type	Roll-in	N/A					n/a	$ -	
F09138	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F09139	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Grab Bar	Front wall	Vertical grab bar?	N	N/A					n/a	$ -	
F09140	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F09141	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Toilet Compartment		Water closet type	F	N/A					n/a	$ -	
F09221	Adams County Golf Course		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F09222	Adams County Golf Course		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F09223	Adams County Golf Course		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F09224	Adams County Golf Course		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F09232	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Door Gate		Approach type, pull	L	N/A					n/a	$ -	
F09233	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F09234	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F09235	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Alarm System		Dimension from ceiling	25.5	N/A					n/a	$ -	
F09236	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Toilet Compartment		Door location	F	N/A					n/a	$ -	
F09237	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Protrusion	Feminine product dispenser	Height	56	N/A					n/a	$ -	
F09238	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F09239	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F09240	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F09241	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F09242	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Shower Compartment		Seat?	Y	N/A					n/a	$ -	
F09243	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Shower Compartment		Shower type	Roll-in	N/A					n/a	$ -	
F09244	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F09245	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F09246	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Grab Bar	Front wall	Vertical grab bar?	N	N/A					n/a	$ -	
F09247	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09248	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Toilet Compartment		Water closet type	F	N/A					n/a	$ -	
F15522	Adams County Golf Course	Dunes	Exterior	Owned	Shelter	Near #9 teeing grounds	1-Public Unsupervised	Drinking Fountain	Concession side of shelter	Dimension, knee clearance	0	N/A					n/a	$ -	
F15828	Adams County Golf Course		Exterior	Owned	Walkway	From parking lot to Pro Shop	1-Public Unsupervised	Walking Surface	Walkway - canopy support	Clearance, vertical	79	N/A					n/a	$ -	
F15847	Adams County Golf Course		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate	Main Entrance	Approach type, pull	F	N/A					n/a	$ -	
F15848	Adams County Golf Course		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate	Main Entrance	Approach type, push	F	N/A					n/a	$ -	
F15849	Adams County Golf Course		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate	Main Entrance	Closer?	Y	N/A					n/a	$ -	
F15850	Adams County Golf Course		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate	Main Entrance	Is a peep-hole provided?	Window	N/A					n/a	$ -	
F15851	Adams County Golf Course		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate	Main Entrance	Latch?	N	N/A					n/a	$ -	
F00326	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Break Room		3-Employee Common	Counter		Approach type	S	N/A					n/a	$ -	
F00342	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Counter		Approach type	S	N/A					n/a	$ -	
F00343	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F00344	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F00345	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F00346	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Counter		Dimension, knee clearance	0	N/A					n/a	$ -	
F02996	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Elevator Door		Location	S	N/A					n/a	$ -	
F03472	Adams County Service Center		Interior	Owned	Exercise Room		3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F03473	Adams County Service Center		Interior	Owned	Exercise Room		3-Employee Common	Door Gate		Approach type, push	H	N/A					n/a	$ -	
F03474	Adams County Service Center		Interior	Owned	Exercise Room		3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F03475	Adams County Service Center		Interior	Owned	Exercise Room		3-Employee Common	Door Gate		Height, peep-hole	48.5	N/A					n/a	$ -	
F03476	Adams County Service Center		Interior	Owned	Exercise Room		3-Employee Common	Door Gate		Is a peep-hole provided?	Y	N/A					n/a	$ -	
F03477	Adams County Service Center		Interior	Owned	Exercise Room		3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F03711	Adams County Service Center	DMV	Interior	Owned	Hallway	Suite A	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F03712	Adams County Service Center	DMV	Interior	Owned	Hallway	Suite A	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F03713	Adams County Service Center	DMV	Interior	Owned	Hallway	Suite A	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F03719	Adams County Service Center		2nd Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	In emergency area	High-low fountain?	Y	N/A					n/a	$ -	
F04301	Adams County Service Center		Interior	Owned	Lobby Reception	Central entrance	3-Employee Common	Counter	Traffic & Comm. Service	Approach type	S	N/A					n/a	$ -	
F04640	Adams County Service Center		2nd Floor	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Seat?	Y	N/A					n/a	$ -	
F04641	Adams County Service Center		2nd Floor	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Shower type	Roll-in	N/A					n/a	$ -	
F04643	Adams County Service Center		2nd Floor	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Dimension, entry to back wall	66	N/A					n/a	$ -	
F04920	Adams County Service Center	Sheriff's Substation	Interior	Owned	Other Room	Equipment lockers	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F04921	Adams County Service Center	Sheriff's Substation	Interior	Owned	Other Room	Equipment lockers	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F04922	Adams County Service Center	Sheriff's Substation	Interior	Owned	Other Room	Equipment lockers	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F04923	Adams County Service Center	Sheriff's Substation	Interior	Owned	Other Room	Equipment lockers	3-Employee Common	Door Gate		Height, peep-hole	48.5	N/A					n/a	$ -	
F04924	Adams County Service Center	Sheriff's Substation	Interior	Owned	Other Room	Equipment lockers	3-Employee Common	Door Gate		Is a peep-hole provided?	Y	N/A					n/a	$ -	
F05726	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#1	Other attribute	Faded	N/A					n/a	$ -	
F09419	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Approach type, pull	L	N/A					n/a	$ -	
F09420	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09421	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F09422	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F09423	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F09424	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F09452	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Door location	F	N/A					n/a	$ -	
F09453	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	3-Employee Common	Protrusion	Metal shelf	Height	46	N/A					n/a	$ -	
F09454	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F09455	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F09456	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F09480	Adams County Service Center	Sheriff's Substation	Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F09481	Adams County Service Center	Sheriff's Substation	Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F09482	Adams County Service Center	Sheriff's Substation	Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F09503	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F09504	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F09505	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F09506	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F09507	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F09508	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F09533	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Door Gate		Approach type, pull	L	N/A					n/a	$ -	
F09534	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F09535	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F09536	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F09537	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Protrusion	Wall mounted shelf	Height	46	N/A					n/a	$ -	
F09538	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F09539	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F09540	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09541	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F09587	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F09588	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Door Gate		Approach type, push	H	N/A					n/a	$ -	
F09589	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F09590	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Toilet Compartment		Door location	F	N/A					n/a	$ -	
F09591	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F09592	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F09634	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F09635	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F09636	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F09637	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F09638	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F09639	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F09640	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F09675	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Door Gate		Approach type, pull	L	N/A					n/a	$ -	
F09676	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F09677	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F09678	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Door Gate	WIC	Closer?	N	N/A					n/a	$ -	
F09679	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F09680	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F09681	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F09682	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F09683	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F09684	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F09685	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F09686	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F09687	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F09770	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Client	2-Public Supervised	Door Gate		Approach type, pull	L	N/A					n/a	$ -	
F09771	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Client	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F09772	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Client	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F09773	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Client	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F09795	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Door Gate		Closing speed	None	N/A					n/a	$ -	
F09796	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F09845	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F09846	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F09847	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09848	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Alarm System		Dimension from ceiling	22	N/A					n/a	$ -	
F09849	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Protrusion	PT	Height	47	N/A					n/a	$ -	
F09850	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F09851	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F09852	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F09853	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F09854	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F09855	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F09894	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F09895	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F09896	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F09897	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Alarm System		Dimension from ceiling	23	N/A					n/a	$ -	
F09898	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Protrusion	PT	Height	51	N/A					n/a	$ -	
F09899	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F09900	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F09901	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F09947	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F09948	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Door Gate		Approach type, push	H	N/A					n/a	$ -	
F09980	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F09981	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Door Gate		Approach type, push	H	N/A					n/a	$ -	
F09982	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Alarm System		Dimension from ceiling	22	N/A					n/a	$ -	
F10018	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Toilet Compartment		Door location	F	N/A					n/a	$ -	
F10019	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F15539	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Shower Room		3-Employee Common	Shower Compartment		Seat?	Y	N/A					n/a	$ -	
F15540	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Shower Room		3-Employee Common	Shower Compartment		Shower type	Transfer	N/A					n/a	$ -	
F15541	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Shower Room		3-Employee Common	Grab Bar	Continuous	Vertical grab bar?	N	N/A					n/a	$ -	
F15555	Adams County Service Center		2nd Floor	Owned	Shower Room	Women's - Locker Room	3-Employee Common	Shower Compartment		Seat?	Y	N/A					n/a	$ -	
F15556	Adams County Service Center		2nd Floor	Owned	Shower Room	Women's - Locker Room	3-Employee Common	Shower Compartment		Shower type	Roll-in	N/A					n/a	$ -	
F15876	Adams County Service Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	Center walkway island	Other attribute	No markings	N/A					n/a	$ -	
F16765	Adams County Service Center	Crime Prevention	Interior	Owned	Work Area		3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F16766	Adams County Service Center	Crime Prevention	Interior	Owned	Work Area		3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F16767	Adams County Service Center	Crime Prevention	Interior	Owned	Work Area		3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F16768	Adams County Service Center	Crime Prevention	Interior	Owned	Work Area		3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F16774	Adams County Service Center	DMV	Interior	Owned	Work Area	Suite A	1-Public Unsupervised	Counter		Approach type	S	N/A					n/a	$ -	
F16779	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Work Area		3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16780	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Work Area		3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F16781	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Work Area		3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F16782	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Work Area		3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F16783	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Work Area		3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F16784	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Work Area		3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F16785	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Work Area		3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F16786	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Work Area		3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F00084	Adams County Workforce Center		Interior	Leased	Assembly Area		1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F00085	Adams County Workforce Center		Interior	Leased	Assembly Area		1-Public Unsupervised	Alarm System		Dimension from ceiling	Ceiling mount	N/A					n/a	$ -	
F03727	Adams County Workforce Center		Interior	Leased	Hallway	Between restrooms	1-Public Unsupervised	Drinking Fountain		High-low fountain?	Y	N/A					n/a	$ -	
F03741	Adams County Workforce Center		Interior	Leased	Hallway		1-Public Unsupervised	Door Gate	Into suite	Approach type, pull	F	N/A					n/a	$ -	
F03742	Adams County Workforce Center		Interior	Leased	Hallway		1-Public Unsupervised	Door Gate	Into suite	Approach type, push	F	N/A					n/a	$ -	
F03743	Adams County Workforce Center		Interior	Leased	Hallway		1-Public Unsupervised	Door Gate	Into suite	Closer?	Y	N/A					n/a	$ -	
F03744	Adams County Workforce Center		Interior	Leased	Hallway		1-Public Unsupervised	Door Gate	Into suite	Is a peep-hole provided?	N	N/A					n/a	$ -	
F03745	Adams County Workforce Center		Interior	Leased	Hallway		1-Public Unsupervised	Door Gate	Into suite	Kick plate?	Y	N/A					n/a	$ -	
F03746	Adams County Workforce Center		Interior	Leased	Hallway		1-Public Unsupervised	Door Gate	Into suite	Latch?	N	N/A					n/a	$ -	
F04305	Adams County Workforce Center		Interior	Leased	Lobby Reception		1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F10053	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F10054	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F10055	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F10056	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Door location	F	N/A					n/a	$ -	
F10057	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Changing Station		Height	52	N/A					n/a	$ -	
F10058	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F10059	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F10060	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F10061	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	Y	N/A					n/a	$ -	
F10062	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Water closet type	F	N/A					n/a	$ -	
F10125	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F10126	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F10127	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Door location	F	N/A					n/a	$ -	
F10128	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Changing Station		Height	52.5	N/A					n/a	$ -	
F10129	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Door Gate		Latch?	N	N/A					n/a	$ -	
F10130	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F10131	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F10132	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F10133	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F10134	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	Y	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10135	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Water closet type	F	N/A					n/a	$ -	
F15898	Adams County Workforce Center		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F15899	Adams County Workforce Center		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F15900	Adams County Workforce Center		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F15901	Adams County Workforce Center		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F15902	Adams County Workforce Center		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate		Latch?	N	N/A					n/a	$ -	
F00096	Animal Shelter		Interior	Owned	Assembly Area		3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F00097	Animal Shelter		Interior	Owned	Assembly Area		3-Employee Common	Door Gate		Height, peep-hole	Window	N/A					n/a	$ -	
F00098	Animal Shelter		Interior	Owned	Assembly Area		3-Employee Common	Alarm System		Other attribute	None Provided	N/A					n/a	$ -	
F00375	Animal Shelter		Interior	Owned	Break Room		3-Employee Common	Door Gate		Approach type, pull	OK	N/A					n/a	$ -	
F00376	Animal Shelter		Interior	Owned	Break Room		3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F00377	Animal Shelter		Interior	Owned	Break Room		3-Employee Common	Door Gate		Height, peep-hole	None	N/A					n/a	$ -	
F04311	Animal Shelter		Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F04650	Animal Shelter		Interior	Owned	Locker Room	Men's	3-Employee Common	Signage		Other attribute	Mounted on door	N/A					n/a	$ -	
F04659	Animal Shelter		Interior	Owned	Locker Room		3-Employee Common	Door Gate		Approach type, pull	99	N/A					n/a	$ -	
F04660	Animal Shelter		Interior	Owned	Locker Room		3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F04661	Animal Shelter		Interior	Owned	Locker Room		3-Employee Common	Shower Compartment		Length, hose	None	N/A					n/a	$ -	
F04662	Animal Shelter		Interior	Owned	Locker Room		3-Employee Common	Shower Compartment		Seat?	Y	N/A					n/a	$ -	
F05806	Animal Shelter		Exterior	Owned	Parking Facility		3-Employee Common	Facility Specifications		Number, total spaces	37	N/A					n/a	$ -	
F05807	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Type	STD	N/A					n/a	$ -	
F05808	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Type	Van	N/A					n/a	$ -	
F10199	Animal Shelter		Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Other attribute	Mounted on door	N/A					n/a	$ -	
F10200	Animal Shelter		Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Other attribute	Single user	N/A					n/a	$ -	
F10201	Animal Shelter		Interior	Owned	Restroom	Men's	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F10221	Animal Shelter		Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F10222	Animal Shelter		Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F10246	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F10247	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Toilet Compartment		Door location	F	N/A					n/a	$ -	
F10248	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Signage		Other attribute	Paper sign indicating employees only	N/A					n/a	$ -	
F10249	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F10250	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F10277	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Threshold beveled?	N	N/A					n/a	$ -	
F10278	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Approach type, push	99	N/A					n/a	$ -	
F10279	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F10280	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Height, threshold	None	N/A					n/a	$ -	
F10281	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Other attribute	Mounted on door	N/A					n/a	$ -	
F10282	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Alarm System		Visible alarm	None Provided	N/A					n/a	$ -	
F10283	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Water closet type	F	N/A					n/a	$ -	
F10326	Animal Shelter		Interior	Owned	Restroom	Women's - Locker Room	3-Employee Common	Door Gate		Approach type, pull	99	N/A					n/a	$ -	
F10327	Animal Shelter		Interior	Owned	Restroom	Women's - Locker Room	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F15565	Animal Shelter		Interior	Owned	Shower Room	Roll-in	3-Employee Common	Grab Bar	Front wall	Dimension, end to wall	6	N/A					n/a	$ -	
F15566	Animal Shelter		Interior	Owned	Shower Room	Roll-in	3-Employee Common	Grab Bar	Side	Dimension, end to wall	6.5	N/A					n/a	$ -	
F15567	Animal Shelter		Interior	Owned	Shower Room	Roll-in	3-Employee Common	Grab Bar	Front wall	Vertical grab bar?	N	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15662	Animal Shelter		Interior	Owned	Visiting Area	Lost dogs	2-Public Supervised	Door Gate		Approach type, push	99	N/A					n/a	$ -	
F15663	Animal Shelter		Interior	Owned	Visiting Area	Lost dogs	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F15664	Animal Shelter		Interior	Owned	Visiting Area	Lost dogs	2-Public Supervised	Door Gate		Is a peep-hole provided?	Window	N/A					n/a	$ -	
F15916	Animal Shelter	Adoption Area	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Approach type, pull	Auto	N/A					n/a	$ -	
F15917	Animal Shelter	Adoption Area	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Closer?	Auto	N/A					n/a	$ -	
F15921	Animal Shelter	Lost and Found	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F15931	Animal Shelter		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp		Other attribute	OK	N/A					n/a	$ -	
F05837	Aurora Motor Vehicle		Exterior	Leased	Parking Facility		3-Employee Common	Facility Specifications		Number, total spaces	OK	N/A					n/a	$ -	
F05839	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	#2	Adjacent pathway?	N	N/A					n/a	$ -	
F05840	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Facility Specifications		Number, total spaces	213	N/A					n/a	$ -	
F05871	Children and Family Center		Exterior	Owned	Parking Facility	Visitors	1-Public Unsupervised	Facility Specifications		Number, total spaces	52	N/A					n/a	$ -	
F10359	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F10360	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F10361	Children and Family Center		4th Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F10362	Children and Family Center		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Approach type, pull	L	N/A					n/a	$ -	
F10363	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F10364	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Water closet type	F	N/A					n/a	$ -	
F10365	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Water closet type	F	N/A					n/a	$ -	
F10406	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Signage		ISA?	N	N/A					n/a	$ -	
F10448	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F10449	Children and Family Center		3rd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F10450	Children and Family Center		4th Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F10451	Children and Family Center		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Approach type, pull	L	N/A					n/a	$ -	
F10452	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Water closet type	F	N/A					n/a	$ -	
F15933	Children and Family Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp		Are detectable warnings present?	N	N/A					n/a	$ -	
F15942	Children and Family Center		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Other attribute	Sliding door	N/A					n/a	$ -	
F07374	City View Park		Exterior	Owned	Play Area		1-Public Unsupervised	Area Specifications		Number, elevated components	5	N/A					n/a	$ -	
F07375	City View Park		Exterior	Owned	Play Area		1-Public Unsupervised	Area Specifications		Number, elevated components connected by ramp	0	N/A					n/a	$ -	
F07376	City View Park		Exterior	Owned	Play Area		1-Public Unsupervised	Area Specifications		Number, elevated types connected by ramp	0	N/A					n/a	$ -	
F07377	City View Park		Exterior	Owned	Play Area		1-Public Unsupervised	Area Specifications		Number, ground components on accessible route	0	N/A					n/a	$ -	
F07378	City View Park		Exterior	Owned	Play Area		1-Public Unsupervised	Area Specifications		Number, ground types	1	N/A					n/a	$ -	
F07379	City View Park		Exterior	Owned	Play Area		1-Public Unsupervised	Area Specifications		Number, ground types on accessible route	0	N/A					n/a	$ -	
F00110	District Attorneys Building		Interior	Owned	Assembly Area	Sean May Training	3-Employee Common	Other Element	Front speaker dials	Height	12	N/A					n/a	$ -	
F04678	District Attorneys Building		Interior	Owned	Locker Room	Men's	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F04679	District Attorneys Building		Interior	Owned	Locker Room	Men's	3-Employee Common	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F04680	District Attorneys Building		Interior	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment	Roll-in	Shower type	Roll-in	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F04689	District Attorneys Building		Interior	Owned	Locker Room	Women's	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F04690	District Attorneys Building		Interior	Owned	Locker Room	Women's	3-Employee Common	Shower Compartment		Seat?	Y	N/A					n/a	$ -	
F04691	District Attorneys Building		Interior	Owned	Locker Room	Women's	3-Employee Common	Shower Compartment		Shower type	Hand held	N/A					n/a	$ -	
F04939	District Attorneys Building		Interior	Owned	Other Room	DA office	1-Public Unsupervised	Signage	Wall directory only sign	Other attribute	No accompanying sign at door	N/A					n/a	$ -	
F05892	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 3 between spaces #3 & #4	Adjacent pathway?	N	N/A					n/a	$ -	
F05893	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 3 between spaces #5 & #6	Adjacent pathway?	N	N/A					n/a	$ -	
F05894	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 3 right of space #7	Adjacent pathway?	N	N/A					n/a	$ -	
F05895	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Facility Specifications		Number, total spaces	195	N/A					n/a	$ -	
F05896	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 1 space #1	Type	STD	N/A					n/a	$ -	
F05897	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 1 space #2	Type	STD	N/A					n/a	$ -	
F05898	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 3 space #1	Type	STD	N/A					n/a	$ -	
F05899	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 3 space #2	Type	STD	N/A					n/a	$ -	
F05900	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 3 space #3	Type	Van	N/A					n/a	$ -	
F05901	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Type	Van	N/A					n/a	$ -	
F05902	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Type	Van	N/A					n/a	$ -	
F05903	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Type	Van	N/A					n/a	$ -	
F05904	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Type	Van	N/A					n/a	$ -	
F10521	District Attorneys Building		Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F10522	District Attorneys Building		Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F10527	District Attorneys Building		Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Signage		ISA?	N	N/A					n/a	$ -	
F10533	District Attorneys Building		Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F10536	District Attorneys Building		Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Signage		ISA?	N	N/A					n/a	$ -	
F15949	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp at roundabout	1-Public Unsupervised	Landing		Edge protection?	N	N/A					n/a	$ -	
F03525	Elaine Valente Open Space		Exterior	Owned	Fishing Pier		1-Public Unsupervised	Railing		Length, total railing	76 feet	N/A					n/a	$ -	
F03526	Elaine Valente Open Space		Exterior	Owned	Fishing Pier		1-Public Unsupervised	Railing		Lowered sections dispersed?	N	N/A					n/a	$ -	
F05997	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, total spaces	38	N/A					n/a	$ -	
F05998	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Type	STD	N/A					n/a	$ -	
F05999	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Type	STD	N/A					n/a	$ -	
F10539	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F10540	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F10541	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F10542	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Water Closet		Control force	None	N/A					n/a	$ -	
F10543	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Water Closet		Height, flush control	None	N/A					n/a	$ -	
F10544	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Height, peep-hole	None	N/A					n/a	$ -	
F10545	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F10546	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Water Closet		Location, flush control	None	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10547	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Coat Hook		Over obstruction?	N	N/A					n/a	$ -	
F10548	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F10549	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F10550	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F10577	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Threshold beveled?	N	N/A					n/a	$ -	
F03776	Facilities Mgmt's Storage Facility		Interior	Owned	Hallway		2-Public Supervised	Door Gate	To restrooms	Approach type, pull	F	N/A					n/a	$ -	
F03777	Facilities Mgmt's Storage Facility		Interior	Owned	Hallway		2-Public Supervised	Door Gate	To restrooms	Approach type, push	F	N/A					n/a	$ -	
F03778	Facilities Mgmt's Storage Facility		Interior	Owned	Hallway		2-Public Supervised	Door Gate	To restrooms	Closer?	Y	N/A					n/a	$ -	
F10585	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F10586	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Shower Compartment		Seat?	Y	N/A					n/a	$ -	
F10587	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Shower Compartment		Shower type	Transfer	N/A					n/a	$ -	
F16048	Facilities Mgmt's Storage Facility		Exterior	Owned	Walkway		2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F16049	Facilities Mgmt's Storage Facility		Exterior	Owned	Walkway		2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F16050	Facilities Mgmt's Storage Facility		Exterior	Owned	Walkway		2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F00111	Government Center		Interior	Owned	Assembly Area	#C4413	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F00113	Government Center		Interior	Owned	Assembly Area	#C4415	1-Public Unsupervised	Seating Area		Number, seats	18	N/A					n/a	$ -	
F00114	Government Center		Interior	Owned	Assembly Area	Hearing Room	2-Public Supervised	Seating Area		Amplified sound?	Y	N/A					n/a	$ -	
F00115	Government Center		Interior	Owned	Assembly Area	Hearing Room	2-Public Supervised	Door Gate	East doors to seating area	Approach type, pull	F	N/A					n/a	$ -	
F00116	Government Center		Interior	Owned	Assembly Area	Hearing Room	2-Public Supervised	Door Gate	East doors to seating area	Approach type, push	F	N/A					n/a	$ -	
F00117	Government Center		Interior	Owned	Assembly Area	Hearing Room	2-Public Supervised	Door Gate	East doors to seating area	Closer?	Y	N/A					n/a	$ -	
F00119	Government Center		Interior	Owned	Assembly Area	Hearing Room	2-Public Supervised	Seating Area		Number, marked aisle seats	0	N/A					n/a	$ -	
F00120	Government Center		Interior	Owned	Assembly Area	Hearing Room	2-Public Supervised	Seating Area		Number, seats	221	N/A					n/a	$ -	
F00121	Government Center		Interior	Owned	Assembly Area	Hearing Room	2-Public Supervised	Seating Area		Seating dispersed?	N	N/A					n/a	$ -	
F00122	Government Center		Interior	Owned	Assembly Area	Hearing Room	2-Public Supervised	Aisle Seat	Spectator	ISA?	N	N/A					n/a	$ -	
F00428	Government Center		Interior	Owned	Break Room	#W1014	3-Employee Common	Protrusion	Wall mounted TV	Height	51.5	N/A					n/a	$ -	
F00432	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Counter		Approach type	S	N/A					n/a	$ -	
F00433	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F00434	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F00435	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Door Gate		Closer?	Sliding door	N/A					n/a	$ -	
F00436	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	0	N/A					n/a	$ -	
F00437	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Door Gate		Is a peep-hole provided?	Window	N/A					n/a	$ -	
F00486	Government Center		Interior	Owned	Break Room	#W8205 - Catering/Pantry	3-Employee Common	Counter		Approach type	F	N/A					n/a	$ -	
F00810	Government Center		Interior	Owned	Cafeteria		1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F00937	Government Center		Interior	Owned	Conference Room	#W8302	2-Public Supervised	Seating Area		Amplified sound?	Y	N/A					n/a	$ -	
F00938	Government Center		Interior	Owned	Conference Room	#W8302	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F00939	Government Center		Interior	Owned	Conference Room	#W8302	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F00940	Government Center		Interior	Owned	Conference Room	#W8302	2-Public Supervised	Seating Area		Audible comm. Integral?	Y	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00941	Government Center		Interior	Owned	Conference Room	#W8302	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F00942	Government Center		Interior	Owned	Conference Room	#W8302	2-Public Supervised	Aisle Seat		Folding/removable armrest?	R	N/A					n/a	$ -	
F00943	Government Center		Interior	Owned	Conference Room	#W8302	2-Public Supervised	Door Gate		Is a peep-hole provided?	Window	N/A					n/a	$ -	
F00944	Government Center		Interior	Owned	Conference Room	#W8302	2-Public Supervised	Door Gate		Kick plate?	Y	N/A					n/a	$ -	
F00945	Government Center		Interior	Owned	Conference Room	#W8302	2-Public Supervised	Door Gate		Latch?	N	N/A					n/a	$ -	
F00946	Government Center		Interior	Owned	Conference Room	#W8302	2-Public Supervised	Seating Area		Number, seats	56	N/A					n/a	$ -	
F00947	Government Center		Interior	Owned	Conference Room	#W8302	2-Public Supervised	Seating Area		Seating dispersed?	Y	N/A					n/a	$ -	
F00972	Government Center		Interior	Owned	Conference Room	#W8501	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F00973	Government Center		Interior	Owned	Conference Room	#W8501	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F00974	Government Center		Interior	Owned	Conference Room	#W8501	2-Public Supervised	Aisle Seat		Folding/removable armrest?	R	N/A					n/a	$ -	
F00983	Government Center		Interior	Owned	Conference Room	#W8503/W8304	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F00984	Government Center		Interior	Owned	Conference Room	#W8503/W8304	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F03033	Government Center		Interior	Owned	Elevator	#1 - #3 elevator	1-Public Unsupervised	Elevator Door		Location	Center	N/A					n/a	$ -	
F03038	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Handrail		Diameter	1	N/A					n/a	$ -	
F03039	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Handrail		Diameter	1	N/A					n/a	$ -	
F03078	Government Center		Interior	Owned	Elevator	#4 - Freight elevator	1-Public Unsupervised	Handrail		Cross section type	Round	N/A					n/a	$ -	
F03079	Government Center		Interior	Owned	Elevator	#4 - Freight elevator	1-Public Unsupervised	Elevator Door		Location	Center	N/A					n/a	$ -	
F03080	Government Center		Interior	Owned	Elevator	#4 - Freight elevator	1-Public Unsupervised	Handrail		Diameter	1	N/A					n/a	$ -	
F03787	Government Center		Interior	Owned	Hallway	West entrance	1-Public Unsupervised	Signage	Exit Sign	Height, bottom	8.5 feet	N/A					n/a	$ -	
F03788	Government Center		Interior	Owned	Hallway	West entrance	1-Public Unsupervised	Signage	Exit Sign	Height, top	9 feet	N/A					n/a	$ -	
F03793	Government Center		Interior	Owned	Hallway	West hallway	2-Public Supervised	Drinking Fountain	Near #W5007	Flow direction	OK	N/A					n/a	$ -	
F03794	Government Center		Interior	Owned	Hallway	West hallway	2-Public Supervised	Drinking Fountain	Near #W5007	High-low fountain?	Y	N/A					n/a	$ -	
F04953	Government Center		Interior	Owned	Other Room	#W5000 - Workforce Business Center	1-Public Unsupervised	Counter		Approach type	S	N/A					n/a	$ -	
F04954	Government Center		Interior	Owned	Other Room	#W5000 - Workforce Business Center	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F04955	Government Center		Interior	Owned	Other Room	#W5000 - Workforce Business Center	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F04968	Government Center		Interior	Owned	Other Room	#W8506 - Video Conference Room	2-Public Supervised	Protrusion	Attached Video camera	Height	37	N/A					n/a	$ -	
F04971	Government Center		Interior	Owned	Other Room	Planning & Development Public Works Reception Area	1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F06026	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#1	Type	Van	N/A					n/a	$ -	
F06027	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#2	Type	Van	N/A					n/a	$ -	
F06028	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#3	Type	STD	N/A					n/a	$ -	
F06029	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#4	Type	STD	N/A					n/a	$ -	
F06073	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#1	Type	STD	N/A					n/a	$ -	
F06074	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#1	Type	STD	N/A					n/a	$ -	
F06075	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#2	Type	STD	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06076	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#3	Type	STD	N/A					n/a	$ -	
F06077	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#4	Type	STD	N/A					n/a	$ -	
F06078	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#5	Type	Van	N/A					n/a	$ -	
F06079	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#6	Type	Van	N/A					n/a	$ -	
F06148	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#2	Type	STD	N/A					n/a	$ -	
F06149	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#3	Type	STD	N/A					n/a	$ -	
F06150	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#4	Type	STD	N/A					n/a	$ -	
F06151	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#5	Type	STD	N/A					n/a	$ -	
F06197	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#1	Type	STD	N/A					n/a	$ -	
F06198	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#2	Type	STD	N/A					n/a	$ -	
F06199	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#3	Type	STD	N/A					n/a	$ -	
F06200	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#4	Type	Van	N/A					n/a	$ -	
F06201	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#5	Type	Van	N/A					n/a	$ -	
F06258	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#1	Type	Van	N/A					n/a	$ -	
F06259	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#2	Type	Van	N/A					n/a	$ -	
F06260	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#3	Type	STD	N/A					n/a	$ -	
F06261	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#4	Type	STD	N/A					n/a	$ -	
F06305	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#5	Type	STD	N/A					n/a	$ -	
F06306	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#6	Type	STD	N/A					n/a	$ -	
F06307	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#7	Type	Van	N/A					n/a	$ -	
F06308	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#8	Type	Van	N/A					n/a	$ -	
F07392	Government Center		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Area Specifications		Area, less than 1,000	N	N/A					n/a	$ -	
F07393	Government Center		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Area Specifications		Number, elevated components	6	N/A					n/a	$ -	
F07394	Government Center		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Area Specifications		Number, ground types	1	N/A					n/a	$ -	
F07402	Government Center		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Area Specifications		Area, less than 1,000	N	N/A					n/a	$ -	
F07403	Government Center		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Area Specifications		Number, elevated components	10	N/A					n/a	$ -	
F07404	Government Center		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Walking Surface		Firm, stable, slip resistant	N	N/A					n/a	$ -	
F10631	Government Center		Interior	Owned	Restroom	Men's - Near C1205	1-Public Unsupervised	Protrusion	Hand dryer	Height	40	N/A					n/a	$ -	
F10632	Government Center		Interior	Owned	Restroom	Men's - Near C1205	1-Public Unsupervised	Protrusion	Hand dryer	Height	40.5	N/A					n/a	$ -	
F10646	Government Center		Interior	Owned	Restroom	Men's - Near C1304	3-Employee Common	Protrusion		Height	41	N/A					n/a	$ -	
F10655	Government Center		Interior	Owned	Restroom	Men's - Near C3506	3-Employee Common	Protrusion	Hand dryer	Height	41	N/A					n/a	$ -	
F10657	Government Center		Interior	Owned	Restroom	Men's - Near C4506	3-Employee Common	Protrusion	Hand dryer	Height	41	N/A					n/a	$ -	
F10659	Government Center		Interior	Owned	Restroom	Men's - Near C5506	3-Employee Common	Protrusion	Hand dryer	Height	41	N/A					n/a	$ -	
F10660	Government Center		Interior	Owned	Restroom	Men's - Near C5506	3-Employee Common	Protrusion	Hand dryer	Height	41	N/A					n/a	$ -	
F10663	Government Center		Interior	Owned	Restroom	Men's - Near E1203	1-Public Unsupervised	Protrusion	Hand dryer	Height	41	N/A					n/a	$ -	
F10665	Government Center		Interior	Owned	Restroom	Men's - Near E2606	3-Employee Common	Protrusion	Hand dryer	Height	41	N/A					n/a	$ -	
F10667	Government Center		Interior	Owned	Restroom	Men's - Near E3309	3-Employee Common	Protrusion	Hand dryer	Height	41	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10669	Government Center		Interior	Owned	Restroom	Men's - Near E4012	3-Employee Common	Protrusion	Hand dryer	Height	41	N/A					n/a	$ -	
F10671	Government Center		Interior	Owned	Restroom	Men's - Near W2606	3-Employee Common	Protrusion		Height	41	N/A					n/a	$ -	
F10714	Government Center		Interior	Owned	Restroom	Men's - Near W6504	3-Employee Common	Protrusion	Hand dryer	Height	41	N/A					n/a	$ -	
F10723	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F10724	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F10725	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F10726	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Protrusion	Hand dryer	Height	41	N/A					n/a	$ -	
F10727	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F10728	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Door Gate		Kick plate?	Y	N/A					n/a	$ -	
F10729	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Door Gate		Latch?	N	N/A					n/a	$ -	
F10763	Government Center		Interior	Owned	Restroom	Men's - Near W8404	2-Public Supervised	Protrusion	Hand dryer	Height	41	N/A					n/a	$ -	
F10764	Government Center		Interior	Owned	Restroom	Men's - Near W8404	2-Public Supervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F10774	Government Center		Interior	Owned	Restroom	Women's - Near C1205	1-Public Unsupervised	Protrusion	Hand dryer	Height	41	N/A					n/a	$ -	
F10775	Government Center		Interior	Owned	Restroom	Women's - Near C1205	1-Public Unsupervised	Protrusion	Feminine product dispenser	Height	41	N/A					n/a	$ -	
F10776	Government Center		Interior	Owned	Restroom	Women's - Near C1205	1-Public Unsupervised	Protrusion	Hand dryer	Height	41	N/A					n/a	$ -	
F10794	Government Center		Interior	Owned	Restroom	Women's - Near C1304	3-Employee Common	Protrusion	Hand dryer	Height	40	N/A					n/a	$ -	
F10802	Government Center		Interior	Owned	Restroom	Women's - Near C2506	3-Employee Common	Protrusion	Hand dryer	Height	41	N/A					n/a	$ -	
F10803	Government Center		Interior	Owned	Restroom	Women's - Near C2506	3-Employee Common	Protrusion	Hand dryer	Height	41	N/A					n/a	$ -	
F10806	Government Center		Interior	Owned	Restroom	Women's - Near C3506	3-Employee Common	Protrusion	Hand dryer	Height	41	N/A					n/a	$ -	
F10807	Government Center		Interior	Owned	Restroom	Women's - Near C3506	3-Employee Common	Protrusion	Hand dryer	Height	41	N/A					n/a	$ -	
F10808	Government Center		Interior	Owned	Restroom	Women's - Near C3506	3-Employee Common	Protrusion	Feminine product dispenser	Height	49	N/A					n/a	$ -	
F10812	Government Center		Interior	Owned	Restroom	Women's - Near C4506	3-Employee Common	Protrusion	Hand dryer	Height	41	N/A					n/a	$ -	
F10814	Government Center		Interior	Owned	Restroom	Women's - Near C5506	3-Employee Common	Protrusion	Hand dryer	Height	41	N/A					n/a	$ -	
F10815	Government Center		Interior	Owned	Restroom	Women's - Near C5506	3-Employee Common	Protrusion	Feminine product dispenser	Height	49	N/A					n/a	$ -	
F10818	Government Center		Interior	Owned	Restroom	Women's - Near E1203	1-Public Unsupervised	Protrusion	Hand dryer	Height	41	N/A					n/a	$ -	
F10820	Government Center		Interior	Owned	Restroom	Women's - Near E2606	3-Employee Common	Protrusion	Hand dryer	Height	41	N/A					n/a	$ -	
F10822	Government Center		Interior	Owned	Restroom	Women's - Near E3309	3-Employee Common	Protrusion	Hand dryer	Height	41	N/A					n/a	$ -	
F10824	Government Center		Interior	Owned	Restroom	Women's - Near W2606	3-Employee Common	Protrusion	Hand dryer	Height	41	N/A					n/a	$ -	
F10858	Government Center		Interior	Owned	Restroom	Women's - Near W6504	3-Employee Common	Protrusion	Hand dryer	Height	40	N/A					n/a	$ -	
F10866	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F10867	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F10868	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F10869	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F10870	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F10871	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F10872	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Grab Bar	Side	Cross section type	Round	N/A					n/a	$ -	
F10873	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Grab Bar	Rear	Cross section type	Round	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10874	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Alarm System		Dimension from ceiling	Ceiling mount	N/A					n/a	$ -	
F10875	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Grab Bar	Side	Dimension, centerline to wall (vertical)	50	N/A					n/a	$ -	
F10876	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F10877	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Changing Station		Height	46	N/A					n/a	$ -	
F10878	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Protrusion	Feminine product dispenser	Height	40	N/A					n/a	$ -	
F10879	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Protrusion	Hand dryer	Height	41	N/A					n/a	$ -	
F10880	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F10881	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F10882	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Kick plate?	Y	N/A					n/a	$ -	
F10883	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Latch?	N	N/A					n/a	$ -	
F10884	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F10885	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F10886	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Mirror	Full length	Over lavatory?	N	N/A					n/a	$ -	
F10887	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Coat Hook		Over obstruction?	N	N/A					n/a	$ -	
F10888	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F10889	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F10890	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Dispenser	Toilet seat covers	Over obstruction?	Y	N/A					n/a	$ -	
F10891	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F10892	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Changing Station		Over obstruction?	N	N/A					n/a	$ -	
F10893	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Grab Bar	Side	Perimeter	Round	N/A					n/a	$ -	
F10894	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	Y	N/A					n/a	$ -	
F10895	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F10896	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Grab Bar	Side	Wall reinforcement	Y	N/A					n/a	$ -	
F10897	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Grab Bar	Rear	Wall reinforcement	Y	N/A					n/a	$ -	
F10898	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F10996	Government Center		Interior	Owned	Restroom	Women's - Near W8404	2-Public Supervised	Protrusion	Hand dryer	Height	41	N/A					n/a	$ -	
F10997	Government Center		Interior	Owned	Restroom	Women's - Near W8404	2-Public Supervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F15636	Government Center		Exterior	Owned	Stairway	West Parking Lot	1-Public Unsupervised	Handrail		Cross section type	Oval	N/A					n/a	$ -	
F16057	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate		Height, threshold	None	N/A					n/a	$ -	
F16058	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate		Threshold beveled?	N	N/A					n/a	$ -	
F16061	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	2nd set in series	Threshold beveled?	N	N/A					n/a	$ -	
F16070	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate	1st set in series	Approach type, pull	F	N/A					n/a	$ -	
F16071	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F16072	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate	1st set in series	Approach type, push	F	N/A					n/a	$ -	
F16073	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F16074	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate	1st set in series	Closer?	Auto	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16075	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate		Closer?	Auto	N/A					n/a	$ -	
F16077	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate	1st set in series	Is a peep-hole provided?	Window	N/A					n/a	$ -	
F16078	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate		Is a peep-hole provided?	Window	N/A					n/a	$ -	
F16079	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate	1st set in series	Kick plate?	Y	N/A					n/a	$ -	
F16080	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate		Kick plate?	Y	N/A					n/a	$ -	
F16081	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate	1st set in series	Latch?	N	N/A					n/a	$ -	
F16082	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate		Latch?	N	N/A					n/a	$ -	
F16086	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	2nd set in series	Height, threshold	None	N/A					n/a	$ -	
F16087	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	2nd set in series	Threshold beveled?	N	N/A					n/a	$ -	
F16119	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	1st set in series	Approach type, pull	F	N/A					n/a	$ -	
F16120	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	2nd set in series	Approach type, pull	F	N/A					n/a	$ -	
F16121	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	1st set in series	Approach type, push	F	N/A					n/a	$ -	
F16122	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	2nd set in series	Approach type, push	F	N/A					n/a	$ -	
F16123	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	1st set in series	Closer?	Auto	N/A					n/a	$ -	
F16124	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	2nd set in series	Closer?	Auto	N/A					n/a	$ -	
F16125	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	1st set in series	Is a peep-hole provided?	Window	N/A					n/a	$ -	
F16126	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	2nd set in series	Is a peep-hole provided?	Window	N/A					n/a	$ -	
F16127	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	1st set in series	Kick plate?	Y	N/A					n/a	$ -	
F16128	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	2nd set in series	Kick plate?	Y	N/A					n/a	$ -	
F16129	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	1st set in series	Latch?	N	N/A					n/a	$ -	
F16130	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	2nd set in series	Latch?	N	N/A					n/a	$ -	
F16133	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	2nd set in series	Threshold beveled?	N	N/A					n/a	$ -	
F16166	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	1st set in series	Approach type, pull	F	N/A					n/a	$ -	
F16167	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	2nd set in series	Approach type, pull	F	N/A					n/a	$ -	
F16168	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	1st set in series	Approach type, push	F	N/A					n/a	$ -	
F16169	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	2nd set in series	Approach type, push	F	N/A					n/a	$ -	
F16170	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	1st set in series	Closer?	Auto	N/A					n/a	$ -	
F16171	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	2nd set in series	Closer?	Auto	N/A					n/a	$ -	
F16173	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	1st set in series	Is a peep-hole provided?	Window	N/A					n/a	$ -	
F16174	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	2nd set in series	Is a peep-hole provided?	Window	N/A					n/a	$ -	
F16175	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	1st set in series	Kick plate?	Y	N/A					n/a	$ -	
F16176	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	2nd set in series	Kick plate?	Y	N/A					n/a	$ -	
F16177	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	1st set in series	Latch?	N	N/A					n/a	$ -	
F16178	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	2nd set in series	Latch?	N	N/A					n/a	$ -	
F16204	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	1st set in series	Approach type, pull	F	N/A					n/a	$ -	
F16205	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	2nd set in series	Approach type, pull	F	N/A					n/a	$ -	
F16206	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	1st set in series	Approach type, push	F	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16207	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	2nd set in series	Approach type, push	F	N/A					n/a	$ -	
F16208	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	1st set in series	Closer?	Auto	N/A					n/a	$ -	
F16209	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	2nd set in series	Closer?	Auto	N/A					n/a	$ -	
F16210	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	1st set in series	Is a peep-hole provided?	Window	N/A					n/a	$ -	
F16211	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	2nd set in series	Is a peep-hole provided?	Window	N/A					n/a	$ -	
F16212	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	1st set in series	Kick plate?	Y	N/A					n/a	$ -	
F16213	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	2nd set in series	Kick plate?	Y	N/A					n/a	$ -	
F16214	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	1st set in series	Latch?	N	N/A					n/a	$ -	
F16215	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	2nd set in series	Latch?	N	N/A					n/a	$ -	
F16240	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	2nd set in series	Height, threshold	None	N/A					n/a	$ -	
F00493	Honnen Building	Food Pantry	Interior	Owned	Break Room	Warehouse area	3-Employee Common	Lavatory Sink	Large utility sink	Other attribute	30.5	N/A					n/a	$ -	
F00506	Honnen Building		2nd Floor	Owned	Break Room		3-Employee Common	Counter		Approach type	F	N/A					n/a	$ -	
F00507	Honnen Building		2nd Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Other attribute	End cabinet	N/A					n/a	$ -	
F00508	Honnen Building		2nd Floor	Owned	Break Room		3-Employee Common	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F03802	Honnen Building	Food Pantry	Interior	Owned	Hallway	To secured office & classrooms	2-Public Supervised	Door Gate	Security keypad	Approach type, pull	F	N/A					n/a	$ -	
F03803	Honnen Building	Food Pantry	Interior	Owned	Hallway	To secured office & classrooms	2-Public Supervised	Door Gate	Security keypad	Approach type, push	F	N/A					n/a	$ -	
F03804	Honnen Building	Food Pantry	Interior	Owned	Hallway	To secured office & classrooms	2-Public Supervised	Door Gate	Security keypad	Closer?	Y	N/A					n/a	$ -	
F03805	Honnen Building	Food Pantry	Interior	Owned	Hallway	To secured office & classrooms	2-Public Supervised	Door Gate	Security keypad	Latch?	Y	N/A					n/a	$ -	
F04329	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Approach type	S	N/A					n/a	$ -	
F04330	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F04331	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate	Into open office	Approach type, pull	F	N/A					n/a	$ -	
F04332	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F04333	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate	Into open office	Approach type, push	L	N/A					n/a	$ -	
F04334	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Closer?	y	N/A					n/a	$ -	
F04335	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate	Into open office	Closer?	N	N/A					n/a	$ -	
F04336	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F04337	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate	Into open office	Latch?	Y	N/A					n/a	$ -	
F04361	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Counter		Approach type	S	N/A					n/a	$ -	
F04362	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Door Gate	Entry to Head Start #1	Approach type, pull	F	N/A					n/a	$ -	
F04363	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Door Gate	Entry to Head Start #2	Approach type, pull	F	N/A					n/a	$ -	
F04364	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Door Gate	Entry to Head Start #1	Approach type, push	F	N/A					n/a	$ -	
F04365	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Door Gate	Entry to Head Start #2	Approach type, push	F	N/A					n/a	$ -	
F04366	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Door Gate	Entry to Head Start #1	Closer?	Y	N/A					n/a	$ -	
F04367	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Door Gate	Entry to Head Start #2	Closer?	Y	N/A					n/a	$ -	
F04368	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Door Gate	Entry to Head Start #1	Latch?	Y	N/A					n/a	$ -	
F04369	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Door Gate	Entry to Head Start #2	Latch?	Y	N/A					n/a	$ -	
F04370	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Counter		Other attribute	7.5	N/A					n/a	$ -	
F04977	Honnen Building	Food Pantry	Interior	Owned	Other Room	Pantry office to warehouse	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F04978	Honnen Building	Food Pantry	Interior	Owned	Other Room	Pantry office to warehouse	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F04979	Honnen Building	Food Pantry	Interior	Owned	Other Room	Pantry office to warehouse	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F04980	Honnen Building	Food Pantry	Interior	Owned	Other Room	Pantry office to warehouse	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F04990	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F04991	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Door Gate	To children's restroom	Approach type, pull	F	N/A					n/a	$ -	
F04992	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Door Gate		Approach type, push	H	N/A					n/a	$ -	
F04993	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Door Gate	To children's restroom	Approach type, push	F	N/A					n/a	$ -	
F04994	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F04995	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Door Gate	To children's restroom	Closer?	N	N/A					n/a	$ -	
F04996	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Door Gate	To children's restroom	Latch?	Y	N/A					n/a	$ -	
F05023	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom B	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F05024	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom B	2-Public Supervised	Door Gate		Approach type, push	H	N/A					n/a	$ -	
F05025	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom B	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F05026	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom B	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F05037	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom C	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F05038	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom C	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F05039	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom C	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F05040	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom C	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F05051	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom D	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F05052	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom D	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F05053	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom D	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F05054	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom D	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F06345	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#3	Adjacent pathway?	N	N/A					n/a	$ -	
F06346	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, total spaces	80	N/A					n/a	$ -	
F07412	Honnen Building		Exterior	Owned	Play Area		2-Public Supervised	Area Specifications		Number, elevated components	8	N/A					n/a	$ -	
F07413	Honnen Building		Exterior	Owned	Play Area		2-Public Supervised	Area Specifications		Number, ground types	3	N/A					n/a	$ -	
F07414	Honnen Building		Exterior	Owned	Play Area		2-Public Supervised	Area Specifications		Number, ground types on accessible route	1	N/A					n/a	$ -	
F11040	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F11041	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F11042	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F11043	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F11044	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F11045	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F11084	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Fixture Count		Number, toilet compartments	4	N/A					n/a	$ -	
F11085	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Fixture Count		Number, urinals	0	N/A					n/a	$ -	
F11086	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Dispenser	PT	Other attribute	Children's restroom	N/A					n/a	$ -	
F11087	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Fixture Count		Other attribute	Children's restroom	N/A					n/a	$ -	
F11088	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Lavatory Sink		Other attribute	Children's restroom	N/A					n/a	$ -	
F11111	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F11112	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F11113	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F11114	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11115	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Dispenser	Soap	Other attribute	Children's restroom	N/A					n/a	$ -	
F11116	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Lavatory Sink		Other attribute	Children's restroom	N/A					n/a	$ -	
F11145	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F11146	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F11147	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F11148	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F11149	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F11150	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F11181	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F11182	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F11183	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F11184	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F11185	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Door Gate		Other attribute	Single user	N/A					n/a	$ -	
F11186	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F11187	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F11213	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F11214	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F11215	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F11216	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Dispenser	Toilet seat covers	Over obstruction?	Y	N/A					n/a	$ -	
F11246	Honnen Building		2nd Floor	Owned	Restroom	Unisex - North	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F11247	Honnen Building		2nd Floor	Owned	Restroom	Unisex - North	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F11259	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Northeast	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F11260	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Northeast	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F11275	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Southeast	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F11276	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Southeast	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F16251	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From East parking lot to entrance	1-Public Unsupervised	Curb Ramp		Are detectable warnings present?	N	N/A					n/a	$ -	
F16261	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From North side to parking lot	1-Public Unsupervised	Curb Ramp		Are detectable warnings present?	N	N/A					n/a	$ -	
F16262	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From North side to parking lot	1-Public Unsupervised	Curb Ramp	West side of lot entry	Are detectable warnings present?	N	N/A					n/a	$ -	
F00143	Human Service Building		Interior	Owned	Assembly Area	Basement	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F00144	Human Service Building		Interior	Owned	Assembly Area	Basement	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F00145	Human Service Building		Interior	Owned	Assembly Area	Basement	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F00146	Human Service Building		Interior	Owned	Assembly Area	Basement	2-Public Supervised	Alarm System		Dimension from ceiling	15	N/A					n/a	$ -	
F00147	Human Service Building		Interior	Owned	Assembly Area	Basement	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F00154	Human Service Building		Interior	Owned	Assembly Area	Basement - Conf Rm. #2	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F00155	Human Service Building		Interior	Owned	Assembly Area	Basement - Conf Rm. #2	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F00156	Human Service Building		Interior	Owned	Assembly Area	Basement - Conf Rm. #2	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F00157	Human Service Building		Interior	Owned	Assembly Area	Basement - Conf Rm. #2	2-Public Supervised	Alarm System		Dimension from ceiling	15	N/A					n/a	$ -	
F00158	Human Service Building		Interior	Owned	Assembly Area	Basement - Conf Rm. #2	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F00168	Human Service Building		5th Floor	Owned	Assembly Area	Meeting room	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F00169	Human Service Building		5th Floor	Owned	Assembly Area	Meeting room	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F00170	Human Service Building		5th Floor	Owned	Assembly Area	Meeting room	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F00171	Human Service Building		5th Floor	Owned	Assembly Area	Meeting room	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00522	Human Service Building		Interior	Owned	Break Room	Basement	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F00523	Human Service Building		Interior	Owned	Break Room	Basement	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F00524	Human Service Building		Interior	Owned	Break Room	Basement	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F00525	Human Service Building		Interior	Owned	Break Room	Basement	1-Public Unsupervised	Alarm System		Dimension from ceiling	12	N/A					n/a	$ -	
F00526	Human Service Building		Interior	Owned	Break Room	Basement	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F00533	Human Service Building		5th Floor	Owned	Break Room	Child Support Services	2-Public Supervised	Counter		Approach type	F	N/A					n/a	$ -	
F00539	Human Service Building		6th Floor	Owned	Break Room	Family Transition	2-Public Supervised	Counter		Approach type	F	N/A					n/a	$ -	
F00545	Human Service Building		6th Floor	Owned	Break Room	Housing Authority	3-Employee Common	Counter		Approach type	F	N/A					n/a	$ -	
F00555	Human Service Building		4th Floor	Owned	Break Room	South	3-Employee Common	Counter		Approach type	S	N/A					n/a	$ -	
F00556	Human Service Building		4th Floor	Owned	Break Room	South	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F00557	Human Service Building		4th Floor	Owned	Break Room	South	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F00558	Human Service Building		4th Floor	Owned	Break Room	South	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F03107	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Elevator Door		Location	Center	N/A					n/a	$ -	
F03144	Human Service Building		Interior	Owned	Elevator	#2 - South/East car	1-Public Unsupervised	Elevator Door		Location	S	N/A					n/a	$ -	
F03156	Human Service Building		Interior	Owned	Elevator	#3 - North/East car	1-Public Unsupervised	Elevator Door		Location	S	N/A					n/a	$ -	
F04389	Human Service Building	Child Support Services	5th Floor	Owned	Lobby Reception		2-Public Supervised	Door Gate	Interview rooms #1 thru #6	Closer?	N	N/A					n/a	$ -	
F04392	Human Service Building		5th Floor	Owned	Lobby Reception	Child Support Services	2-Public Supervised	Counter	Check-in	Approach type	F	N/A					n/a	$ -	
F05061	Human Service Building		4th Floor	Owned	Other Room	Adult Services	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F05062	Human Service Building		4th Floor	Owned	Other Room	Adult Services	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F05063	Human Service Building		4th Floor	Owned	Other Room	Adult Services	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F05064	Human Service Building		4th Floor	Owned	Other Room	Adult Services	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F05069	Human Service Building		6th Floor	Owned	Other Room	Family Transition	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F05070	Human Service Building		6th Floor	Owned	Other Room	Family Transition	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F05071	Human Service Building		6th Floor	Owned	Other Room	Family Transition	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F05072	Human Service Building		6th Floor	Owned	Other Room	Family Transition	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F05078	Human Service Building		6th Floor	Owned	Other Room	Housing Authority	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F05079	Human Service Building		6th Floor	Owned	Other Room	Housing Authority	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F05088	Human Service Building		Interior	Owned	Other Room	Interview Room #1	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F05089	Human Service Building		Interior	Owned	Other Room	Interview Room #1	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F05090	Human Service Building		Interior	Owned	Other Room	Interview Room #1	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F06404	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #10 & #11	Adjacent pathway?	N	N/A					n/a	$ -	
F06405	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #11 & #12	Adjacent pathway?	N	N/A					n/a	$ -	
F06406	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #12 & #13	Adjacent pathway?	N	N/A					n/a	$ -	
F06407	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #13 & #14	Adjacent pathway?	N	N/A					n/a	$ -	
F06408	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#10	Type	STD	N/A					n/a	$ -	
F06509	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	#1	Adjacent pathway?	N	N/A					n/a	$ -	
F06510	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	#3	Adjacent pathway?	N	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06511	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#4	Type	STD	N/A					n/a	$ -	
F06512	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#1 North	Type	STD	N/A					n/a	$ -	
F06587	Human Service Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, total spaces	373	N/A					n/a	$ -	
F11290	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Approach type, pull	L	N/A					n/a	$ -	
F11291	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Approach type, pull	L	N/A					n/a	$ -	
F11292	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Approach type, push	H	N/A					n/a	$ -	
F11293	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Approach type, push	H	N/A					n/a	$ -	
F11294	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F11295	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F11296	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Alarm System		Dimension from ceiling	14	N/A					n/a	$ -	
F11297	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Alarm System		Dimension from ceiling	17	N/A					n/a	$ -	
F11298	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Sides	Dimension, between	25.5	N/A					n/a	$ -	
F11299	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Ambulatory Compartment		Dimension, door to partition	5.5	N/A					n/a	$ -	
F11300	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet	Ambulatory	Dimension, sidewall	16.5	N/A					n/a	$ -	
F11301	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet	Ambulatory	Dimension, wide side	18	N/A					n/a	$ -	
F11302	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Ambulatory Compartment		Door location	S	N/A					n/a	$ -	
F11303	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F11304	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Protrusion	PT	Height	44	N/A					n/a	$ -	
F11305	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Latch?	N	N/A					n/a	$ -	
F11306	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F11307	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F11308	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Amb - Side #1	Vertical grab bar?	N	N/A					n/a	$ -	
F11309	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Amb - Side #2	Vertical grab bar?	N	N/A					n/a	$ -	
F11310	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Ambulatory	Vertical grab bar?	N	N/A					n/a	$ -	
F11311	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F11312	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Ambulatory Compartment		Water closet type	F	N/A					n/a	$ -	
F11313	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Water closet type	F	N/A					n/a	$ -	
F11397	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Approach type, pull	L	N/A					n/a	$ -	
F11398	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Approach type, push	H	N/A					n/a	$ -	
F11399	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F11400	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Alarm System		Dimension from ceiling	14	N/A					n/a	$ -	
F11401	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Amb - Side #1	Dimension, between	25	N/A					n/a	$ -	
F11402	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F11403	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	N/A					n/a	$ -	
F11404	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Protrusion	PT	Height	44	N/A					n/a	$ -	
F11405	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, urinals	0	N/A					n/a	$ -	
F11406	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11407	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Amb - Side #1	Vertical grab bar?	N	N/A					n/a	$ -	
F11408	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Amb - Side #2	Vertical grab bar?	N	N/A					n/a	$ -	
F11409	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F11410	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F11411	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Water closet type	F	N/A					n/a	$ -	
F16289	Human Service Building		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	At corner crosswalk - North side	Are detectable warnings present?	N	N/A					n/a	$ -	
F03531	Jim Baker Reservoir		Exterior	Owned	Fishing Pier		1-Public Unsupervised	Railing		Lowered sections dispersed?	N	N/A					n/a	$ -	
F11488	Jim Baker Reservoir		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F11489	Jim Baker Reservoir		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F11490	Jim Baker Reservoir		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Water Closet		Other attribute	No plumbing	N/A					n/a	$ -	
F11491	Jim Baker Reservoir		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F00174	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S431	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F00175	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S431	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F00176	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S431	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F00177	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S431	2-Public Supervised	Door Gate		Height, peep-hole	62	N/A					n/a	$ -	
F00178	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S431	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F00189	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S432	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F00190	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S432	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F00191	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S432	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F00192	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S432	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F00203	Justice Center	Self Help Resource Center	Interior	Owned	Assembly Area	Training Room	1-Public Unsupervised	Seating Area		Amplified sound?	Y	N/A					n/a	$ -	
F00204	Justice Center	Self Help Resource Center	Interior	Owned	Assembly Area	Training Room	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F00205	Justice Center	Self Help Resource Center	Interior	Owned	Assembly Area	Training Room	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F00206	Justice Center	Self Help Resource Center	Interior	Owned	Assembly Area	Training Room	1-Public Unsupervised	Seating Area		Audible comm. Integral?	Y	N/A					n/a	$ -	
F00207	Justice Center	Self Help Resource Center	Interior	Owned	Assembly Area	Training Room	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F00208	Justice Center	Self Help Resource Center	Interior	Owned	Assembly Area	Training Room	1-Public Unsupervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F00209	Justice Center	Self Help Resource Center	Interior	Owned	Assembly Area	Training Room	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F00210	Justice Center	Self Help Resource Center	Interior	Owned	Assembly Area	Training Room	1-Public Unsupervised	Seating Area		Number, seats	200	N/A					n/a	$ -	
F00228	Justice Center		Interior	Owned	Assembly Area	Jury Assembly Area	1-Public Unsupervised	Counter		Approach type	S	N/A					n/a	$ -	
F00229	Justice Center		Interior	Owned	Assembly Area	Jury Assembly Area	1-Public Unsupervised	Counter		Dimension, knee clearance	0	N/A					n/a	$ -	
F00230	Justice Center		Interior	Owned	Assembly Area	Jury Assembly Area	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	0	N/A					n/a	$ -	
F00246	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Seating Area		Amplified sound?	Y	N/A					n/a	$ -	
F00247	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F00248	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00249	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Seating Area		Audible comm. Integral?	Y	N/A					n/a	$ -	
F00250	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F00251	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Protrusion	Angled beam #1	Height	60	N/A					n/a	$ -	
F00252	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Protrusion	Angled beam #2	Height	60	N/A					n/a	$ -	
F00253	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Is a peep-hole provided?	Window	N/A					n/a	$ -	
F00254	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Latch?	N	N/A					n/a	$ -	
F00255	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Seating Area		Number, seats	1250	N/A					n/a	$ -	
F00568	Justice Center		Interior	Owned	Break Room	#105 - South wall	3-Employee Common	Counter		Approach type	S	N/A					n/a	$ -	
F00569	Justice Center		Interior	Owned	Break Room	#105 - South wall	3-Employee Common	Counter		Dimension, knee clearance	0	N/A					n/a	$ -	
F00570	Justice Center		Interior	Owned	Break Room	#105 - South wall	3-Employee Common	Lavatory Sink		Dimension, knee clearance	0	N/A					n/a	$ -	
F00571	Justice Center		Interior	Owned	Break Room	#105 - South wall	3-Employee Common	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F00572	Justice Center		Interior	Owned	Break Room	#105 - South wall	3-Employee Common	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F00582	Justice Center		Interior	Owned	Break Room	#105 - Work Area	3-Employee Common	Counter		Approach type	S	N/A					n/a	$ -	
F00583	Justice Center		Interior	Owned	Break Room	#105 - Work Area	3-Employee Common	Counter		Dimension, knee clearance	0	N/A					n/a	$ -	
F00584	Justice Center		Interior	Owned	Break Room	#105 - Work Area	3-Employee Common	Lavatory Sink		Dimension, knee clearance	0	N/A					n/a	$ -	
F00585	Justice Center		Interior	Owned	Break Room	#105 - Work Area	3-Employee Common	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F00586	Justice Center		Interior	Owned	Break Room	#105 - Work Area	3-Employee Common	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F00600	Justice Center		4th Floor	Owned	Break Room	#405 - Staff Area	3-Employee Common	Counter		Approach type	S	N/A					n/a	$ -	
F00601	Justice Center		4th Floor	Owned	Break Room	#405 - Staff Area	3-Employee Common	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F00602	Justice Center		4th Floor	Owned	Break Room	#405 - Staff Area	3-Employee Common	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F00619	Justice Center		6th Floor	Owned	Break Room	#605 - Staff Area	3-Employee Common	Dispenser	Soap	Over obstruction?	22	N/A					n/a	$ -	
F00620	Justice Center		6th Floor	Owned	Break Room	#605 - Staff Area	3-Employee Common	Dispenser	PT	Over obstruction?	18	N/A					n/a	$ -	
F00627	Justice Center		4th Floor	Owned	Break Room	#S437	3-Employee Common	Counter		Approach type	S	N/A					n/a	$ -	
F00628	Justice Center		4th Floor	Owned	Break Room	#S437	3-Employee Common	Lavatory Sink		Dimension, knee clearance	0	N/A					n/a	$ -	
F00629	Justice Center		4th Floor	Owned	Break Room	#S437	3-Employee Common	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F00643	Justice Center		5th Floor	Owned	Break Room	South	3-Employee Common	Counter		Approach type	S	N/A					n/a	$ -	
F00644	Justice Center		5th Floor	Owned	Break Room	South	3-Employee Common	Counter		Dimension, knee clearance	0	N/A					n/a	$ -	
F00645	Justice Center		5th Floor	Owned	Break Room	South	3-Employee Common	Lavatory Sink		Dimension, knee clearance	0	N/A					n/a	$ -	
F00658	Justice Center		5th Floor	Owned	Break Room		3-Employee Common	Counter		Approach type	F	N/A					n/a	$ -	
F00659	Justice Center		Interior	Owned	Break Room		3-Employee Common	Counter		Approach type	S	N/A					n/a	$ -	
F00660	Justice Center		Interior	Owned	Break Room		3-Employee Common	Counter		Dimension, knee clearance	0	N/A					n/a	$ -	
F00661	Justice Center		5th Floor	Owned	Break Room		3-Employee Common	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F00662	Justice Center		5th Floor	Owned	Break Room		3-Employee Common	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F00663	Justice Center		Interior	Owned	Break Room		3-Employee Common	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F00843	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Counter	Tray slide	Approach type	S	N/A					n/a	$ -	
F00844	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Counter	At cash register	Approach type	S	N/A					n/a	$ -	
F00845	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Counter	Condiment countertop	Approach type	S	N/A					n/a	$ -	
F00846	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F00847	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate	To exterior Courtyard	Approach type, pull	F	N/A					n/a	$ -	
F00848	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F00849	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate	To exterior Courtyard	Approach type, push	F	N/A					n/a	$ -	
F00850	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F00851	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate	To exterior Courtyard	Closer?	Y	N/A					n/a	$ -	
F00852	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Alarm System		Dimension from ceiling	54.5	N/A					n/a	$ -	
F00853	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Counter	At cash register	Dimension, knee clearance	0	N/A					n/a	$ -	
F00854	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate		Height, peep-hole	None	N/A					n/a	$ -	
F00855	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate	To exterior Courtyard	Is a peep-hole provided?	Window	N/A					n/a	$ -	
F00856	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F00857	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate	To exterior Courtyard	Latch?	Y	N/A					n/a	$ -	
F01000	Justice Center		2nd Floor	Owned	Conference Room	#258	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01001	Justice Center		2nd Floor	Owned	Conference Room	#258	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F01002	Justice Center		2nd Floor	Owned	Conference Room	#258	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F01003	Justice Center		2nd Floor	Owned	Conference Room	#258	2-Public Supervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F01004	Justice Center		2nd Floor	Owned	Conference Room	#258	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F01026	Justice Center		5th Floor	Owned	Conference Room	#512	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01027	Justice Center		5th Floor	Owned	Conference Room	#512	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F01028	Justice Center		5th Floor	Owned	Conference Room	#512	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F01029	Justice Center		5th Floor	Owned	Conference Room	#512	2-Public Supervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F01030	Justice Center		5th Floor	Owned	Conference Room	#512	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F01040	Justice Center		5th Floor	Owned	Conference Room	#512 - Family Court	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01041	Justice Center		5th Floor	Owned	Conference Room	#512 - Family Court	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F01042	Justice Center		5th Floor	Owned	Conference Room	#512 - Family Court	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F01043	Justice Center		5th Floor	Owned	Conference Room	#512 - Family Court	2-Public Supervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F01044	Justice Center		5th Floor	Owned	Conference Room	#512 - Family Court	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F01064	Justice Center		5th Floor	Owned	Conference Room	#552	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01065	Justice Center		5th Floor	Owned	Conference Room	#552	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F01066	Justice Center		5th Floor	Owned	Conference Room	#552	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F01067	Justice Center		5th Floor	Owned	Conference Room	#552	2-Public Supervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F01068	Justice Center		5th Floor	Owned	Conference Room	#552	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F01081	Justice Center		4th Floor	Owned	Conference Room	#S410	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01082	Justice Center		4th Floor	Owned	Conference Room	#S410	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F01083	Justice Center		4th Floor	Owned	Conference Room	#S410	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F01084	Justice Center		4th Floor	Owned	Conference Room	#S410	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F01099	Justice Center		5th Floor	Owned	Conference Room	#S510	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F01100	Justice Center		5th Floor	Owned	Conference Room	#S510	2-Public Supervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F01101	Justice Center		5th Floor	Owned	Conference Room	#S510	2-Public Supervised	Door Gate		Kick plate?	Y	N/A					n/a	$ -	
F01102	Justice Center		5th Floor	Owned	Conference Room	#S510	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F01119	Justice Center		2nd Floor	Owned	Conference Room	Court 201 - Inside double door area	2-Public Supervised	Door Gate	Room 1	Approach type, pull	F	N/A					n/a	$ -	
F01120	Justice Center		2nd Floor	Owned	Conference Room	Court 201 - Inside double door area	2-Public Supervised	Door Gate	Room 2 - #228	Approach type, pull	F	N/A					n/a	$ -	
F01121	Justice Center		2nd Floor	Owned	Conference Room	Court 201 - Inside double door area	2-Public Supervised	Door Gate	Room 1	Approach type, push	F	N/A					n/a	$ -	
F01122	Justice Center		2nd Floor	Owned	Conference Room	Court 201 - Inside double door area	2-Public Supervised	Door Gate	Room 2 - #228	Approach type, push	F	N/A					n/a	$ -	
F01123	Justice Center		2nd Floor	Owned	Conference Room	Court 201 - Inside double door area	2-Public Supervised	Door Gate	Room 1	Closer?	N	N/A					n/a	$ -	
F01124	Justice Center		2nd Floor	Owned	Conference Room	Court 201 - Inside double door area	2-Public Supervised	Door Gate	Room 2 - #228	Closer?	N	N/A					n/a	$ -	
F01125	Justice Center		2nd Floor	Owned	Conference Room	Court 201 - Inside double door area	2-Public Supervised	Door Gate	Room 2 - #228	Is a peep-hole provided?	N	N/A					n/a	$ -	
F01126	Justice Center		2nd Floor	Owned	Conference Room	Court 201 - Inside double door area	2-Public Supervised	Door Gate	Room 1	Latch?	Y	N/A					n/a	$ -	
F01127	Justice Center		2nd Floor	Owned	Conference Room	Court 201 - Inside double door area	2-Public Supervised	Door Gate	Room 2 - #228	Latch?	Y	N/A					n/a	$ -	
F01144	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Counter		Approach type	F	N/A					n/a	$ -	
F01145	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01146	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F01147	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F01148	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F01149	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F01150	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F01151	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F01208	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Counter		Approach type	S	N/A					n/a	$ -	
F01209	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01210	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F01211	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F01212	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Door Gate		Height, peep-hole	None	N/A					n/a	$ -	
F01213	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F01214	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F01241	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Counter		Approach type	S	N/A					n/a	$ -	
F01242	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01243	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01244	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F01245	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F01246	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F01247	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F01248	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Alarm System		Dimension from ceiling	Ceiling mount	N/A					n/a	$ -	
F01249	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F01250	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F01287	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Counter		Approach type	S	N/A					n/a	$ -	
F01288	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01289	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F01290	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F01291	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Alarm System		Dimension from ceiling	Ceiling mount	N/A					n/a	$ -	
F01292	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F01293	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F01294	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F01319	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Counter		Approach type	S	N/A					n/a	$ -	
F01320	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01321	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F01322	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F01323	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F01324	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F01325	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F01326	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F01355	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Counter		Approach type	F	N/A					n/a	$ -	
F01356	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01357	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F01358	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F01359	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F01360	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F01361	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F01362	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F01390	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Counter		Approach type	F	N/A					n/a	$ -	
F01391	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01392	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F01393	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F01394	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F01395	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F01396	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F01397	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F01431	Justice Center		6th Floor	Owned	Conference Room	Jury Room 631	2-Public Supervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F01432	Justice Center		6th Floor	Owned	Conference Room	Jury Room 631	2-Public Supervised	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F01439	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Counter		Approach type	S	N/A					n/a	$ -	
F01440	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01441	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01442	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Approach type, push	H	N/A					n/a	$ -	
F01443	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F01444	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Clearance, series doors	None	N/A					n/a	$ -	
F01445	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F01446	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F01447	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Alarm System		Dimension from ceiling	Ceiling mount	N/A					n/a	$ -	
F01448	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F01449	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F01450	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F01482	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Counter		Approach type	S	N/A					n/a	$ -	
F01483	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Counter		Approach type	S	N/A					n/a	$ -	
F01484	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01485	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F01486	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F01487	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F01488	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Counter		Dimension, knee clearance	0	N/A					n/a	$ -	
F01489	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F01490	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Kick plate?	Y	N/A					n/a	$ -	
F01491	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F01492	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F01539	Justice Center		6th Floor	Owned	Conference Room	Jury Room S622	2-Public Supervised	Door Gate		Approach type, pull	L	N/A					n/a	$ -	
F01540	Justice Center		6th Floor	Owned	Conference Room	Jury Room S622	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F01541	Justice Center		6th Floor	Owned	Conference Room	Jury Room S622	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F01542	Justice Center		6th Floor	Owned	Conference Room	Jury Room S622	2-Public Supervised	Door Gate		Kick plate?	Y	N/A					n/a	$ -	
F01578	Justice Center	Traffic Court	2nd Floor	Owned	Courtroom	#251	2-Public Supervised	Counter		Approach type	F	N/A					n/a	$ -	
F01579	Justice Center	Traffic Court	2nd Floor	Owned	Courtroom	#251	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01580	Justice Center	Traffic Court	2nd Floor	Owned	Courtroom	#251	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F01581	Justice Center	Traffic Court	2nd Floor	Owned	Courtroom	#251	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F01582	Justice Center	Traffic Court	2nd Floor	Owned	Courtroom	#251	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F01598	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Seating Area	Spectator	Amplified sound?	Y	N/A					n/a	$ -	
F01599	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Counter	Clerk	Approach type	F	N/A					n/a	$ -	
F01600	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Wheelchair Space	Spectator	Approach type	F	N/A					n/a	$ -	
F01601	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Court staff entrance	Approach type, pull	F	N/A					n/a	$ -	
F01602	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Jury entrance	Approach type, pull	F	N/A					n/a	$ -	
F01603	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Court staff entrance	Approach type, push	F	N/A					n/a	$ -	
F01604	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Jury entrance	Approach type, push	F	N/A					n/a	$ -	
F01605	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Court staff entrance	Closer?	Y	N/A					n/a	$ -	
F01606	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Jury entrance	Closer?	Y	N/A					n/a	$ -	
F01607	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Alarm System		Dimension from ceiling	Ceiling mount	N/A					n/a	$ -	
F01608	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Courtroom Station		Fixed seating?	N	N/A					n/a	$ -	
F01609	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Judge Bench		Fixed seating?	N	N/A					n/a	$ -	
F01610	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Jury Box		Fixed seating?	Y	N/A					n/a	$ -	
F01611	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Witness Stand		Fixed seating?	N	N/A					n/a	$ -	
F01612	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Court staff entrance	Height, peep-hole	61.5	N/A					n/a	$ -	
F01613	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Court staff entrance	Is a peep-hole provided?	Y	N/A					n/a	$ -	
F01614	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Jury entrance	Latch?	Y	N/A					n/a	$ -	
F01615	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Seating Area		Number, aisle seats	0	N/A					n/a	$ -	
F01616	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Seating Area		Number, marked aisle seats	0	N/A					n/a	$ -	
F01617	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Seating Area		Number, seats	54	N/A					n/a	$ -	
F01618	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Courtroom Station		Raised location?	Y	N/A					n/a	$ -	
F01619	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Judge Bench		Raised location?	Y	N/A					n/a	$ -	
F01620	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Jury Box		Raised location?	Back row	N/A					n/a	$ -	
F01621	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Witness Stand		Raised location?	Y	N/A					n/a	$ -	
F01631	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Jury Box		Ramp?	N	N/A					n/a	$ -	
F01668	Justice Center		2nd Floor	Owned	Courtroom	#201 - Room 226	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01669	Justice Center		2nd Floor	Owned	Courtroom	#201 - Room 226	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F01670	Justice Center		2nd Floor	Owned	Courtroom	#201 - Room 226	2-Public Supervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F01671	Justice Center		2nd Floor	Owned	Courtroom	#201 - Room 226	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F01687	Justice Center		2nd Floor	Owned	Courtroom	#202 - Room 220	2-Public Supervised	Courtroom Station		Fixed seating?	N	N/A					n/a	$ -	
F01688	Justice Center		2nd Floor	Owned	Courtroom	#202 - Room 220	2-Public Supervised	Judge Bench		Fixed seating?	N	N/A					n/a	$ -	
F01694	Justice Center		2nd Floor	Owned	Courtroom	#203 - Room 256	2-Public Supervised	Courtroom Station		Fixed seating?	N	N/A					n/a	$ -	
F01695	Justice Center		2nd Floor	Owned	Courtroom	#203 - Room 256	2-Public Supervised	Judge Bench		Fixed seating?	N	N/A					n/a	$ -	
F01704	Justice Center		3rd Floor	Owned	Courtroom	#303 - Room 350	2-Public Supervised	Courtroom Station		Fixed seating?	N	N/A					n/a	$ -	
F01705	Justice Center		3rd Floor	Owned	Courtroom	#303 - Room 350	2-Public Supervised	Judge Bench		Fixed seating?	N	N/A					n/a	$ -	
F01706	Justice Center		3rd Floor	Owned	Courtroom	#303 - Room 350	2-Public Supervised	Judge Bench		Fixed seating?	N	N/A					n/a	$ -	
F01712	Justice Center		3rd Floor	Owned	Courtroom	#304 - Room 356	2-Public Supervised	Courtroom Station		Fixed seating?	N	N/A					n/a	$ -	
F01713	Justice Center		4th Floor	Owned	Courtroom	#304 - Room 356	2-Public Supervised	Jury Box		Fixed seating?	Y	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F01714	Justice Center		4th Floor	Owned	Courtroom	#304 - Room 356	2-Public Supervised	Jury Box		Raised location?	Y	N/A					n/a	$ -	
F01720	Justice Center		4th Floor	Owned	Courtroom	#304 - Room 356	2-Public Supervised	Jury Box		Ramp?	N	N/A					n/a	$ -	
F01724	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Seating Area	Spectator	Amplified sound?	Y	N/A					n/a	$ -	
F01725	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Counter	Clerk	Approach type	S	N/A					n/a	$ -	
F01726	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01727	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F01728	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Seating Area	Spectator	Audible comm. Integral?	Y	N/A					n/a	$ -	
F01729	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F01730	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Alarm System		Dimension from ceiling	Ceiling mount	N/A					n/a	$ -	
F01731	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Judge Bench		Fixed seating?	N	N/A					n/a	$ -	
F01732	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Jury Box		Fixed seating?	Y	N/A					n/a	$ -	
F01733	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Witness Stand		Fixed seating?	N	N/A					n/a	$ -	
F01734	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F01735	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Seating Area		Number, aisle seats	8	N/A					n/a	$ -	
F01736	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Seating Area		Number, marked aisle seats	0	N/A					n/a	$ -	
F01737	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Seating Area		Number, seats	46	N/A					n/a	$ -	
F01738	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Judge Bench		Raised location?	Y	N/A					n/a	$ -	
F01739	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Jury Box		Raised location?	Back row	N/A					n/a	$ -	
F01740	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Witness Stand		Raised location?	Y	N/A					n/a	$ -	
F01741	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Seating Area		Seating dispersed?	N	N/A					n/a	$ -	
F01748	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Jury Box		Ramp?	N	N/A					n/a	$ -	
F01750	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01774	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Seating Area	Spectator	Amplified sound?	Y	N/A					n/a	$ -	
F01775	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Counter	Clerk	Approach type	S	N/A					n/a	$ -	
F01776	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01777	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F01778	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Seating Area	Spectator	Audible comm. Integral?	Y	N/A					n/a	$ -	
F01779	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F01780	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Judge Bench		Fixed seating?	N	N/A					n/a	$ -	
F01781	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Jury Box		Fixed seating?	Y	N/A					n/a	$ -	
F01782	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Witness Stand		Fixed seating?	N	N/A					n/a	$ -	
F01783	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Door Gate		Kick plate?	Y	N/A					n/a	$ -	
F01784	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F01785	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Seating Area	Spectator	Number, aisle seats	14	N/A					n/a	$ -	
F01786	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Seating Area		Number, marked aisle seats	0	N/A					n/a	$ -	
F01787	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Seating Area	Spectator	Number, seats	72	N/A					n/a	$ -	
F01788	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Judge Bench		Raised location?	Y	N/A					n/a	$ -	
F01789	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Jury Box		Raised location?	Back row only	N/A					n/a	$ -	
F01790	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Witness Stand		Raised location?	Y	N/A					n/a	$ -	
F01797	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Jury Box		Ramp?	N	N/A					n/a	$ -	
F01827	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Seating Area	Spectator	Amplified sound?	Y	N/A					n/a	$ -	
F01828	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Counter		Approach type	F	N/A					n/a	$ -	
F01829	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Counter	Clerk	Approach type	S	N/A					n/a	$ -	
F01830	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Door Gate	Double door entrance	Approach type, pull	F	N/A					n/a	$ -	
F01831	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Door Gate	Double door entrance	Approach type, push	F	N/A					n/a	$ -	
F01832	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Seating Area	Spectator	Audible comm. Integral?	Y	N/A					n/a	$ -	
F01833	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Door Gate	Double door entrance	Closer?	Y	N/A					n/a	$ -	
F01834	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Alarm System		Dimension from ceiling	Ceiling mount	N/A					n/a	$ -	
F01835	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Judge Bench		Fixed seating?	N	N/A					n/a	$ -	
F01836	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Jury Box		Fixed seating?	Y	N/A					n/a	$ -	
F01837	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Witness Stand		Fixed seating?	N	N/A					n/a	$ -	
F01838	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Door Gate	Double door entrance	Kick plate?	Y	N/A					n/a	$ -	
F01839	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Door Gate	Double door entrance	Latch?	Y	N/A					n/a	$ -	
F01840	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Seating Area	Spectator	Number, aisle seats	8	N/A					n/a	$ -	
F01841	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Seating Area		Number, marked aisle seats	0	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F01842	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Seating Area	Spectator	Number, seats	46	N/A					n/a	$ -	
F01843	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Judge Bench		Raised location?	Y	N/A					n/a	$ -	
F01844	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Jury Box		Raised location?	Back row	N/A					n/a	$ -	
F01845	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Witness Stand		Raised location?	Y	N/A					n/a	$ -	
F01852	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Jury Box		Ramp?	N	N/A					n/a	$ -	
F01854	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01855	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01884	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Seating Area	Spectator	Amplified sound?	Y	N/A					n/a	$ -	
F01885	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Counter	Clerk	Approach type	S	N/A					n/a	$ -	
F01886	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01887	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F01888	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Seating Area	Spectator	Audible comm. Integral?	Y	N/A					n/a	$ -	
F01889	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F01890	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Judge Bench		Fixed seating?	N	N/A					n/a	$ -	
F01891	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Jury Box		Fixed seating?	Y	N/A					n/a	$ -	
F01892	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F01893	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Seating Area	Spectator	Number, aisle seats	8	N/A					n/a	$ -	
F01894	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Seating Area		Number, marked aisle seats	0	N/A					n/a	$ -	
F01895	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Seating Area	Spectator	Number, seats	46	N/A					n/a	$ -	
F01896	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Judge Bench		Raised location?	Y	N/A					n/a	$ -	
F01897	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Jury Box		Raised location?	Y	N/A					n/a	$ -	
F01898	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Seating Area	Spectator	Seating dispersed?	N	N/A					n/a	$ -	
F01904	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Jury Box		Ramp?	N	N/A					n/a	$ -	
F01905	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01906	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01931	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Seating Area	Spectator	Amplified sound?	Y	N/A					n/a	$ -	
F01932	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Counter	Clerk	Approach type	S	N/A					n/a	$ -	
F01933	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Wheelchair Space		Approach type	S	N/A					n/a	$ -	
F01934	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01935	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate	Jury entrance	Approach type, pull	F	N/A					n/a	$ -	
F01936	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F01937	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate	Jury entrance	Approach type, push	F	N/A					n/a	$ -	
F01938	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate	Jury entrance	Approach type, push	F	N/A					n/a	$ -	
F01939	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Seating Area	Spectator	Audible comm. Integral?	Y	N/A					n/a	$ -	
F01940	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F01941	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate	Jury entrance	Closer?	Y	N/A					n/a	$ -	
F01942	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Judge Bench		Fixed seating?	N	N/A					n/a	$ -	
F01943	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Jury Box		Fixed seating?	Y	N/A					n/a	$ -	
F01944	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Witness Stand		Fixed seating?	N	N/A					n/a	$ -	
F01945	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate	Jury entrance	Is a peep-hole provided?	N	N/A					n/a	$ -	
F01946	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F01947	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate	Jury entrance	Latch?	Y	N/A					n/a	$ -	
F01948	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Seating Area	Spectator	Number, aisle seats	6	N/A					n/a	$ -	
F01949	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Seating Area		Number, marked aisle seats	0	N/A					n/a	$ -	
F01950	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Seating Area	Spectator	Number, seats	40	N/A					n/a	$ -	
F01951	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Judge Bench		Raised location?	Y	N/A					n/a	$ -	
F01952	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Jury Box		Raised location?	Back row	N/A					n/a	$ -	
F01953	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Witness Stand		Raised location?	Y	N/A					n/a	$ -	
F01954	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Seating Area	Spectator	Seating dispersed?	N	N/A					n/a	$ -	
F01961	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Jury Box		Ramp?	N	N/A					n/a	$ -	
F01962	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F02002	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Seating Area	Spectator	Amplified sound?	Y	N/A					n/a	$ -	
F02003	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Counter	Clerk	Approach type	S	N/A					n/a	$ -	
F02004	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F02005	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F02006	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F02007	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F02008	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Seating Area	Spectator	Audible comm. Integral?	Y	N/A					n/a	$ -	
F02009	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F02010	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F02011	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Judge Bench		Fixed seating?	N	N/A					n/a	$ -	
F02012	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Jury Box		Fixed seating?	Y	N/A					n/a	$ -	
F02013	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F02014	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F02015	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Seating Area		Number, aisle seats	6	N/A					n/a	$ -	
F02016	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Seating Area		Number, marked aisle seats	0	N/A					n/a	$ -	
F02017	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Seating Area		Number, seats	40	N/A					n/a	$ -	
F02018	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Judge Bench		Raised location?	Y	N/A					n/a	$ -	
F02019	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Jury Box		Raised location?	Back row	N/A					n/a	$ -	
F02020	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Seating Area		Seating dispersed?	N	N/A					n/a	$ -	
F02026	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Jury Box		Ramp?	N	N/A					n/a	$ -	
F02062	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Seating Area	Spectator	Amplified sound?	Y	N/A					n/a	$ -	
F02063	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Counter	Clerk	Approach type	S	N/A					n/a	$ -	
F02064	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Wheelchair Space	Spectator	Approach type	F	N/A					n/a	$ -	
F02065	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F02066	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	2nd set in series	Approach type, pull	F	N/A					n/a	$ -	
F02067	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Court staff entrance	Approach type, pull	F	N/A					n/a	$ -	
F02068	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Jury entrance	Approach type, pull	F	N/A					n/a	$ -	
F02069	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F02070	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	2nd set in series	Approach type, push	F	N/A					n/a	$ -	
F02071	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Court staff entrance	Approach type, push	F	N/A					n/a	$ -	
F02072	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Jury entrance	Approach type, push	F	N/A					n/a	$ -	
F02073	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F02074	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	2nd set in series	Closer?	Y	N/A					n/a	$ -	
F02075	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Court staff entrance	Closer?	Y	N/A					n/a	$ -	
F02076	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Jury entrance	Closer?	Y	N/A					n/a	$ -	
F02077	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Alarm System		Dimension from ceiling	Ceiling mount	N/A					n/a	$ -	
F02078	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Courtroom Station		Fixed seating?	N	N/A					n/a	$ -	
F02079	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Judge Bench		Fixed seating?	N	N/A					n/a	$ -	
F02080	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Jury Box		Fixed seating?	Y	N/A					n/a	$ -	
F02081	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Witness Stand		Fixed seating?	N	N/A					n/a	$ -	
F02082	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	2nd set in series	Height, peep-hole	51	N/A					n/a	$ -	
F02083	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Court staff entrance	Height, peep-hole	61.5	N/A					n/a	$ -	
F02084	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F02085	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	2nd set in series	Is a peep-hole provided?	Window	N/A					n/a	$ -	
F02086	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Court staff entrance	Is a peep-hole provided?	Y	N/A					n/a	$ -	
F02087	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Jury entrance	Is a peep-hole provided?	N	N/A					n/a	$ -	
F02088	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F02089	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	2nd set in series	Latch?	N	N/A					n/a	$ -	
F02090	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Court staff entrance	Latch?	Y	N/A					n/a	$ -	
F02091	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Jury entrance	Latch?	Y	N/A					n/a	$ -	
F02092	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Seating Area		Number, aisle seats	0	N/A					n/a	$ -	
F02093	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Seating Area		Number, marked aisle seats	0	N/A					n/a	$ -	
F02094	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Seating Area		Number, seats	54	N/A					n/a	$ -	
F02095	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Courtroom Station		Raised location?	Y	N/A					n/a	$ -	
F02096	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Judge Bench		Raised location?	Y	N/A					n/a	$ -	
F02097	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Jury Box		Raised location?	Back row	N/A					n/a	$ -	
F02098	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Witness Stand		Raised location?	Y	N/A					n/a	$ -	
F02111	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Jury Box		Ramp?	N	N/A					n/a	$ -	
F02167	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Circulation Path		Adjacent pathway?	N	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F02168	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Seating Area	Spectator	Amplified sound?	Y	N/A					n/a	$ -	
F02169	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Counter		Approach type	S	N/A					n/a	$ -	
F02170	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Wheelchair Space		Approach type	F	N/A					n/a	$ -	
F02171	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F02172	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	2nd set in series	Approach type, pull	F	N/A					n/a	$ -	
F02173	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F02174	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	Court staff entrance	Approach type, pull	F	N/A					n/a	$ -	
F02175	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F02176	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	2nd set in series	Approach type, push	F	N/A					n/a	$ -	
F02177	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F02178	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	Court staff entrance	Approach type, push	F	N/A					n/a	$ -	
F02179	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Seating Area	Spectator	Audible comm. Integral?	Y	N/A					n/a	$ -	
F02180	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F02181	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	2nd set in series	Closer?	Y	N/A					n/a	$ -	
F02182	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F02183	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	Court staff entrance	Closer?	Y	N/A					n/a	$ -	
F02184	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Courtroom Station		Fixed seating?	N	N/A					n/a	$ -	
F02185	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Judge Bench		Fixed seating?	N	N/A					n/a	$ -	
F02186	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Witness Stand		Fixed seating?	N	N/A					n/a	$ -	
F02187	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Aisle Seat		Folding/removable armrest?	None	N/A					n/a	$ -	
F02188	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	2nd set in series	Height, peep-hole	51	N/A					n/a	$ -	
F02189	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	Court staff entrance	Height, peep-hole	62	N/A					n/a	$ -	
F02190	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F02191	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	2nd set in series	Is a peep-hole provided?	Window	N/A					n/a	$ -	
F02192	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F02193	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	Court staff entrance	Is a peep-hole provided?	Y	N/A					n/a	$ -	
F02194	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Aisle Seat		ISA?	N	N/A					n/a	$ -	
F02195	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F02196	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	2nd set in series	Latch?	N	N/A					n/a	$ -	
F02197	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F02198	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	Court staff entrance	Latch?	Y	N/A					n/a	$ -	
F02199	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Seating Area		Number, aisle seats	0	N/A					n/a	$ -	
F02200	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Seating Area		Number, marked aisle seats	0	N/A					n/a	$ -	
F02201	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Seating Area		Number, seats	40	N/A					n/a	$ -	
F02202	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Courtroom Station		Raised location?	Y	N/A					n/a	$ -	
F02203	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Judge Bench		Raised location?	Y	N/A					n/a	$ -	
F02204	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Witness Stand		Raised location?	Y	N/A					n/a	$ -	
F02294	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 511	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F02295	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 511	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F02296	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 511	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F02297	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 511	2-Public Supervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F02298	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 511	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F02309	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Circulation Path		Adjacent pathway?	N	N/A					n/a	$ -	
F02310	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Seating Area	Spectator	Amplified sound?	Y	N/A					n/a	$ -	
F02311	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Counter		Approach type	S	N/A					n/a	$ -	
F02312	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Wheelchair Space		Approach type	F	N/A					n/a	$ -	
F02313	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F02314	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	2nd set in series	Approach type, pull	F	N/A					n/a	$ -	
F02315	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	Court staff entrance	Approach type, pull	F	N/A					n/a	$ -	
F02316	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F02317	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	2nd set in series	Approach type, push	F	N/A					n/a	$ -	
F02318	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	Court staff entrance	Approach type, push	F	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F02319	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Seating Area	Spectator	Audible comm. Integral?	Y	N/A					n/a	$ -	
F02320	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F02321	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	2nd set in series	Closer?	Y	N/A					n/a	$ -	
F02322	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	Court staff entrance	Closer?	Y	N/A					n/a	$ -	
F02323	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Courtroom Station		Fixed seating?	N	N/A					n/a	$ -	
F02324	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Judge Bench		Fixed seating?	N	N/A					n/a	$ -	
F02325	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Witness Stand		Fixed seating?	N	N/A					n/a	$ -	
F02326	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Aisle Seat		Folding/removable armrest?	None	N/A					n/a	$ -	
F02327	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	Court staff entrance	Height, peep-hole	61	N/A					n/a	$ -	
F02328	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F02329	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	2nd set in series	Is a peep-hole provided?	Window	N/A					n/a	$ -	
F02330	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	Court staff entrance	Is a peep-hole provided?	Y	N/A					n/a	$ -	
F02331	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Aisle Seat		ISA?	N	N/A					n/a	$ -	
F02332	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F02333	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	2nd set in series	Latch?	N	N/A					n/a	$ -	
F02334	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	Court staff entrance	Latch?	Y	N/A					n/a	$ -	
F02335	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Seating Area		Number, aisle seats	0	N/A					n/a	$ -	
F02336	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Seating Area		Number, marked aisle seats	0	N/A					n/a	$ -	
F02337	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Seating Area		Number, seats	20	N/A					n/a	$ -	
F02338	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Courtroom Station		Raised location?	Y	N/A					n/a	$ -	
F02339	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Judge Bench		Raised location?	Y	N/A					n/a	$ -	
F02340	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Witness Stand		Raised location?	N	N/A					n/a	$ -	
F02410	Justice Center		5th Floor	Owned	Courtroom	#503 - Room 507	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F02411	Justice Center		5th Floor	Owned	Courtroom	#503 - Room 507	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F02412	Justice Center		5th Floor	Owned	Courtroom	#503 - Room 507	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F02413	Justice Center		5th Floor	Owned	Courtroom	#503 - Room 507	2-Public Supervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F02414	Justice Center		5th Floor	Owned	Courtroom	#503 - Room 507	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F02430	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Circulation Path		Adjacent pathway?	N	N/A					n/a	$ -	
F02431	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Seating Area	Spectator	Amplified sound?	Y	N/A					n/a	$ -	
F02432	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Counter		Approach type	S	N/A					n/a	$ -	
F02433	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Wheelchair Space		Approach type	S	N/A					n/a	$ -	
F02434	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Court staff entrance	Approach type, pull	F	N/A					n/a	$ -	
F02435	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Jury entrance	Approach type, pull	F	N/A					n/a	$ -	
F02436	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	2nd set in series	Approach type, pull	F	N/A					n/a	$ -	
F02437	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Double door entrance	Approach type, pull	F	N/A					n/a	$ -	
F02438	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Court staff entrance	Approach type, push	F	N/A					n/a	$ -	
F02439	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Jury entrance	Approach type, push	F	N/A					n/a	$ -	
F02440	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	2nd set in series	Approach type, push	F	N/A					n/a	$ -	
F02441	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Double door entrance	Approach type, push	F	N/A					n/a	$ -	
F02442	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Seating Area	Spectator	Audible comm. Integral?	Y	N/A					n/a	$ -	
F02443	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Court staff entrance	Closer?	Y	N/A					n/a	$ -	
F02444	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Jury entrance	Closer?	Y	N/A					n/a	$ -	
F02445	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	2nd set in series	Closer?	Y	N/A					n/a	$ -	
F02446	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Double door entrance	Closer?	Y	N/A					n/a	$ -	
F02447	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Courtroom Station		Fixed seating?	N	N/A					n/a	$ -	
F02448	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Judge Bench		Fixed seating?	N	N/A					n/a	$ -	
F02449	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Jury Box		Fixed seating?	Y	N/A					n/a	$ -	
F02450	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Witness Stand		Fixed seating?	N	N/A					n/a	$ -	
F02451	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Aisle Seat		Folding/removable armrest?	None	N/A					n/a	$ -	
F02452	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Court staff entrance	Height, peep-hole	61.25	N/A					n/a	$ -	
F02453	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	2nd set in series	Height, peep-hole	51	N/A					n/a	$ -	
F02454	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Court staff entrance	Is a peep-hole provided?	Y	N/A					n/a	$ -	
F02455	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Jury entrance	Is a peep-hole provided?	N	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F02456	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	2nd set in series	Is a peep-hole provided?	Window	N/A					n/a	$ -	
F02457	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Double door entrance	Is a peep-hole provided?	N	N/A					n/a	$ -	
F02458	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Aisle Seat		ISA?	N	N/A					n/a	$ -	
F02459	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Court staff entrance	Kick plate?	Y	N/A					n/a	$ -	
F02460	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Court staff entrance	Latch?	Y	N/A					n/a	$ -	
F02461	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Jury entrance	Latch?	Y	N/A					n/a	$ -	
F02462	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	2nd set in series	Latch?	N	N/A					n/a	$ -	
F02463	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Double door entrance	Latch?	N	N/A					n/a	$ -	
F02464	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Seating Area		Number, aisle seats	0	N/A					n/a	$ -	
F02465	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Seating Area		Number, marked aisle seats	0	N/A					n/a	$ -	
F02466	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Seating Area		Number, seats	54	N/A					n/a	$ -	
F02467	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Courtroom Station		Raised location?	Y	N/A					n/a	$ -	
F02468	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Judge Bench		Raised location?	Y	N/A					n/a	$ -	
F02469	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Jury Box		Raised location?	N	N/A					n/a	$ -	
F02470	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Witness Stand		Raised location?	Y	N/A					n/a	$ -	
F02489	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Jury Box		Ramp?	N	N/A					n/a	$ -	
F02560	Justice Center		5th Floor	Owned	Courtroom	#504 - Room 551	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F02561	Justice Center		5th Floor	Owned	Courtroom	#504 - Room 551	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F02562	Justice Center		5th Floor	Owned	Courtroom	#504 - Room 551	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F02563	Justice Center		5th Floor	Owned	Courtroom	#504 - Room 551	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F02574	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S505	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F02575	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S505	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F02576	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S505	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F02577	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S505	2-Public Supervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F02578	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S505	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F02595	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S507	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F02596	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S507	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F02597	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S507	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F02598	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S507	2-Public Supervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F02599	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S507	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F02615	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Circulation Path		Adjacent pathway?	N	N/A					n/a	$ -	
F02616	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Seating Area	Spectator	Amplified sound?	Y	N/A					n/a	$ -	
F02617	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Counter		Approach type	S	N/A					n/a	$ -	
F02618	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Wheelchair Space		Approach type	F	N/A					n/a	$ -	
F02619	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	2nd set in series	Approach type, pull	F	N/A					n/a	$ -	
F02620	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Double door entrance	Approach type, pull	F	N/A					n/a	$ -	
F02621	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F02622	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Jury entrance	Approach type, pull	F	N/A					n/a	$ -	
F02623	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	2nd set in series	Approach type, push	F	N/A					n/a	$ -	
F02624	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Double door entrance	Approach type, push	F	N/A					n/a	$ -	
F02625	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F02626	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Jury entrance	Approach type, push	F	N/A					n/a	$ -	
F02627	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Seating Area	Spectator	Audible comm. Integral?	Y	N/A					n/a	$ -	
F02628	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	2nd set in series	Closer?	Y	N/A					n/a	$ -	
F02629	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Double door entrance	Closer?	Y	N/A					n/a	$ -	
F02630	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F02631	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Jury entrance	Closer?	Y	N/A					n/a	$ -	
F02632	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Courtroom Station		Fixed seating?	N	N/A					n/a	$ -	
F02633	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Judge Bench		Fixed seating?	N	N/A					n/a	$ -	
F02634	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Jury Box		Fixed seating?	Y	N/A					n/a	$ -	
F02635	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Witness Stand		Fixed seating?	N	N/A					n/a	$ -	
F02636	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate		Height, peep-hole	61.25	N/A					n/a	$ -	
F02637	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Double door entrance	Is a peep-hole provided?	N	N/A					n/a	$ -	
F02638	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate		Is a peep-hole provided?	Y	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F02639	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Jury entrance	Is a peep-hole provided?	N	N/A					n/a	$ -	
F02640	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	2nd set in series	Latch?	N	N/A					n/a	$ -	
F02641	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Double door entrance	Latch?	Y	N/A					n/a	$ -	
F02642	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F02643	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Jury entrance	Latch?	Y	N/A					n/a	$ -	
F02644	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Seating Area		Number, aisle seats	0	N/A					n/a	$ -	
F02645	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Seating Area		Number, marked aisle seats	0	N/A					n/a	$ -	
F02646	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Seating Area		Number, seats	40	N/A					n/a	$ -	
F02647	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Courtroom Station		Raised location?	Y	N/A					n/a	$ -	
F02648	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Judge Bench		Raised location?	Y	N/A					n/a	$ -	
F02649	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Jury Box		Raised location?	N	N/A					n/a	$ -	
F02650	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Witness Stand		Raised location?	Y	N/A					n/a	$ -	
F02665	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Jury Box		Ramp?	N	N/A					n/a	$ -	
F02744	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Seating Area	Spectator	Amplified sound?	Y	N/A					n/a	$ -	
F02745	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Counter		Approach type	F	N/A					n/a	$ -	
F02746	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Wheelchair Space		Approach type	S	N/A					n/a	$ -	
F02747	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Alarm System		Dimension from ceiling	Ceiling mount	N/A					n/a	$ -	
F02748	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Counter		Dimension, knee clearance	0	N/A					n/a	$ -	
F02749	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Protrusion		Dimension, protruding	None	N/A					n/a	$ -	
F02750	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Courtroom Station		Fixed seating?	N	N/A					n/a	$ -	
F02751	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Judge Bench		Fixed seating?	N	N/A					n/a	$ -	
F02752	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Jury Box		Fixed seating?	Y	N/A					n/a	$ -	
F02753	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Witness Stand		Fixed seating?	N	N/A					n/a	$ -	
F02754	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Aisle Seat		Folding/removable armrest?	None	N/A					n/a	$ -	
F02755	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Seating Area		Number, aisle seats	N	N/A					n/a	$ -	
F02756	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Seating Area		Number, marked aisle seats	None	N/A					n/a	$ -	
F02757	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Seating Area		Number, seats	42	N/A					n/a	$ -	
F02758	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Courtroom Station		Raised location?	Y	N/A					n/a	$ -	
F02759	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Judge Bench		Raised location?	Y	N/A					n/a	$ -	
F02760	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Jury Box		Raised location?	N	N/A					n/a	$ -	
F02761	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Witness Stand		Raised location?	Y	N/A					n/a	$ -	
F02766	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Jury Box		Ramp?	N	N/A					n/a	$ -	
F02791	Justice Center		5th Floor	Owned	Courtroom	#507 - Employee Entrance	2-Public Supervised	Door Gate		Clearance, series doors	None	N/A					n/a	$ -	
F02792	Justice Center		5th Floor	Owned	Courtroom	#507 - Employee Entrance	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F02793	Justice Center		5th Floor	Owned	Courtroom	#507 - Employee Entrance	2-Public Supervised	Door Gate		Height, peep-hole	62	N/A					n/a	$ -	
F02794	Justice Center		5th Floor	Owned	Courtroom	#507 - Employee Entrance	2-Public Supervised	Door Gate		Is a peep-hole provided?	Y	N/A					n/a	$ -	
F02808	Justice Center		5th Floor	Owned	Courtroom	#507 - Juror Entrance	2-Public Supervised	Door Gate		Approach type, pull	Y	N/A					n/a	$ -	
F02809	Justice Center		5th Floor	Owned	Courtroom	#507 - Juror Entrance	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F02810	Justice Center		5th Floor	Owned	Courtroom	#507 - Juror Entrance	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F02822	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S511	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F02823	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S511	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F02835	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate		Approach type, pull	Y	N/A					n/a	$ -	
F02836	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F02837	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate	2nd set in series	Closer?	Y	N/A					n/a	$ -	
F02838	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate		Height, peep-hole	None	N/A					n/a	$ -	
F02839	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F02840	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate		Latch?	N	N/A					n/a	$ -	
F02869	Justice Center		6th Floor	Owned	Courtroom	#601	2-Public Supervised	Judge Bench		Fixed seating?	N	N/A					n/a	$ -	
F02874	Justice Center		6th Floor	Owned	Courtroom	#602	2-Public Supervised	Seating Area	Spectator	Amplified sound?	Y	N/A					n/a	$ -	
F02875	Justice Center		6th Floor	Owned	Courtroom	#602	2-Public Supervised	Judge Bench		Fixed seating?	N	N/A					n/a	$ -	
F02876	Justice Center		6th Floor	Owned	Courtroom	#602	2-Public Supervised	Jury Box		Fixed seating?	Y	N/A					n/a	$ -	
F02877	Justice Center		6th Floor	Owned	Courtroom	#602	2-Public Supervised	Seating Area		Number, seats	45	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F02878	Justice Center		6th Floor	Owned	Courtroom	#602	2-Public Supervised	Judge Bench		Raised location?	Y	N/A					n/a	$ -	
F02879	Justice Center		6th Floor	Owned	Courtroom	#602	2-Public Supervised	Jury Box		Raised location?	Back row only	N/A					n/a	$ -	
F02880	Justice Center		6th Floor	Owned	Courtroom	#602	2-Public Supervised	Jury Box		Raised location?	13	N/A					n/a	$ -	
F02881	Justice Center		6th Floor	Owned	Courtroom	#602	2-Public Supervised	Witness Stand		Raised location?	Y	N/A					n/a	$ -	
F02882	Justice Center		6th Floor	Owned	Courtroom	#602	2-Public Supervised	Seating Area		Seating dispersed?	OK	N/A					n/a	$ -	
F02886	Justice Center		6th Floor	Owned	Courtroom	#602	2-Public Supervised	Jury Box		Ramp?	N	N/A					n/a	$ -	
F02890	Justice Center		6th Floor	Owned	Courtroom	#603	2-Public Supervised	Courtroom Station		Fixed seating?	N	N/A					n/a	$ -	
F02891	Justice Center		6th Floor	Owned	Courtroom	#603	2-Public Supervised	Judge Bench		Fixed seating?	N	N/A					n/a	$ -	
F02895	Justice Center		6th Floor	Owned	Courtroom	#604	2-Public Supervised	Seating Area	Spectator	Amplified sound?	Y	N/A					n/a	$ -	
F02896	Justice Center		6th Floor	Owned	Courtroom	#604	2-Public Supervised	Witness Stand		Fixed seating?	N	N/A					n/a	$ -	
F02897	Justice Center		6th Floor	Owned	Courtroom	#604	2-Public Supervised	Door Gate		Height, peep-hole	61	N/A					n/a	$ -	
F02898	Justice Center		6th Floor	Owned	Courtroom	#604	2-Public Supervised	Seating Area		Number, aisle seats	2	N/A					n/a	$ -	
F02899	Justice Center		6th Floor	Owned	Courtroom	#604	2-Public Supervised	Seating Area		Number, marked aisle seats	0	N/A					n/a	$ -	
F02900	Justice Center		6th Floor	Owned	Courtroom	#604	2-Public Supervised	Seating Area		Number, seats	32	N/A					n/a	$ -	
F02901	Justice Center		6th Floor	Owned	Courtroom	#604	2-Public Supervised	Judge Bench		Raised location?	Y	N/A					n/a	$ -	
F02902	Justice Center		6th Floor	Owned	Courtroom	#604	2-Public Supervised	Jury Box		Raised location?	None	N/A					n/a	$ -	
F02903	Justice Center		6th Floor	Owned	Courtroom	#604	2-Public Supervised	Witness Stand		Raised location?	Y	N/A					n/a	$ -	
F02904	Justice Center		6th Floor	Owned	Courtroom	#604	2-Public Supervised	Seating Area		Seating dispersed?	OK	N/A					n/a	$ -	
F02911	Justice Center		6th Floor	Owned	Courtroom	#605	2-Public Supervised	Courtroom Station		Fixed seating?	N	N/A					n/a	$ -	
F02915	Justice Center		6th Floor	Owned	Courtroom	#605	2-Public Supervised	Jury Box		Ramp?	N	N/A					n/a	$ -	
F02916	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Seating Area	Spectator	Amplified sound?	Y	N/A					n/a	$ -	
F02917	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Counter	Check-in	Approach type	S	N/A					n/a	$ -	
F02918	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Door Gate	Court staff entrance	Approach type, pull	F	N/A					n/a	$ -	
F02919	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Door Gate	Court staff entrance	Approach type, push	F	N/A					n/a	$ -	
F02920	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Door Gate	Court staff entrance	Closer?	Y	N/A					n/a	$ -	
F02921	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Alarm System		Dimension from ceiling	Ceiling mount	N/A					n/a	$ -	
F02922	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Judge Bench		Fixed seating?	N	N/A					n/a	$ -	
F02923	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Jury Box		Fixed seating?	Y	N/A					n/a	$ -	
F02924	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Witness Stand		Fixed seating?	N	N/A					n/a	$ -	
F02925	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Other Element	Public Seating	Height	16.5	N/A					n/a	$ -	
F02926	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Door Gate	Court staff entrance	Kick plate?	Y	N/A					n/a	$ -	
F02927	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Door Gate	Court staff entrance	Latch?	N	N/A					n/a	$ -	
F02928	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Seating Area		Number, marked aisle seats	0	N/A					n/a	$ -	
F02929	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Seating Area		Number, seats	46	N/A					n/a	$ -	
F02930	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Other Element	Public Seating	Other attribute	15	N/A					n/a	$ -	
F02931	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Other Element	Public Seating	Other attribute	18	N/A					n/a	$ -	
F02932	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Other Element	Public Seating	Other attribute	No side transfer	N/A					n/a	$ -	
F02933	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Judge Bench		Raised location?	Y	N/A					n/a	$ -	
F02934	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Jury Box		Raised location?	Back row only	N/A					n/a	$ -	
F02935	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Witness Stand		Raised location?	Y	N/A					n/a	$ -	
F02936	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Seating Area		Seating dispersed?	N	N/A					n/a	$ -	
F02941	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Jury Box		Ramp?	N	N/A					n/a	$ -	
F03166	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Handrail		Continuous?	N	N/A					n/a	$ -	
F03167	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Handrail		Cross section type	Round	N/A					n/a	$ -	
F03168	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Elevator Door		Location	Center	N/A					n/a	$ -	
F03169	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Position Indicators		Location	Above door	N/A					n/a	$ -	
F03218	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Elevator Door		Location	Center	N/A					n/a	$ -	
F03259	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Handrail		Continuous?	N	N/A					n/a	$ -	
F03260	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Elevator Door		Location	Center	N/A					n/a	$ -	
F03297	Justice Center		Interior	Owned	Elevator	North	2-Public Supervised	Elevator Car		Height, level change	None	N/A					n/a	$ -	
F03302	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Elevator Door		Location	Center	N/A					n/a	$ -	
F03331	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Elevator Car		Height, level change	None	N/A					n/a	$ -	
F03332	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Elevator Door		Location	Center	N/A					n/a	$ -	
F03367	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Handrail		Continuous?	N	N/A					n/a	$ -	
F03368	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Elevator Door		Location	Center	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F03408	Justice Center		Interior	Owned	Elevator		3-Employee Common	Elevator Door	Door #401 from Staff Area 405	Other attribute	Rear entry to elevator	N/A					n/a	$ -	
F03819	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room A	Approach type, pull	F	N/A					n/a	$ -	
F03820	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room B	Approach type, pull	F	N/A					n/a	$ -	
F03821	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room A	Approach type, push	H	N/A					n/a	$ -	
F03822	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room B	Approach type, push	H	N/A					n/a	$ -	
F03823	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room A	Closer?	Y	N/A					n/a	$ -	
F03824	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room B	Closer?	Y	N/A					n/a	$ -	
F03825	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room A	Latch?	Y	N/A					n/a	$ -	
F03826	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room B	Latch?	Y	N/A					n/a	$ -	
F03854	Justice Center	CASA	Interior	Owned	Hallway	#152 - Office	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F03855	Justice Center	CASA	Interior	Owned	Hallway	#152 - Office	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F03856	Justice Center	CASA	Interior	Owned	Hallway	#152 - Office	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F03857	Justice Center	CASA	Interior	Owned	Hallway	#152 - Office	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F03873	Justice Center	Self Help Resource Center	1st Floor	Owned	Hallway	Training Room	1-Public Unsupervised	Alarm System		Dimension from ceiling	30.5	N/A					n/a	$ -	
F03874	Justice Center	Self Help Resource Center	Interior	Owned	Hallway	Training Room	1-Public Unsupervised	Other Element	Changing station	Height	44	N/A					n/a	$ -	
F03875	Justice Center	Self Help Resource Center	Interior	Owned	Hallway	Training Room	1-Public Unsupervised	Other Element		Other attribute	N	N/A					n/a	$ -	
F03886	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F03887	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F03888	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F03889	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F03890	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Height, peep-hole	62	N/A					n/a	$ -	
F03891	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F03892	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F03893	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F03914	Justice Center		4th Floor	Owned	Hallway	#S412 - Back hall entrance	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F03915	Justice Center		4th Floor	Owned	Hallway	#S412 - Back hall entrance	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F03916	Justice Center		4th Floor	Owned	Hallway	#S412 - Back hall entrance	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F03917	Justice Center		4th Floor	Owned	Hallway	#S412 - Back hall entrance	3-Employee Common	Door Gate		Height, peep-hole	62	N/A					n/a	$ -	
F03918	Justice Center		4th Floor	Owned	Hallway	#S412 - Back hall entrance	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F03928	Justice Center		4th Floor	Owned	Hallway	#S418 - Back hall entrance	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F03929	Justice Center		4th Floor	Owned	Hallway	#S418 - Back hall entrance	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F03930	Justice Center		4th Floor	Owned	Hallway	#S418 - Back hall entrance	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F03931	Justice Center		4th Floor	Owned	Hallway	#S418 - Back hall entrance	2-Public Supervised	Door Gate		Height, peep-hole	62	N/A					n/a	$ -	
F03932	Justice Center		4th Floor	Owned	Hallway	#S418 - Back hall entrance	2-Public Supervised	Door Gate		Is a peep-hole provided?	Y	N/A					n/a	$ -	
F03933	Justice Center		4th Floor	Owned	Hallway	#S418 - Back hall entrance	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F03943	Justice Center		4th Floor	Owned	Hallway	#S437 - Back hall entrance	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F03944	Justice Center		4th Floor	Owned	Hallway	#S437 - Back hall entrance	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F03945	Justice Center		4th Floor	Owned	Hallway	#S437 - Back hall entrance	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F03946	Justice Center		4th Floor	Owned	Hallway	#S437 - Back hall entrance	2-Public Supervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F03947	Justice Center		4th Floor	Owned	Hallway	#S437 - Back hall entrance	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F03958	Justice Center		6th Floor	Owned	Hallway	Between restrooms	1-Public Unsupervised	Drinking Fountain		High-low fountain?	Y	N/A					n/a	$ -	
F03974	Justice Center		3rd Floor	Owned	Hallway	Between rooms #354 & #355	1-Public Unsupervised	Drinking Fountain		High-low fountain?	Y	N/A					n/a	$ -	
F03981	Justice Center		4th Floor	Owned	Hallway	Between rooms #410 & #411	1-Public Unsupervised	Protrusion	Drinking Fountain	Height	28	N/A					n/a	$ -	
F03982	Justice Center		4th Floor	Owned	Hallway	Between rooms #410 & #411	1-Public Unsupervised	Drinking Fountain		High-low fountain?	Y	N/A					n/a	$ -	
F03991	Justice Center		4th Floor	Owned	Hallway	Between rooms #454 & #455	1-Public Unsupervised	Protrusion		Height	27.75	N/A					n/a	$ -	
F03992	Justice Center		4th Floor	Owned	Hallway	Between rooms #454 & #455	1-Public Unsupervised	Drinking Fountain		High-low fountain?	Y	N/A					n/a	$ -	
F04000	Justice Center		5th Floor	Owned	Hallway	Between rooms #504 & #505	1-Public Unsupervised	Drinking Fountain		High-low fountain?	Y	N/A					n/a	$ -	
F04008	Justice Center		6th Floor	Owned	Hallway	Between rooms #616 & #617	1-Public Unsupervised	Drinking Fountain		High-low fountain?	Y	N/A					n/a	$ -	
F04023	Justice Center		4th Floor	Owned	Hallway	Between rooms #S403 & #S404	1-Public Unsupervised	Drinking Fountain		High-low fountain?	Y	N/A					n/a	$ -	
F04031	Justice Center		5th Floor	Owned	Hallway	Employee entrance	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F04032	Justice Center		5th Floor	Owned	Hallway	Employee entrance	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F04033	Justice Center		5th Floor	Owned	Hallway	Employee entrance	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F04034	Justice Center		5th Floor	Owned	Hallway	Employee entrance	3-Employee Common	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F04035	Justice Center		5th Floor	Owned	Hallway	Employee entrance	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F04046	Justice Center		5th Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain		High-low fountain?	Y	N/A					n/a	$ -	
F04047	Justice Center		Interior	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Between rooms #224 & #225	High-low fountain?	Y	N/A					n/a	$ -	
F04116	Justice Center		Interior	Owned	Holding Cell	Adult Female #4	2-Public Supervised	Holding Specifications		Cell type	AF	N/A					n/a	$ -	
F04137	Justice Center		Interior	Owned	Holding Cell	Adult Male #1	2-Public Supervised	Holding Specifications		Cell type	Male/female	N/A					n/a	$ -	
F04157	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Holding Specifications		Cell type	Juvenile	N/A					n/a	$ -	
F04158	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Holding Specifications		Cell type	Juvenile	N/A					n/a	$ -	
F04159	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Water Closet		Location, flush control	Rear wall	N/A					n/a	$ -	
F04160	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Water Closet		Location, flush control	Rear wall	N/A					n/a	$ -	
F04254	Justice Center	Self Help Resource Center	1st Floor	Owned	Kitchen	#159 - Training Room	1-Public Unsupervised	Counter		Approach type	S	N/A					n/a	$ -	
F04255	Justice Center	Self Help Resource Center	1st Floor	Owned	Kitchen	#159 - Training Room	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F04256	Justice Center	Self Help Resource Center	1st Floor	Owned	Kitchen	#159 - Training Room	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F04257	Justice Center	Self Help Resource Center	1st Floor	Owned	Kitchen	#159 - Training Room	1-Public Unsupervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F04258	Justice Center	Self Help Resource Center	1st Floor	Owned	Kitchen	#159 - Training Room	1-Public Unsupervised	Counter		Dimension, knee clearance	0	N/A					n/a	$ -	
F04259	Justice Center	Self Help Resource Center	1st Floor	Owned	Kitchen	#159 - Training Room	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	0	N/A					n/a	$ -	
F04260	Justice Center	Self Help Resource Center	1st Floor	Owned	Kitchen	#159 - Training Room	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F04401	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception	Training Room	1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F04402	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception	Training Room	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F04403	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception	Training Room	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F04404	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception	Training Room	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F04405	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception	Training Room	1-Public Unsupervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F04406	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception	Training Room	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F04422	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F04432	Justice Center		Interior	Owned	Lobby Reception	Court Clerk	2-Public Supervised	Counter		Approach type	F	N/A					n/a	$ -	
F04438	Justice Center		Interior	Owned	Lobby Reception	Court Clerk 6	2-Public Supervised	Counter		Approach type	F	N/A					n/a	$ -	
F04444	Justice Center		5th Floor	Owned	Lobby Reception	Family Court Facilitator	1-Public Unsupervised	Counter	Check-in	Approach type	F	N/A					n/a	$ -	
F04450	Justice Center		Interior	Owned	Lobby Reception	Interior Series Door	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F04451	Justice Center		Interior	Owned	Lobby Reception	Interior Series Door	1-Public Unsupervised	Door Gate		Approach type, push	H	N/A					n/a	$ -	
F04452	Justice Center		Interior	Owned	Lobby Reception	Interior Series Door	1-Public Unsupervised	Door Gate		Clearance, push parallel	OK	N/A					n/a	$ -	
F04453	Justice Center		Interior	Owned	Lobby Reception	Interior Series Door	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F04454	Justice Center		Interior	Owned	Lobby Reception	Interior Series Door	1-Public Unsupervised	Door Gate		Kick plate?	Y	N/A					n/a	$ -	
F04455	Justice Center		Interior	Owned	Lobby Reception	Interior Series Door	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F04466	Justice Center		Interior	Owned	Lobby Reception	Jury check-in	1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F04472	Justice Center		Interior	Owned	Lobby Reception	Self Pay Center	1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F04703	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F04704	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Door Gate		Approach type, push	L	N/A					n/a	$ -	
F04705	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F04706	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F04707	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Signage		ISA?	N	N/A					n/a	$ -	
F04708	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Door Gate		Kick plate?	Y	N/A					n/a	$ -	
F04709	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Door Gate		Latch?	N	N/A					n/a	$ -	
F04710	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Coat Hook		Over obstruction?	N	N/A					n/a	$ -	
F04734	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F04735	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F04736	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F04737	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F04738	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F04739	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F04740	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F04741	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F04742	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Signage		ISA?	N	N/A					n/a	$ -	
F04743	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Kick plate?	Y	N/A					n/a	$ -	
F04744	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Latch?	N	N/A					n/a	$ -	
F04745	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Coat Hook		Over obstruction?	N	N/A					n/a	$ -	
F05095	Justice Center		5th Floor	Owned	Other Room	#501 - Room 516	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F05096	Justice Center		5th Floor	Owned	Other Room	#501 - Room 516	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F05097	Justice Center		5th Floor	Owned	Other Room	#501 - Room 516	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F05098	Justice Center		5th Floor	Owned	Other Room	#501 - Room 516	2-Public Supervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F05099	Justice Center		5th Floor	Owned	Other Room	#501 - Room 516	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F05115	Justice Center		5th Floor	Owned	Other Room	#501 - Room 517	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05116	Justice Center		5th Floor	Owned	Other Room	#501 - Room 517	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F05117	Justice Center		5th Floor	Owned	Other Room	#501 - Room 517	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F05118	Justice Center		5th Floor	Owned	Other Room	#501 - Room 517	2-Public Supervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F05119	Justice Center		5th Floor	Owned	Other Room	#501 - Room 517	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F05135	Justice Center		6th Floor	Owned	Other Room	#S611	1-Public Unsupervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F05138	Justice Center		5th Floor	Owned	Other Room	Domestic check-in	1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F05139	Justice Center		5th Floor	Owned	Other Room	Domestic check-in	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F05140	Justice Center		5th Floor	Owned	Other Room	Domestic check-in	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F05141	Justice Center		5th Floor	Owned	Other Room	Domestic check-in	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F05142	Justice Center		5th Floor	Owned	Other Room	Domestic check-in	1-Public Unsupervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F05143	Justice Center		5th Floor	Owned	Other Room	Domestic check-in	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F05159	Justice Center		Interior	Owned	Other Room	Unisex - Holding cells	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F05160	Justice Center		Interior	Owned	Other Room	Unisex - Holding cells	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F05161	Justice Center		Interior	Owned	Other Room	Unisex - Holding cells	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F05162	Justice Center		Interior	Owned	Other Room	Unisex - Holding cells	2-Public Supervised	Door Gate		Is a peep-hole provided?	Window	N/A					n/a	$ -	
F05163	Justice Center		Interior	Owned	Other Room	Unisex - Holding cells	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F06601	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Near curb ramp #11	Adjacent pathway?	N	N/A					n/a	$ -	
F06602	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#2	Adjacent pathway?	N	N/A					n/a	$ -	
F06603	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#3	Adjacent pathway?	N	N/A					n/a	$ -	
F06604	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Row 2	Adjacent pathway?	N	N/A					n/a	$ -	
F06605	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#2	Adjacent pathway?	N	N/A					n/a	$ -	
F06606	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#3	Adjacent pathway?	N	N/A					n/a	$ -	
F06607	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#4	Adjacent pathway?	N	N/A					n/a	$ -	
F06608	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#1 - Row 2	Type	Van	N/A					n/a	$ -	
F06609	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#2 - Row 2	Type	Van	N/A					n/a	$ -	
F06610	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 2	Type	Van	N/A					n/a	$ -	
F06611	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 1	Type	STD	N/A					n/a	$ -	
F06612	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 1	Type	STD	N/A					n/a	$ -	
F06613	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 2	Type	STD	N/A					n/a	$ -	
F06614	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#5 - Row 2	Type	STD	N/A					n/a	$ -	
F06615	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	Row 1 space #1	Type	STD	N/A					n/a	$ -	
F06616	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	Row 1 space #2	Type	STD	N/A					n/a	$ -	
F06717	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Row 1	Adjacent pathway?	N	N/A					n/a	$ -	
F06718	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	Row 1 between spaces #2 & #3	Adjacent pathway?	N	N/A					n/a	$ -	
F06719	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	Row 1 between spaces #4 & #5	Adjacent pathway?	N	N/A					n/a	$ -	
F06720	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Row 2	Adjacent pathway?	N	N/A					n/a	$ -	
F06721	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#2	Adjacent pathway?	N	N/A					n/a	$ -	
F06722	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#3	Adjacent pathway?	N	N/A					n/a	$ -	
F06723	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#4	Adjacent pathway?	N	N/A					n/a	$ -	
F06724	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#1 - Row 1	Type	Van	N/A					n/a	$ -	
F06725	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#1 - Row 2	Type	STD	N/A					n/a	$ -	
F06726	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#2 - Row 1	Type	Van	N/A					n/a	$ -	
F06727	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#2 - Row 2	Type	Van	N/A					n/a	$ -	
F06728	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 2	Type	Van	N/A					n/a	$ -	
F06729	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 1	Type	Van	N/A					n/a	$ -	
F06730	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 2	Type	Van	N/A					n/a	$ -	
F06731	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#5 - Row 1	Type	STD	N/A					n/a	$ -	
F06732	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#5 - Row 2	Type	STD	N/A					n/a	$ -	
F06733	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#6 - Row 2	Type	STD	N/A					n/a	$ -	
F11511	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Alarm System		Dimension from ceiling	16.25	N/A					n/a	$ -	
F11512	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Counter		Approach type	F	N/A					n/a	$ -	
F11513	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Counter		Height	34.25	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11514	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F11515	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F11516	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Door Gate		Approach type, pull	L	N/A					n/a	$ -	
F11517	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F11518	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F11519	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Door Gate		Kick plate?	Y	N/A					n/a	$ -	
F11520	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F11521	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F11522	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F11523	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F11524	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Signage		ISA?	N	N/A					n/a	$ -	
F11525	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F11526	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F11586	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Counter		Approach type	F	N/A					n/a	$ -	
F11587	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Door Gate		Approach type, pull	L	N/A					n/a	$ -	
F11588	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F11589	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F11590	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Alarm System		Dimension from ceiling	17.5	N/A					n/a	$ -	
F11591	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F11592	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F11593	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F11594	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F11595	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F11596	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11597	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F11598	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F11607	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Signage		ISA?	N	N/A					n/a	$ -	
F11660	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F11661	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F11662	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F11663	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Alarm System		Dimension from ceiling	17.5	N/A					n/a	$ -	
F11664	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F11665	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Changing Station		Height	51.5	N/A					n/a	$ -	
F11666	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F11667	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F11668	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F11669	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F11670	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Coat Hook		Over obstruction?	N	N/A					n/a	$ -	
F11671	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F11672	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F11673	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F11674	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F11675	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F11690	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Signage		ISA?	N	N/A					n/a	$ -	
F11754	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Door Gate		Approach type, pull	L	N/A					n/a	$ -	
F11755	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F11756	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F11757	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Alarm System		Dimension from ceiling	18	N/A					n/a	$ -	
F11758	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Toilet Compartment	Inaccessible	Door location	F	N/A					n/a	$ -	
F11759	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Door Gate		Latch?	N	N/A					n/a	$ -	
F11760	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F11803	Justice Center		2nd Floor	Owned	Restroom	Men's - #224	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F11804	Justice Center		2nd Floor	Owned	Restroom	Men's - #224	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F11805	Justice Center		2nd Floor	Owned	Restroom	Men's - #224	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F11806	Justice Center		2nd Floor	Owned	Restroom	Men's - #224	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F11809	Justice Center		2nd Floor	Owned	Restroom	Men's - #224	1-Public Unsupervised	Signage		ISA?	N	N/A					n/a	$ -	
F11835	Justice Center		3rd Floor	Owned	Restroom	Men's - #354	1-Public Unsupervised	Signage		ISA?	N	N/A					n/a	$ -	
F11836	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F11837	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F11838	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F11839	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Alarm System		Dimension from ceiling	17.5	N/A					n/a	$ -	
F11840	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F11841	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F11842	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Coat Hook		Over obstruction?	N	N/A					n/a	$ -	
F11843	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F11844	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F11845	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F11846	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F11854	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Signage		ISA?	N	N/A					n/a	$ -	
F11901	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F11902	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F11903	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F11904	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Alarm System		Dimension from ceiling	18	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11905	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F11906	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Changing Station		Height	52	N/A					n/a	$ -	
F11907	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F11908	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F11909	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F11910	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F11911	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F11922	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Signage		ISA?	N	N/A					n/a	$ -	
F11968	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F11969	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F11970	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F11971	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Alarm System		Dimension from ceiling	19	N/A					n/a	$ -	
F11972	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F11973	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F11974	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F11975	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F11976	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F11977	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F11978	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F11983	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Signage		ISA?	N	N/A					n/a	$ -	
F12036	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F12037	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F12038	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F12039	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Alarm System		Dimension from ceiling	18.5	N/A					n/a	$ -	
F12040	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F12041	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F12042	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F12077	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F12078	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F12079	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Alarm System		Dimension from ceiling	17.5	N/A					n/a	$ -	
F12080	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Changing Station		Height	51.5	N/A					n/a	$ -	
F12081	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F12082	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F12122	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F12123	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F12124	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F12125	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Toilet Compartment		Door location	F	N/A					n/a	$ -	
F12126	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Grab Bar	Vertical	Height, bottom (vertical)	40	N/A					n/a	$ -	
F12127	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F12128	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Door Gate		Latch?	N	N/A					n/a	$ -	
F12129	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F12130	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Coat Hook		Over obstruction?	N	N/A					n/a	$ -	
F12131	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F12132	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F12133	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	Y	N/A					n/a	$ -	
F12134	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F12135	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F12207	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F12208	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F12209	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F12210	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Alarm System		Dimension from ceiling	Ceiling mount	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F12211	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F12212	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Changing Station		Height	47	N/A					n/a	$ -	
F12213	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Door Gate		Latch?	N	N/A					n/a	$ -	
F12214	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F12215	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F12216	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F12217	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	Y	N/A					n/a	$ -	
F12218	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F12284	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F12285	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F12286	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F12287	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F12289	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F12290	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Grab Bar	Vertical	Height, bottom (vertical)	41.5	N/A					n/a	$ -	
F12291	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Door Gate		Latch?	N	N/A					n/a	$ -	
F12292	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F12293	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Coat Hook		Over obstruction?	N	N/A					n/a	$ -	
F12294	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F12295	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F12296	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Changing Station		Over obstruction?	N	N/A					n/a	$ -	
F12297	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F12298	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	Y	N/A					n/a	$ -	
F12299	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F12378	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F12379	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F12380	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F12381	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F12382	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Grab Bar	Vertical	Height, bottom (vertical)	40.5	N/A					n/a	$ -	
F12383	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F12384	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	13	N/A					n/a	$ -	
F12385	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F12426	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F12427	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F12428	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F12429	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F12430	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Alarm System		Dimension from ceiling	15	N/A					n/a	$ -	
F12431	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F12432	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Counter		Height	34.5	N/A					n/a	$ -	
F12433	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Changing Station		Height	51.75	N/A					n/a	$ -	
F12434	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F12435	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F12436	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F12437	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Coat Hook		Over obstruction?	N	N/A					n/a	$ -	
F12438	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F12439	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F12440	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F12441	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Changing Station		Over obstruction?	N	N/A					n/a	$ -	
F12442	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F12443	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F12444	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F12518	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F12519	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Door Gate		Approach type, push	L	N/A					n/a	$ -	
F12520	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F12521	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Grab Bar	Vertical	Height, bottom (vertical)	39.5	N/A					n/a	$ -	
F12522	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F12523	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F12524	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F12525	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F12526	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F12527	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Dispenser	Soap	Over obstruction?	N	N/A					n/a	$ -	
F12528	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Grab Bar	Side	Vertical grab bar?	Y	N/A					n/a	$ -	
F12529	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F12578	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F12579	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F12580	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F12581	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F12582	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F12583	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F12584	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Dispenser	Soap	Over obstruction?	N	N/A					n/a	$ -	
F12585	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F12586	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Side	Vertical grab bar?	Y	N/A					n/a	$ -	
F12587	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Vertical	Vertical grab bar?	Y	N/A					n/a	$ -	
F12639	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Door Gate		Approach type, pull	L	N/A					n/a	$ -	
F12640	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F12641	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F12642	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Alarm System		Dimension from ceiling	6	N/A					n/a	$ -	
F12643	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F12644	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F12645	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F12646	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F12647	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F12648	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F12693	Justice Center		3rd Floor	Owned	Restroom	Unisex - #303	3-Employee Common	Signage		ISA?	N	N/A					n/a	$ -	
F12695	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F12696	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F12697	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F12698	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F12699	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F12700	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F12701	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Alarm System		Dimension from ceiling	6.5	N/A					n/a	$ -	
F12702	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Alarm System		Dimension from ceiling	6	N/A					n/a	$ -	
F12703	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F12704	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F12705	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F12706	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F12707	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F12708	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F12709	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F12710	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Signage		ISA?	N	N/A					n/a	$ -	
F12725	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Signage		ISA?	N	N/A					n/a	$ -	
F12780	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F12781	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F12782	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F12783	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Alarm System		Dimension from ceiling	4	N/A					n/a	$ -	
F12784	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F12785	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F12786	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F12787	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F12788	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Dispenser	Soap	Over obstruction?	N	N/A					n/a	$ -	
F12789	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F12790	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F12791	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F12838	Justice Center		6th Floor	Owned	Restroom	Unisex - #603	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F12839	Justice Center		6th Floor	Owned	Restroom	Unisex - #603	3-Employee Common	Alarm System		Dimension from ceiling	5.5	N/A					n/a	$ -	
F12840	Justice Center		6th Floor	Owned	Restroom	Unisex - #603	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F12858	Justice Center		6th Floor	Owned	Restroom	Unisex - #604	3-Employee Common	Alarm System		Dimension from ceiling	5.5	N/A					n/a	$ -	
F12859	Justice Center		6th Floor	Owned	Restroom	Unisex - #604	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F12883	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F12884	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F12885	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F12886	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Alarm System		Dimension from ceiling	Ceiling mount	N/A					n/a	$ -	
F12887	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Grab Bar	Vertical	Height, bottom (vertical)	40.5	N/A					n/a	$ -	
F12888	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F12889	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F12890	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F12891	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Dispenser	Soap	Over obstruction?	N	N/A					n/a	$ -	
F12892	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F12893	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Grab Bar	Side	Vertical grab bar?	Y	N/A					n/a	$ -	
F12894	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F12939	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F12940	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F12941	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F12942	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Grab Bar	Vertical	Height, bottom (vertical)	41	N/A					n/a	$ -	
F12943	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F12944	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F12977	Justice Center		Interior	Owned	Restroom	Unisex - Holding cells	2-Public Supervised	Grab Bar	Side	Clearance, to wall	OK	N/A					n/a	$ -	
F12978	Justice Center		Interior	Owned	Restroom	Unisex - Holding cells	2-Public Supervised	Grab Bar	Rear	Clearance, to wall	OK	N/A					n/a	$ -	
F12979	Justice Center		Interior	Owned	Restroom	Unisex - Holding cells	2-Public Supervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F12980	Justice Center		Interior	Owned	Restroom	Unisex - Holding cells	2-Public Supervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F12981	Justice Center		Interior	Owned	Restroom	Unisex - Holding cells	2-Public Supervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F12991	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F12992	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F12993	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F12994	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Alarm System		Dimension from ceiling	6	N/A					n/a	$ -	
F12995	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F12996	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F12997	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	N	N/A					n/a	$ -	
F12998	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F13068	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F13069	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F13070	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F13071	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Alarm System		Dimension from ceiling	6.5	N/A					n/a	$ -	
F13072	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F13073	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F13074	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F13075	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F13101	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 425	2-Public Supervised	Alarm System		Dimension from ceiling	4.75	N/A					n/a	$ -	
F13102	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 425	2-Public Supervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F13103	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 425	2-Public Supervised	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F13104	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 425	2-Public Supervised	Mirror		Over obstruction?	Y	N/A					n/a	$ -	
F13124	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F13125	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F13126	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F13127	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Alarm System		Dimension from ceiling	6	N/A					n/a	$ -	
F13128	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F13129	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F13130	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F13131	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F13160	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F13161	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F13162	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F13163	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Alarm System		Dimension from ceiling	6	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13164	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F13165	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F13200	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 524	1-Public Unsupervised	Alarm System		Dimension from ceiling	7	N/A					n/a	$ -	
F13201	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 524	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F13202	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 524	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	N	N/A					n/a	$ -	
F13203	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 524	1-Public Unsupervised	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F13204	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 524	1-Public Unsupervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F13225	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Alarm System		Dimension from ceiling	4	N/A					n/a	$ -	
F13226	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F13227	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F13228	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Dispenser	Soap	Over obstruction?	N	N/A					n/a	$ -	
F13229	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F13230	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F13231	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F13263	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 627	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F13264	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 627	1-Public Unsupervised	Alarm System		Dimension from ceiling	6.5	N/A					n/a	$ -	
F13265	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 627	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F13284	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 631	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F13285	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 631	1-Public Unsupervised	Alarm System		Dimension from ceiling	6	N/A					n/a	$ -	
F13286	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 631	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F13306	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F13307	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F13308	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F13309	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Grab Bar	Vertical	Height, bottom (vertical)	40	N/A					n/a	$ -	
F13310	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F13311	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F13312	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F13313	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Dispenser	Soap	Over obstruction?	N	N/A					n/a	$ -	
F13314	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F13315	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F13316	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Grab Bar	Side	Vertical grab bar?	Y	N/A					n/a	$ -	
F13317	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Grab Bar	Vertical	Vertical grab bar?	Y	N/A					n/a	$ -	
F13357	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F13358	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F13359	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F13360	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F13361	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13362	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Alarm System		Dimension from ceiling	Ceiling mount	N/A					n/a	$ -	
F13363	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Vertical	Height, bottom (vertical)	41	N/A					n/a	$ -	
F13364	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F13365	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F13366	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F13367	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F13368	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F13369	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F13370	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F13371	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Dispenser	Soap	Over obstruction?	N	N/A					n/a	$ -	
F13372	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F13373	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F13374	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Dispenser	Soap	Over obstruction?	N	N/A					n/a	$ -	
F13375	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Side	Vertical grab bar?	Y	N/A					n/a	$ -	
F13376	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Vertical	Vertical grab bar?	Y	N/A					n/a	$ -	
F13377	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F13378	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Side	Vertical grab bar?	Y	N/A					n/a	$ -	
F13379	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F13473	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Grab Bar	Vertical	Height, bottom (vertical)	40	N/A					n/a	$ -	
F13474	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F13501	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #1	2-Public Supervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F13502	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #1	2-Public Supervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F13513	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #2	2-Public Supervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F13514	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #2	2-Public Supervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F13527	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F13528	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Door Gate		Approach type, push	L	N/A					n/a	$ -	
F13529	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F13530	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Alarm System		Dimension from ceiling	5.75	N/A					n/a	$ -	
F13531	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F13532	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Dispenser	Soap	Over obstruction?	N	N/A					n/a	$ -	
F13533	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Dispenser	PT	Over obstruction?	Y	N/A					n/a	$ -	
F13543	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Signage		ISA?	N	N/A					n/a	$ -	
F13566	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F13567	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F13568	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F13569	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F13570	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Alarm System		Dimension from ceiling	18	N/A					n/a	$ -	
F13571	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Toilet Compartment	With sink	Door location	S	N/A					n/a	$ -	
F13572	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Counter		Height	34.5	N/A					n/a	$ -	
F13573	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Changing Station		Height	52	N/A					n/a	$ -	
F13574	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F13575	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F13576	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Mirror	In toilet compartment	Over lavatory?	Y	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13577	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F13578	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F13579	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F13580	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F13581	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F13582	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Toilet Compartment	With sink	Water closet type	W	N/A					n/a	$ -	
F13596	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Signage		ISA?	N	N/A					n/a	$ -	
F13656	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Door Gate		Approach type, pull	L	N/A					n/a	$ -	
F13657	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F13658	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F13659	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Alarm System		Dimension from ceiling	18	N/A					n/a	$ -	
F13660	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Door Gate		Latch?	N	N/A					n/a	$ -	
F13661	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F13662	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F13671	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Signage		ISA?	N	N/A					n/a	$ -	
F13699	Justice Center		2nd Floor	Owned	Restroom	Women's - #225	1-Public Unsupervised	Signage		ISA?	N	N/A					n/a	$ -	
F13704	Justice Center		3rd Floor	Owned	Restroom	Women's - #314	1-Public Unsupervised	Signage		ISA?	N	N/A					n/a	$ -	
F13710	Justice Center		3rd Floor	Owned	Restroom	Women's - #355	1-Public Unsupervised	Signage		ISA?	N	N/A					n/a	$ -	
F13711	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F13712	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F13713	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F13714	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F13715	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F13722	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Signage		ISA?	N	N/A					n/a	$ -	
F13762	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F13763	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F13764	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F13765	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Alarm System		Dimension from ceiling	18	N/A					n/a	$ -	
F13766	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F13767	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Changing Station		Height	52	N/A					n/a	$ -	
F13768	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F13769	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F13770	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F13771	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F13772	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F13773	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F13784	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Signage		ISA?	N	N/A					n/a	$ -	
F13829	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F13830	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Door Gate		Approach type, pull	Y	N/A					n/a	$ -	
F13831	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F13832	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F13833	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Changing Station		Height	47.5	N/A					n/a	$ -	
F13834	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Grab Bar	Vertical	Height, bottom (vertical)	41	N/A					n/a	$ -	
F13835	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F13836	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Coat Hook		Over obstruction?	N	N/A					n/a	$ -	
F13837	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F13838	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F13839	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F13840	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Changing Station		Over obstruction?	N	N/A					n/a	$ -	
F13841	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F13842	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	Y	N/A					n/a	$ -	
F13843	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F13913	Justice Center		5th Floor	Owned	Restroom	Women's - #514	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F13914	Justice Center		5th Floor	Owned	Restroom	Women's - #514	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F13915	Justice Center		5th Floor	Owned	Restroom	Women's - #514	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F13916	Justice Center		5th Floor	Owned	Restroom	Women's - #514	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F13919	Justice Center		5th Floor	Owned	Restroom	Women's - #514	1-Public Unsupervised	Signage		ISA?	N	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13933	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F13934	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F13935	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F13936	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F13937	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Alarm System		Dimension from ceiling	16	N/A					n/a	$ -	
F13938	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F13939	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Counter		Height	34.25	N/A					n/a	$ -	
F13940	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Changing Station		Height	52	N/A					n/a	$ -	
F13941	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F13942	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F13943	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F13944	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Coat Hook		Over obstruction?	N	N/A					n/a	$ -	
F13945	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F13946	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F13947	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F13948	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Changing Station		Over obstruction?	N	N/A					n/a	$ -	
F13949	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F13950	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F13951	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F14023	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F14024	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F14025	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F14026	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Alarm System		Dimension from ceiling	10.5	N/A					n/a	$ -	
F14027	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F14028	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F14029	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F14030	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F14067	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F14068	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F14069	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F14070	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Alarm System		Dimension from ceiling	18	N/A					n/a	$ -	
F14071	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F14072	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Changing Station		Height	52	N/A					n/a	$ -	
F14073	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Door Gate		Latch?	N	N/A					n/a	$ -	
F14074	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F14075	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F14115	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Toilet Compartment		Door location	F	N/A					n/a	$ -	
F14116	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F14117	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Coat Hook		Over obstruction?	N	N/A					n/a	$ -	
F14118	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F14119	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F14120	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	Y	N/A					n/a	$ -	
F14121	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F14122	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F14168	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F14169	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F14170	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F14171	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Alarm System		Dimension from ceiling	Ceiling mount	N/A					n/a	$ -	
F14172	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F14173	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Changing Station		Height	47	N/A					n/a	$ -	
F14174	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Grab Bar	Vertical	Height, bottom (vertical)	41	N/A					n/a	$ -	
F14175	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Door Gate		Latch?	N	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14176	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F14177	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F14178	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F14179	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	Y	N/A					n/a	$ -	
F14180	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F14244	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F14245	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F14246	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F14248	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F14249	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Grab Bar	Vertical	Height, bottom (vertical)	40.5	N/A					n/a	$ -	
F14250	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Door Gate		Kick plate?	Y	N/A					n/a	$ -	
F14251	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Door Gate		Latch?	N	N/A					n/a	$ -	
F14252	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F14253	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	15	N/A					n/a	$ -	
F14254	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F14295	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F14296	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F14297	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F14298	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Grab Bar	Vertical	Height, bottom (vertical)	40.5	N/A					n/a	$ -	
F14299	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	1-Public Unsupervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F14300	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F14301	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	1-Public Unsupervised	Door Gate		Latch?	N	N/A					n/a	$ -	
F14302	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F14303	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Dispenser	Soap	Over obstruction?	N	N/A					n/a	$ -	
F14304	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F14305	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Grab Bar	Side	Vertical grab bar?	Y	N/A					n/a	$ -	
F14306	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F15672	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Counter		Approach type	F	N/A					n/a	$ -	
F15673	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Public Phone		Approach type	F	N/A					n/a	$ -	
F15674	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F15675	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F15676	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F15677	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Door Gate		Is a peep-hole provided?	Window	N/A					n/a	$ -	
F15678	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F16301	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#1	Are detectable warnings present?	N	N/A					n/a	$ -	
F16302	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#2	Are detectable warnings present?	N	N/A					n/a	$ -	
F16303	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#3	Are detectable warnings present?	N	N/A					n/a	$ -	
F16304	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#4	Are detectable warnings present?	N	N/A					n/a	$ -	
F16305	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#5	Are detectable warnings present?	N	N/A					n/a	$ -	
F16306	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#6	Are detectable warnings present?	N	N/A					n/a	$ -	
F16307	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#7	Are detectable warnings present?	N	N/A					n/a	$ -	
F16308	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#8	Are detectable warnings present?	N	N/A					n/a	$ -	
F16309	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#9	Are detectable warnings present?	N	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16310	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#10	Are detectable warnings present?	N	N/A					n/a	$ -	
F16311	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Landing		Edge protection?	N	N/A					n/a	$ -	
F16435	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#1	Are detectable warnings present?	N	N/A					n/a	$ -	
F16436	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#2	Are detectable warnings present?	N	N/A					n/a	$ -	
F16437	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#3	Are detectable warnings present?	N	N/A					n/a	$ -	
F16438	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#4	Are detectable warnings present?	N	N/A					n/a	$ -	
F16439	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#12	Are detectable warnings present?	N	N/A					n/a	$ -	
F16440	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#13	Are detectable warnings present?	N	N/A					n/a	$ -	
F16508	Justice Center		Exterior	Owned	Walkway	Main Entrance	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F16509	Justice Center		Exterior	Owned	Walkway	Main Entrance	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F16510	Justice Center		Exterior	Owned	Walkway	Main Entrance	1-Public Unsupervised	Door Gate		Clearance, push parallel	OK	N/A					n/a	$ -	
F16511	Justice Center		Exterior	Owned	Walkway	Main Entrance	1-Public Unsupervised	Door Gate		Closer?	Auto	N/A					n/a	$ -	
F16512	Justice Center		Exterior	Owned	Walkway	Main Entrance	1-Public Unsupervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F16513	Justice Center		Exterior	Owned	Walkway	Main Entrance	1-Public Unsupervised	Door Gate		Kick plate?	Y	N/A					n/a	$ -	
F16514	Justice Center		Exterior	Owned	Walkway	Main Entrance	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F16800	Justice Center	CASA	Interior	Owned	Work Area	#309 - Office	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F16801	Justice Center	CASA	Interior	Owned	Work Area	#309 - Office	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F16802	Justice Center	CASA	Interior	Owned	Work Area	#309 - Office	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F16803	Justice Center	CASA	Interior	Owned	Work Area	#309 - Office	1-Public Unsupervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F16804	Justice Center	CASA	Interior	Owned	Work Area	#309 - Office	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F16822	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F16823	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Counter	L-shaped	Approach type	F	N/A					n/a	$ -	
F16824	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F16825	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F16826	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F16827	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Alarm System		Dimension from ceiling	Ceiling mount	N/A					n/a	$ -	
F16828	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F16850	Justice Center		3rd Floor	Owned	Work Area	#305 - Staff Area	3-Employee Common	Counter		Approach type	F	N/A					n/a	$ -	
F16851	Justice Center		3rd Floor	Owned	Work Area	#305 - Staff Area	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F16852	Justice Center		3rd Floor	Owned	Work Area	#305 - Staff Area	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F16853	Justice Center		3rd Floor	Owned	Work Area	#305 - Staff Area	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F16854	Justice Center		3rd Floor	Owned	Work Area	#305 - Staff Area	3-Employee Common	Door Gate		Is a peep-hole provided?	N	N/A					n/a	$ -	
F16855	Justice Center		3rd Floor	Owned	Work Area	#305 - Staff Area	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F16871	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Counter		Approach type	F	N/A					n/a	$ -	
F16872	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F16873	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate	Into Fire Vestibule	Approach type, pull	F	N/A					n/a	$ -	
F16874	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F16875	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F16876	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate	Into Fire Vestibule	Approach type, push	F	N/A					n/a	$ -	
F16877	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F16878	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F16879	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate	Into Fire Vestibule	Closer?	Y	N/A					n/a	$ -	
F16880	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F16881	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate	Into Fire Vestibule	Height, peep-hole	None	N/A					n/a	$ -	
F16882	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate	Into Fire Vestibule	Latch?	Y	N/A					n/a	$ -	
F16883	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F16931	Justice Center		4th Floor	Owned	Work Area	#S426 - Trial Support Center Annex	2-Public Supervised	Door Gate		Approach type, pull	L	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16932	Justice Center		4th Floor	Owned	Work Area	#S426 - Trial Support Center Annex	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F16933	Justice Center		4th Floor	Owned	Work Area	#S426 - Trial Support Center Annex	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F16934	Justice Center		4th Floor	Owned	Work Area	#S426 - Trial Support Center Annex	2-Public Supervised	Door Gate		Height, peep-hole	61	N/A					n/a	$ -	
F16935	Justice Center		4th Floor	Owned	Work Area	#S426 - Trial Support Center Annex	2-Public Supervised	Door Gate		Is a peep-hole provided?	Y	N/A					n/a	$ -	
F16936	Justice Center		4th Floor	Owned	Work Area	#S426 - Trial Support Center Annex	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F16945	Justice Center		Interior	Owned	Work Area	Off lobby	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F16946	Justice Center		Interior	Owned	Work Area	Off lobby	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F16947	Justice Center		Interior	Owned	Work Area	Off lobby	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F16948	Justice Center		Interior	Owned	Work Area	Off lobby	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F16964	Justice Center		Interior	Owned	Work Area		1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F16965	Justice Center		Interior	Owned	Work Area		1-Public Unsupervised	Door Gate		Other attribute	Remains open during bus hours	N/A					n/a	$ -	
F06852	Lowell Street Trailhead		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, total spaces	12	N/A					n/a	$ -	
F00693	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Break Room		3-Employee Common	Counter		Approach type	S	N/A					n/a	$ -	
F00694	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Break Room		3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F00695	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Break Room		3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F00696	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Break Room		3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F00697	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Break Room		3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F00709	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Break Room	Coffee/copy room	3-Employee Common	Counter		Approach type	S	N/A					n/a	$ -	
F00712	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Break Room		3-Employee Common	Counter		Approach type	S	N/A					n/a	$ -	
F01556	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Conference Room	Coroner	2-Public Supervised	Door Gate		Approach type, pull	H	N/A					n/a	$ -	
F01557	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Conference Room	Coroner	2-Public Supervised	Door Gate		Approach type, push	H	N/A					n/a	$ -	
F01558	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Conference Room	Coroner	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F01559	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Conference Room	Coroner	2-Public Supervised	Door Gate		Latch?	N	N/A					n/a	$ -	
F01570	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Conference Room		2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F01571	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Conference Room		2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F01572	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Conference Room		2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F04072	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Hallway	To exterior Break Area	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F04073	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Hallway	To exterior Break Area	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F04074	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Hallway	To exterior Break Area	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F04075	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Hallway	To exterior Break Area	3-Employee Common	Door Gate		Kick plate?	Y	N/A					n/a	$ -	
F04088	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Hallway		3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F04089	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Hallway		3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F04482	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception	Employee entrance	3-Employee Common	Door Gate	To locker/shower area	Approach type, pull	F	N/A					n/a	$ -	
F04483	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception	Employee entrance	3-Employee Common	Door Gate	To locker/shower area	Approach type, push	F	N/A					n/a	$ -	
F04484	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception	Employee entrance	3-Employee Common	Door Gate	To locker/shower area	Closer?	Y	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F04494	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter	Check-in	Approach type	S	N/A					n/a	$ -	
F04495	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter	Check-in	Approach type	S	N/A					n/a	$ -	
F04496	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		3-Employee Common	Door Gate	From shared lobby to Coroner's Office	Approach type, pull	F	N/A					n/a	$ -	
F04497	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		3-Employee Common	Door Gate	From shared lobby to Coroner's Office	Approach type, pull	F	N/A					n/a	$ -	
F04498	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		3-Employee Common	Door Gate	From shared lobby to Coroner's Office	Approach type, push	F	N/A					n/a	$ -	
F04499	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F04500	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		3-Employee Common	Door Gate	From shared lobby to Coroner's Office	Closer?	Y	N/A					n/a	$ -	
F04501	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		3-Employee Common	Door Gate	From shared lobby to Coroner's Office	Closer?	Y	N/A					n/a	$ -	
F04502	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Protrusion	Drinking Fountain	Height	40.5	N/A					n/a	$ -	
F04503	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Drinking Fountain		High-low fountain?	Y	N/A					n/a	$ -	
F04504	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		3-Employee Common	Door Gate	From shared lobby to Coroner's Office	Latch?	Y	N/A					n/a	$ -	
F04784	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Seat?	Y	N/A					n/a	$ -	
F04785	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Shower type	Transfer	N/A					n/a	$ -	
F06861	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility	Employee parking lot	1-Public Unsupervised	Facility Specifications		Number, total spaces	71	N/A					n/a	$ -	
F06872	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, total spaces	24	N/A					n/a	$ -	
F06873	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Type	STD	N/A					n/a	$ -	
F06874	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Type	Van	N/A					n/a	$ -	
F06875	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Type	STD	N/A					n/a	$ -	
F14358	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Approach type, push	H	N/A					n/a	$ -	
F14359	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F14360	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Cross section type	Round	N/A					n/a	$ -	
F14361	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Side	Cross section type	Round	N/A					n/a	$ -	
F14362	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F14363	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Coat Hook		Over obstruction?	N	N/A					n/a	$ -	
F14364	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	N	N/A					n/a	$ -	
F14365	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F14366	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F14367	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Water closet type	W	N/A					n/a	$ -	
F14423	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F14424	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F14425	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F14426	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F14442	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Approach type, push	H	N/A					n/a	$ -	
F14443	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F14455	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Side	Cross section type	Round	N/A					n/a	$ -	
F14456	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F14501	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14502	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F14503	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F14504	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Alarm System		Dimension from ceiling	16	N/A					n/a	$ -	
F14505	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F14506	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F16535	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Landing	At base of walkway	Edge protection?	N	N/A					n/a	$ -	
F00718	Parks Admin Building		1st Floor	Owned	Break Room	Meeting Room	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F00722	Parks Admin Building		2nd Floor	Owned	Break Room		3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F04544	Parks Admin Building		1st Floor	Owned	Lobby Reception		1-Public Unsupervised	Counter		Other attribute	Not used	N/A					n/a	$ -	
F06911	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North of Park Admin building	1-Public Unsupervised	Parking Space	#2	Type	STD	N/A					n/a	$ -	
F06919	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Access Aisle	#1	Adjacent pathway?	N	N/A					n/a	$ -	
F06920	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Parking Space	#1	Type	STD	N/A					n/a	$ -	
F06921	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Parking Space	#2	Type	STD	N/A					n/a	$ -	
F06922	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Parking Space	#3	Type	STD	N/A					n/a	$ -	
F06948	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	West side of North parking lot	1-Public Unsupervised	Access Aisle	#1	Adjacent pathway?	N	N/A					n/a	$ -	
F06949	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	West side of North parking lot	1-Public Unsupervised	Parking Space	#1	Type	STD	N/A					n/a	$ -	
F06950	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	West side of North parking lot	1-Public Unsupervised	Parking Space	#2	Type	STD	N/A					n/a	$ -	
F06970	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Type	STD	N/A					n/a	$ -	
F14541	Parks Admin Building		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F14542	Parks Admin Building		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Approach type, push	L	N/A					n/a	$ -	
F14543	Parks Admin Building		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Other attribute	OK	N/A					n/a	$ -	
F14561	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F14562	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Alarm System		Dimension from ceiling	12	N/A					n/a	$ -	
F14563	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F14591	Parks Admin Building		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F14603	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F14604	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Alarm System		Dimension from ceiling	12	N/A					n/a	$ -	
F14605	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F14606	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F14607	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F14608	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Toilet Compartment		Water closet type	F	N/A					n/a	$ -	
F16544	Parks Admin Building	North Parking Area	Exterior	Owned	Walkway	From 'New' North parking lot	1-Public Unsupervised	Curb Ramp		Are detectable warnings present?	Y	N/A					n/a	$ -	
F16555	Parks Admin Building		Exterior	Owned	Walkway	From parking lot	1-Public Unsupervised	Curb Ramp		Are detectable warnings present?	N	N/A					n/a	$ -	
F16563	Parks Admin Building		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F16564	Parks Admin Building		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F16565	Parks Admin Building		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F16566	Parks Admin Building		Exterior	Owned	Walkway		1-Public Unsupervised	Protrusion	Fire/alarm box	Height	55	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00739	Public Works and Fleet		2nd Floor	Owned	Break Room		3-Employee Common	Dispenser	PT	Over obstruction?	18	N/A					n/a	$ -	
F04551	Public Works and Fleet		Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Threshold beveled?	Y	N/A					n/a	$ -	
F07009	Public Works and Fleet		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, total spaces	76	N/A					n/a	$ -	
F14649	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F14650	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F14651	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F14652	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Approach type, push	L	N/A					n/a	$ -	
F14653	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F14742	Public Works and Fleet		1st Floor	Owned	Restroom	Men's - Fleet Break Room	3-Employee Common	Mirror		Over lavatory?	N	N/A					n/a	$ -	
F14776	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F14777	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F14778	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Approach type, push	H	N/A					n/a	$ -	
F14779	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F15582	Public Works and Fleet		2nd Floor	Owned	Shower Room	Men's	3-Employee Common	Shower Compartment	Currently used as storage	Dimension, entry to back wall	34	N/A					n/a	$ -	
F15583	Public Works and Fleet		2nd Floor	Owned	Shower Room	Men's	3-Employee Common	Shower Compartment	Currently used as storage	Shower type	Roll-in	N/A					n/a	$ -	
F15589	Public Works and Fleet		2nd Floor	Owned	Shower Room	Women's	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F15590	Public Works and Fleet		2nd Floor	Owned	Shower Room	Women's	3-Employee Common	Shower Compartment		Dimension, entry to back wall	34	N/A					n/a	$ -	
F15591	Public Works and Fleet		2nd Floor	Owned	Shower Room	Women's	3-Employee Common	Shower Compartment		Shower type	Roll-in	N/A					n/a	$ -	
F16573	Public Works and Fleet		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Threshold beveled?	Y	N/A					n/a	$ -	
F07029	Rotella Park		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Facility Specifications		Number, total spaces	14	N/A					n/a	$ -	
F07030	Rotella Park		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#1	Type	STD	N/A					n/a	$ -	
F07031	Rotella Park		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#2	Type	STD	N/A					n/a	$ -	
F07054	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, total spaces	100	N/A					n/a	$ -	
F07055	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Type	STD	N/A					n/a	$ -	
F07056	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Type	Van	N/A					n/a	$ -	
F07057	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Type	STD	N/A					n/a	$ -	
F07058	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Type	STD	N/A					n/a	$ -	
F07059	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Type	STD	N/A					n/a	$ -	
F07426	Rotella Park		Exterior	Owned	Play Area	#2 - Up the hill	1-Public Unsupervised	Area Specifications		Number, elevated components	None	N/A					n/a	$ -	
F07427	Rotella Park		Exterior	Owned	Play Area	#2 - Up the hill	1-Public Unsupervised	Area Specifications		Number, ground components	11	N/A					n/a	$ -	
F07428	Rotella Park		Exterior	Owned	Play Area	#2 - Up the hill	1-Public Unsupervised	Area Specifications		Number, ground types	1	N/A					n/a	$ -	
F07431	Rotella Park		Exterior	Owned	Play Area		1-Public Unsupervised	Area Specifications		Number, elevated components	10	N/A					n/a	$ -	
F07432	Rotella Park		Exterior	Owned	Play Area		1-Public Unsupervised	Area Specifications		Number, elevated components connected by ramp	None	N/A					n/a	$ -	
F07433	Rotella Park		Exterior	Owned	Play Area		1-Public Unsupervised	Area Specifications		Number, ground components	3	N/A					n/a	$ -	
F07434	Rotella Park		Exterior	Owned	Play Area		1-Public Unsupervised	Area Specifications		Number, ground types	2	N/A					n/a	$ -	
F14860	Rotella Park		Exterior	Owned	Restroom	Accessible Porta-Potty	1-Public Unsupervised	Water Closet		Height, flush control	None	N/A					n/a	$ -	
F14861	Rotella Park		Exterior	Owned	Restroom	Accessible Porta-Potty	1-Public Unsupervised	Water Closet		Other attribute	OK	N/A					n/a	$ -	
F14868	Rotella Park		Exterior	Owned	Restroom	Porta-Potty	1-Public Unsupervised	Toilet Compartment		Other attribute	Porta-Pottys not accessible	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14869	Rotella Park		Exterior	Owned	Restroom	Porta-Potty	1-Public Unsupervised	Toilet Compartment		Water closet type	Porta-Pottys not accessible	N/A					n/a	$ -	
F15627	Rotella Park		Exterior	Owned	Sport Area	Basketball court	1-Public Unsupervised	Circulation Path		Adjacent pathway?	N	N/A					n/a	$ -	
F15631	Rotella Park		Exterior	Owned	Sport Area	Volleyball Court	1-Public Unsupervised	Circulation Path		Adjacent pathway?	N	N/A					n/a	$ -	
F15661	Sandhofer Lake		Exterior	Owned	Trailhead		1-Public Unsupervised	Other Element		Other attribute	No amenities	N/A					n/a	$ -	
F07114	Steele Street Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, total spaces	20	N/A					n/a	$ -	
F07115	Steele Street Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Type	STD	N/A					n/a	$ -	
F00754	Strasburg Facility	Sheriff's Office	Interior	Owned	Break Room	North End	2-Public Supervised	Counter		Approach type	S	N/A					n/a	$ -	
F00755	Strasburg Facility	Sheriff's Office	Interior	Owned	Break Room	North End	2-Public Supervised	Counter		Dimension, knee clearance	0	N/A					n/a	$ -	
F00756	Strasburg Facility	Sheriff's Office	Interior	Owned	Break Room	North End	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	0	N/A					n/a	$ -	
F03481	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F03482	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Door Gate		Approach type, push	L	N/A					n/a	$ -	
F03483	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F03484	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Protrusion	Wall mounted TV	Height	69	N/A					n/a	$ -	
F03485	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Door Gate		Latch?	Y	N/A					n/a	$ -	
F04199	Strasburg Facility	Sheriff's Office	Interior	Owned	Holding Cell	Left of main entry	2-Public Supervised	Holding Specifications		Cell type	Intoxilyzer	N/A					n/a	$ -	
F04200	Strasburg Facility	Sheriff's Office	Interior	Owned	Holding Cell	Left of main entry	2-Public Supervised	Lavatory Sink	Combination lav/toilet	Dimension, knee clearance	0	N/A					n/a	$ -	
F04201	Strasburg Facility	Sheriff's Office	Interior	Owned	Holding Cell	Left of main entry	2-Public Supervised	Bench		Slip resistant?	N	N/A					n/a	$ -	
F04584	Strasburg Facility	Public Works Shops	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Approach type	S	N/A					n/a	$ -	
F04585	Strasburg Facility	Public Works Shops	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Dimension, knee clearance	0	N/A					n/a	$ -	
F04805	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Off weight room	3-Employee Common	Shower Compartment		Dimension, entry to back wall	35	N/A					n/a	$ -	
F04806	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Off weight room	3-Employee Common	Shower Compartment		Seat?	Y	N/A					n/a	$ -	
F04807	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Off weight room	3-Employee Common	Shower Compartment		Shower type	Transfer	N/A					n/a	$ -	
F04818	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Shower	3-Employee Common	Grab Bar	Side	Dimension, end to wall	2.5	N/A					n/a	$ -	
F04819	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Shower	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	1.5	N/A					n/a	$ -	
F04820	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Shower	3-Employee Common	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F04830	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room		3-Employee Common	Door Gate		Approach type, pull	L	N/A					n/a	$ -	
F04831	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room		3-Employee Common	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F04832	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room		3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F04833	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room		3-Employee Common	Bench		Length	8	N/A					n/a	$ -	
F04834	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room		3-Employee Common	Mirror		Over lavatory?	N	N/A					n/a	$ -	
F04854	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Off weight room	3-Employee Common	Shower Compartment		Threshold beveled?	N	N/A					n/a	$ -	
F05174	Strasburg Facility	Sheriff's Office	Interior	Owned	Other Room	Processing/Intoxilyzer	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F05175	Strasburg Facility	Sheriff's Office	Interior	Owned	Other Room	Processing/Intoxilyzer	2-Public Supervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F05176	Strasburg Facility	Sheriff's Office	Interior	Owned	Other Room	Processing/Intoxilyzer	2-Public Supervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F05177	Strasburg Facility	Sheriff's Office	Interior	Owned	Other Room	Processing/Intoxilyzer	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F07132	Strasburg Facility	Sheriff's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Adjacent pathway?	N	N/A					n/a	$ -	
F07133	Strasburg Facility	Sheriff's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, total spaces	31	N/A					n/a	$ -	
F07157	Strasburg Facility	Public Works Shops	Exterior	Owned	Parking Facility	Public Works Shops	1-Public Unsupervised	Facility Specifications		Number, total spaces	25	N/A					n/a	$ -	
F14874	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F14875	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Door Gate		Approach type, push	L	N/A					n/a	$ -	
F14876	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F14878	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Vertical	Height, bottom (vertical)	40	N/A					n/a	$ -	
F14879	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F14880	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F14881	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F14882	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F14883	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14884	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Side	Vertical grab bar?	Y	N/A					n/a	$ -	
F14885	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F14886	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Vertical	Vertical grab bar?	Y	N/A					n/a	$ -	
F14894	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Signage		ISA?	N	N/A					n/a	$ -	
F14933	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F14934	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Door Gate		Approach type, push	H	N/A					n/a	$ -	
F14935	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F14936	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Grab Bar	Side	Cross section type	1.5	N/A					n/a	$ -	
F14937	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Grab Bar	Vertical	Height, bottom (vertical)	41	N/A					n/a	$ -	
F14938	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F14939	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F14940	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Dispenser	TP	Over obstruction?	N	N/A					n/a	$ -	
F14941	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F14942	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Grab Bar	Side	Vertical grab bar?	Y	N/A					n/a	$ -	
F14943	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F14944	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Grab Bar	Vertical	Vertical grab bar?	Y	N/A					n/a	$ -	
F14950	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Signage		ISA?	N	N/A					n/a	$ -	
F16590	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F16591	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		2-Public Supervised	Door Gate	Secured double door entrance	Approach type, pull	F	N/A					n/a	$ -	
F16592	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F16593	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		2-Public Supervised	Door Gate	Secured double door entrance	Approach type, push	F	N/A					n/a	$ -	
F16594	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp		Are detectable warnings present?	N	N/A					n/a	$ -	
F16595	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Closer?	Auto	N/A					n/a	$ -	
F16596	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		2-Public Supervised	Door Gate	Secured double door entrance	Closer?	Y	N/A					n/a	$ -	
F16597	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Landing		Edge protection?	N	N/A					n/a	$ -	
F16598	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		2-Public Supervised	Door Gate	Secured double door entrance	Height, hardware	OK	N/A					n/a	$ -	
F16599	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Kick plate?	Y	N/A					n/a	$ -	
F16600	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F16601	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		2-Public Supervised	Door Gate	Secured double door entrance	Latch?	Y	N/A					n/a	$ -	
F07160	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, total spaces	36	N/A					n/a	$ -	
F07161	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Type	STD	N/A					n/a	$ -	
F07162	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Type	STD	N/A					n/a	$ -	
F07163	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Type	STD	N/A					n/a	$ -	
F07444	Twin Lakes Park		Exterior	Owned	Play Area		1-Public Unsupervised	Area Specifications		Number, elevated components	6	N/A					n/a	$ -	
F07445	Twin Lakes Park		Exterior	Owned	Play Area		1-Public Unsupervised	Area Specifications		Number, ground types	1	N/A					n/a	$ -	
F14991	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Other attribute	Under repairs	N/A					n/a	$ -	
F14992	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar		Vertical grab bar?	N	N/A					n/a	$ -	
F14993	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Water closet type	F	N/A					n/a	$ -	
F15020	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F15021	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F15022	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F15023	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Height, peep-hole	None	N/A					n/a	$ -	
F15024	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F15025	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F15026	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F00771	Western Service Center	ACED	1st Floor	Owned	Break Room		3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F00784	Western Service Center		2nd Floor	Owned	Break Room		3-Employee Common	Door Gate		Approach type, pull	L	N/A					n/a	$ -	
F03444	Western Service Center		1st Floor	Owned	Elevator		1-Public Unsupervised	Car Controls		Braille instructions	N	N/A					n/a	$ -	
F03445	Western Service Center		1st Floor	Owned	Elevator		1-Public Unsupervised	Elevator Door		Location	Center	N/A					n/a	$ -	
F03446	Western Service Center		1st Floor	Owned	Elevator		1-Public Unsupervised	Car Controls		Star?	N	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F04099	Western Service Center		1st Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near rear restrooms	High-low fountain?	Y	N/A					n/a	$ -	
F04296	Western Service Center	DMV	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F04555	Western Service Center	DMV	1st Floor	Owned	Lobby Reception		1-Public Unsupervised	Counter		Approach type	S	N/A					n/a	$ -	
F04558	Western Service Center		3rd Floor	Owned	Lobby Reception	Diversion	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F04563	Western Service Center		2nd Floor	Owned	Lobby Reception	Probation	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F04564	Western Service Center		2nd Floor	Owned	Lobby Reception	Probation	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F04855	Western Service Center		2nd Floor	Owned	Locker Room	Employee Showers	3-Employee Common	Door Gate		Approach type, pull	L	N/A					n/a	$ -	
F07215	Western Service Center	ACED	Exterior	Owned	Parking Facility	Underground parking	5-Tenant Common	Facility Specifications		Other attribute	Interior	N/A					n/a	$ -	
F07291	Western Service Center		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, total spaces	194	N/A					n/a	$ -	
F09320	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F09321	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F09322	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F09323	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F09324	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F09325	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	Toilet seat covers	Over obstruction?	Y	N/A					n/a	$ -	
F09326	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F09327	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F09328	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F09329	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F09369	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F09370	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F09371	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F09372	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F09373	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F09374	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Over obstruction?	N	N/A					n/a	$ -	
F09375	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Soap	Over obstruction?	Y	N/A					n/a	$ -	
F09376	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Toilet seat covers	Over obstruction?	Y	N/A					n/a	$ -	
F09377	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Vertical grab bar?	N	N/A					n/a	$ -	
F09378	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F15072	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F15073	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Door Gate		Approach type, push	H	N/A					n/a	$ -	
F15074	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F15075	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F15076	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Protrusion	PT	Height	38.5	N/A					n/a	$ -	
F15077	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Side	Vertical grab bar?	Y	N/A					n/a	$ -	
F15078	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Vertical	Vertical grab bar?	Y	N/A					n/a	$ -	
F15079	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Toilet Compartment		Water closet type	F	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15123	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Vertical	Height, bottom (vertical)	40	N/A					n/a	$ -	
F15163	Western Service Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Approach type, pull	L	N/A					n/a	$ -	
F15164	Western Service Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F15165	Western Service Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F15166	Western Service Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F15167	Western Service Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Water closet type	F	N/A					n/a	$ -	
F15184	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Alarm System		Dimension from ceiling	8	N/A					n/a	$ -	
F15185	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F15186	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Water Closet		Other attribute	F	N/A					n/a	$ -	
F15187	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Side	Vertical grab bar?	N	N/A					n/a	$ -	
F15224	Western Service Center		2nd Floor	Owned	Restroom	Unisex - Drug Screening Area	3-Employee Common	Grab Bar	Vertical	Height, bottom (vertical)	41	N/A					n/a	$ -	
F15259	Western Service Center		2nd Floor	Owned	Restroom	Women's - Employee	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F15271	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Approach type, push	H	N/A					n/a	$ -	
F15272	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F15273	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Water Closet		Other attribute	F	N/A					n/a	$ -	
F15863	Western Service Center	DMV	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F15864	Western Service Center	DMV	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F15865	Western Service Center	DMV	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F16667	Western Service Center	DMV	Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate		Approach type, pull	L	N/A					n/a	$ -	
F16668	Western Service Center	DMV	Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate		Approach type, push	H	N/A					n/a	$ -	
F16669	Western Service Center	DMV	Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F16670	Western Service Center	DMV	Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate		Kick plate?	Y	N/A					n/a	$ -	
F16675	Western Service Center	DMV	Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate		Threshold beveled?	Y	N/A					n/a	$ -	
F16686	Western Service Center		Exterior	Owned	Walkway	From nearest Bus Stop to entrance	1-Public Unsupervised	Curb Ramp	At 122nd & Pecos	Are detectable warnings present?	Y	N/A					n/a	$ -	
F16709	Western Service Center		Exterior	Owned	Walkway	Ramp to entrance	1-Public Unsupervised	Handrail		Cross section type	Square	N/A					n/a	$ -	
F16716	Western Service Center		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	At accessible parking spaces	Are detectable warnings present?	N	N/A					n/a	$ -	
F00796	Westminster Motor Vehicle		Interior	Leased	Break Room		3-Employee Common	Counter		Approach type	S	N/A					n/a	$ -	
F04108	Westminster Motor Vehicle		Interior	Leased	Hallway	Entire building	1-Public Unsupervised	Alarm System		Other attribute	None Provided	N/A					n/a	$ -	
F04575	Westminster Motor Vehicle		Interior	Leased	Lobby Reception		1-Public Unsupervised	Counter		Approach type	F	N/A					n/a	$ -	
F07303	Westminster Motor Vehicle		Exterior	Leased	Parking Facility		1-Public Unsupervised	Access Aisle		Adjacent pathway?	N	N/A					n/a	$ -	
F07304	Westminster Motor Vehicle		Exterior	Leased	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, total spaces	OK	N/A					n/a	$ -	
F07305	Westminster Motor Vehicle		Exterior	Leased	Parking Facility		1-Public Unsupervised	Parking Space		Type	STD	N/A					n/a	$ -	
F15309	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F15310	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F15311	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F15312	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Door Gate		Kick plate?	Y	N/A					n/a	$ -	
F15313	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Door Gate		Latch?	N	N/A					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15314	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F15315	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Water closet type	F	N/A					n/a	$ -	
F15356	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F15389	Westminster Motor Vehicle		Interior	Leased	Restroom	Unisex	3-Employee Common	Door Gate		Closer?	N	N/A					n/a	$ -	
F15390	Westminster Motor Vehicle		Interior	Leased	Restroom	Unisex	3-Employee Common	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F15413	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F15414	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F15415	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F15416	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Door location	S	N/A					n/a	$ -	
F15417	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Door Gate		Latch?	N	N/A					n/a	$ -	
F15418	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Water closet type	F	N/A					n/a	$ -	
F15452	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F15453	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Door Gate		Approach type, push	F	N/A					n/a	$ -	
F15454	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Door Gate		Closer?	N	N/A					n/a	$ -	
F15455	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Door Gate		Latch?	Y	N/A					n/a	$ -	
F15456	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Mirror		Over lavatory?	Y	N/A					n/a	$ -	
F16729	Westminster Motor Vehicle		Exterior	Leased	Walkway	To employee entrance	3-Employee Common	Door Gate		Approach type, pull	F	N/A					n/a	$ -	
F16730	Westminster Motor Vehicle		Exterior	Leased	Walkway	To employee entrance	3-Employee Common	Door Gate		Closer?	Y	N/A					n/a	$ -	
F16735	Westminster Motor Vehicle		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate	Main entrance	Approach type, pull	F	N/A					n/a	$ -	
F16736	Westminster Motor Vehicle		Exterior	Leased	Walkway		1-Public Unsupervised	Curb Ramp		Are detectable warnings present?	N	N/A					n/a	$ -	
F16737	Westminster Motor Vehicle		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate	Main entrance	Closer?	Y	N/A					n/a	$ -	
F00804	Whittier Public Works Support Facility		Interior	Owned	Break Room		1-Public Unsupervised	Alarm System		Other attribute	None Provided	N/A					n/a	$ -	
F04577	Whittier Public Works Support Facility		Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F15491	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Closer?	Y	N/A					n/a	$ -	
F15492	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Grab Bar	Vertical	Height, bottom (vertical)	40	N/A					n/a	$ -	
F16754	Whittier Public Works Support Facility		Exterior	Owned	Walkway		3-Employee Common	Door Gate	Main entrance	Approach type, push	F	N/A					n/a	$ -	
F16755	Whittier Public Works Support Facility		Exterior	Owned	Walkway		3-Employee Common	Door Gate	Main entrance	Closer?	Y	N/A					n/a	$ -	
F16756	Whittier Public Works Support Facility		Exterior	Owned	Walkway		3-Employee Common	Door Gate	Main entrance	Latch?	Y	N/A					n/a	$ -	
F16764	Whittier Public Works Support Facility		Exterior	Owned	Walkway		3-Employee Common	Door Gate	Main entrance	Threshold beveled?	Y	N/A					n/a	$ -	
F00004	Adams County Detention Center	Existing Jail	Interior	Owned	Assembly Area		3-Employee Common	Door Gate		Clearance, pull parallel	14	No	Clearance on pull side of door is insufficient.	2-Services	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F00005	Adams County Detention Center	Existing Jail	Interior	Owned	Assembly Area		3-Employee Common	Door Gate		Clearance, vertical	79.25	No	Vertical clearance is too low.	2-Services	Replace the doorway with a compliant vertical clearance.	80 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F00006	Adams County Detention Center	Existing Jail	Interior	Owned	Assembly Area		3-Employee Common	Door Gate		Hardware type	Knob	No	Hardware requires twisting of wrist.	2-Services	Install lever type door hardware.		When Renovated	n/a	TBD - Pre-ADA

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00012	Adams County Detention Center	F Module	2nd Floor	Owned	Assembly Area	Training - F Adm	2-Public Supervised	Door Gate		Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F02963	Adams County Detention Center	Existing Jail	Interior	Owned	Detention Facility	Inmates	3-Employee Common	Cell Specifications		Number, mobility access by type	1	No	Too few mobility accessible cells are provided.	2-Services	Provide at least the minimum number of mobility accessible cells.	10 minimum	When Renovated	n/a	TBD - Pre-ADA
F02966	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Elevator Door		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	When Renovated	n/a	TBD - Pre-ADA
F02967	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Elevator Car		Dimension, gap	1.5	No	Platform to hoistway clearance is too wide.	5-Tolerance	No action recommended - within construction tolerance.	1.25 inches	When Renovated	n/a	TBD - Pre-ADA
F02968	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Car Controls		Height, emergency control	29	No	Emergency control is too low.	2-Services	Relocate the emergency control to provide centerline height of 35 inches.	35 inches	When Renovated	n/a	TBD - Pre-ADA
F03639	Adams County Detention Center	Existing Jail	Interior	Owned	Hallway	From lobby to video phone bank	1-Public Unsupervised	Ramp		Edge protection?	N	No	No edge protection provided for ramp.	2-Services	Install edge protection on both sides of the ramp, for the entire length of the ramp.	4 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F03640	Adams County Detention Center	Existing Jail	Interior	Owned	Hallway	From lobby to video phone bank	1-Public Unsupervised	Ramp		Slope, running	8.4%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	8.33% maximum	When Renovated	n/a	TBD - Pre-ADA
F03652	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Ramp	Section #2	Slope, running	9.1%	No	Slope is too steep.	2-Services	Rebuild the ramp with a compliant running slope, cross slope, and landing.	8.33% maximum	None	n/a	Per Code - Technically Infeasible (3402 & 3411)
F04287	Adams County Detention Center	Existing Jail	Interior	Owned	Lobby Reception	From parking lot to Main entrance	2-Public Supervised	Counter		Height	40.5	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F04590	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Men's	3-Employee Common	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Relocate or Replace Mirror
F04607	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Signage		Braille?	N	No	Signage does not provide Braille.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F04608	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Clearance, pull parallel	16	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2017	$ 2,000.00	Move door in existing wall
F04609	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Clearance, push parallel	7	No	Clearance on push side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	12 inches minimum	2017	$ 2,000.00	Move door in existing wall
F04610	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Closing speed	3	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F04611	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F04612	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Protrusion	Fire extinguisher	Dimension, protruding	6	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2016	$ 250.00	Recess Extinguisher
F04613	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Shower Compartment		Hand spray unit?	N	No	Shower does not include a handheld spray unit.	3-Restrooms	Replace the shower head with a handheld spray unit, mounted a maximum of 48 inches above the finished floor, with a spray hose no less than 59 inches long.		2017	$ 250.00	Install new Shower Head
F04614	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Opening force	11	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F04615	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Opening force	15	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F04616	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Shower Compartment		Seat?	N	No	No seat provided in the transfer shower.	3-Restrooms	Install a folding seat on the wall perpendicular to the shower controls.		2017	$ 500.00	Install new Shower Seat
F04637	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Shower Compartment		Height, threshold	2	No	Threshold is too high.	3-Restrooms	Provide a threshold which is 0.25 inch maximum, or a beveled threshold which is 0.5 inch maximum, at the door entrance.	0.5 inch maximum	2017	$ 250.00	Replace Threshold
F04868	Adams County Detention Center	Existing Jail	Interior	Owned	Other Room	All rooms	3-Employee Common	Signage		Braille?	No tactile or Braille	No	Signage does not provide Braille.	2-Services	Install signage, with both raised letters and Braille, to all rooms requiring room identification.		When Renovated	n/a	TBD - Pre-ADA
F04872	Adams County Detention Center	Existing Jail	Interior	Owned	Other Room	Library	3-Employee Common	Door Gate		Clearance, vertical	72.5	No	Vertical clearance is too low.	2-Services	Replace the doorway with a compliant vertical clearance.	80 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F04873	Adams County Detention Center	Existing Jail	Interior	Owned	Other Room	Library	3-Employee Common	Door Gate		Hardware type	Knob	No	Hardware requires twisting of wrist.	2-Services	Install lever type door hardware.		When Renovated	n/a	TBD - Pre-ADA
F04874	Adams County Detention Center	Existing Jail	Interior	Owned	Other Room	Library	3-Employee Common	Door Gate		Opening force	9	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	When Renovated	n/a	TBD - Pre-ADA
F05191	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	#1	Height, sign	55	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F05192	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space		Height, sign	55	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05193	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	#3	Height, sign	55	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F05194	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	#4	Height, sign	55	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F05195	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	#5	Height, sign	55	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F05196	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	#6	Height, sign	55	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F05197	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	Youth Services	Height, sign	55	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F05198	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Facility Specifications		Number, accessible	7	No	Too few accessible parking spaces and van accessible parking spaces.	1-Entry	Provide a total of 8 accessible parking spaces, 2 of which should be a van accessible size parking spaces.	8 minimum	When Renovated	n/a	TBD - Pre-ADA
F05199	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Facility Specifications		Number, van spaces	0	No	Too few van accessible parking spaces are provided.	1-Entry	Provide the minimum number of required van accessible parking spaces.	2 minimum	When Renovated	n/a	TBD - Pre-ADA
F05200	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Access Aisle	Youth Services	Slope, cross	2.2%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F05201	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	#6	Slope, cross	2.8%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F05202	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	#4	Slope, cross	2.9%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F05203	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	#5	Slope, cross	3.8%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F05204	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	Youth Services	Slope, cross	4.4%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F05205	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Access Aisle	#1	Slope, running	2.9%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F05206	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	#1	Slope, running	3.3%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F05207	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space		Slope, running	3.4%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F05208	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Access Aisle	#2	Width	59	No	Access aisle is too narrow.	1-Entry	Restripe the parking space and aisle to provide a compliant sized access aisle.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F05255	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Height, sign	54	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F05256	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Height, sign	48	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05257	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Height, sign	48	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F05258	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Height, sign	48	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F05259	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#6	Height, sign	48.5	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F05260	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#7	Height, sign	44	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F05261	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#8	Height, sign	51	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F05262	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#9	Height, sign	53	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F05263	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Sign?	N	No	No accessible signage provided.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F05264	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Slope, cross	4.0%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F05265	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Slope, cross	4.2%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F05266	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Slope, cross	4.4%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F05267	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #6 & #7	Slope, cross	5.8%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F05268	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #8 & #9	Slope, cross	6.7%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F05269	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Slope, cross	3.8%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F05270	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Slope, cross	3.9%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F05271	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Slope, cross	3.9%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F05272	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Slope, cross	4.0%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05273	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Slope, cross	4.3%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F05274	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#9	Slope, cross	4.8%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F05275	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#6	Slope, cross	5.0%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F05276	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#7	Slope, cross	5.2%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F05277	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#8	Slope, cross	7.0%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F05278	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Slope, running	2.2%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F05279	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Slope, running	2.5%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F05280	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Slope, running	2.1%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F05281	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Slope, running	2.5%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F05282	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#9	Van sign?	N	No	Van Accessible' sign is not present.	1-Entry	Install a 'Van Accessible' sign.		When Renovated	n/a	TBD - Pre-ADA
F05283	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Width	58	No	Access aisle is too narrow.	1-Entry	Restripe the parking space and aisle to provide a compliant sized access aisle.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F05284	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #8 & #9	Width	57.5	No	Access aisle is too narrow.	1-Entry	Restripe the parking space and aisle to provide a compliant sized access aisle.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F05351	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Facility Specifications		Cars obstruct pathway	Y	No	Cars protrude into path of travel.	1-Entry	Install curb stops at the head of parking spaces to avoid obstruction in the path of travel.		2016	$ -	Internal Staff - Operations
F05352	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#1	Height, sign	54	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	2017	$ 100.00	Internal Staff - Operations
F05353	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#2	Height, sign	55	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	2017	$ 100.00	Internal Staff - Operations
F05354	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#3	Height, sign	55	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	2017	$ 100.00	Internal Staff - Operations
F05355	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#4	Height, sign	55	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	2017	$ 100.00	Internal Staff - Operations
F05356	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#5	Height, sign	55	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	2017	$ 100.00	Internal Staff - Operations
F05357	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#6	Height, sign	56.5	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	2017	$ 100.00	Internal Staff - Operations
F05358	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Facility Specifications		Number, accessible	6	No	Too few accessible parking spaces and van accessible parking spaces.	1-Entry	Provide a total of 7 accessible parking spaces, 2 of which should be a van accessible size parking spaces.	7 minimum	2017	$ 50.00	Part of Annual Parking project
F05359	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Facility Specifications		Number, van spaces	0	No	Too few van accessible parking spaces are provided.	1-Entry	Provide the minimum number of required van accessible parking spaces.	2 minimum	2017	$ 100.00	Part of Annual Parking project

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05360	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Access Aisle	Between parking spaces #5 & #6	Slope, cross	2.4%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	Within Tolerance (per Assessment)
F05361	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Access Aisle	Between parking spaces #3 & #4	Slope, cross	2.7%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	Within Tolerance (per Assessment)
F05362	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#5	Slope, cross	2.8%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	Within Tolerance (per Assessment)
F05363	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#6	Slope, cross	2.9%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	Within Tolerance (per Assessment)
F05364	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#4	Slope, cross	4.7%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Mill & Overlay -or- Relocate Space
F05365	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Access Aisle	#1	Slope, running	2.9%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	Within Tolerance (per Assessment)
F05366	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#3	Slope, running	2.4%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	Within Tolerance (per Assessment)
F05367	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#4	Slope, running	2.4%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	Within Tolerance (per Assessment)
F05368	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#1	Slope, running	2.8%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	Within Tolerance (per Assessment)
F05369	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#2	Slope, running	2.8%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	Within Tolerance (per Assessment)
F05370	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Access Aisle	Between parking spaces #3 & #4	Width	58	No	Access aisle is too narrow.	1-Entry	Restripe the parking space and aisle to provide a compliant sized access aisle.	60 inches minimum	2017	$ 50.00	Part of 2017 Re-Stripe
F07465	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Urinal		Clearance, parallel	27.5	No	Clear floor space is too narrow.	3-Restrooms	Remove the separator or reconfigure the urinals.	30 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F07466	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	When Renovated	n/a	TBD - Pre-ADA
F07467	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Urinal		Depth	11	No	Urinal is not deep enough.	3-Restrooms	Install a urinal with the correct depth.	13.5 inches	When Renovated	n/a	TBD - Pre-ADA
F07468	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	16	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	When Renovated	n/a	TBD - Pre-ADA
F07469	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	5	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	When Renovated	n/a	TBD - Pre-ADA
F07470	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Lavatory Sink		Height	35	No	Lavatory sink is too high.	3-Restrooms	Lower the lavatory sink to the correct height.	34 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F07471	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Changing Station		Height	36	No	Work surface does not comply with height requirements.	3-Restrooms	Lower the work surface to a compliant height.	Between 28 and 34 inches	When Renovated	n/a	TBD - Pre-ADA
F07472	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Mirror		Height, bottom	40.5	No	Mirror is too high.	5-Tolerance	No action recommended - within construction tolerance.	40 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F07474	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Opening force	15	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	When Renovated	n/a	TBD - Pre-ADA
F07475	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		When Renovated	n/a	TBD - Pre-ADA
F07528	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Medical Wing	3-Employee Common	Signage		Braille?	No tactile or Braille	No	Signage does not provide Braille.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		When Renovated	n/a	TBD - Pre-ADA
F07529	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Medical Wing	3-Employee Common	Dispenser	TP	Dimension from water closet seat	12.5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	When Renovated	n/a	TBD - Pre-ADA
F07530	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Medical Wing	3-Employee Common	Water Closet		Dimension, sidewall	19	No	Toilet is located too far from the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	When Renovated	n/a	TBD - Pre-ADA
F07531	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Medical Wing	3-Employee Common	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F07532	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Medical Wing	3-Employee Common	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		When Renovated	n/a	TBD - Pre-ADA
F07533	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Medical Wing	3-Employee Common	Signage		Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		When Renovated	n/a	TBD - Pre-ADA
F07536	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Staff lower level	3-Employee Common	Door Gate		Clearance, vertical	79.5	No	Vertical clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	80 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F07537	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Staff lower level	3-Employee Common	Dispenser	TP	Dimension from water closet seat	16	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	When Renovated	n/a	TBD - Pre-ADA
F07538	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Staff lower level	3-Employee Common	Lavatory Sink		Dimension, knee clearance	26.5	No	Knee clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	27 inches	When Renovated	n/a	TBD - Pre-ADA
F07539	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Staff lower level	3-Employee Common	Water Closet		Dimension, sidewall	19	No	Toilet is located too far from the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	When Renovated	n/a	TBD - Pre-ADA
F07540	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Staff lower level	3-Employee Common	Water Closet		Dimension, sidewall	14.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	When Renovated	n/a	TBD - Pre-ADA

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07541	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Staff lower level	3-Employee Common	Water Closet		Dimension, wide side	28	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F07542	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Staff lower level	3-Employee Common	Water Closet		Dimension, wide side	24.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F07543	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Staff lower level	3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		When Renovated	n/a	TBD - Pre-ADA
F07544	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Staff lower level	3-Employee Common	Coat Hook		Height	60	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F07545	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Staff lower level	3-Employee Common	Dispenser	Soap	Height	50	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F07546	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Staff lower level	3-Employee Common	Lavatory Sink		Height	36.5	No	Lavatory sink is too high.	3-Restrooms	Lower the lavatory sink to the correct height.	34 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F07547	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Staff lower level	3-Employee Common	Mirror		Height, bottom	55	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F07575	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - East hallway	3-Employee Common	Dispenser	TP	Dimension from water closet seat	1	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	When Renovated	n/a	TBD - Pre-ADA
F07576	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - East hallway	3-Employee Common	Water Closet		Dimension, sidewall	25	No	Toilet is located too far from the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	When Renovated	n/a	TBD - Pre-ADA
F07577	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - East hallway	3-Employee Common	Water Closet		Dimension, wide side	26.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F07578	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - East hallway	3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		When Renovated	n/a	TBD - Pre-ADA
F07579	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - East hallway	3-Employee Common	Coat Hook		Height	60	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F07580	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - East hallway	3-Employee Common	Dispenser	PT	Height	54	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F07581	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - East hallway	3-Employee Common	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F07582	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - East hallway	3-Employee Common	Water Closet		Height, seat	16	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	When Renovated	n/a	TBD - Pre-ADA
F07591	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - Staff library	3-Employee Common	Dispenser	TP	Dimension from water closet seat	17	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	When Renovated	n/a	TBD - Pre-ADA
F07592	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - Staff library	3-Employee Common	Water Closet		Dimension, sidewall	15	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	When Renovated	n/a	TBD - Pre-ADA
F07593	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - Staff library	3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		When Renovated	n/a	TBD - Pre-ADA
F07594	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - Staff library	3-Employee Common	Coat Hook		Height	73	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F07595	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - Staff library	3-Employee Common	Dispenser	PT	Height	54	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F07596	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - Staff library	3-Employee Common	Mirror		Height, bottom	44.5	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F07597	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - Staff library	3-Employee Common	Grab Bar		Other attribute	None Provided	No	No grab bars provided.	3-Restrooms	Install grab bars on the rear and side wall.		When Renovated	n/a	TBD - Pre-ADA
F07598	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - Staff library	3-Employee Common	Signage		Other attribute	None	No	Braille and raised letter signage is not provided.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		When Renovated	n/a	TBD - Pre-ADA
F07626	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Clearance, pull parallel	11	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F07627	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Closing speed	3	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	When Renovated	n/a	TBD - Pre-ADA
F07628	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	21	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	When Renovated	n/a	TBD - Pre-ADA
F07629	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		When Renovated	n/a	TBD - Pre-ADA
F07630	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Hardware type	Knob	No	Hardware requires twisting of wrist.	3-Restrooms	Install lever type door hardware.		When Renovated	n/a	TBD - Pre-ADA
F07631	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Mirror		Height, bottom	40.5	No	Mirror is too high.	5-Tolerance	No action recommended - within construction tolerance.	40 inches maximum	When Renovated	n/a	TBD - Pre-ADA

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07633	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Opening force	15	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	When Renovated	n/a	TBD - Pre-ADA
F07634	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		When Renovated	n/a	TBD - Pre-ADA
F07689	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Signage		Braille?	No tactile or Braille	No	Signage does not provide Braille.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		When Renovated	n/a	TBD - Pre-ADA
F07690	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Dispenser	TP	Dimension from water closet seat	12	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	When Renovated	n/a	TBD - Pre-ADA
F07691	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	4	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	When Renovated	n/a	TBD - Pre-ADA
F07692	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Water Closet		Dimension, wide side	27	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F07693	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F07694	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Water Closet		Height, seat	16	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	When Renovated	n/a	TBD - Pre-ADA
F07720	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Door Gate		Clear opening	29	No	Clear opening is too narrow.	3-Restrooms	Reframe the doorway to provide a compliant clear opening width. Offset hinges may be used to facilitate the process.	32 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F07721	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Water Closet		Clearance, parallel	57	No	Clearance at water closet is too narrow.	3-Restrooms	Remodel the restroom to provide at least the minimum required width.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F07722	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Dispenser	TP	Dimension from water closet seat	12	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	When Renovated	n/a	TBD - Pre-ADA
F07723	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Lavatory Sink		Dimension, knee clearance	26	No	Knee clearance is too low.	3-Restrooms	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	When Renovated	n/a	TBD - Pre-ADA
F07724	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Water Closet		Dimension, sidewall	15.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	When Renovated	n/a	TBD - Pre-ADA
F07725	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Water Closet		Dimension, wide side	19	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F07726	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		When Renovated	n/a	TBD - Pre-ADA
F07727	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Door Gate		Hardware type	Knob	No	Hardware requires twisting of wrist.	3-Restrooms	Install lever type door hardware.		When Renovated	n/a	TBD - Pre-ADA
F07728	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Coat Hook		Height	60	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F07729	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Dispenser	Feminine products	Height	53	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F07730	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Mirror		Height, bottom	40.5	No	Mirror is too high.	5-Tolerance	No action recommended - within construction tolerance.	40 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F07742	Adams County Detention Center	F Module	Interior	Owned	Restroom	Men's - F Adm locker room	3-Employee Common	Dispenser	TP	Dimension from water closet seat	14.5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2017	$ 100.00	Relocate or Replace Dispenser
F07743	Adams County Detention Center	F Module	Interior	Owned	Restroom	Men's - F Adm locker room	3-Employee Common	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 100.00	Install new Hinges
F07764	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - #F1100 Housing Dorm	3-Employee Common	Grab Bar	Side	Dimension, end to wall	9.5	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Replace Grab Bar
F07765	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - #F1100 Housing Dorm	3-Employee Common	Shower Compartment	Stainless steel unit	Hand spray unit?	N	No	Shower does not include a handheld spray unit.	3-Restrooms	Replace the shower head with a handheld spray unit, mounted a maximum of 48 inches above the finished floor, with a spray hose no less than 59 inches long.		2017	$ 250.00	Install new Shower Head
F07766	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - #F1100 Housing Dorm	3-Employee Common	Grab Bar	Side	Height, top	37	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	2017	$ 250.00	Replace Grab Bar
F07767	Adams County Detention Center	F Module	3rd Floor	Owned	Restroom	Unisex - #F1100 Housing Dorm	3-Employee Common	Lavatory Sink		Clearance, perpendicular	32	No	Clear floor space is too short.	3-Restrooms	Reconfigure the lavatory sink to provide at least the minimum clear floor space.	48 inches minimum	2017	$ 1,500.00	Rework Lavatory
F07781	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Dispenser	TP	Dimension from water closet seat	12	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2017	$ 100.00	Relocate or Replace Dispenser
F07782	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Grab Bar	Side	Dimension, end to wall	10	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Replace Grab Bar

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07783	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	7	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2017	$ 250.00	Replace Grab Bar
F07784	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Water Closet		Dimension, sidewall	18.5	No	Toilet is located too far from the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2020	$ 2,500.00	Rework Wall or Toilet
F07785	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Water Closet		Dimension, wide side	32.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2020	$ 2,500.00	Rework Wall or Toilet
F07786	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 100.00	Install Pipe Wrap
F07787	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Coat Hook		Height	72	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2016	$ 50.00	Rework Coat Hook
F07788	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Relocate or Replace Mirror
F07806	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Unisex - F Dorm	3-Employee Common	Lavatory Sink		Clearance, perpendicular	32	No	Clear floor space is too short.	3-Restrooms	Reconfigure the lavatory sink to provide at least the minimum clear floor space.	48 inches minimum	2017	$ 1,500.00	Rework Lavatory
F07807	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Unisex - F Dorm	3-Employee Common	Dispenser	TP	Dimension from water closet seat	11	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2017	$ 100.00	Relocate or Replace Dispenser
F07808	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Unisex - F Dorm	3-Employee Common	Toilet Compartment		Dimension, door to partition	5.5	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2020	$ 5,000.00	Rework Wall or Toilet
F07809	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Unisex - F Dorm	3-Employee Common	Dispenser	PT	Height	51	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Relocate or Replace Dispenser
F07810	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Unisex - F Dorm	3-Employee Common	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Relocate or Replace Mirror
F07811	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Unisex - F Dorm	3-Employee Common	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 100.00	Install new Hinges
F07812	Adams County Detention Center	F Module	3rd Floor	Owned	Restroom	Unisex - #F1100 Housing Dorm	3-Employee Common	Dispenser	TP	Dimension from water closet seat	11	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2017	$ 100.00	Relocate or Replace Dispenser
F07813	Adams County Detention Center	F Module	3rd Floor	Owned	Restroom	Unisex - #F1100 Housing Dorm	3-Employee Common	Toilet Compartment		Dimension, door to partition	5.5	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2020	$ 2,500.00	Rework Wall or Toilet
F07814	Adams County Detention Center	F Module	3rd Floor	Owned	Restroom	Unisex - #F1100 Housing Dorm	3-Employee Common	Dispenser	PT	Height	51	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Relocate or Replace Dispenser
F07815	Adams County Detention Center	F Module	3rd Floor	Owned	Restroom	Unisex - #F1100 Housing Dorm	3-Employee Common	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Relocate or Replace Mirror
F07816	Adams County Detention Center	F Module	3rd Floor	Owned	Restroom	Unisex - #F1100 Housing Dorm	3-Employee Common	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 100.00	Install new Hinges
F07830	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Lavatory Sink		Clearance, perpendicular	32	No	Clear floor space is too short.	3-Restrooms	Reconfigure the lavatory sink to provide at least the minimum clear floor space.	48 inches minimum	2020	$ 2,500.00	Rework Wall or Toilet
F07831	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Dispenser	TP	Dimension from water closet seat	11	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2017	$ 100.00	Relocate or Replace Dispenser
F07832	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Toilet Compartment		Dimension, door to partition	5.5	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2020	$ 2,500.00	Rework Wall or Toilet
F07833	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Dispenser	PT	Height	51	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Relocate or Replace Dispenser
F07834	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Relocate or Replace Mirror
F07835	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 100.00	Install new Hinges
F15601	Adams County Detention Center	Existing Jail	Interior	Owned	Sport Area	Weight room	3-Employee Common	Door Gate		Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	When Renovated	n/a	TBD - Pre-ADA
F15701	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway	From parking lot	1-Public Unsupervised	Curb Ramp		Landing?	N	No	No landing provided at top of curb ramp.	1-Entry	Provide a landing at the top of the curb ramp that is the same width as the curb ramp and at least 36 inches long.		When Renovated	n/a	TBD - Pre-ADA
F15711	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway	South parking lot near Facilities Management	1-Public Unsupervised	Walking Surface		Width, opening	2	No	Opening in walking surface is too wide.	1-Entry	Fill/patch the gaps in the walking surface.	0.5 inch maximum	When Renovated	n/a	TBD - Pre-ADA
F15712	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway	Youth Services Public Entrance	1-Public Unsupervised	Walking Surface	At curb ramp	Height, level change	2	No	Vertical change in level is too high.	1-Entry	Grind the surface to provide a change in level no higher than 1/2 inch (beveled), with a slope not > 1:2.		When Renovated	n/a	TBD - Pre-ADA

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15713	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway	Youth Services Public Entrance	1-Public Unsupervised	Curb Ramp		Slope, running	11.0%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp, curb, and gutter to provide compliant running slope.	8.33% maximum	When Renovated	n/a	TBD - Pre-ADA
F15719	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Walking Surface		Slope, cross	2.4%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F15720	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Landing	Between sections #1 & #2	Slope, running	4.3%	No	Slope is too steep.	1-Entry	Rebuild the landing to provide compliant running and cross slopes.	2.08% maximum	When Renovated	n/a	TBD - Pre-ADA
F15721	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Ramp	Section #1	Slope, running	8.7%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	8.33% maximum	When Renovated	n/a	TBD - Pre-ADA
F15722	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Ramp	Section #3	Slope, running	9.3%	No	Slope is too steep.	1-Entry	Rebuild the ramp with a compliant running slope, cross slope, and landing.	8.33% maximum	When Renovated	n/a	TBD - Pre-ADA
F15723	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Walking Surface		Slope, running	6.3%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with compliant running and cross slopes, or install handrails, edge protection, and landings required for ramps.	5.0% maximum	When Renovated	n/a	TBD - Pre-ADA
F15754	Adams County Detention Center	F Module	Exterior	Owned	Walkway	Employee Parking - Lot F	3-Employee Common	Walking Surface		Slope, running	8.7%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with compliant running and cross slopes, or install handrails, edge protection, and landings required for ramps.	5.0% maximum	2020	$ 10,000.00	Potential to relocate accessible route/spaces - otherwise regrade and pave
F15758	Adams County Detention Center	F Module	Exterior	Owned	Walkway	From parking lot to Employee entrance	3-Employee Common	Walking Surface		Slope, running	8.7%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with compliant running and cross slopes, or install handrails, edge protection, and landings required for ramps.	5.0% maximum	2020	$ 10,000.00	Potential to relocate accessible route/spaces - otherwise regrade and pave
F00018	Adams County Fair Grounds	Exhibit Hall	Exterior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Clearance, vertical	79	No	Vertical clearance is too low.	1-Entry	Replace the doorway with a compliant vertical clearance.	80 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F00019	Adams County Fair Grounds	Exhibit Hall	Exterior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Opening force	9	No	Opening force is too high.	1-Entry	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00020	Adams County Fair Grounds	Exhibit Hall	Exterior	Owned	Assembly Area		1-Public Unsupervised	Walking Surface	At door	Width, opening	1.25	No	Opening in walking surface is too wide.	1-Entry	Repair the gap in the walking surface.	0.5 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F00027	Adams County Fair Grounds	Lesser Bldg	Exterior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	1-Entry	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F00028	Adams County Fair Grounds	Lesser Bldg	Exterior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Hardware type	Knob	No	Hardware requires twisting of wrist.	1-Entry	Install lever type door hardware.		When Renovated	n/a	TBD - Pre-ADA
F00029	Adams County Fair Grounds	Lesser Bldg	Exterior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Opening force	10	No	Opening force is too high.	1-Entry	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00040	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Closing speed	3	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F00041	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Hardware type	Knob	No	Hardware requires twisting of wrist.	2-Services	Install lever type door hardware.		When Renovated	n/a	TBD - Pre-ADA
F00042	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Opening force	9	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00043	Adams County Fair Grounds	Old Red Cross Bldg	Exterior	Owned	Assembly Area		1-Public Unsupervised	Walking Surface	At door	Width, opening	1.5	No	Opening in walking surface is too wide.	1-Entry	Repair the gap in the walking surface.	0.5 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F00053	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #1	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F00054	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #1	1-Public Unsupervised	Door Gate		Opening force	8	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00067	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #2	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F00068	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #2	1-Public Unsupervised	Door Gate		Opening force	8	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00070	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #3	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F00071	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #3	1-Public Unsupervised	Door Gate		Opening force	8	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00072	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #1	1-Public Unsupervised	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2020	$ 5,000.00	Rework Counter
F00073	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #1	1-Public Unsupervised	Dispenser	PT	Height	54.5	No	Dispenser is too high.	2-Services	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Relocate or Replace Dispenser
F00074	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #1	1-Public Unsupervised	Lavatory Sink		Height	36.25	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2020	$ 2,500.00	Rework Lavatory
F00075	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #2	1-Public Unsupervised	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2020	$ 5,000.00	Rework Counter
F00076	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #2	1-Public Unsupervised	Dispenser	PT	Height	54.5	No	Dispenser is too high.	2-Services	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Relocate or Replace Dispenser
F00077	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #2	1-Public Unsupervised	Lavatory Sink		Height	36.25	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2020	$ 2,500.00	Rework Lavatory
F00078	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #3	1-Public Unsupervised	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2020	$ 5,000.00	Rework Counter
F00079	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #3	1-Public Unsupervised	Dispenser	PT	Height	54.5	No	Dispenser is too high.	2-Services	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Relocate or Replace Dispenser
F00080	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #3	1-Public Unsupervised	Lavatory Sink		Height	36.25	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2020	$ 2,500.00	Rework Lavatory

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00922	Adams County Fair Grounds		Exterior	Owned	Concessions	Exterior of indoor arena	1-Public Unsupervised	Counter		Height	42	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2020	$ 5,000.00	Rework Counter
F00929	Adams County Fair Grounds		Exterior	Owned	Concessions		1-Public Unsupervised	Counter		Height	46	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2020	$ 5,000.00	Rework Counter
F03693	Adams County Fair Grounds	Sale Barn	Interior	Owned	Hallway		1-Public Unsupervised	Ramp	Leading to exit	Edge protection?	N	No	No edge protection provided for ramp.	2-Services	Install edge protection on both sides of the ramp, for the entire length of the ramp.	4 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F03694	Adams County Fair Grounds		Interior	Owned	Hallway		1-Public Unsupervised	Ramp		Length	42 feet	No	Ramp run is too long between landings.	2-Services	Redesign, remove, and replace the ramp run with no more than 30 inches of vertical rise between the landings.	Maximum 30 feet of ramp between landings	2020	$ 25,000.00	Rework Ramp (undetermined location)
F04243	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Kitchen		1-Public Unsupervised	Kitchen Clearance		Dimension between counters	39	No	Clearance between counters is too narrow.	2-Services	Reconfigure the kitchen cabinets to provide at least the minimum clearance between the counters.	40 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F04244	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Kitchen		1-Public Unsupervised	Counter		Height	45.5	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	When Renovated	n/a	TBD - Pre-ADA
F04245	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Kitchen		1-Public Unsupervised	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	When Renovated	n/a	TBD - Pre-ADA
F05416	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Access aisle?	N	No	No access aisle provided.	1-Entry	Provide a marked access aisle adjacent to the parking space.	60 inches minimum	2017	$ 50.00	Part of Annual Parking project
F05417	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Access aisle?	N	No	No access aisle provided.	1-Entry	Provide a marked access aisle adjacent to the parking space.	60 inches minimum	2017	$ 50.00	Part of Annual Parking project
F05418	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Height, sign	52.5	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	2017	$ 50.00	Part of Annual Parking project
F05419	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Height, sign	52.5	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	2017	$ 50.00	Part of Annual Parking project
F05420	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, van spaces	0	No	Too few van accessible parking spaces are provided.	1-Entry	Provide the minimum number of required van accessible parking spaces.	1 minimum	2017	$ 50.00	Part of Annual Parking project
F05421	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Surface Material	Gravel	No	Walking surface is not stable, firm, and slip resistant.	1-Entry	Provide an accessible route connecting the bike path to the parking lot.		2017	$ 50.00	Part of Annual Parking project
F05436	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Access aisle?	N	No	No access aisle provided.	1-Entry	Provide a marked access aisle adjacent to the parking space.	60 inches minimum	2017	$ 50.00	Part of Annual Parking project
F05437	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Height, sign	54	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	2017	$ 50.00	Part of Annual Parking project
F05438	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Slope, running	3.0%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2017	$ 50.00	Part of Annual Parking project
F05449	Adams County Fair Grounds		Exterior	Owned	Parking Facility	At play area	1-Public Unsupervised	Parking Space	#1	Access aisle?	N	No	No access aisle provided.	1-Entry	Provide a marked access aisle adjacent to the parking space.	60 inches minimum	2017	$ 50.00	Part of Annual Parking project
F05450	Adams County Fair Grounds		Exterior	Owned	Parking Facility	At play area	1-Public Unsupervised	Parking Space	#2	Access aisle?	N	No	No access aisle provided.	1-Entry	Provide a marked access aisle adjacent to the parking space.	60 inches minimum	2017	$ 50.00	Part of Annual Parking project
F05451	Adams County Fair Grounds		Exterior	Owned	Parking Facility	At play area	1-Public Unsupervised	Facility Specifications		Cars obstruct pathway	Y	No	Cars protrude into path of travel.	1-Entry	Install curb stops at the head of parking spaces to avoid obstruction in the path of travel.		2017	$ 50.00	Part of Annual Parking project
F05452	Adams County Fair Grounds		Exterior	Owned	Parking Facility	At play area	1-Public Unsupervised	Parking Space	#1	Height, sign	40.5	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	2017	$ 50.00	Part of Annual Parking project
F05453	Adams County Fair Grounds		Exterior	Owned	Parking Facility	At play area	1-Public Unsupervised	Parking Space	#2	Height, sign	42	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	2017	$ 50.00	Part of Annual Parking project
F05454	Adams County Fair Grounds		Exterior	Owned	Parking Facility	At play area	1-Public Unsupervised	Facility Specifications		Number, van spaces	0	No	Too few van accessible parking spaces are provided.	1-Entry	Provide the minimum number of required van accessible parking spaces.	1 minimum	2017	$ 50.00	Part of Annual Parking project
F05455	Adams County Fair Grounds		Exterior	Owned	Parking Facility	At play area	1-Public Unsupervised	Parking Space	#1	Surface material	Gravel	No	Walking surface is not stable, firm, and slip resistant.	1-Entry	Provide an accessible route connecting the play area to the parking lot.		2017	$ 50.00	Part of Annual Parking project
F05456	Adams County Fair Grounds		Exterior	Owned	Parking Facility	At play area	1-Public Unsupervised	Parking Space	#2	Surface material	Gravel	No	Walking surface is not stable, firm, and slip resistant.	1-Entry	Provide an accessible route connecting the play area to the parking lot.		2017	$ 50.00	Part of Annual Parking project
F05465	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Facility Specifications		Number, accessible	12	No	Too few accessible parking spaces and van accessible parking spaces.	1-Entry	Provide a total of 16 accessible parking spaces, 3 of which should be a van accessible size parking spaces.	16 minimum	2017	$ 50.00	Part of Annual Parking project

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05466	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Facility Specifications		Number, van spaces	0	No	Too few van accessible parking spaces are provided.	1-Entry	Provide the minimum number of required van accessible parking spaces.	3 minimum	2017	$ 50.00	Part of Annual Parking project
F05493	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Facility Specifications		Number, van spaces	0	No	Too few van accessible parking spaces are provided.	1-Entry	Provide the minimum number of required van accessible parking spaces.	1 minimum	2017	$ 50.00	Part of Annual Parking project
F05530	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Facility Specifications		Number, van spaces	0	No	Too few van accessible parking spaces are provided.	1-Entry	Provide the minimum number of required van accessible parking spaces.	2 minimum	2017	$ 50.00	Part of Annual Parking project
F05531	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#1	Van sign?	N	No	Van Accessible' sign is not present.	1-Entry	Install a 'Van Accessible' sign.		2017	$ 50.00	Part of Annual Parking project
F05532	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Width	58.5	No	Access aisle is too narrow.	1-Entry	Restripe the parking space and aisle to provide a compliant sized access aisle.	60 inches minimum	2017	$ 50.00	Part of Annual Parking project
F05596	Adams County Fair Grounds		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, van spaces	0	No	Too few van accessible parking spaces are provided.	1-Entry	Provide the minimum number of required van accessible parking spaces.	1 minimum	2017	$ 50.00	Part of Annual Parking project
F07322	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Ramp	From sidewalk to play structure	Edge protection?	N	No	No edge protection provided for ramp.	1-Entry	Install edge protection on both sides of ramp.	4 inches maximum	2017	$ 50.00	Part of Annual Parking project
F07323	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Area Specifications		Number, ground components on accessible route	0	No	Too few ground level play components are provided on an accessible route.	2-Services	Provide not < 5 ground level play components of not < 3 different types with clear ground space at each. Provide an accessible route connecting perimeter of play area to each ground level component required to be accessible.	5 of 3	2017	$ 50.00	Part of Annual Parking project
F07324	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Walking Surface		Surface material	Pea gravel	No	Surface of ground level route to ground level play components or to transfer system is not an accessible surface.	2-Services	Provide an accessible route connecting the perimeter of the play area to the entry point of the elevated composite play structures.		2017	$ 50.00	Part of Annual Parking project
F07361	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Door Gate	Under play structure	Clearance, vertical	64	No	Vertical clearance is too low.	2-Services	Replace the doorway with a compliant vertical clearance.	80 inches minimum	2017	$ 50.00	Part of Annual Parking project
F07362	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Area Specifications		Number, elevated components on accessible route	3	No	Too few elevated play components are provided on an accessible route.	2-Services	Provide not < 3 elevated play components on an accessible route. Alter structure or add an accessible Entry Point to composite structure so that not < 3 additional elevated components are on an accessible route, 36 inches wide.	9 minimum	2017	$ 50.00	Part of Annual Parking project
F07363	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Area Specifications		Number, ground components	2	No	Too few ground level play components are provided on an accessible route.	2-Services	Provide not < 6 ground level play components of not < 3 different types with clear ground space at each. Provide an accessible route connecting the perimeter of the play area to each ground level component required to be accessible.	6 of 3	2017	$ 50.00	Part of Annual Parking project
F07875	Adams County Fair Grounds	Exhibit Hall	Exterior	Owned	Restroom	Men's - Back side	1-Public Unsupervised	Door Gate		Height, threshold	0.5	No	Threshold is too high.	3-Restrooms	Provide a threshold which is 0.25 inch maximum, or a beveled threshold which is 0.5 inch maximum, at the door entrance.	0.5 inch maximum	When Renovated	n/a	TBD - Pre-ADA
F07876	Adams County Fair Grounds	Exhibit Hall	Exterior	Owned	Restroom	Back Hall	1-Public Unsupervised	Signage		Height, bottom	60.5	No	Signage is too high.	3-Restrooms	Remount sign with tactile letters located 48 inches minimum and 60 inches maximum, above the finished floor, measured from the baseline of the tactile letters.	48 to 60 inches	When Renovated	n/a	TBD - Pre-ADA
F07877	Adams County Fair Grounds	Exhibit Hall	Exterior	Owned	Restroom	Back Hall	1-Public Unsupervised	Signage		Location	On door	No	Sign is not mounted in the correct location.	3-Restrooms	Move the sign to the latch side of the door.		When Renovated	n/a	TBD - Pre-ADA
F07893	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	Ambulatory	Clear opening	28	No	Clear opening is too narrow.	3-Restrooms	Reframe the doorway to provide a compliant clear opening width. Offset hinges may be used to facilitate the process.	32 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F07894	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Ambulatory Compartment		Clearance, parallel	30	No	Ambulatory compartment is too narrow.	3-Restrooms	Reconfigure the toilet compartments to accommodate a correct sized ambulatory compartment.	60" deep and 35" to 37" wide	When Renovated	n/a	TBD - Pre-ADA
F07896	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP - Amb	Dimension from water closet seat	19.5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	When Renovated	n/a	TBD - Pre-ADA
F07897	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP - #1	Dimension from water closet seat	14	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	When Renovated	n/a	TBD - Pre-ADA
F07898	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP - #2	Dimension from water closet seat	12	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	When Renovated	n/a	TBD - Pre-ADA
F07899	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	#1	Dimension, door to partition	19	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	When Renovated	n/a	TBD - Pre-ADA
F07900	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	#2	Dimension, door to partition	6.75	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	When Renovated	n/a	TBD - Pre-ADA
F07901	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear - #2 stall	Dimension, end to wall	5.5	No	Grab bar is not mounted in correct location.	5-Tolerance	No action recommended - within construction tolerance.	6 inches	When Renovated	n/a	TBD - Pre-ADA
F07902	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet	#1	Dimension, sidewall	15.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	When Renovated	n/a	TBD - Pre-ADA

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07903	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		When Renovated	n/a	TBD - Pre-ADA
F07904	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	#1	Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		When Renovated	n/a	TBD - Pre-ADA
F07905	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	#2	Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		When Renovated	n/a	TBD - Pre-ADA
F07906	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Coat Hook	Ambulatory	Height	66	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F07907	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	PT	Height	49	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F07909	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear - #1 stall	Length	30	No	Rear grab bar is too short.	3-Restrooms	Replace the grab bar with a 36 inch long minimum grab bar.	36 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F07910	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear - #2 stall	Length	30	No	Rear grab bar is too short.	3-Restrooms	Replace the grab bar with a 36 inch long minimum grab bar.	36 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F07911	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP - Amb	Over obstruction?	Y	No	Toilet paper dispenser is mounted above the grab bar.	3-Restrooms	Move the toilet paper dispenser to a compliant position under the grab bar.		When Renovated	n/a	TBD - Pre-ADA
F07912	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP - #1	Over obstruction?	Y	No	Toilet paper dispenser is mounted above the grab bar.	3-Restrooms	Move the toilet paper dispenser to a compliant position under the grab bar.		When Renovated	n/a	TBD - Pre-ADA
F07913	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP - #2	Over obstruction?	Y	No	Toilet paper dispenser is mounted above the grab bar.	3-Restrooms	Move the toilet paper dispenser to a compliant position under the grab bar.		When Renovated	n/a	TBD - Pre-ADA
F07914	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	#1	Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		When Renovated	n/a	TBD - Pre-ADA
F07993	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's - Back side	1-Public Unsupervised	Door Gate		Width, opening	1	No	Opening in walking surface is too wide.	3-Restrooms	Repair the gap in the walking surface.	0.5 inch maximum	When Renovated	n/a	TBD - Pre-ADA
F07998	Adams County Fair Grounds	Exhibit Hall	Exterior	Owned	Restroom	Men's - Back side	1-Public Unsupervised	Door Gate		Opening force	9	No	Opening force is too high.	3-Restrooms	Although exterior door force is not covered under the ADA, it is recommended that this be adjusted or install an automatic door opener.	5 lbs maximum	When Renovated	n/a	TBD - Pre-ADA
F08000	Adams County Fair Grounds	Exhibit Hall	Exterior	Owned	Restroom	Women's - Back side	1-Public Unsupervised	Door Gate		Height, threshold	2	No	Threshold is too high.	3-Restrooms	Provide a threshold which is 0.25 inch maximum, or a beveled threshold which is 0.5 inch maximum, at the door entrance.	0.5 inch maximum	When Renovated	n/a	TBD - Pre-ADA
F08002	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Door Gate	Partition into shower & urinal	Clear opening	24	No	Clear opening is too narrow.	3-Restrooms	Reframe the doorway to provide a compliant clear opening width. Offset hinges may be used to facilitate the process.	32 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08018	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Ambulatory Compartment		Clear opening	28.5	No	Clear opening is too narrow.	3-Restrooms	Reframe the doorway to provide a compliant clear opening width. Offset hinges may be used to facilitate the process.	32 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08019	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Ambulatory Compartment		Clearance, parallel	30	No	Ambulatory compartment is too narrow.	3-Restrooms	Reconfigure the toilet compartments to accommodate a correct sized ambulatory compartment.	60" deep and 35" to 37" wide	When Renovated	n/a	TBD - Pre-ADA
F08020	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Amb - Side #2	Clearance, to wall	1.75	No	Space between wall and grab bar is too wide.	5-Tolerance	No action recommended - within construction tolerance.	1.5 inches	When Renovated	n/a	TBD - Pre-ADA
F08021	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP - #1	Dimension from water closet seat	13	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	When Renovated	n/a	TBD - Pre-ADA
F08022	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP - #2	Dimension from water closet seat	12.5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	When Renovated	n/a	TBD - Pre-ADA
F08023	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP - Amb	Dimension from water closet seat	18	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	When Renovated	n/a	TBD - Pre-ADA
F08024	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment	#1	Dimension, door to partition	19	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	When Renovated	n/a	TBD - Pre-ADA
F08025	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment	#2	Dimension, door to partition	7	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	When Renovated	n/a	TBD - Pre-ADA
F08026	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear - #1 stall	Dimension, end to wall	5.5	No	Grab bar is not mounted in correct location.	5-Tolerance	No action recommended - within construction tolerance.	6 inches	When Renovated	n/a	TBD - Pre-ADA
F08027	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear - #2 stall	Dimension, end to wall	5.5	No	Grab bar is not mounted in correct location.	5-Tolerance	No action recommended - within construction tolerance.	6 inches	When Renovated	n/a	TBD - Pre-ADA
F08028	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side - #2 stall	Dimension, end to wall	11	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F08029	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		When Renovated	n/a	TBD - Pre-ADA
F08030	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Ambulatory Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		When Renovated	n/a	TBD - Pre-ADA

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08031	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment	#1	Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		When Renovated	n/a	TBD - Pre-ADA
F08032	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment	#2	Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		When Renovated	n/a	TBD - Pre-ADA
F08033	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Feminine products	Height	49.5	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F08034	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet	Ambulatory	Height, seat	15.5	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	When Renovated	n/a	TBD - Pre-ADA
F08036	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear - #1 stall	Length	30	No	Rear grab bar is too short.	3-Restrooms	Replace the grab bar with a 36 inch long minimum grab bar.	36 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08037	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear - #2 stall	Length	30	No	Rear grab bar is too short.	3-Restrooms	Replace the grab bar with a 36 inch long minimum grab bar.	36 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08038	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet	#1	Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		When Renovated	n/a	TBD - Pre-ADA
F08039	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet	#2	Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		When Renovated	n/a	TBD - Pre-ADA
F08040	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP - #1	Over obstruction?	Y	No	Toilet paper dispenser is mounted above the grab bar.	3-Restrooms	Move the toilet paper dispenser to a compliant position under the grab bar.		When Renovated	n/a	TBD - Pre-ADA
F08041	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP - #2	Over obstruction?	Y	No	Toilet paper dispenser is mounted above the grab bar.	3-Restrooms	Move the toilet paper dispenser to a compliant position under the grab bar.		When Renovated	n/a	TBD - Pre-ADA
F08042	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP - Amb	Over obstruction?	Y	No	Toilet paper dispenser is mounted above the grab bar.	3-Restrooms	Move the toilet paper dispenser to a compliant position under the grab bar.		When Renovated	n/a	TBD - Pre-ADA
F08043	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Ambulatory Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		When Renovated	n/a	TBD - Pre-ADA
F08044	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment	#1	Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		When Renovated	n/a	TBD - Pre-ADA
F08045	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment	#2	Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		When Renovated	n/a	TBD - Pre-ADA
F08123	Adams County Fair Grounds	Exhibit Hall	Exterior	Owned	Restroom	Women's - Back side	1-Public Unsupervised	Door Gate		Clearance, vertical	78.25	No	Vertical clearance is too low.	3-Restrooms	Replace the doorway with a compliant vertical clearance.	80 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08129	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's - Exhibit Hall rear	1-Public Unsupervised	Door Gate	Partition to showers	Clear opening	22	No	Clear opening is too narrow.	3-Restrooms	Reframe the doorway to provide a compliant clear opening width. Offset hinges may be used to facilitate the process.	32 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08130	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Door Gate		Opening force	11	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	When Renovated	n/a	TBD - Pre-ADA
F08142	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	43	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08143	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Clearance, pull perpendicular	57.5	No	Clearance on pull side of door is insufficient.	3-Restrooms	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08144	Adams County Fair Grounds	Grandstand	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.75	No	Space between wall and grab bar is too wide.	5-Tolerance	No action recommended - within construction tolerance.	1.5 inches	When Renovated	n/a	TBD - Pre-ADA
F08145	Adams County Fair Grounds	Grandstand	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.75	No	Space between wall and grab bar is too wide.	5-Tolerance	No action recommended - within construction tolerance.	1.5 inches	When Renovated	n/a	TBD - Pre-ADA
F08146	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Clearance, vertical	78	No	Vertical clearance is too low.	3-Restrooms	Replace the doorway with a compliant vertical clearance.	80 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08147	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	When Renovated	n/a	TBD - Pre-ADA
F08149	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4.75	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	When Renovated	n/a	TBD - Pre-ADA
F08150	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	3	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	When Renovated	n/a	TBD - Pre-ADA
F08151	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	10.5	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F08152	Adams County Fair Grounds	Grandstand	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	26.5	No	Knee clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	27 inches	When Renovated	n/a	TBD - Pre-ADA
F08153	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, sidewall	21.75	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	When Renovated	n/a	TBD - Pre-ADA

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08154	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, wide side	20.25	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08155	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		When Renovated	n/a	TBD - Pre-ADA
F08156	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		When Renovated	n/a	TBD - Pre-ADA
F08157	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Hardware type	Knob	No	Hardware requires twisting of wrist.	3-Restrooms	Install lever type door hardware.		When Renovated	n/a	TBD - Pre-ADA
F08158	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Hardware type	Twist	No	Hardware requires twisting of wrist.	3-Restrooms	Install lever type door hardware.		When Renovated	n/a	TBD - Pre-ADA
F08159	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	Soap	Height	52	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F08160	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	PT	Height	57	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F08161	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Mirror		Height, bottom	50	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F08162	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Urinal	None accessible	Height, rim	26	No	Urinal rim is too high.	3-Restrooms	Where multiple urinals are installed, replace or remount at least one urinal to the correct height.	17 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F08163	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Height, seat	19.5	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	When Renovated	n/a	TBD - Pre-ADA
F08164	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	No	No ambulatory toilet compartments are provided.	3-Restrooms	Provide 1 ambulatory compartment that is 35 to 37 inches wide, with grab bars on both sides of the compartment.	1 minimum	When Renovated	n/a	TBD - Pre-ADA
F08165	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		When Renovated	n/a	TBD - Pre-ADA
F08189	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Height, threshold	1	No	Threshold is too high.	3-Restrooms	Provide a threshold which is 0.25 inch maximum, or a beveled threshold which is 0.5 inch maximum, at the door entrance.	0.5 inch maximum	When Renovated	n/a	TBD - Pre-ADA
F08215	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	43	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08216	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Clearance, parallel	43	No	Clearance at water closet is too narrow.	3-Restrooms	Remodel the restroom to provide at least the minimum required width.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08217	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	57	No	Clearance on pull side of door is insufficient.	3-Restrooms	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08218	Adams County Fair Grounds	Grandstand	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.75	No	Space between wall and grab bar is too wide.	5-Tolerance	No action recommended - within construction tolerance.	1.5 inches	When Renovated	n/a	TBD - Pre-ADA
F08219	Adams County Fair Grounds	Grandstand	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.75	No	Space between wall and grab bar is too wide.	5-Tolerance	No action recommended - within construction tolerance.	1.5 inches	When Renovated	n/a	TBD - Pre-ADA
F08220	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, vertical	79	No	Vertical clearance is too low.	3-Restrooms	Replace the doorway with a compliant vertical clearance.	80 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08221	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	When Renovated	n/a	TBD - Pre-ADA
F08222	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	6.25	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	When Renovated	n/a	TBD - Pre-ADA
F08223	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	2.75	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	When Renovated	n/a	TBD - Pre-ADA
F08224	Adams County Fair Grounds	Grandstand	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	26.5	No	Knee clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	27 inches	When Renovated	n/a	TBD - Pre-ADA
F08225	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, sidewall	20	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	When Renovated	n/a	TBD - Pre-ADA
F08226	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, wide side	23.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08227	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		When Renovated	n/a	TBD - Pre-ADA
F08228	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Hardware type	Knob	No	Hardware requires twisting of wrist.	3-Restrooms	Install lever type door hardware.		When Renovated	n/a	TBD - Pre-ADA
F08229	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Hardware type	Twist	No	Hardware requires twisting of wrist.	3-Restrooms	Install lever type door hardware.		When Renovated	n/a	TBD - Pre-ADA
F08230	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Coat Hook		Height	59.5	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F08231	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Height	55	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	When Renovated	n/a	TBD - Pre-ADA

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08232	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Mirror		Height, bottom	53	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F08233	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Height, seat	19.5	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	When Renovated	n/a	TBD - Pre-ADA
F08234	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		When Renovated	n/a	TBD - Pre-ADA
F08235	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	No	No ambulatory toilet compartments are provided.	3-Restrooms	Provide 1 ambulatory compartment that is 35 to 37 inches wide, with grab bars on both sides of the compartment.	1 minimum	When Renovated	n/a	TBD - Pre-ADA
F08236	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		When Renovated	n/a	TBD - Pre-ADA
F08287	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Clearance, pull perpendicular	46	No	Clearance on pull side of door is insufficient.	3-Restrooms	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08288	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Interior access	Clearance, pull perpendicular	48	No	Clearance on pull side of door is insufficient.	3-Restrooms	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08289	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Clearance, vertical	78.5	No	Vertical clearance is too low.	3-Restrooms	Replace the doorway with a compliant vertical clearance.	80 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08290	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Interior access	Clearance, vertical	78	No	Vertical clearance is too low.	3-Restrooms	Replace the doorway with a compliant vertical clearance.	80 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08291	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Interior access	Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F08292	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Urinal		Depth	13	No	Urinal is not deep enough.	5-Tolerance	No action recommended - within construction tolerance.	13.5 inches	When Renovated	n/a	TBD - Pre-ADA
F08293	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	-4	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2017	$ 100.00	Relocate or Replace Dispenser
F08294	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	2	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2020	$ 250.00	Renovated as part of Parks Master Plan
F08295	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	13	No	Side wall grab bar is located too far away from the back wall.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2020	$ 250.00	Renovated as part of Parks Master Plan
F08296	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	24.5	No	Knee clearance is too low.	3-Restrooms	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	When Renovated	n/a	TBD - Pre-ADA
F08297	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		When Renovated	n/a	TBD - Pre-ADA
F08298	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		When Renovated	n/a	TBD - Pre-ADA
F08299	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Hardware type	Knob	No	Hardware requires twisting of wrist.	3-Restrooms	Install lever type door hardware.		When Renovated	n/a	TBD - Pre-ADA
F08300	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	PT	Height	54	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Relocate or Replace Dispenser
F08301	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Mirror		Height, bottom	43	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Relocate or Replace Mirror
F08302	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Urinal		Height, rim	20	No	Urinal rim is too high.	3-Restrooms	Where multiple urinals are installed, replace or remount at least one urinal to the correct height.	17 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F08304	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Opening force	9	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F08305	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Interior access	Opening force	9	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F08306	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Over obstruction?	Y	No	Toilet paper dispenser is mounted above the grab bar.	3-Restrooms	Move the toilet paper dispenser to a compliant position under the grab bar.		2017	$ 100.00	Relocate or Replace Dispenser
F08307	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		When Renovated	n/a	TBD - Pre-ADA
F08383	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	47	No	Clear floor space is too short.	3-Restrooms	Provide at least the minimum clear floor space at the counter.	48 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08384	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Exterior access	Clearance, pull perpendicular	44	No	Clearance on pull side of door is insufficient.	3-Restrooms	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08385	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Interior access	Clearance, vertical	78	No	Vertical clearance is too low.	3-Restrooms	Replace the doorway with a compliant vertical clearance.	80 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08386	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Exterior access	Clearance, vertical	78	No	Vertical clearance is too low.	3-Restrooms	Replace the doorway with a compliant vertical clearance.	80 inches minimum	When Renovated	n/a	TBD - Pre-ADA

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08387	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Interior access	Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F08388	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Exterior access	Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F08389	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	2	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2017	$ 100.00	Relocate or Replace Dispenser
F08390	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	5	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	When Renovated	n/a	TBD - Pre-ADA
F08391	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	3	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2020	$ 250.00	Renovated as part of Parks Master Plan
F08392	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	26.5	No	Knee clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	27 inches	When Renovated	n/a	TBD - Pre-ADA
F08393	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	26.5	No	Knee clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	27 inches	When Renovated	n/a	TBD - Pre-ADA
F08394	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		When Renovated	n/a	TBD - Pre-ADA
F08395	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		When Renovated	n/a	TBD - Pre-ADA
F08396	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Exterior access	Hardware type	Knob	No	Hardware requires twisting of wrist.	3-Restrooms	Install lever type door hardware.		When Renovated	n/a	TBD - Pre-ADA
F08397	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Height	55	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Relocate or Replace Dispenser
F08398	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Mirror		Height, bottom	43	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Relocate or Replace Mirror
F08400	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		When Renovated	n/a	TBD - Pre-ADA
F08401	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Interior access	Opening force	8	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F08402	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Exterior access	Opening force	10	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F08403	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Over obstruction?	Y	No	Toilet paper dispenser is mounted above the grab bar.	3-Restrooms	Move the toilet paper dispenser to a compliant position under the grab bar.		2017	$ 100.00	Relocate or Replace Dispenser
F08404	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		When Renovated	n/a	TBD - Pre-ADA
F08458	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	40	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08459	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	1	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	When Renovated	n/a	TBD - Pre-ADA
F08460	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, wide side	23.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08461	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		When Renovated	n/a	TBD - Pre-ADA
F08462	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		When Renovated	n/a	TBD - Pre-ADA
F08472	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	47	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08473	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F08474	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2017	$ 100.00	Relocate or Replace Dispenser
F08475	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	5	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	When Renovated	n/a	TBD - Pre-ADA
F08476	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, sidewall	22.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	When Renovated	n/a	TBD - Pre-ADA
F08477	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, wide side	24.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08478	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		When Renovated	n/a	TBD - Pre-ADA

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08479	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Mirror		Height, bottom	40.75	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Relocate or Replace Mirror
F08481	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		When Renovated	n/a	TBD - Pre-ADA
F08482	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Opening force	15	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F08483	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Over obstruction?	Y	No	Toilet paper dispenser is mounted above the grab bar.	3-Restrooms	Move the toilet paper dispenser to a compliant position under the grab bar.		2017	$ 100.00	Relocate or Replace Dispenser
F08507	Adams County Fair Grounds	Mann-Nyholt Lake Parking	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	4	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2017	$ 100.00	Relocate or Replace Dispenser
F08508	Adams County Fair Grounds	Mann-Nyholt Lake Parking	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Other attribute	None	No	Braille and raised letter signage is not provided.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 250.00	Signs have been ordered - Should be Installed by March
F08516	Adams County Fair Grounds	Mann-Nyholt Lake Parking	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Height, threshold	0.75	No	Threshold is too high.	3-Restrooms	Provide a threshold which is 0.25 inch maximum, or a beveled threshold which is 0.5 inch maximum, at the door entrance.	0.5 inch maximum	2017	$ 1,500.00	Concrete needs to be re-done in addition to threshold
F08521	Adams County Fair Grounds	Mann-Nyholt Lake Parking	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	6	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2017	$ 100.00	Relocate or Replace Dispenser
F08524	Adams County Fair Grounds	Mann-Nyholt Lake Parking	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Height, threshold	1.25	No	Threshold is too high.	3-Restrooms	Provide a threshold which is 0.25 inch maximum, or a beveled threshold which is 0.5 inch maximum, at the door entrance.	0.5 inch maximum	2017	$ 1,500.00	Concrete needs to be re-done in addition to threshold
F08525	Adams County Fair Grounds	Mann-Nyholt Lake Parking	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Height, threshold	1.25	No	Threshold is too high.	3-Restrooms	Provide a threshold which is 0.25 inch maximum, or a beveled threshold which is 0.5 inch maximum, at the door entrance.	0.5 inch maximum	2017	$ 1,500.00	Concrete needs to be re-done in addition to threshold
F08534	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, pull parallel	2	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08535	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar		Clearance, to wall	2.25	No	Space between wall and grab bar is too wide.	3-Restrooms	Install a new grab bar with the correct spacing between the grab bar and the wall.	1.5 inches	When Renovated	n/a	TBD - Pre-ADA
F08536	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, vertical	75	No	Vertical clearance is too low.	3-Restrooms	Replace the doorway with a compliant vertical clearance.	80 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08537	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Closing speed	3	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F08538	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	10	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2017	$ 100.00	Relocate or Replace Dispenser
F08539	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, sidewall	19.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	When Renovated	n/a	TBD - Pre-ADA
F08540	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, wide side	23	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08541	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	PT	Height	50	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Relocate or Replace Dispenser
F08542	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Mirror		Height, bottom	45.25	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Relocate or Replace Mirror
F08543	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Opening force	6	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F08544	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Other attribute	Angled bar	No	No grab bars provided.	3-Restrooms	Install grab bars on the rear and side wall.		When Renovated	n/a	TBD - Pre-ADA
F08545	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Other attribute	None	No	Braille and raised letter signage is not provided.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F08560	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Both sides	Other attribute	Angled bars	No	Incorrect grab bars provided.	3-Restrooms	Install grab bars on both side walls in an ambulatory compartment.		When Renovated	n/a	TBD - Pre-ADA
F08592	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Urinal		Clearance, parallel	28.5	No	Clear floor space is too narrow.	3-Restrooms	Remove the separator or reconfigure the urinals.	30 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08593	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	49.5	No	Clearance on pull side of door is insufficient.	3-Restrooms	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08594	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F08596	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	25	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	When Renovated	n/a	TBD - Pre-ADA
F08597	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		When Renovated	n/a	TBD - Pre-ADA
F08598	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	PT	Height	51	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Relocate or Replace Dispenser

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08599	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	No	No ambulatory toilet compartments are provided.	3-Restrooms	Provide 1 ambulatory compartment that is 35 to 37 inches wide, with grab bars on both sides of the compartment.	1 minimum	When Renovated	n/a	TBD - Pre-ADA
F08600	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Opening force	8	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F08601	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		When Renovated	n/a	TBD - Pre-ADA
F08673	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	59.5	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08674	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Closing speed	3	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F08675	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	20.25	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	When Renovated	n/a	TBD - Pre-ADA
F08676	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Protrusion	Feminine product dispenser	Dimension, protruding	6	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		When Renovated	n/a	TBD - Pre-ADA
F08677	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		When Renovated	n/a	TBD - Pre-ADA
F08678	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Height	52	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Relocate or Replace Dispenser
F08679	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Height, top	37.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	When Renovated	n/a	TBD - Pre-ADA
F08680	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	No	No ambulatory toilet compartments are provided.	3-Restrooms	Provide 1 ambulatory compartment that is 35 to 37 inches wide, with grab bars on both sides of the compartment.	1 minimum	When Renovated	n/a	TBD - Pre-ADA
F08681	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Opening force	12	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F08682	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		When Renovated	n/a	TBD - Pre-ADA
F08737	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's - Picnic Site B	1-Public Unsupervised	Door Gate		Height, threshold	1.5	No	Threshold is too high.	3-Restrooms	Provide a threshold which is 0.25 inch maximum, or a beveled threshold which is 0.5 inch maximum, at the door entrance.	0.5 inch maximum	2017	$ 250.00	Internal Staff - Operations
F08738	Adams County Fair Grounds		Exterior	Owned	Restroom	Accessible Porta-Potty	1-Public Unsupervised	Door Gate		Other attribute	No accessible symbol	No	No ISA symbol is provided on the signage for the accessible restroom.	3-Restrooms	Replace the signage to include the ISA symbol for an accessible restroom.		2016	$ 100.00	Portable Restroom - by Parks. Not a permanent structure - Signs have been ordered
F08754	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	46	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08755	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	55.5	No	Toilet compartment is not deep enough.	3-Restrooms	Reconfigure the stall to provide a minimum of 59 inches in depth.	59 inches	When Renovated	n/a	TBD - Pre-ADA
F08756	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	2.25	No	Space between wall and grab bar is too wide.	3-Restrooms	Install a new grab bar with the correct spacing between the grab bar and the wall.	1.5 inches	When Renovated	n/a	TBD - Pre-ADA
F08757	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Urinal		Depth	13.25	No	Urinal is not deep enough.	5-Tolerance	No action recommended - within construction tolerance.	13.5 inches	When Renovated	n/a	TBD - Pre-ADA
F08758	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Grab Bar	Side	Diameter	1	No	Diameter of grab bar is too small.	3-Restrooms	Install compliant grab bars.	1.25 to 2 inches	When Renovated	n/a	TBD - Pre-ADA
F08759	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	-3	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2017	$ 100.00	Relocate or Replace Dispenser
F08760	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	16.5	No	Side wall grab bar is located too far away from the back wall.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F08761	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Water Closet		Dimension, sidewall	15.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	When Renovated	n/a	TBD - Pre-ADA
F08762	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Water Closet		Dimension, wide side	32.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08763	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Shower Compartment		Hand spray unit?	N	No	Shower does not include a handheld spray unit.	3-Restrooms	Replace the shower head with a handheld spray unit, mounted a maximum of 48 inches above the finished floor, with a spray hose no less than 59 inches long.		When Renovated	n/a	TBD - Pre-ADA
F08764	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Coat Hook		Height	63	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F08765	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Dispenser	PT	Height	49	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Relocate or Replace Dispenser

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08766	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Lavatory Sink		Height	36	No	Lavatory sink is too high.	3-Restrooms	Lower the lavatory sink to the correct height.	34 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F08767	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Urinal		Height, rim	25.5	No	Urinal rim is too high.	3-Restrooms	Where multiple urinals are installed, replace or remount at least one urinal to the correct height.	17 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F08768	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Shower Compartment		Height, shower control	52	No	Shower controls are mounted too high.	3-Restrooms	Provide a lowered shower control.	48 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F08769	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		When Renovated	n/a	TBD - Pre-ADA
F08770	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Grab Bar	Rear	Other attribute	None Provided	No	No grab bars provided.	3-Restrooms	Install grab bars on the rear and side wall.		When Renovated	n/a	TBD - Pre-ADA
F08785	Adams County Fair Grounds		Exterior	Owned	Restroom	Men's - Picnic Site B	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	5.5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2017	$ 100.00	Relocate or Replace Dispenser
F08797	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clear opening	30.5	No	Clear opening is too narrow.	3-Restrooms	Reframe the doorway to provide a compliant clear opening width. Offset hinges may be used to facilitate the process.	32 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08798	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	36	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08799	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	55.5	No	Toilet compartment is not deep enough.	3-Restrooms	Reconfigure the stall to provide a minimum of 59 inches in depth.	59 inches	When Renovated	n/a	TBD - Pre-ADA
F08800	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, pull parallel	7	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08801	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Closing speed	3	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F08802	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Both sides	Diameter	1	No	Diameter of grab bar is too small.	3-Restrooms	Install compliant grab bars.	1.25 to 2 inches	When Renovated	n/a	TBD - Pre-ADA
F08803	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, wide side	18.75	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08804	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		When Renovated	n/a	TBD - Pre-ADA
F08805	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Coat Hook		Height	66	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F08806	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Height	49	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Relocate or Replace Dispenser
F08807	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Mirror		Height, bottom	45	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Relocate or Replace Mirror
F08808	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		When Renovated	n/a	TBD - Pre-ADA
F08809	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Opening force	6	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F08810	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Both sides	Clearance, to wall	2.25	No	Spacing between the grab bar and the wall is insufficient.	3-Restrooms	Install new grab bars with the correct spacing between the grab bars and the wall.	1.5 inches	When Renovated	n/a	TBD - Pre-ADA
F08843	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Toilet Compartment		Clear opening	28	No	Clear opening is too narrow.	3-Restrooms	Reframe the doorway to provide a compliant clear opening width. Offset hinges may be used to facilitate the process.	32 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08844	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	45	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08845	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	55.5	No	Toilet compartment is not deep enough.	3-Restrooms	Reconfigure the stall to provide a minimum of 59 inches in depth.	59 inches	When Renovated	n/a	TBD - Pre-ADA
F08846	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	2	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2017	$ 100.00	Relocate or Replace Dispenser
F08847	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Shower Compartment		Dimension, side to side	37	No	Transfer shower is too wide.	3-Restrooms	Redesign and remodel the shower compartment with compliant grab bars, seat, hose, and shower controls.	36 inches wide by 36 inches deep	When Renovated	n/a	TBD - Pre-ADA
F08848	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Water Closet		Dimension, sidewall	15	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	When Renovated	n/a	TBD - Pre-ADA
F08849	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Water Closet		Dimension, wide side	30	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	When Renovated	n/a	TBD - Pre-ADA
F08850	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Shower Compartment		Hand spray unit?	N	No	Shower does not include a handheld spray unit.	3-Restrooms	Replace the shower head with a handheld spray unit, mounted a maximum of 48 inches above the finished floor, with a spray hose no less than 59 inches long.		When Renovated	n/a	TBD - Pre-ADA
F08851	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Lavatory Sink		Height	36.25	No	Lavatory sink is too high.	3-Restrooms	Lower the lavatory sink to the correct height.	34 inches maximum	When Renovated	n/a	TBD - Pre-ADA

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08852	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Changing Station		Height	39.25	No	Work surface does not comply with height requirements.	3-Restrooms	Lower the work surface to a compliant height.	Between 28 and 34 inches	When Renovated	n/a	TBD - Pre-ADA
F08853	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Water Closet		Height, seat	15	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	When Renovated	n/a	TBD - Pre-ADA
F08854	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Shower Compartment		Height, shower control	51	No	Shower controls are mounted too high.	3-Restrooms	Provide a lowered shower control.	48 inches maximum	When Renovated	n/a	TBD - Pre-ADA
F08855	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		When Renovated	n/a	TBD - Pre-ADA
F08856	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Dispenser	TP	Over obstruction?	Y	No	Toilet paper dispenser is mounted above the grab bar.	3-Restrooms	Move the toilet paper dispenser to a compliant position under the grab bar.		2017	$ 100.00	Relocate or Replace Dispenser
F08857	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		When Renovated	n/a	TBD - Pre-ADA
F08871	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Shower Compartment		Height, threshold	3.25	No	Threshold is too high.	3-Restrooms	Provide a threshold which is 0.25 inch maximum, or a beveled threshold which is 0.5 inch maximum, at the door entrance.	0.5 inch maximum	When Renovated	n/a	TBD - Pre-ADA
F08878	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's - Picnic Site B	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F08879	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's - Picnic Site B	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	3	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2017	$ 100.00	Relocate or Replace Dispenser
F08880	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's - Picnic Site B	1-Public Unsupervised	Door Gate		Opening force	9	No	Opening force is too high.	3-Restrooms	Although exterior door force is not covered under the ADA, it is recommended that this be adjusted or install an automatic door opener.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F08895	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Shower Compartment		Height, threshold	3	No	Threshold is too high.	3-Restrooms	Provide a threshold which is 0.25 inch maximum, or a beveled threshold which is 0.5 inch maximum, at the door entrance.	0.5 inch maximum	When Renovated	n/a	TBD - Pre-ADA
F15615	Adams County Fair Grounds		Exterior	Owned	Sport Area	Open rodeo grandstand	1-Public Unsupervised	Seating Area	Grandstands	Assistive listening systems?	None found - no sign	No	No Assistive Listening devices found and no instructional signage visible.	2-Services	Provide an assistive listening system and signage stating that an assistive listening system is provided.	1 sign and 4 ALS receivers	When Renovated	n/a	TBD - Pre-ADA
F15769	Adams County Fair Grounds	Waymire Dome	Exterior	Owned	Walkway	From North parking lot	1-Public Unsupervised	Curb Ramp		Landing?	N	No	No landing provided at top of curb ramp.	1-Entry	Provide a landing at the top of the curb ramp that is the same width as the curb ramp and at least 36 inches long.		When Renovated	n/a	TBD - Pre-ADA
F15778	Adams County Fair Grounds		Exterior	Owned	Walkway	From parking lot to play area	1-Public Unsupervised	Walking Surface		Slope, running	7.6%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with compliant running and cross slopes, or install handrails, edge protection, and landings required for ramps.	5.0% maximum	2020	$ 7,500.00	Part of Annual Parking project
F15782	Adams County Fair Grounds		Exterior	Owned	Walkway	South of Waymire Dome	1-Public Unsupervised	Ramp		Length	45 feet	No	Ramp run is too long between landings.	1-Entry	Redesign, remove, and replace the ramp run with no more than 30 inches of vertical rise between the landings.	Maximum 30 feet of ramp between landings	2020	$ 7,500.00	Part of Annual Parking project
F15783	Adams County Fair Grounds		Exterior	Owned	Walkway	South of Waymire Dome	1-Public Unsupervised	Ramp	East ramp	Edge protection?	N	No	No edge protection provided for ramp.	1-Entry	Install edge protection on both sides of the ramp, for the entire length of the ramp.	4 inches maximum	2020	$ 7,500.00	Part of Annual Parking project
F15784	Adams County Fair Grounds		Exterior	Owned	Walkway	South of Waymire Dome	1-Public Unsupervised	Ramp	East ramp	Edge protection?	N	No	No edge protection provided for ramp.	1-Entry	Install edge protection or raise landscape along walkway.	4 inches maximum	2020	$ 7,500.00	Part of Annual Parking project
F15785	Adams County Fair Grounds		Exterior	Owned	Walkway	South of Waymire Dome	1-Public Unsupervised	Ramp	East ramp	Handrails?	No	No	No handrail on ramp.	1-Entry	Install handrails on both sides of the ramp.		2020	$ 15,000.00	Part of Annual Parking project
F15786	Adams County Fair Grounds		Exterior	Owned	Walkway	South of Waymire Dome	1-Public Unsupervised	Ramp	East ramp	Handrails?	No	No	No handrail on ramp.	1-Entry	Install handrails on both sides of the ramp.		2020	$ 15,000.00	Part of Annual Parking project
F03699	Adams County Golf Course		Interior	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Between men's & women's restrooms	Dimension, knee clearance	26	No	Knee clearance is too low.	4-Other	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	2019	$ 3,500.00	Replace Drinking Fountain
F04884	Adams County Golf Course		Interior	Owned	Other Room	Pro shop	1-Public Unsupervised	Alarm System		Height	101	No	Visible alarm is too high.	4-Other	Lower the fire alarm to a compliant range.	Between 80" and 96" AFF	2016	$ 2,500.00	Replace Device
F04885	Adams County Golf Course		Interior	Owned	Other Room	Pro shop	1-Public Unsupervised	Counter		Height	36.5	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2019	$ 3,500.00	Rework Counter
F04904	Adams County Golf Course		Interior	Owned	Other Room	Public use computer room	1-Public Unsupervised	Door Gate		Clearance, pull parallel	17	No	Clearance on pull side of door is insufficient.	2-Services	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2019	$ 3,500.00	Rework Door
F04905	Adams County Golf Course		Interior	Owned	Other Room	Public use computer room	1-Public Unsupervised	Door Gate		Closing speed	3	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F04906	Adams County Golf Course		Interior	Owned	Other Room	Public use computer room	1-Public Unsupervised	Signage		Height, bottom	60.5	No	Signage is too high.	2-Services	Remount sign with tactile letters located 48 inches minimum and 60 inches maximum, above the finished floor, measured from the baseline of the tactile letters.	48 to 60 inches	2016	$ 100.00	Internal Staff - Operations
F04907	Adams County Golf Course		Interior	Owned	Other Room	Public use computer room	1-Public Unsupervised	Door Gate		Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F05609	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Cars obstruct pathway	Y	No	Cars protrude into path of travel.	1-Entry	Install curb stops at the head of parking spaces to avoid obstruction in the path of travel.		2017	$ 50.00	Part of Annual Parking project
F05610	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, van spaces	0	No	Too few van accessible parking spaces are provided.	1-Entry	Provide the minimum number of required van accessible parking spaces.	2 minimum	2017	$ 50.00	Part of Annual Parking project

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05611	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#6	Slope, cross	3.0%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2019	$ 2,500.00	Part of Annual Parking Project
F05612	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Slope, running	2.5%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	2019	$ 2,500.00	Part of Annual Parking Project
F05613	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Width	48	No	Access aisle is too narrow.	1-Entry	Restripe the parking space and aisle to provide a compliant sized access aisle.	60 inches minimum	2017	$ 50.00	Part of Annual Parking project
F05614	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Width	52	No	Access aisle is too narrow.	1-Entry	Restripe the parking space and aisle to provide a compliant sized access aisle.	60 inches minimum	2017	$ 50.00	Part of Annual Parking project
F05615	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Width	48	No	Access aisle is too narrow.	1-Entry	Restripe the parking space and aisle to provide a compliant sized access aisle.	60 inches minimum	2017	$ 50.00	Part of Annual Parking project
F05616	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #6 & #7	Width	56.5	No	Access aisle is too narrow.	1-Entry	Restripe the parking space and aisle to provide a compliant sized access aisle.	60 inches minimum	2017	$ 50.00	Part of Annual Parking project
F05681	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Van sign?	N	No	Van Accessible' sign is not present.	1-Entry	Install a 'Van Accessible' sign.		2017	$ 50.00	Part of Annual Parking project
F08903	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Door Gate		Clearance, push parallel	3	No	Clearance on push side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	12 inches minimum	2019	$ 3,500.00	Rework Door
F08904	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F08905	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	13.5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Internal Staff - Operations
F08906	Adams County Golf Course	Dunes	Interior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6.5	No	Grab bar is not mounted in correct location.	5-Tolerance	No action recommended - within construction tolerance.	6 inches	2019	$ 250.00	Internal Staff - Operations
F08907	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	11.25	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2019	$ 250.00	Internal Staff - Operations
F08908	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Door Gate		Opening force	9	No	Opening force is too high.	3-Restrooms	Although exterior door force is not covered under the ADA, it is recommended that this be adjusted or install an automatic door opener.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F08909	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Signage		Other attribute	None	No	Braille and raised letter signage is not provided.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F08937	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Signage		Braille?	N	No	Signage does not provide Braille.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F08938	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Closing speed	3	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F08939	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	12.5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Rework Dispenser
F08940	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	5	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2019	$ 250.00	Rework Grab bar
F08941	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	11	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2019	$ 250.00	Rework Grab bar
F08942	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Water Closet		Dimension, sidewall	18.25	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2019	$ 5,000.00	Rework Toilet
F08943	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Water Closet		Dimension, wide side	34	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2019	$ 5,000.00	Rework Toilet
F08944	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2019	$ 150.00	Install Pipe Wrap
F08945	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Lavatory Sink		Height	34.75	No	Lavatory sink is too high.	3-Restrooms	Lower the lavatory sink to the correct height.	34 inches maximum	2019	$ 1,500.00	Replace Lavatory
F08946	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Signage		Height, bottom	63.5	No	Signage is too high.	3-Restrooms	Remount sign with tactile letters located 48 inches minimum and 60 inches maximum, above the finished floor, measured from the baseline of the tactile letters.	48 to 60 inches	2016	$ 100.00	Internal Staff - Operations
F08948	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Signage		Location	On door	No	Sign is not mounted in the correct location.	3-Restrooms	Move the sign to the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F08949	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		2019	$ 500.00	Rework Flush Valve

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08950	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Opening force	19	No	Opening force is too high.	3-Restrooms	Although exterior door force is not covered under the ADA, it is recommended that this be adjusted or install an automatic door opener.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F08951	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Signage		Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F08968	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Height, threshold	0.75	No	Threshold is too high.	3-Restrooms	Provide a threshold which is 0.25 inch maximum, or a beveled threshold which is 0.5 inch maximum, at the door entrance.	0.5 inch maximum	2019	$ 250.00	Internal Staff - Operations
F08983	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Closing speed	2	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F08984	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	13.5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Internal Staff - Operations
F08985	Adams County Golf Course	Dunes	Interior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	11.75	No	Grab bar is not mounted in correct location.	5-Tolerance	No action recommended - within construction tolerance.	12 inches maximum	2019	$ 250.00	Rework Grab bar
F08986	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	4.75	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2019	$ 250.00	Rework Grab bar
F08987	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Water Closet		Dimension, wide side	36	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2019	$ 5,000.00	Rework Toilet
F08988	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2019	$ 150.00	Install Pipe Wrap
F08989	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Dispenser	Soap	Height	49.75	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Internal Staff - Operations
F08990	Adams County Golf Course	Dunes	Interior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Lavatory Sink		Height	34.5	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	None	$ -	Within Tolerance (per Assessment)
F08991	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Opening force	23	No	Opening force is too high.	3-Restrooms	Although exterior door force is not covered under the ADA, it is recommended that this be adjusted or install an automatic door opener.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F09016	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex - Near #10 teeing grounds	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	14	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2017	$ 100.00	Internal Staff - Operations
F09017	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex - Near #10 teeing grounds	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	5.25	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2019	$ 250.00	Rework Grab bar
F09018	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex - Near #10 teeing grounds	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	10.5	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2019	$ 250.00	Rework Grab bar
F09019	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex - Near #10 teeing grounds	1-Public Unsupervised	Dispenser	Hand sanitizer	Height	53.75	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Internal Staff - Operations
F09020	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex - Near #10 teeing grounds	1-Public Unsupervised	Signage		Other attribute	None	No	Braille and raised letter signage is not provided.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F09042	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Closing speed	3	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2019	$ -	Internal Staff - Operations
F09043	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	15	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Internal Staff - Operations
F09044	Adams County Golf Course	Knolls	Interior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	5.5	No	Grab bar is not mounted in correct location.	5-Tolerance	No action recommended - within construction tolerance.	6 inches	None	$ -	Within Tolerance (per Assessment)
F09045	Adams County Golf Course	Knolls	Interior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	11.5	No	Grab bar is not mounted in correct location.	5-Tolerance	No action recommended - within construction tolerance.	12 inches maximum	None	$ -	Within Tolerance (per Assessment)
F09046	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Water Closet		Dimension, sidewall	18.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2019	$ 5,000.00	Rework Toilet
F09047	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Water Closet		Dimension, wide side	34.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2019	$ 5,000.00	Rework Toilet
F09048	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2019	$ 150.00	Install Pipe Wrap
F09049	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Hardware type	Knob	No	Hardware requires twisting of wrist.	3-Restrooms	Install lever type door hardware.		2019	$ 500.00	Install new Lockset
F09050	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Dispenser	PT	Height	58	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Internal Staff - Operations
F09051	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Signage		Height, bottom	63	No	Signage is too high.	3-Restrooms	Remount sign with tactile letters located 48 inches minimum and 60 inches maximum, above the finished floor, measured from the baseline of the tactile letters.	48 to 60 inches	2016	$ 100.00	Internal Staff - Operations

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09052	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Signage		Location	On door	No	Sign is not mounted in the correct location.	3-Restrooms	Move the sign to the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F09053	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		2019	$ 500.00	Rework Flush Valve
F09054	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Door Gate	At door	Width, opening	0.75	No	Opening in walking surface is too wide.	3-Restrooms	Repair the gap in the walking surface.	0.5 inches maximum	2019	$ 250.00	Internal Staff - Operations
F09090	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Signage		Braille?	N	No	Braille and raised letter signage is not provided.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F09091	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F09092	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	12	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Internal Staff - Operations
F09093	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	5.25	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2019	$ 250.00	Rework Grab bar
F09094	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Water Closet		Dimension, sidewall	18.75	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2019	$ 5,000.00	Rework Toilet
F09095	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Water Closet		Dimension, wide side	35	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2019	$ 5,000.00	Rework Toilet
F09096	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2019	$ 150.00	Install Pipe Wrap
F09097	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Dispenser	PT	Height	58	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Internal Staff - Operations
F09098	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Opening force	12	No	Opening force is too high.	3-Restrooms	Although exterior door force is not covered under the ADA, it is recommended that this be adjusted or install an automatic door opener.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F09124	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Height, threshold	1	No	Threshold is too high.	3-Restrooms	Provide a threshold which is 0.25 inch maximum, or a beveled threshold which is 0.5 inch maximum, at the door entrance.	0.5 inch maximum	2019	$ 250.00	Internal Staff - Operations
F09142	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	59.5	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	2019	$ 5,000.00	Rework Toilet
F09143	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Urinal		Clearance, parallel	28	No	Clear floor space is too narrow.	3-Restrooms	Remove the separator or reconfigure the urinals.	30 inches minimum	2019	$ 5,000.00	Rework Urinal
F09144	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Urinal		Depth	13	No	Urinal is not deep enough.	5-Tolerance	No action recommended - within construction tolerance.	13.5 inches	2019	$ 5,000.00	Rework Urinal
F09145	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	12	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Internal Staff - Operations
F09146	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Water Closet		Dimension, sidewall	18.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2019	$ 5,000.00	Rework Toilet
F09147	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2019	$ 150.00	Install Pipe Wrap
F09148	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2019	$ 250.00	Internal Staff - Operations
F09149	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Coat Hook		Height	56	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2019	$ 150.00	Rework Coat Hook
F09150	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Dispenser	PT	Height	60	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Internal Staff - Operations
F09151	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Dispenser	Shower soap	Height	58	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Internal Staff - Operations
F09152	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Mirror		Height, bottom	42.75	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2019	$ 250.00	Internal Staff - Operations
F09153	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Grab Bar	Rear	Height, top	36.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	2019	$ 250.00	Rework Grab bar
F09154	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Grab Bar	Side	Height, top	36.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	2019	$ 250.00	Rework Grab bar
F09155	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		2019	$ 500.00	Rework Flush Valve
F09156	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		2019	$ 500.00	Rework Flush Valve
F09157	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	No	No ambulatory toilet compartments are provided.	3-Restrooms	Provide 1 ambulatory compartment that is 35 to 37 inches wide, with grab bars on both sides of the compartment.	1 minimum	2019	$ 250.00	Rework Partition
F09158	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Door Gate		Opening force	12	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F09159	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2019	$ 250.00	Rework Partition

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09249	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F09250	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	11.5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Internal Staff - Operations
F09251	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4.25	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2019	$ 5,000.00	Rework Toilet
F09252	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Protrusion	Feminine product dispenser	Dimension, protruding	7.5	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2019	$ 250.00	Rework Dispenser
F09253	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Shower Compartment		Dimension, side to side	36.5	No	Transfer shower is too wide.	5-Tolerance	No action recommended - within construction tolerance.	36 inches	None	$ -	Within Tolerance (per Assessment)
F09254	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2019	$ 250.00	Internal Staff - Operations
F09255	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Coat Hook		Height	52	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2019	$ 50.00	Internal Staff - Operations
F09256	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Dispenser	PT	Height	60	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Internal Staff - Operations
F09257	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Dispenser	Shower soap	Height	58	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Internal Staff - Operations
F09258	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Mirror		Height, bottom	42.5	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2019	$ 250.00	Internal Staff - Operations
F09259	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Grab Bar	Rear	Height, top	36.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	2019	$ 250.00	Rework Grab bar
F09260	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Grab Bar	Side	Height, top	36.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	2019	$ 250.00	Rework Grab bar
F09261	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Door Gate		Opening force	13	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F09262	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2019	$ 250.00	Rework Partition
F15523	Adams County Golf Course	Dunes	Exterior	Owned	Shelter	Near #9 teeing grounds	1-Public Unsupervised	Drinking Fountain	Concession side of shelter	Height	42	No	Drinking fountain spout height is too high.	4-Other	Replace the existing fountain with a high/low fountain. The low fountain spout height must be 36 inches minimum and the high fountain spout height must be 38 inches to 43 inches.		2019	$ 2,500.00	Replace Fixture
F15524	Adams County Golf Course	Dunes	Exterior	Owned	Shelter	Near #9 teeing grounds	1-Public Unsupervised	Drinking Fountain	Concession side of shelter	High-low fountain?	N	No	Fountain provided is not a hi/low fountain.	4-Other	No action recommended - this element has safe harbor.		2019	$ 2,500.00	Replace Fixture
F15829	Adams County Golf Course		Exterior	Owned	Walkway	From parking lot to Pro Shop	1-Public Unsupervised	Ramp		Edge protection?	N	No	No edge protection provided for ramp.	1-Entry	Install edge protection on both sides of the ramp, for the entire length of the ramp.	4 inches maximum	2019	$ 5,000.00	Rework Ramp
F15830	Adams County Golf Course		Exterior	Owned	Walkway	From parking lot to Pro Shop	1-Public Unsupervised	Ramp		Length	36.5 feet	No	Ramp run is too long between landings.	1-Entry	Redesign, remove, and replace the ramp run with no more than 30 inches of vertical rise between the landings.	Maximum 30 feet of ramp between landings	2019	$ 5,000.00	Rework Ramp
F15831	Adams County Golf Course		Exterior	Owned	Walkway	From parking lot to Pro Shop	1-Public Unsupervised	Walking Surface	Sidewalk	Slope, cross	4.4%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with a compliant cross slope.	2.08% maximum	2019	$ 5,000.00	Rework Ramp
F15832	Adams County Golf Course		Exterior	Owned	Walkway	From parking lot to Pro Shop	1-Public Unsupervised	Ramp		Slope, running	10.1%	No	Slope is too steep.	1-Entry	Rebuild the ramp with a compliant running slope, cross slope, and landing.	8.33% maximum	2019	$ 5,000.00	Rework Ramp
F15843	Adams County Golf Course		Exterior	Owned	Walkway	From Pro Shop to golf cart area	1-Public Unsupervised	Walking Surface		Slope, cross	2.1%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F15852	Adams County Golf Course		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate	Main Entrance	Height, smooth surface (kick plate)	8.5	No	Smooth surface at bottom edge of door is insufficient.	1-Entry	No action recommended - this element has safe harbor.	10 inches minimum	None	$ -	Within Tolerance (per Assessment)
F00304	Adams County Service Center	Sheriff's Substation	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	2-Services	Wrap or insulate the drain and supply lines to protect against contact.		2019	$ 150.00	
F00305	Adams County Service Center	Sheriff's Substation	Interior	Owned	Break Room		3-Employee Common	Counter		Height	46	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2019	$ 2,500.00	
F00306	Adams County Service Center	Sheriff's Substation	Interior	Owned	Break Room		3-Employee Common	Dispenser	PT	Height	51	No	Dispenser is too high.	2-Services	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Internal Staff - Operations
F00307	Adams County Service Center	Sheriff's Substation	Interior	Owned	Break Room		3-Employee Common	Vending Machine	Snacks	Height, control	51	No	Operable part is out of reach range.	4-Other	Replace the Vending Machine with one that has operable parts within the reach range.	48 inches maximum	2016	$ -	Internal Staff - Operations
F00319	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Break Room		3-Employee Common	Appliance	Refrig/Freezer	Height	50	No	50% of freezer space is not below 54" AFF.	4-Other	Replace the existing refrig/freezer with a compliant refrig/freezer.	Side by side Refrig/Freezer	2019	$ 500.00	
F00327	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Clearance, perpendicular	23	No	Clear floor space is too short.	2-Services	Reconfigure the lavatory sink to provide at least the minimum clear floor space.	48 inches minimum	2019	$ 1,500.00	
F00328	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	2-Services	Wrap or insulate the drain and supply lines to protect against contact.		2019	$ 150.00	
F00329	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Break Room		3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2019	$ 2,500.00	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00338	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Height	34.5	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	None	$ -	Within Tolerance (per Assessment)
F00347	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Door Gate		Clearance, pull parallel	13.5	No	Clearance on pull side of door is insufficient.	2-Services	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2019	$ 3,500.00	
F00348	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F00349	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Appliance	Refrig/Freezer	Height	49	No	50% of freezer space is not below 54" AFF.	4-Other	Replace the existing refrig/freezer with a compliant refrig/freezer.	Side by side Refrig/Freezer	2019	$ 500.00	
F00350	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2019	$ 2,500.00	
F00351	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Door Gate		Opening force	11	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00368	Adams County Service Center		2nd Floor	Owned	Break Room	Sheriff's #2	3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	2-Services	Wrap or insulate the drain and supply lines to protect against contact.		2019	$ 150.00	
F00369	Adams County Service Center		2nd Floor	Owned	Break Room	Sheriff's #2	3-Employee Common	Appliance	Refrig/Freezer	Height	50	No	50% of freezer space is not below 54" AFF.	4-Other	Replace the existing refrig/freezer with a compliant refrig/freezer.	Side by side Refrig/Freezer	2019	$ 500.00	
F02997	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Hall Signal		Audible signal?	Single beep only	No	Elevator does not have compliant audible signals indicating elevators direction of travel.	2-Services	Change the audible signals to provide one beep for 'up' and two beeps for 'down'.		2019	$ 500.00	
F03469	Adams County Service Center		Interior	Owned	Exercise Room	Men's	3-Employee Common	Signage		Braille?	N	No	Signage does not provide Braille.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F03470	Adams County Service Center		Interior	Owned	Exercise Room	Men's	3-Employee Common	Signage		Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F03478	Adams County Service Center		Interior	Owned	Exercise Room		3-Employee Common	Door Gate		Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F03480	Adams County Service Center		Interior	Owned	Exercise Room		3-Employee Common	Door Gate		Height, threshold	1.5	No	Threshold is too high.	2-Services	Provide a threshold which is 0.25 inch maximum, or a beveled threshold which is 0.5 inch maximum, at the door entrance.	0.5 inch maximum	2019	$ 500.00	
F03720	Adams County Service Center		2nd Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	In emergency area	Dimension, knee clearance	26	No	Knee clearance is too low.	4-Other	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	2019	$ 1,500.00	
F03721	Adams County Service Center		2nd Floor	Owned	Hallway		1-Public Unsupervised	Vending Machine	Aquafina	Height	50.5	No	Operable part is out of reach range.	4-Other	Replace the Vending Machine with one that has operable parts within the reach range.	48 inches maximum	2016	$ -	Internal Staff - Operations
F03722	Adams County Service Center		2nd Floor	Owned	Hallway		1-Public Unsupervised	Vending Machine	Snacks	Height	53	No	Operable part is out of reach range.	4-Other	Replace the Vending Machine with one that has operable parts within the reach range.	48 inches maximum	2016	$ -	Internal Staff - Operations
F03723	Adams County Service Center		2nd Floor	Owned	Hallway		1-Public Unsupervised	Vending Machine	Coke	Height, control	50.5	No	Operable part is out of reach range.	4-Other	Replace the Vending Machine with one that has operable parts within the reach range.	48 inches maximum	2016	$ -	Internal Staff - Operations
F04302	Adams County Service Center		Interior	Owned	Lobby Reception	Central entrance	1-Public Unsupervised	Counter	Check-in	Height	40.5	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2019	$ 2,500.00	
F04642	Adams County Service Center		2nd Floor	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Hand spray unit?	N	No	Shower does not include a handheld spray unit.	3-Restrooms	Replace the shower head with a handheld spray unit, mounted a maximum of 48 inches above the finished floor, with a spray hose no less than 59 inches long.		2019	$ 350.00	
F04925	Adams County Service Center	Sheriff's Substation	Interior	Owned	Other Room	Equipment lockers	3-Employee Common	Signage		Braille?	N	No	Signage does not provide Braille.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F04926	Adams County Service Center	Sheriff's Substation	Interior	Owned	Other Room	Equipment lockers	3-Employee Common	Door Gate		Clearance, pull parallel	14	No	Clearance on pull side of door is insufficient.	2-Services	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2019	$ 3,500.00	
F04927	Adams County Service Center	Sheriff's Substation	Interior	Owned	Other Room	Equipment lockers	3-Employee Common	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F04928	Adams County Service Center	Sheriff's Substation	Interior	Owned	Other Room	Equipment lockers	3-Employee Common	Signage		Location	H	No	Sign is not mounted in the correct location.	2-Services	Move the sign to the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F04929	Adams County Service Center	Sheriff's Substation	Interior	Owned	Other Room	Equipment lockers	3-Employee Common	Door Gate		Opening force	12	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F04930	Adams County Service Center	Sheriff's Substation	Interior	Owned	Other Room	Equipment lockers	3-Employee Common	Signage		Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F05727	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#1	Sign?	N	No	No accessible signage provided.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	2017	$ 50.00	Part of Annual Parking project
F05728	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#2	Sign?	N	No	No accessible signage provided.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	2017	$ 50.00	Part of Annual Parking project

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05729	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#3	Sign?	N	No	No accessible signage provided.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	2017	$ 50.00	Part of Annual Parking project
F05730	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#4	Sign?	N	No	No accessible signage provided.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	2017	$ 50.00	Internal Staff - Operations
F05731	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#5	Slope, running	2.6%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	n/a	$ 2,500.00	Within Tolerance (per Assessment)
F05732	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#2	Surface marking?	Faded	No	Paint is fading at parking space access aisle.	1-Entry	Repaint the faded access aisle to discourage use as a parking space.		2017	$ 50.00	Part of Annual Parking project
F05733	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#3	Surface marking?	Faded	No	Paint is fading at parking space access aisle.	1-Entry	Repaint the faded access aisle to discourage use as a parking space.		2017	$ 50.00	Part of Annual Parking project
F05734	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#4	Surface marking?	Faded	No	Paint is fading at parking space access aisle.	1-Entry	Repaint the faded access aisle to discourage use as a parking space.		2017	$ 50.00	Part of Annual Parking project
F05735	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#6	Surface marking?	Faded	No	Paint is fading at parking space access aisle.	1-Entry	Repaint the faded access aisle to discourage use as a parking space.		2017	$ 50.00	Part of Annual Parking project
F05736	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#4	Width	59	No	Access aisle is too narrow.	1-Entry	Restripe the parking space and aisle to provide a compliant sized access aisle.	60 inches minimum	2017	$ 50.00	Part of Annual Parking project
F09425	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F09426	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	12	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2017	$ 100.00	Relocate or Replace Dispenser
F09427	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Protrusion	Hand dryer	Dimension, protruding	7.5	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2019	$ 250.00	
F09428	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2019	$ 250.00	
F09429	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Urinal		Height, rim	17.5	No	Urinal rim is too high.	5-Tolerance	No action recommended - within construction tolerance.	17 inches maximum	None	$ -	Within Tolerance (per Assessment)
F09430	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Height, seat	19.5	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2019	$ 250.00	
F09431	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Opening force	8	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F09457	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	5	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2019	$ 2,500.00	
F09458	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	3-Employee Common	Protrusion	Metal shelf	Dimension, protruding	12	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2019	$ 250.00	
F09459	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	2-Public Supervised	Water Closet		Dimension, sidewall	18.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2019	$ 5,000.00	
F09460	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, wide side	41	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2019	$ 5,000.00	
F09461	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2019	$ 250.00	
F09462	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F09463	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Opening force	8	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F09483	Adams County Service Center	Sheriff's Substation	Interior	Owned	Restroom	Unisex	3-Employee Common	Dispenser	TP	Dimension from water closet seat	14	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Relocate or Replace Dispenser
F09484	Adams County Service Center	Sheriff's Substation	Interior	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Dimension, sidewall	19.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2019	$ 5,000.00	
F09485	Adams County Service Center	Sheriff's Substation	Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Height	34.5	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	n/a	$ -	Within Tolerance (per Assessment)
F09486	Adams County Service Center	Sheriff's Substation	Interior	Owned	Restroom	Unisex	3-Employee Common	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2019	$ 250.00	Relocate or Replace Mirror
F09487	Adams County Service Center	Sheriff's Substation	Interior	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Height, seat	20	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2019	$ 250.00	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09509	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Dimension, sidewall	19.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2019	$ 5,000.00	
F09510	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Dimension, wide side	37	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2019	$ 5,000.00	
F09511	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Dispenser	PT	Height	51	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F09512	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Height	34.5	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	n/a	$ -	Within Tolerance (per Assessment)
F09513	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2019	$ 250.00	Relocate or Replace Mirror
F09514	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Height, seat	20	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2019	$ 250.00	
F09542	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F09543	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Toilet Compartment		Dimension, door to partition	4.75	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2019	$ 2,500.00	
F09544	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Protrusion	Wall mounted shelf	Dimension, protruding	11	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2019	$ 250.00	
F09545	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Protrusion	Hand dryer	Dimension, protruding	7.5	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2019	$ 250.00	
F09546	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2019	$ 150.00	
F09547	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2019	$ 250.00	
F09548	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Dispenser	Hand dryer	Height	49	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F09549	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2019	$ 250.00	Relocate or Replace Mirror
F09550	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Door Gate		Opening force	12	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F09551	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2019	$ 150.00	
F09585	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Women's	3-Employee Common	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F09586	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Women's	3-Employee Common	Door Gate		Opening force	12	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F09593	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Toilet Compartment		Clearance, parallel	59	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	2019	$ 5,000.00	
F09594	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F09595	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Dispenser	TP	Dimension from water closet seat	14	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Relocate or Replace Dispenser
F09596	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Toilet Compartment		Dimension, door to partition	18	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2019	$ 5,000.00	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09597	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2019	$ 250.00	
F09598	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Coat Hook		Height	50	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2019	$ 150.00	
F09599	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Dispenser	Toilet seat covers	Height	56	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F09600	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Water Closet		Height, seat	19.5	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2019	$ 250.00	
F09601	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Door Gate		Opening force	11	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F09602	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2019	$ 250.00	
F09603	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Shower Compartment		Hand spray unit?	N	No	Shower does not include a handheld spray unit.	3-Restrooms	Replace the shower head with a handheld spray unit, mounted a maximum of 48 inches above the finished floor, with a spray hose no less than 59 inches long.		2019	$ 350.00	
F09641	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Water Closet		Dimension, wide side	30	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2019	$ 5,000.00	
F09642	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2019	$ 150.00	
F09643	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2019	$ 250.00	Relocate or Replace Mirror
F09644	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Water Closet		Height, seat	19.5	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2019	$ 250.00	
F09688	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Water Closet		Clearance, parallel	30	No	Clearance at water closet is too narrow.	3-Restrooms	Remodel the restroom to provide at least the minimum required width.	60 inches minimum	2019	$ 7,500.00	
F09689	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Lavatory Sink		Clearance, perpendicular	37	No	Clear floor space is too short.	3-Restrooms	Reconfigure the lavatory sink to provide at least the minimum clear floor space.	48 inches minimum	2019	$ 1,500.00	
F09690	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Water Closet		Clearance, perpendicular	35	No	Toilet compartment is not deep enough.	3-Restrooms	Reconfigure the stall to provide a minimum of 56 inches in depth.	56 inches	2019	$ 5,000.00	
F09691	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Door Gate		Clearance, push perpendicular	37	No	Clearance on push side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	48 inches minimum	2019	$ 3,500.00	
F09692	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Dispenser	TP	Dimension from water closet seat	14	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Relocate or Replace Dispenser
F09693	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Dispenser	TP	Dimension from water closet seat	17	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Relocate or Replace Dispenser
F09694	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Protrusion	Feminine product dispenser	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2019	$ 250.00	
F09695	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Water Closet		Dimension, wide side	29.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2019	$ 5,000.00	
F09696	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Dispenser	PT	Height	54	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F09697	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Dispenser	PT	Height	54.5	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F09698	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Dispenser	PT	Height	50	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F09699	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2019	$ 250.00	Relocate or Replace Mirror
F09700	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2019	$ 250.00	Relocate or Replace Mirror
F09701	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2019	$ 250.00	Relocate or Replace Mirror
F09702	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Water Closet		Height, seat	19.5	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2019	$ 250.00	
F09703	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Water Closet		Height, seat	20	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2019	$ 250.00	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09774	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Client	2-Public Supervised	Dispenser	TP	Dimension from water closet seat	17	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Relocate or Replace Dispenser
F09775	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Client	2-Public Supervised	Dispenser	PT	Height	56	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F09776	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Client	2-Public Supervised	Lavatory Sink		Height	35.5	No	Lavatory sink is too high.	3-Restrooms	Lower the lavatory sink to the correct height.	34 inches maximum	2019	$ 1,500.00	
F09777	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Client	2-Public Supervised	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2019	$ 250.00	Relocate or Replace Mirror
F09797	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Dispenser	TP	Dimension from water closet seat	17	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Relocate or Replace Dispenser
F09798	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Dispenser	PT	Height	56	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F09799	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2019	$ 250.00	Relocate or Replace Mirror
F09802	Adams County Service Center		Interior	Owned	Restroom	Men's	3-Employee Common	Lavatory Sink		Height	35	No	Lavatory sink is too high.	3-Restrooms	Lower the lavatory sink to the correct height.	34 inches maximum	2019	$ 1,500.00	
F09803	Adams County Service Center		Interior	Owned	Restroom	Men's	3-Employee Common	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2019	$ 250.00	Relocate or Replace Mirror
F09804	Adams County Service Center		Interior	Owned	Restroom	Men's	3-Employee Common	Urinal		Height, rim	17.5	No	Urinal rim is too high.	5-Tolerance	No action recommended - within construction tolerance.	17 inches maximum	None	$ -	Within Tolerance (per Assessment)
F09815	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	59	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	2019	$ 5,000.00	
F09816	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Urinal		Clearance, parallel	28.5	No	Clear floor space is too narrow.	3-Restrooms	Remove the separator or reconfigure the urinals.	30 inches minimum	2019	$ 150.00	
F09817	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	10	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Relocate or Replace Dispenser
F09818	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Protrusion	Hand dryer	Dimension, protruding	8	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2019	$ 250.00	
F09819	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2019	$ 150.00	
F09820	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2019	$ 250.00	
F09821	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Coat Hook		Height	50	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2019	$ 150.00	
F09822	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Dispenser	PT	Height	59	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F09823	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Dispenser	Hand dryer	Height	49.5	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F09824	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Lavatory Sink		Height	34.5	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	None	$ -	Within Tolerance (per Assessment)
F09825	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2019	$ 250.00	Relocate or Replace Mirror
F09826	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Water Closet		Height, seat	20	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2019	$ 250.00	
F09827	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Door Gate		Opening force	7	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F09856	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Dispenser	TP	Dimension from water closet seat	15.5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Relocate or Replace Dispenser
F09857	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Protrusion	PT	Dimension, protruding	9	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2019	$ 250.00	
F09858	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Water Closet		Dimension, sidewall	20	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2019	$ 5,000.00	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09859	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Water Closet		Dimension, wide side	27.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2019	$ 5,000.00	
F09860	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Dispenser	PT	Height	50	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F09861	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Lavatory Sink		Height	35	No	Lavatory sink is too high.	3-Restrooms	Lower the lavatory sink to the correct height.	34 inches maximum	2019	$ 1,500.00	
F09862	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2019	$ 250.00	Relocate or Replace Mirror
F09863	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Water Closet		Height, seat	20.5	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2019	$ 250.00	
F09902	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Signage		Braille?	N	No	Signage does not provide Braille.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F09903	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Lavatory Sink		Clearance, perpendicular	33	No	Clear floor space is too short.	3-Restrooms	Reconfigure the lavatory sink to provide at least the minimum clear floor space.	48 inches minimum	2019	$ 1,500.00	
F09904	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Water Closet		Clearance, perpendicular	36	No	Toilet compartment is not deep enough.	3-Restrooms	Reconfigure the stall to provide a minimum of 56 inches in depth.	56 inches	2019	$ 2,500.00	
F09905	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Dispenser	TP	Dimension from water closet seat	16.5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Relocate or Replace Dispenser
F09906	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Protrusion	PT	Dimension, protruding	9	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2019	$ 250.00	
F09907	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Dispenser	PT	Height	54	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F09908	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Lavatory Sink		Height	34.5	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	None	$ -	Within Tolerance (per Assessment)
F09909	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2019	$ 250.00	Relocate or Replace Mirror
F09910	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Water Closet		Height, seat	21	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2019	$ 250.00	
F09911	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Signage		Other attribute	None	No	Braille and raised letter signage is not provided.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F09912	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Dispenser	Soap	Over obstruction?	Y	No	Soap dispenser is mounted above the grab bar.	3-Restrooms	Move the soap dispenser to a more compliant location.		2019	$ 100.00	Relocate or Replace Dispenser
F09913	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Signage		Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F09914	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Door Gate		Clearance, push parallel	-5, sink encroaches	No	Clearance on push side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	12 inches minimum	2019	$ 3,500.00	
F09949	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Dispenser	TP	Dimension from water closet seat	10	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Relocate or Replace Dispenser
F09950	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Grab Bar	Rear	Dimension, between	3	No	Space above grab bar is interrupted.	3-Restrooms	Move the dispenser to a minimum of 12 inches above the grab bar or remount the object to another location.	12 inches minimum	2019	$ 250.00	
F09951	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Water Closet		Dimension, wide side	31	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2019	$ 5,000.00	
F09952	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2019	$ 150.00	
F09953	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Dispenser	PT	Height	59	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F09954	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Mirror		Height, bottom	40.5	No	Mirror is too high.	5-Tolerance	No action recommended - within construction tolerance.	40 inches maximum	2019	$ 250.00	Relocate or Replace Mirror
F09955	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Water Closet		Height, seat	20	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2019	$ 250.00	
F09956	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Signage		Other attribute	None	No	Braille and raised letter signage is not provided.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F09983	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	59	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	2019	$ 2,500.00	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09984	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Door Gate		Clearance, push parallel	12	No	Clearance on push side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	12 inches minimum	2019	$ 3,500.00	
F09985	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	18	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Relocate or Replace Dispenser
F09986	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	5	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2019	$ 2,500.00	
F09987	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Protrusion	PT	Dimension, protruding	9	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2019	$ 250.00	
F09988	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Protrusion	Hand dryer	Dimension, protruding	7.5	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2019	$ 250.00	
F09989	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Protrusion	Feminine product dispenser	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2019	$ 250.00	
F09990	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2019	$ 150.00	
F09991	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2019	$ 250.00	
F09992	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Dispenser	PT	Height	59	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F09993	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Dispenser	Hand dryer	Height	50	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F09994	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Lavatory Sink		Height	34.5	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	None	$ -	Within Tolerance (per Assessment)
F09995	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2019	$ 250.00	Relocate or Replace Mirror
F09996	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Water Closet		Height, seat	20	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2019	$ 250.00	
F09997	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Door Gate		Opening force	7	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F09998	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2019	$ 150.00	
F10020	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Dispenser	TP	Dimension from water closet seat	20	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Relocate or Replace Dispenser
F10021	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Protrusion	Feminine product dispenser	Dimension, protruding	7.5	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2019	$ 250.00	
F10022	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Protrusion	Hand dryer	Dimension, protruding	7.5	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2019	$ 250.00	
F10023	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Water Closet		Dimension, sidewall	18.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2019	$ 2,500.00	
F10024	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Water Closet		Dimension, wide side	41	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2019	$ 5,000.00	
F10025	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2019	$ 250.00	
F10026	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Dispenser	PT	Height	55.5	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F10027	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Lavatory Sink		Height	35	No	Lavatory sink is too high.	3-Restrooms	Lower the lavatory sink to the correct height.	34 inches maximum	2019	$ 1,500.00	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10028	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2019	$ 250.00	Relocate or Replace Mirror
F10029	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Water Closet		Height, seat	19.5	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2019	$ 250.00	
F10030	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2019	$ 150.00	
F15542	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Shower Room		3-Employee Common	Shower Compartment		Hand spray unit?	N	No	Shower does not include a handheld spray unit.	3-Restrooms	Replace the shower head with a handheld spray unit, mounted a maximum of 48 inches above the finished floor, with a spray hose no less than 59 inches long.		2019	$ 350.00	
F15543	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Shower Room		3-Employee Common	Grab Bar	Continuous	Height, top	36.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	2019	$ 250.00	
F15557	Adams County Service Center		2nd Floor	Owned	Shower Room	Women's - Locker Room	3-Employee Common	Shower Compartment		Hand spray unit?	N	No	Shower does not include a handheld spray unit.	3-Restrooms	Replace the shower head with a handheld spray unit, mounted a maximum of 48 inches above the finished floor, with a spray hose no less than 59 inches long.		2019	$ 350.00	
F15877	Adams County Service Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface	At bus stop	Height, level change	0.75	No	Vertical change in level is too high.	5-Tolerance	No action recommended - within construction tolerance.	.05 inch maximum	None	$ -	Within Tolerance (per Assessment)
F15878	Adams County Service Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface	At bus stop	Slope, cross	4.4%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with a compliant cross slope.	2.08% maximum	2017	$ 5,000.00	Part of Annual Parking project
F15879	Adams County Service Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	North end of island/walk into parking lot	Slope, running	9.6%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp, curb, and gutter to provide compliant running slope.	8.33% maximum	2017	$ 5,000.00	Part of Annual Parking project
F15880	Adams County Service Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface		Slope, running	6.7%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with compliant running and cross slopes, or install handrails, edge protection, and landings required for ramps.	5.0% maximum	2017	$ 5,000.00	Part of Annual Parking project
F15894	Adams County Service Center		Exterior	Owned	Walkway	North side of South parking lot to entrance	1-Public Unsupervised	Walking Surface		Slope, running	7.9%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with compliant running and cross slopes, or install handrails, edge protection, and landings required for ramps.	5.0% maximum	2017	$ 5,000.00	Part of Annual Parking project
F16769	Adams County Service Center	Crime Prevention	Interior	Owned	Work Area		3-Employee Common	Door Gate		Opening force	7	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00086	Adams County Workforce Center		Interior	Leased	Assembly Area		1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F00087	Adams County Workforce Center		Interior	Leased	Assembly Area		1-Public Unsupervised	Door Gate		Opening force	12	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F03728	Adams County Workforce Center		Interior	Leased	Hallway	Between restrooms	1-Public Unsupervised	Drinking Fountain		Dimension, knee clearance	26.5	No	Knee clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	27 inches	None	$ -	Within Tolerance (per Assessment)
F03747	Adams County Workforce Center		Interior	Leased	Hallway		1-Public Unsupervised	Door Gate	Into suite	Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F03748	Adams County Workforce Center		Interior	Leased	Hallway		1-Public Unsupervised	Door Gate	Into suite	Opening force	8	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F10063	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	57	No	Toilet compartment is not deep enough.	3-Restrooms	Reconfigure the stall to provide a minimum of 59 inches in depth.	59 inches	2018	$ 2,500.00	Replace Partition
F10064	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, pull parallel	9	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2018	$ 2,500.00	Install new Door
F10065	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	58	No	Clearance on pull side of door is insufficient.	3-Restrooms	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	2018	$ 2,500.00	Install new Door
F10066	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F10067	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	34.5	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2018	$ 2,500.00	Replace Partition
F10068	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Height	34.25	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	None	$ -	Within Tolerance (per Assessment)
F10069	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Door Gate		Opening force	12	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F10136	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Changing Station		Clearance, perpendicular	35.5	No	Clear floor space is too short.	3-Restrooms	Relocate the changing station to a location with compliant clear floor space.	48 inches minimum	2018	$ 500.00	Relocate Device
F10137	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	57	No	Toilet compartment is not deep enough.	3-Restrooms	Reconfigure the stall to provide a minimum of 59 inches in depth.	59 inches	2018	$ 2,500.00	Replace Partition
F10138	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, pull parallel	9	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2018	$ 2,500.00	Install new Door

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10139	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	56	No	Clearance on pull side of door is insufficient.	3-Restrooms	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	2018	$ 2,500.00	Install new Door
F10140	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F10141	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Height	34.25	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	None	$ -	Within Tolerance (per Assessment)
F10142	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Height, top	37.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	2018	$ 250.00	Rework Grab bar
F10143	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Door Gate		Opening force	13	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F15903	Adams County Workforce Center		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	1-Entry	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F15904	Adams County Workforce Center		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	7	No	Smooth surface at bottom edge of door is insufficient.	1-Entry	No action recommended - this element has safe harbor.	10 inches minimum	None	$ -	Within Tolerance (per Assessment)
F00099	Animal Shelter		Interior	Owned	Assembly Area		2-Public Supervised	Door Gate		Clearance, pull parallel	10	No	Clearance on pull side of door is insufficient.	2-Services	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	None	$ 2,500.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F00100	Animal Shelter		Interior	Owned	Assembly Area		2-Public Supervised	Door Gate		Opening force	11	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	None	$ -	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F00101	Animal Shelter		Interior	Owned	Assembly Area		2-Public Supervised	Signage	Exit	Other attribute	No sign next to door	No	No signage to identify Exit to parking lot.	2-Services	Install a compliant Exit sign which includes Braille and tactile letters, positioned on the latch side of door.		None	$ 100.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F00378	Animal Shelter		Interior	Owned	Break Room		3-Employee Common	Door Gate		Clearance, vertical	77.5	No	Vertical clearance is too low.	2-Services	Replace the doorway with a compliant vertical clearance.	80 inches minimum	None	$ 2,500.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F00379	Animal Shelter		Interior	Owned	Break Room		3-Employee Common	Appliance	Refrig/Freezer	Height	48.5	No	50% of freezer space is not below 54" AFF.	5-Tolerance	No action recommended - within construction tolerance.		None	$ -	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F00380	Animal Shelter		Interior	Owned	Break Room		3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	$ 2,500.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F00381	Animal Shelter		Interior	Owned	Break Room		3-Employee Common	Door Gate		Opening force	11	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	None	$ -	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F04651	Animal Shelter		Interior	Owned	Locker Room	Men's	3-Employee Common	Signage		Location	On door	No	Sign is not mounted in the correct location.	3-Restrooms	Move the sign to the latch side of the door.		None	$ 100.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F04656	Animal Shelter		Interior	Owned	Locker Room	women's	3-Employee Common	Signage		Location	On door	No	Sign is not mounted in the correct location.	3-Restrooms	Move the sign to the latch side of the door.		None	$ 100.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F04657	Animal Shelter		Interior	Owned	Locker Room	women's	3-Employee Common	Shower Compartment		Hand spray unit?	N	No	Shower does not include a handheld spray unit.	3-Restrooms	Replace the shower head with a handheld spray unit, mounted a maximum of 48 inches above the finished floor, with a spray hose no less than 59 inches long.		None	$ 250.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F04663	Animal Shelter		Interior	Owned	Locker Room		3-Employee Common	Bench		Back support?	N	No	No back support provided on fixed bench seat.	3-Restrooms	Provide a bench with a back support that extends from a point 2 inches maximum above the seat surface to a point 18 inches minimum above the seat surface.		None	$ 500.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F04664	Animal Shelter		Interior	Owned	Locker Room		3-Employee Common	Shower Compartment		Hand spray unit?	N	No	Shower does not include a handheld spray unit.	3-Restrooms	Replace the shower head with a handheld spray unit, mounted a maximum of 48 inches above the finished floor, with a spray hose no less than 59 inches long.		None	$ 250.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F04665	Animal Shelter		Interior	Owned	Locker Room		3-Employee Common	Door Gate		Opening force	11	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	None	$ -	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F05809	Animal Shelter		Exterior	Owned	Parking Facility		3-Employee Common	Facility Specifications		Number, accessible	0	No	Too few accessible parking spaces and van accessible parking spaces.	1-Entry	Provide a total of 2 accessible parking spaces, one of which should be a van accessible size parking space.	2 minimum	None	$ 50.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F05810	Animal Shelter		Exterior	Owned	Parking Facility		3-Employee Common	Facility Specifications		Number, van spaces	0	No	Too few van accessible parking spaces are provided.	1-Entry	Provide the minimum number of required van accessible parking spaces.	1 minimum	None	$ 50.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F05811	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Slope, running	2.2%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F05812	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Van sign?	N	No	Van Accessible' sign is not present.	1-Entry	Install a 'Van Accessible' sign.		None	$ 50.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10202	Animal Shelter		Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	7.5	No	Space between wall and grab bar is too wide.	3-Restrooms	Install a new grab bar with the correct spacing between the grab bar and the wall.	1.5 inches	None		Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10203	Animal Shelter		Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	-3	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	None	$ 100.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10204	Animal Shelter		Interior	Owned	Restroom	Men's	3-Employee Common	Lavatory Sink		Dimension, knee clearance	25	No	Knee clearance is too low.	3-Restrooms	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	None		Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10205	Animal Shelter		Interior	Owned	Restroom	Men's	1-Public Unsupervised	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	None	$ 250.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10206	Animal Shelter		Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Over obstruction?	Y	No	Toilet paper dispenser is mounted above the grab bar.	3-Restrooms	Move the toilet paper dispenser to a compliant position under the grab bar.		None	$ 100.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10207	Animal Shelter		Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	2	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	None	$ 250.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10208	Animal Shelter		Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, sidewall	20.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	None	$ 2,500.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10209	Animal Shelter		Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, wide side	28.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	None	$ 7,500.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10223	Animal Shelter		Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	2	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	None	$ 250.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10224	Animal Shelter		Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		None	$ 250.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10225	Animal Shelter		Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Coat Hook		Height	62	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	None	$ 150.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10226	Animal Shelter		Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Grab Bar	Side	Height, top	31	No	Grab bar is too low.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	None	$ 250.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10227	Animal Shelter		Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		None	$ 500.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10228	Animal Shelter		Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		None	$ 150.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10251	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Toilet Compartment		Clearance, parallel	49	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	None	$ 5,000.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10252	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Clearance, perpendicular	20.5	No	Clear floor space is too short.	3-Restrooms	Reconfigure the lavatory sink to provide at least the minimum clear floor space.	48 inches minimum	None	$ -	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10253	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Dispenser	TP	Dimension from water closet seat	10	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	None	$ 100.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10254	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Dimension, sidewall	14.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	None	$ 5,000.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10255	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Dimension, wide side	30	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	None	$ 7,500.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10256	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Mirror		Height, bottom	40.5	No	Mirror is too high.	5-Tolerance	No action recommended - within construction tolerance.	40 inches maximum	None	$ 250.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10257	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Grab Bar		Other attribute	None Provided	No	No grab bars provided.	3-Restrooms	Install grab bars on the rear and side wall.		None	$ 2,500.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10284	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, pull parallel	4	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	None	$ 250.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10285	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	-4	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	None	$ 100.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10286	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	9.5	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	None	$ 250.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10287	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	4.5	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	None	$ 250.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10288	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, sidewall	20.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	None	$ 5,000.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10289	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, wide side	28.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	None	$ 7,500.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10290	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		None	$ 150.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10291	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Hand sanitizer	Height	53	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	None	$ 100.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10292	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Other attribute	Low	No	Space between grab bar and toilet tank below is too small.	3-Restrooms	Raise the grab bar to provide gripping space between the toilet tank and the grab bar.		None	$ 250.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10293	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Over obstruction?	Y	No	Toilet paper dispenser is mounted above the grab bar.	3-Restrooms	Move the toilet paper dispenser to a compliant position under the grab bar.		None	$ 100.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10328	Animal Shelter		Interior	Owned	Restroom	Women's - Locker Room	3-Employee Common	Door Gate		Opening force	11	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	None	$ -	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10329	Animal Shelter		Interior	Owned	Restroom	Women's - Locker Room	3-Employee Common	Shower Compartment		Hand spray unit?	N	No	Shower does not include a handheld spray unit.	3-Restrooms	Replace the shower head with a handheld spray unit, mounted a maximum of 48 inches above the finished floor, with a spray hose no less than 59 inches long.		None	$ 250.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10330	Animal Shelter		Interior	Owned	Restroom	Women's - Locker Room	3-Employee Common	Toilet Compartment		Hardware both sides?	No	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		None	$ 250.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F10331	Animal Shelter		Interior	Owned	Restroom	Women's - Locker Room	3-Employee Common	Toilet Compartment		Self-closing?	No	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		None	$ 150.00	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F15665	Animal Shelter		Interior	Owned	Visiting Area	Lost dogs	2-Public Supervised	Door Gate		Opening force	11	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	None	$ -	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F15922	Animal Shelter	Lost and Found	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Opening force	6	No	Opening force is too high.	1-Entry	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	None	$ -	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F00389	Aurora Motor Vehicle		Interior	Leased	Break Room		3-Employee Common	Lavatory Sink		Clearance, parallel	27	No	Clear floor space is too narrow.	2-Services	Reconfigure the lavatory sink to provide at least the minimum clear floor space.	30 inches minimum	None	$ -	Intent to Build new Animal Shelter in 2016-2017 / Sell existing in 2017
F00390	Aurora Motor Vehicle		Interior	Leased	Break Room		3-Employee Common	Appliance	Microwave	Height	68	No	Operable part is out of reach range.	4-Other	Relocate the appliance to within a compliant reach range.	48 inches maximum	2016	$ -	Internal Staff - Operations
F05838	Aurora Motor Vehicle		Exterior	Leased	Parking Facility		1-Public Unsupervised	Facility Specifications		Cars obstruct pathway	Y	No	Cars protrude into path of travel.	1-Entry	Install curb stops at the head of parking spaces to avoid obstruction in the path of travel.		2016	$ -	Letter to Landlord - Not County Owned Property
F10336	Aurora Motor Vehicle		Interior	Leased	Restroom	Unisex - Employee	3-Employee Common	Water Closet		Dimension, wide side	32	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2020	$ 7,500.00	Coordinate with Landlord
F10337	Aurora Motor Vehicle		Interior	Leased	Restroom	Unisex - Employee	3-Employee Common	Dispenser	Toilet seat covers	Height	55	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2016	$ 100.00	Relocate or Replace Dispenser
F10338	Aurora Motor Vehicle		Interior	Leased	Restroom	Unisex - Employee	3-Employee Common	Grab Bar	Rear	Length	30	No	Rear grab bar is too short.	3-Restrooms	Replace the existing rear grab bar with a 36 inch long grab bar.	36 inches minimum	2016	$ 250.00	Rework Grab bar
F10339	Aurora Motor Vehicle		Interior	Leased	Restroom	Unisex - Employee	3-Employee Common	Alarm System		Visible alarm	N	No	No visible alarm is provided.	3-Restrooms	Install a visible wall fire alarm.	Between 80 and 96 inches AFF	2016	$ -	Letter to Landlord - Not County Owned Property
F15932	Aurora Motor Vehicle		Exterior	Leased	Walkway		3-Employee Common	Door Gate	Rear entrance	Height, threshold	1	No	Threshold is too high.	1-Entry	Provide a threshold which is 0.25 inch maximum, or a beveled threshold which is 0.5 inch maximum, at the door entrance.	0.5 inch maximum	2016	$ -	Letter to Landlord - Not County Owned Property
F00394	Children and Family Center		1st Floor	Owned	Break Room	Childcare Area	3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F00395	Children and Family Center		1st Floor	Owned	Break Room	Childcare Area	3-Employee Common	Lavatory Sink		Height	36	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F00397	Children and Family Center		4th Floor	Owned	Break Room	East	3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F00398	Children and Family Center		4th Floor	Owned	Break Room	East	3-Employee Common	Lavatory Sink		Height	36	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F00400	Children and Family Center		3rd Floor	Owned	Break Room	West	3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F00401	Children and Family Center		4th Floor	Owned	Break Room	West	3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F00402	Children and Family Center		3rd Floor	Owned	Break Room	West	3-Employee Common	Lavatory Sink		Height	36	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F00403	Children and Family Center		4th Floor	Owned	Break Room	West	3-Employee Common	Lavatory Sink		Height	36	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F00404	Children and Family Center		3rd Floor	Owned	Break Room	West	3-Employee Common	Walking Surface	Path of travel to sink	Width	27	No	Walking surface is too narrow.	2-Services	Move the copier or refrigerator to provide an accessible route to the sink.	36 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F00407	Children and Family Center		2nd Floor	Owned	Break Room		1-Public Unsupervised	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F00408	Children and Family Center		2nd Floor	Owned	Break Room		1-Public Unsupervised	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F00409	Children and Family Center		3rd Floor	Owned	Break Room		3-Employee Common	Counter		Height	37.5	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F00410	Children and Family Center		2nd Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Height	36	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F00411	Children and Family Center		2nd Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Height	36	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F00412	Children and Family Center		3rd Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Height	37.5	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F03757	Children and Family Center		4th Floor	Owned	Hallway		1-Public Unsupervised	Signage	Exit to stairway	Braille?	N	No	Signage does not provide Braille.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		None	n/a	New HSB Under Construction - Relocation in 2017
F03758	Children and Family Center		1st Floor	Owned	Hallway		1-Public Unsupervised	Signage	Conf Room A	Braille?	N	No	Signage does not provide Braille.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		None	n/a	New HSB Under Construction - Relocation in 2017
F03759	Children and Family Center		3rd Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near Restrooms	Dimension, knee clearance	25	No	Knee clearance is too low.	4-Other	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F03760	Children and Family Center		4th Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near Restrooms	Dimension, knee clearance	25	No	Knee clearance is too low.	4-Other	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F03761	Children and Family Center		1st Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near Restrooms	Dimension, knee clearance	25	No	Knee clearance is too low.	4-Other	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	None	n/a	New HSB Under Construction - Relocation in 2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F03762	Children and Family Center		1st Floor	Owned	Hallway		1-Public Unsupervised	Vending Machine	Pepsi	Height	52	No	Operable part is out of reach range.	4-Other	Replace the Vending Machine with one that has operable parts within the reach range.	48 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F03763	Children and Family Center		3rd Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near Restrooms	High-low fountain?	N	No	Fountain provided is not a hi/low fountain.	4-Other	No action recommended - this element has safe harbor.		None	n/a	New HSB Under Construction - Relocation in 2017
F03764	Children and Family Center		4th Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near Restrooms	High-low fountain?	N	No	Fountain provided is not a hi/low fountain.	4-Other	No action recommended - this element has safe harbor.		None	n/a	New HSB Under Construction - Relocation in 2017
F03765	Children and Family Center		1st Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near Restrooms	High-low fountain?	N	No	Fountain provided is not a hi/low fountain.	4-Other	No action recommended - this element has safe harbor.		None	n/a	New HSB Under Construction - Relocation in 2017
F03766	Children and Family Center		1st Floor	Owned	Hallway		1-Public Unsupervised	Signage	Conf Room A	Location	On door	No	Sign is not mounted in the correct location.	2-Services	Move the sign to the latch side of the door.		None	n/a	New HSB Under Construction - Relocation in 2017
F03767	Children and Family Center		1st Floor	Owned	Hallway		1-Public Unsupervised	Signage		Location	On door	No	Sign is not mounted in the correct location.	2-Services	Move the sign to the latch side of the door.		None	n/a	New HSB Under Construction - Relocation in 2017
F03768	Children and Family Center		1st Floor	Owned	Hallway		1-Public Unsupervised	Door Gate		Opening force	15	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F03769	Children and Family Center		1st Floor	Owned	Hallway		1-Public Unsupervised	Signage	Exit Sign	Other attribute	None	No	No signage identifying this exit.	2-Services	Install Exit identification signage which includes raised characters and Braille, positioned on latch side of door.		None	n/a	New HSB Under Construction - Relocation in 2017
F03770	Children and Family Center		4th Floor	Owned	Hallway		3-Employee Common	Signage	Exit to stairway	Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		None	n/a	New HSB Under Construction - Relocation in 2017
F03771	Children and Family Center		1st Floor	Owned	Hallway		1-Public Unsupervised	Signage	Conf Room A	Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		None	n/a	New HSB Under Construction - Relocation in 2017
F03772	Children and Family Center		1st Floor	Owned	Hallway		1-Public Unsupervised	Signage		Braille?	N	No	Signage does not provide Braille.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		None	n/a	New HSB Under Construction - Relocation in 2017
F03773	Children and Family Center		1st Floor	Owned	Hallway		1-Public Unsupervised	Signage		Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		None	n/a	New HSB Under Construction - Relocation in 2017
F04315	Children and Family Center		1st Floor	Owned	Lobby Reception		1-Public Unsupervised	Counter		Height	42	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F04938	Children and Family Center		3rd Floor	Owned	Other Room	All rooms	1-Public Unsupervised	Door Gate	All doors	Opening force	15	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05841	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#4	Access aisle?	N	No	No access aisle provided.	1-Entry	Provide a marked access aisle adjacent to the parking space.	60 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F05842	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	#3	Slope, cross	2.2%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05843	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	#2	Slope, cross	2.9%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05844	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	#1	Slope, cross	3.5%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05845	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#6	Slope, cross	2.5%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05846	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#8	Slope, cross	2.6%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05847	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#1	Slope, cross	3.0%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05848	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#3	Slope, cross	3.0%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05849	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#7	Slope, cross	3.1%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05850	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#5	Slope, cross	3.6%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05851	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#2	Slope, cross	3.9%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05852	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#4	Slope, cross	4.3%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05853	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	#3	Slope, running	3.7%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05854	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	#3	Slope, running	5.4%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05855	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	#4	Slope, running	5.7%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05856	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	#2	Slope, running	5.9%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05857	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	#1	Slope, running	6.2%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05858	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#7	Slope, running	4.3%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05859	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#6	Slope, running	4.8%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05860	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#1	Slope, running	5.0%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05861	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#3	Slope, running	5.1%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05862	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#4	Slope, running	5.2%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05863	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#8	Slope, running	5.7%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05864	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#2	Slope, running	5.9%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05872	Children and Family Center		Exterior	Owned	Parking Facility	Visitors	1-Public Unsupervised	Parking Space	#1	Height, sign	51.5	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F05873	Children and Family Center		Exterior	Owned	Parking Facility	Visitors	1-Public Unsupervised	Parking Space	#4	Height, sign	55	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F05874	Children and Family Center		Exterior	Owned	Parking Facility	Visitors	1-Public Unsupervised	Parking Space	#3	Slope, cross	2.8%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05875	Children and Family Center		Exterior	Owned	Parking Facility	Visitors	1-Public Unsupervised	Parking Space	#4	Slope, cross	2.3%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05876	Children and Family Center		Exterior	Owned	Parking Facility	Visitors	1-Public Unsupervised	Parking Space	#1	Slope, running	3.0%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05877	Children and Family Center		Exterior	Owned	Parking Facility	Visitors	1-Public Unsupervised	Parking Space	#4	Slope, running	2.2%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F10366	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	28	No	Clear floor space is too narrow.	3-Restrooms	Reconfigure the lavatory sink to provide at least the minimum clear floor space.	30 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F10367	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	58	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10368	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	48	No	Clearance on pull side of door is insufficient.	3-Restrooms	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F10369	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	48	No	Clearance on pull side of door is insufficient.	3-Restrooms	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F10370	Children and Family Center		4th Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	48	No	Clearance on pull side of door is insufficient.	3-Restrooms	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F10371	Children and Family Center		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	48	No	Clearance on pull side of door is insufficient.	3-Restrooms	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F10372	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	Behind	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10373	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	1	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10374	Children and Family Center		1st Floor	Owned	Restroom	Men's	3-Employee Common	Dispenser	TP	Dimension from water closet seat	1	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10375	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Dimension, between	10.5	No	Space between the grab bar and dispenser above is too small.	3-Restrooms	Moving the dispenser to a minimum of 12 inches above the grab bar will place the dispenser out of reach range. Relocate the dispenser to another location.	Between 15 and 48 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10376	Children and Family Center		4th Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Dimension, between	7.5	No	Space between the grab bar and dispenser above is too small.	3-Restrooms	Moving the dispenser to a minimum of 12 inches above the grab bar will place the dispenser out of reach range. Relocate the dispenser to another location.	Between 15 and 48 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10377	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	9	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F10378	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Protrusion	PT	Dimension, protruding	9	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		None	n/a	New HSB Under Construction - Relocation in 2017
F10379	Children and Family Center		4th Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, sidewall	21	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10380	Children and Family Center		1st Floor	Owned	Restroom	Men's	3-Employee Common	Water Closet		Dimension, sidewall	21.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10381	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		None	n/a	New HSB Under Construction - Relocation in 2017
F10382	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		None	n/a	New HSB Under Construction - Relocation in 2017
F10383	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		None	n/a	New HSB Under Construction - Relocation in 2017
F10384	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Coat Hook		Height	59	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F10385	Children and Family Center		4th Floor	Owned	Restroom	Men's	1-Public Unsupervised	Coat Hook		Height	59	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F10386	Children and Family Center		1st Floor	Owned	Restroom	Men's	3-Employee Common	Coat Hook		Height	58.5	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F10387	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser		Height	52	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F10388	Children and Family Center		4th Floor	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	PT	Height	53	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F10389	Children and Family Center		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	PT	Height	52	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F10390	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Changing Station		Height	36	No	Work surface does not comply with height requirements.	3-Restrooms	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10391	Children and Family Center		4th Floor	Owned	Restroom	Men's	1-Public Unsupervised	Changing Station		Height	36	No	Work surface does not comply with height requirements.	3-Restrooms	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10392	Children and Family Center		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Changing Station		Height	36	No	Work surface does not comply with height requirements.	3-Restrooms	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10393	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Changing Station		Height	37	No	Work surface does not comply with height requirements.	3-Restrooms	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10394	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Mirror		Height, bottom	43	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F10395	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Mirror		Height, bottom	44	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10396	Children and Family Center		4th Floor	Owned	Restroom	Men's	1-Public Unsupervised	Mirror		Height, bottom	44	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F10397	Children and Family Center		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Mirror		Height, bottom	44	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F10398	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Height, top	36.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10399	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Height, top	36.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10400	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Height, top	37	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10401	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Height, top	37	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10402	Children and Family Center		4th Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Height, top	36.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10403	Children and Family Center		4th Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Height, top	36.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10404	Children and Family Center		1st Floor	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Side	Height, top	37	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10405	Children and Family Center		1st Floor	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Rear	Height, top	37	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10407	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Location	On door	No	Sign is not mounted in the correct location.	3-Restrooms	Move the sign to the latch side of the door.		None	n/a	New HSB Under Construction - Relocation in 2017
F10408	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		None	n/a	New HSB Under Construction - Relocation in 2017
F10409	Children and Family Center		4th Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		None	n/a	New HSB Under Construction - Relocation in 2017
F10410	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Opening force	12	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F10411	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		None	n/a	New HSB Under Construction - Relocation in 2017
F10412	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		None	n/a	New HSB Under Construction - Relocation in 2017
F10453	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	48	No	Clearance on pull side of door is insufficient.	3-Restrooms	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F10454	Children and Family Center		3rd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	48	No	Clearance on pull side of door is insufficient.	3-Restrooms	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F10455	Children and Family Center		4th Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	48	No	Clearance on pull side of door is insufficient.	3-Restrooms	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F10456	Children and Family Center		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	48	No	Clearance on pull side of door is insufficient.	3-Restrooms	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F10457	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10458	Children and Family Center		4th Floor	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	2	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10459	Children and Family Center		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	3	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10460	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Dimension, between	5	No	Space between the grab bar and dispenser above is too small.	3-Restrooms	Moving the dispenser to a minimum of 12 inches above the grab bar will place the dispenser out of reach range. Relocate the dispenser to another location.	Between 15 and 48 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10461	Children and Family Center		3rd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar		Dimension, between	9	No	Space between the grab bar and dispenser above is too small.	3-Restrooms	Moving the dispenser to a minimum of 12 inches above the grab bar will place the dispenser out of reach range. Relocate the dispenser to another location.	Between 15 and 48 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10462	Children and Family Center		4th Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Dimension, between	10	No	Space between the grab bar and dispenser above is too small.	3-Restrooms	Moving the dispenser to a minimum of 12 inches above the grab bar will place the dispenser out of reach range. Relocate the dispenser to another location.	Between 15 and 48 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10463	Children and Family Center		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Dimension, between	8	No	Space between the grab bar and dispenser above is too small.	3-Restrooms	Moving the dispenser to a minimum of 12 inches above the grab bar will place the dispenser out of reach range. Relocate the dispenser to another location.	Between 15 and 48 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10464	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Protrusion	PT	Dimension, protruding	9	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		None	n/a	New HSB Under Construction - Relocation in 2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10465	Children and Family Center		3rd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Protrusion	PT	Dimension, protruding	9	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		None	n/a	New HSB Under Construction - Relocation in 2017
F10466	Children and Family Center		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Protrusion	PT	Dimension, protruding	9	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		None	n/a	New HSB Under Construction - Relocation in 2017
F10467	Children and Family Center		3rd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, sidewall	19	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10468	Children and Family Center		4th Floor	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, sidewall	20	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10469	Children and Family Center		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, sidewall	21	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10470	Children and Family Center		4th Floor	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, wide side	41	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F10471	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		None	n/a	New HSB Under Construction - Relocation in 2017
F10472	Children and Family Center		4th Floor	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		None	n/a	New HSB Under Construction - Relocation in 2017
F10473	Children and Family Center		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		None	n/a	New HSB Under Construction - Relocation in 2017
F10474	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		None	n/a	New HSB Under Construction - Relocation in 2017
F10475	Children and Family Center		3rd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		None	n/a	New HSB Under Construction - Relocation in 2017
F10476	Children and Family Center		4th Floor	Owned	Restroom	Women's	1-Public Unsupervised	Coat Hook		Height	59	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F10477	Children and Family Center		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Coat Hook		Height	59	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F10478	Children and Family Center		3rd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Height	52	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F10479	Children and Family Center		4th Floor	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Height	52	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F10480	Children and Family Center		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Height	51	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F10481	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Changing Station		Height	36	No	Work surface does not comply with height requirements.	3-Restrooms	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10482	Children and Family Center		3rd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Changing Station		Height	36	No	Work surface does not comply with height requirements.	3-Restrooms	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10483	Children and Family Center		4th Floor	Owned	Restroom	Women's	1-Public Unsupervised	Changing Station		Height	36	No	Work surface does not comply with height requirements.	3-Restrooms	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10484	Children and Family Center		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Changing Station		Height	36	No	Work surface does not comply with height requirements.	3-Restrooms	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10485	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Mirror		Height, bottom	44	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F10486	Children and Family Center		3rd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Mirror		Height, bottom	47	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F10487	Children and Family Center		4th Floor	Owned	Restroom	Women's	1-Public Unsupervised	Mirror		Height, bottom	44	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F10488	Children and Family Center		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Mirror		Height, bottom	44	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F10489	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Height, top	36.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10490	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Height, top	36.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10491	Children and Family Center		3rd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar		Height, top	36.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10492	Children and Family Center		3rd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Height, top	36.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10493	Children and Family Center		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Height, top	36.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10494	Children and Family Center		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Height, top	36.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F10495	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Location	On door	No	Sign is not mounted in the correct location.	3-Restrooms	Move the sign to the latch side of the door.		None	n/a	New HSB Under Construction - Relocation in 2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10496	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Opening force	15	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F10497	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		None	n/a	New HSB Under Construction - Relocation in 2017
F15934	Children and Family Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp		Slope, counter	6.2%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp, curb, or gutter to provide compliant counter slope.	5.0% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F15935	Children and Family Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp		Slope, running	10.6%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp, curb, and gutter to provide compliant running slope.	8.33% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F15936	Children and Family Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp		Width	33	No	Curb ramp is too narrow.	1-Entry	Design and build the curb ramp to a minimum width of 36 inches.	48 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F15940	Children and Family Center		Exterior	Owned	Walkway	To employee entrance	3-Employee Common	Door Gate		Slope, running	4.4%	No	Slope is too steep.	1-Entry	Regrade the maneuvering clearance, at the doorway, with a compliant slope.	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F15943	Children and Family Center		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Slope, running	4.4%	No	Slope is too steep.	1-Entry	Regrade the maneuvering clearance, at the doorway, with a compliant slope.	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F07380	City View Park		Exterior	Owned	Play Area		1-Public Unsupervised	Area Specifications		Number, elevated components on accessible route	1	No	Too few elevated play components are provided on an accessible route.	2-Services	Provide not < 3 elevated play components on an accessible route. Alter structure or add an accessible Entry Point to composite structure so that not < 3 additional elevated components are on an accessible route, 36 inches wide.	3 minimum	2020	$ 5,000.00	by Parks
F07381	City View Park		Exterior	Owned	Play Area		1-Public Unsupervised	Area Specifications		Number, ground components	1	No	Too few ground level play components are provided on an accessible route.	2-Services	Provide not < 2 ground level play components of not < 2 different types with clear ground space at each. Provide an accessible route connecting the perimeter of the play area to each ground level component required to be accessible.	2 of 2	2020	$ 5,000.00	by Parks
F07382	City View Park		Exterior	Owned	Play Area		1-Public Unsupervised	Walking Surface		Surface material	Pea gravel and rubberized tiles	No	Surface of ground level route to ground level play components or to transfer system is not an accessible surface.	2-Services	Provide an accessible route connecting the perimeter of the play area to the entry point of the elevated composite play structures.		2020	$ 5,000.00	by Parks
F15945	City View Park		Exterior	Owned	Walkway	From street parking to play area	1-Public Unsupervised	Walking Surface		Slope, cross	2.2%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	n/a		Within Tolerance (per Assessment)
F15946	City View Park		Exterior	Owned	Walkway	From street parking to play area	1-Public Unsupervised	Walking Surface		Slope, running	7.0%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with compliant running and cross slopes, or install handrails, edge protection, and landings required for ramps.	5.0% maximum	2020	$ 5,000.00	by Parks
F00416	District Attorneys Building	Probation Area	Interior	Owned	Break Room		3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2020	$ 2,500.00	
F00417	District Attorneys Building		Interior	Owned	Break Room	Training Servery	3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2020	$ 2,500.00	
F00418	District Attorneys Building		3rd Floor	Owned	Break Room		3-Employee Common	Appliance	Ice and coffee machine on counter	Height	50-54	No	Operable part is out of reach range.	4-Other	Relocate the appliance to within a compliant reach range.	48 inches maximum	2020	$ 500.00	
F00419	District Attorneys Building		3rd Floor	Owned	Break Room		3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2020	$ 2,500.00	
F00420	District Attorneys Building		3rd Floor	Owned	Break Room		3-Employee Common	Vending Machine	Soda and snacks	Height, control	46-54	No	Operable part is out of reach range.	4-Other	Replace the Vending Machine with one that has operable parts within the reach range.	48 inches maximum	2016	$ -	Internal Staff - Operations
F04279	District Attorneys Building		Exterior	Owned	Loading Zone	Street Bus Stop	1-Public Unsupervised	Pullup Space		Slope, running	2.4%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F04316	District Attorneys Building		Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Height	42	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2020	$ 2,500.00	
F04317	District Attorneys Building		Interior	Owned	Lobby Reception		1-Public Unsupervised	Signage	Exit at Main entrance	Location	On door	No	Sign is not mounted in the correct location.	2-Services	Move the sign to the latch side of the door.		2016	$ 100.00	
F04681	District Attorneys Building		Interior	Owned	Locker Room	Men's	3-Employee Common	Dispenser	Soap	Height	54	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2020	$ 100.00	Relocate or Replace Dispenser
F04682	District Attorneys Building		Interior	Owned	Locker Room	Men's	3-Employee Common	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2020	$ 250.00	Relocate or Replace Mirror
F04683	District Attorneys Building		Interior	Owned	Locker Room	Men's	3-Employee Common	Door Gate		Opening force	9	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F04692	District Attorneys Building		Interior	Owned	Locker Room	Women's	3-Employee Common	Dispenser	Soap	Height	52	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2020	$ 100.00	Relocate or Replace Dispenser
F04693	District Attorneys Building		Interior	Owned	Locker Room	Women's	3-Employee Common	Mirror		Height, bottom	46	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2020	$ 250.00	Relocate or Replace Mirror
F04694	District Attorneys Building		Interior	Owned	Locker Room	Women's	3-Employee Common	Shower Compartment		Height, shower control	52	No	Shower controls are mounted too high.	3-Restrooms	Provide a lowered shower control.	48 inches maximum	2020	$ 500.00	
F04695	District Attorneys Building		Interior	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Opening force	10	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F04940	District Attorneys Building		Interior	Owned	Other Room	DA office	1-Public Unsupervised	Counter	Reception	Height	42	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2020	$ 2,500.00	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05888	District Attorneys Building		Exterior	Owned	Parking Facility	East parking lot	1-Public Unsupervised	Facility Specifications		Cars obstruct pathway	Y	No	Cars protrude into path of travel.	1-Entry	Install curb stops at the head of parking spaces to avoid obstruction in the path of travel.		2020	$ 500.00	Part of Annual Parking Project
F05905	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Facility Specifications		Cars obstruct pathway	Y	No	Cars protrude into path of travel.	1-Entry	Install curb stops at the head of parking spaces to avoid obstruction in the path of travel.		2020	$ 500.00	Part of Annual Parking Project
F05906	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 1 between spaces #1 & #2	Slope, running	2.9%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	n/a	$ -	Within Tolerance (per Assessment)
F05907	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 3 between spaces #5 & #6	Slope, running	3.5%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking Project
F05908	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 3 right of space #7	Slope, running	3.8%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking Project
F05909	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 3 between spaces #1 & #2	Slope, running	3.9%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking Project
F05910	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 3 between spaces #3 & #4	Slope, running	4.4%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking Project
F05911	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 1 space #1	Slope, running	3.1%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking Project
F05912	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 1 space #2	Slope, running	3.2%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking Project
F05913	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 3 space #1	Slope, running	3.5%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking Project
F05914	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Slope, running	3.5%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking Project
F05915	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 3 space #2	Slope, running	3.7%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking Project
F05916	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Slope, running	4.0%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking Project
F05917	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Slope, running	4.0%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking Project
F05918	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Slope, running	5.0%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking Project
F05919	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 3 space #3	Slope, running	5.8%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking Project
F10515	District Attorneys Building		Interior	Owned	Restroom	All restrooms	1-Public Unsupervised	Signage		Braille?	N	No	Signage does not provide Braille.	3-Restrooms	Install signage, with both raised letters and Braille, to all restrooms.		2016	$ 100.00	
F10516	District Attorneys Building		Interior	Owned	Restroom	All restrooms	1-Public Unsupervised	Signage		Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	3-Restrooms	Install signage, with both raised letters and Braille, to all restrooms.		2016	$ 100.00	
F10517	District Attorneys Building		2nd Floor	Owned	Restroom	Men's	3-Employee Common	Dispenser	Soap	Height	52	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Relocate or Replace Dispenser
F10518	District Attorneys Building		2nd Floor	Owned	Restroom	Men's	3-Employee Common	Door Gate		Opening force	10	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F10519	District Attorneys Building		3rd Floor	Owned	Restroom	Men's	3-Employee Common	Door Gate		Opening force	10	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F10520	District Attorneys Building		1st Floor	Owned	Restroom	Men's - East	3-Employee Common	Door Gate		Opening force	10	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10523	District Attorneys Building		Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Signage		Braille?	N	No	Signage does not provide Braille.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F10524	District Attorneys Building		Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Dispenser	Soap	Height	54	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Relocate or Replace Dispenser
F10525	District Attorneys Building		Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Signage		Height, bottom	60	No	Signage is too high.	3-Restrooms	Remount sign with tactile letters located 48 inches minimum and 60 inches maximum, above the finished floor, measured from the baseline of the tactile letters.	48 to 60 inches	2016	$ 100.00	
F10526	District Attorneys Building		Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Signage		Height, top	63	No	Signage is too high.	3-Restrooms	Remount sign with tactile letters located 48 inches minimum and 60 inches maximum, above the finished floor, measured from the baseline of the tactile letters.	48 to 60 inches	2016	$ 100.00	
F10528	District Attorneys Building		Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Opening force	8	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F10529	District Attorneys Building		Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Signage		Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F10530	District Attorneys Building		Interior	Owned	Restroom	Men's - Probation Area	3-Employee Common	Dispenser	Soap	Height	52	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Relocate or Replace Dispenser
F10531	District Attorneys Building		3rd Floor	Owned	Restroom	Women's	3-Employee Common	Door Gate		Opening force	16	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F10532	District Attorneys Building		1st Floor	Owned	Restroom	Women's - East	3-Employee Common	Door Gate		Opening force	10	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F10534	District Attorneys Building		Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Signage		Braille?	N	No	Signage does not provide Braille.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F10535	District Attorneys Building		Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Dispenser	Soap	Height	54	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Relocate or Replace Dispenser
F10537	District Attorneys Building		Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Opening force	9	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F10538	District Attorneys Building		Interior	Owned	Restroom	Women's- Probation Area	3-Employee Common	Dispenser	Soap	Height	52	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Relocate or Replace Dispenser
F15950	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp at roundabout	1-Public Unsupervised	Curb Ramp		Slope, left flare	11.6%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp with compliant side flares.	10% maximum	2020	$ 500.00	Part of Annual Parking Project
F15951	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp at roundabout	1-Public Unsupervised	Curb Ramp		Slope, running	8.6%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	8.33% maximum	2020	$ 500.00	Part of Annual Parking Project
F15952	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp at roundabout	1-Public Unsupervised	Landing		Slope, running	3.5%	No	Slope is too steep.	1-Entry	Rebuild the landing to provide compliant running and cross slopes.	2.08% maximum	2020	$ 500.00	Part of Annual Parking Project
F15953	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp at roundabout	1-Public Unsupervised	Walking Surface	Between curb ramp and landing	Width, opening	1.25	No	Opening in walking surface is too wide.	1-Entry	Fill/patch the gaps in the walking surface.	0.5 inch maximum	2020	$ 500.00	Part of Annual Parking Project
F15964	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from roundabout to building entrance	1-Public Unsupervised	Landing		Slope, running	4.5%	No	Slope is too steep.	1-Entry	Rebuild the landing to provide compliant running and cross slopes.	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking Project
F15965	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from roundabout to building entrance	1-Public Unsupervised	Walking Surface		Surface material	No markings or accessible path of travel	No	Curb ramps from public sidewalks and accessible parking require visitors to travel over and through vehicular roundabout in order to access sidewalk leading to building entrance.	1-Entry	Provide an accessible route connecting the public sidewalk, bike path, and accessible parking area to the building entrance.		2020	$ 5,000.00	Part of Annual Parking Project
F15977	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 2 to main entry	1-Public Unsupervised	Landing		Slope, running	5.0%	No	Slope is too steep.	1-Entry	Rebuild the landing to provide compliant running and cross slopes.	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking Project
F15989	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 2 to row 1	1-Public Unsupervised	Curb Ramp		Slope, counter	9.6%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp, curb, or gutter to provide compliant counter slope.	5.0% maximum	2020	$ 500.00	Part of Annual Parking Project
F15990	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 2 to row 1	1-Public Unsupervised	Landing		Slope, running	6.1%	No	Slope is too steep.	1-Entry	Rebuild the landing to provide compliant running and cross slopes.	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking Project
F16001	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 3 to row 2	1-Public Unsupervised	Curb Ramp		Slope, running	9.7%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp, curb, and gutter to provide compliant running slope.	8.33% maximum	2020	$ 500.00	Part of Annual Parking Project
F16002	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 3 to row 2	1-Public Unsupervised	Landing		Slope, running	4.9%	No	Slope is too steep.	1-Entry	Rebuild the landing to provide compliant running and cross slopes.	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking Project
F16013	District Attorneys Building		Exterior	Owned	Walkway	From accessible path to East entry	1-Public Unsupervised	Walking Surface		Slope, running	9.5%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with compliant running and cross slopes, or install handrails, edge protection, and landings required for ramps.	5.0% maximum	2020	$ 5,000.00	Part of Annual Parking Project
F16018	District Attorneys Building		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface		Slope, cross	3.1%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with a compliant cross slope.	2.08% maximum	2020	$ 5,000.00	Part of Annual Parking Project
F16023	District Attorneys Building		Exterior	Owned	Walkway	From roundabout to Main entrance	1-Public Unsupervised	Walking Surface		Slope, cross	2.3%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F16028	District Attorneys Building		Exterior	Owned	Walkway	From street sidewalk to roundabout	1-Public Unsupervised	Walking Surface		Slope, running	8.2%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with compliant running and cross slopes, or install handrails, edge protection, and landings required for ramps.	5.0% maximum	2020	$ 5,000.00	Part of Annual Parking Project
F16033	District Attorneys Building		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate	Main entrance	Clear opening	31.5	No	Clear opening is too narrow.	1-Entry	Reframe the doorway to provide a compliant clear opening width. Offset hinges may be used to facilitate the process.	32 inches minimum	2020	$ 3,500.00	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16034	District Attorneys Building		Exterior	Owned	Walkway		1-Public Unsupervised	Walking Surface	From parking lot to main entrance	Slope, cross	4.4%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with a compliant cross slope.	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking Project
F16035	District Attorneys Building		Exterior	Owned	Walkway		1-Public Unsupervised	Walking Surface	From parking lot to main entrance	Slope, running	8.5%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with compliant running and cross slopes, or install handrails, edge protection, and landings required for ramps.	5.0% maximum	2020	$ 5,000.00	Part of Annual Parking Project
F03527	Elaine Valente Open Space		Exterior	Owned	Fishing Pier		1-Public Unsupervised	Railing		Length, 34 inch max. railing	0	No	Lowered railing is not provided on fishing pier.	2-Services	Provide and disperse at least 25% of the railing at a maximum of 34 inches above the pier surface.	19 feet at 34 inches	2018	$ 2,500.00	by Parks
F06000	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Access aisle?	N	No	No access aisle provided.	1-Entry	Provide a marked access aisle adjacent to the parking space.	60 inches minimum	2018	$ 1,000.00	by Parks
F06001	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, van spaces	0	No	Too few van accessible parking spaces are provided.	1-Entry	Provide the minimum number of required van accessible parking spaces.	1 minimum	2018	$ 1,000.00	by Parks
F10551	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2017	$ 250.00	by Parks
F10552	Elaine Valente Open Space		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Clearance, vertical	79.5	No	Vertical clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	80 inches minimum	n/a	$ -	by Parks
F10553	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2017	$ 100.00	by Parks
F10554	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	5.5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2017	$ 25.00	by Parks
F10555	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	2	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2017	$ 100.00	by Parks
F10556	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Water Closet		Height, seat	19.5	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2017	$ 250.00	by Parks
F10557	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Signage		Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2017	$ 100.00	by Parks
F16039	Elaine Valente Open Space		Exterior	Owned	Walkway	From parking lot to Pier	1-Public Unsupervised	Walking Surface		Slope, running	7.5%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with compliant running and cross slopes, or install handrails, edge protection, and landings required for ramps.	5.0% maximum	2020	$ 25,000.00	by Parks
F04700	Facilities Mgmt's Storage Facility		Interior	Owned	Locker Room		3-Employee Common	Bench	L-shaped seat	Depth	19	No	Bench is not deep enough.	3-Restrooms	Provide a bench with a seat that is a minimum of 20 inches deep and a maximum of 24 inches deep.	20 to 24 inches	2020	$ 2,500.00	
F10588	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Toilet Compartment		Clear opening	22	No	Clear opening is too narrow.	3-Restrooms	Reframe the doorway to provide a compliant clear opening width. Offset hinges may be used to facilitate the process.	32 inches minimum	2020	$ 3,500.00	
F10589	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Lavatory Sink		Clearance, parallel	28	No	Clear floor space is too narrow.	3-Restrooms	Reconfigure the lavatory sink to provide at least the minimum clear floor space.	30 inches minimum	2020	$ 1,500.00	
F10590	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Toilet Compartment		Clearance, parallel	35.5	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	2020	$ 7,500.00	
F10591	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Toilet Compartment		Clearance, perpendicular	53	No	Toilet compartment is not deep enough.	3-Restrooms	Reconfigure the stall to provide a minimum of 59 inches in depth.	59 inches	2020	$ 2,500.00	
F10592	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Grab Bar	Side	Dimension, end to wall	9.5	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2020	$ 250.00	
F10593	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Shower Compartment		Dimension, entry to back wall	54	No	Shower compartment depth is not compliant.	3-Restrooms	Remodel or replace the existing shower with a compliant sized shower.	36 inch depth	2020	$ 500.00	
F10594	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	3-Employee Common	Shower Compartment		Dimension, side to side	35	No	Transfer shower too narrow.	3-Restrooms	Redesign and remodel the shower compartment with compliant grab bars, seat, hose, and shower controls.	36 inches wide by 36 inches deep	2020	$ 2,500.00	
F10595	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Water Closet	Floor mounted	Dimension, wide side	17.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2020	$ 7,500.00	
F10596	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Drain wrapped?	Damaged	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2020	$ 150.00	
F10597	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2020	$ 250.00	
F10598	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Coat Hook		Height	64	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2020	$ 150.00	
F10599	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Dispenser	PT	Height	58	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2020	$ 100.00	Relocate or Replace Dispenser
F10600	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Lavatory Sink		Height	34.25	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	2020	$ -	Within Tolerance (per Assessment)

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10601	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Mirror		Height, bottom	43	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2020	$ 250.00	Relocate or Replace Mirror
F10602	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Fixture Count		Number, accessible compartments	0	No	No accessible toilet compartment in restroom.	3-Restrooms	Rebuild or reconfigure the restroom, with a wheelchair accessible toilet compartment.	1 minimum	2020	$ 15,000.00	
F10603	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Grab Bar	Rear	Other attribute	None Provided	No	No grab bars provided.	3-Restrooms	Install grab bars on the rear and side wall.		2020	$ 250.00	
F10604	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2020	$ 150.00	
F00001	Government Center		Interior	Owned	Assembly Area	#C4413	1-Public Unsupervised	Door Gate		Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00002	Government Center		Interior	Owned	Assembly Area	Hearing Room	2-Public Supervised	Aisle Seat	Spectator	Folding/removable armrest?	None	No	No designated aisle seats are provided.	2-Services	Provide at least 12 seats with folding armrests on the aisles and identify each with signage.	12 minimum	2018	$ 15,000.00	
F00112	Government Center		Interior	Owned	Assembly Area	Hearing Room	2-Public Supervised	Seating Area		Assistive listening systems?	None found - no sign	No	No Assistive Listening devices found and no instructional signage visible.	2-Services	Provide an assistive listening system and signage stating that an assistive listening system is provided.	1 sign and 4 ALS receivers	2018	$ 5,000.00	
F00118	Government Center		Interior	Owned	Assembly Area	Hearing Room	2-Public Supervised	Door Gate	East doors to seating area	Opening force	7	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00421	Government Center		Interior	Owned	Break Room	#C4508	3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2018	$ 2,500.00	
F00422	Government Center		Interior	Owned	Break Room	#C5508	3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2018	$ 2,500.00	
F00425	Government Center		Interior	Owned	Break Room	#W1014	3-Employee Common	Protrusion	Wall mounted TV	Dimension, protruding	16	No	Object protrudes into the path of travel.	4-Other	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F00426	Government Center		Interior	Owned	Break Room	#W1014	3-Employee Common	Door Gate		Opening force	11	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00429	Government Center		Interior	Owned	Break Room	#W5521	3-Employee Common	Appliance	Viking refrigerator	Clearance, perpendicular	36	No	Clear floor space is too short.	4-Other	Reconfigure the break room to provide at least the minimum clear floor space.	48 inches minimum	2018	$ 1,500.00	
F00430	Government Center		Interior	Owned	Break Room	#W8205 - Catering/Pantry	3-Employee Common	Counter		Height	35.5	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2018	$ 2,500.00	
F00438	Government Center		Interior	Owned	Break Room	#W8205 - Catering/Pantry	3-Employee Common	Door Gate		Opening force	11	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00809	Government Center		1st Floor	Owned	Cafeteria		1-Public Unsupervised	Vending Machine	Snacks	Height, control	49	No	Operable part is out of reach range.	4-Other	Replace the Vending Machine with one that has operable parts within the reach range.	48 inches maximum	2016	$ -	Internal Staff - Operations
F00933	Government Center		Interior	Owned	Conference Room	#W8101	2-Public Supervised	Door Gate		Opening force	11	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00934	Government Center		Interior	Owned	Conference Room	#W8302	2-Public Supervised	Seating Area		Assistive listening systems?	None found - no sign	No	No Assistive Listening devices found and no instructional signage visible.	2-Services	Provide an assistive listening system and signage stating that an assistive listening system is provided.	1 sign and 4 ALS receivers	2018	$ 5,000.00	
F00935	Government Center		Interior	Owned	Conference Room	#W8302	2-Public Supervised	Door Gate		Opening force	11	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00948	Government Center		Interior	Owned	Conference Room	#W8305	2-Public Supervised	Door Gate		Opening force	11	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00949	Government Center		Interior	Owned	Conference Room	#W8307	2-Public Supervised	Door Gate		Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00962	Government Center		Interior	Owned	Conference Room	#W8309	2-Public Supervised	Door Gate		Opening force	11	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00964	Government Center		Interior	Owned	Conference Room	#W8311	2-Public Supervised	Door Gate		Opening force	11	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00966	Government Center		Interior	Owned	Conference Room	#W8401	2-Public Supervised	Door Gate		Opening force	11	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00968	Government Center		Interior	Owned	Conference Room	#W8501	2-Public Supervised	Seating Area		Assistive listening systems?	None found - no sign	No	No Assistive Listening devices found and no instructional signage visible.	2-Services	Provide an assistive listening system and signage stating that an assistive listening system is provided.	1 sign and 4 ALS receivers	2018	$ 5,000.00	
F00970	Government Center		Interior	Owned	Conference Room	#W8501	2-Public Supervised	Door Gate		Opening force	15	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00975	Government Center		Interior	Owned	Conference Room	#W8503/W8304	2-Public Supervised	Seating Area		Assistive listening systems?	None found - no sign	No	No Assistive Listening devices found and no instructional signage visible.	2-Services	Provide an assistive listening system and signage stating that an assistive listening system is provided.	1 sign and 4 ALS receivers	2018	$ 5,000.00	
F00976	Government Center		Interior	Owned	Conference Room	#W8503/W8304	2-Public Supervised	Door Gate		Opening force	15	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00985	Government Center		Interior	Owned	Conference Room	#W8508	2-Public Supervised	Door Gate		Opening force	11	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F03031	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Car Controls		Height, emergency control	28	No	Emergency control is too low.	2-Services	Relocate the emergency control to provide centerline height of 35 inches.	35 inches	2018	$ 500.00	
F03032	Government Center		Interior	Owned	Elevator	#4 - Freight elevator	1-Public Unsupervised	Elevator Door		Closing speed	3	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F03785	Government Center		Interior	Owned	Hallway		1-Public Unsupervised	Door Gate		Opening force	12	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F03789	Government Center		Interior	Owned	Hallway	West entrance	1-Public Unsupervised	Signage	Exit Sign	Braille?	N	No	Signage does not provide Braille.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F03790	Government Center		Interior	Owned	Hallway	West entrance	1-Public Unsupervised	Signage	Exit Sign	Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F03795	Government Center		Interior	Owned	Hallway	West hallway	2-Public Supervised	Drinking Fountain	Near #W5007	Dimension, knee clearance	26.5	No	Knee clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	27 inches	None	$ -	Within Tolerance (per Assessment)
F04941	Government Center		Interior	Owned	Other Room	#C1700 - Facility Ops	3-Employee Common	Signage		Height, bottom	62.75	No	Signage is too high.	2-Services	Remount sign with tactile letters located 48 inches minimum and 60 inches maximum, above the finished floor, measured from the baseline of the tactile letters.	48 to 60 inches	2016	$ 100.00	
F04942	Government Center		Interior	Owned	Other Room	#C1700 - Facility Ops	2-Public Supervised	Door Gate		Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F04943	Government Center		Interior	Owned	Other Room	#W1000 - Public Trustee	1-Public Unsupervised	Signage		Height, bottom	62.5	No	Signage is too high.	2-Services	Remount sign with tactile letters located 48 inches minimum and 60 inches maximum, above the finished floor, measured from the baseline of the tactile letters.	48 to 60 inches	2016	$ 100.00	
F04944	Government Center		Interior	Owned	Other Room	#W1000 - Public Trustee	1-Public Unsupervised	Door Gate		Opening force	12	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F04949	Government Center		Interior	Owned	Other Room	#W8301 - Team Room	2-Public Supervised	Door Gate		Opening force	11	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F04950	Government Center		Interior	Owned	Other Room	#W8303 - Team Room	2-Public Supervised	Door Gate		Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F04964	Government Center		Interior	Owned	Other Room	#W8506 - Video Conference Room	2-Public Supervised	Protrusion	Video camera	Dimension, protruding	8	No	Object protrudes into the path of travel.	2-Services	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F04966	Government Center		Interior	Owned	Other Room	#W8506 - Video Conference Room	2-Public Supervised	Door Gate		Opening force	11	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F04969	Government Center		Interior	Owned	Other Room	Planning & Development Public Works Reception Area	1-Public Unsupervised	Counter		Height	40	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2018	$ 2,500.00	
F06024	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#5	Van sign?	N	No	Van Accessible' sign is not present.	1-Entry	Install a 'Van Accessible' sign.		2017	$ 150.00	Part of Annual Parking project
F06025	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#6	Van sign?	N	No	Van Accessible' sign is not present.	1-Entry	Install a 'Van Accessible' sign.		2017	$ 150.00	Part of Annual Parking project
F06080	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Width	57	No	Access aisle is too narrow.	1-Entry	Restripe the parking space and aisle to provide a compliant sized access aisle.	60 inches minimum	2017	$ 50.00	Part of Annual Parking project
F06081	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#4	Slope, running	2.6%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06152	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#4	Van sign?	N	No	Van Accessible' sign is not present.	1-Entry	Install a 'Van Accessible' sign.		2017	$ 150.00	Part of Annual Parking project
F06202	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#5	Van sign?	N	No	Van Accessible' sign is not present.	1-Entry	Install a 'Van Accessible' sign.		2017	$ 150.00	Part of Annual Parking project
F06203	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#1	Slope, cross	2.8%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06204	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#1	Slope, running	2.8%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06262	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Access Aisle	Between parking spaces #5 & #6	Slope, cross	2.3%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06263	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#8	Slope, cross	2.4%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06309	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Access Aisle	Between parking spaces #7 & #8	Slope, running	2.4%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06310	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Access Aisle	Between parking spaces #5 & #6	Slope, running	2.8%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06311	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#7	Slope, running	2.1%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06312	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#5	Slope, running	2.5%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06313	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#8	Slope, running	2.6%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06314	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#6	Slope, running	3.3%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking Project
F07390	Government Center		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Area Specifications		Number, ground components	1	No	Too few ground level play components are provided on an accessible route.	2-Services	Provide not < 2 ground level play components of not < 2 different types with clear ground space at each. Provide an accessible route connecting the perimeter of the play area to each ground level component required to be accessible.	2 of 2	2020	$ 5,000.00	Independent Project

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07391	Government Center		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Walking Surface		Surface material	EWF	No	Surface of ground level route to ground level play components or to transfer system is not an accessible surface.	2-Services	Provide an accessible route connecting the perimeter of the play area to the entry point of the elevated composite play structures.		2020	$ 5,000.00	Independent Project
F07395	Government Center		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Transfer		Transfer support?	N	No	No transfer support is provided on transfer platform.	2-Services	Provide a rope loop, a loop type handle, a slot in the edge of a flat horizontal or vertical member, poles or bars, or D rings on the corner posts.		2020	$ 5,000.00	Independent Project
F07396	Government Center		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Walking Surface		Surface material	EWF	No	Surface of ground level route to ground level play components or to transfer system is not an accessible surface.	2-Services	Provide an accessible route connecting the perimeter of the play area to the entry point of the elevated composite play structures.		2020	$ 5,000.00	Independent Project
F07397	Government Center		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Transfer		Transfer support?	N	No	No transfer support is provided on transfer platform.	2-Services	Provide a rope loop, a loop type handle, a slot in the edge of a flat horizontal or vertical member, poles or bars, or D rings on the corner posts.		2020	$ 5,000.00	Independent Project
F10628	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	47	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	2018	$ 2,500.00	
F10629	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Water Closet		Dimension, wide side	35	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2018	$ 250.00	
F10630	Government Center		Interior	Owned	Restroom	Men's - #W5522	1-Public Unsupervised	Door Gate		Opening force	12	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F10633	Government Center		Interior	Owned	Restroom	Men's - Near C1205	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	-2	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2018	$ 100.00	Relocate or Replace Dispenser
F10634	Government Center		Interior	Owned	Restroom	Men's - Near C1205	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	-2	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2018	$ 100.00	Relocate or Replace Dispenser
F10635	Government Center		Interior	Owned	Restroom	Men's - Near C1205	1-Public Unsupervised	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10636	Government Center		Interior	Owned	Restroom	Men's - Near C1205	1-Public Unsupervised	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10647	Government Center		Interior	Owned	Restroom	Men's - Near C1304	3-Employee Common	Dispenser	TP	Dimension from water closet seat	6	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2018	$ 100.00	Relocate or Replace Dispenser
F10648	Government Center		Interior	Owned	Restroom	Men's - Near C1304	3-Employee Common	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10649	Government Center		Interior	Owned	Restroom	Men's - Near C1304	3-Employee Common	Door Gate		Opening force	12	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F10656	Government Center		Interior	Owned	Restroom	Men's - Near C3506	3-Employee Common	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10658	Government Center		Interior	Owned	Restroom	Men's - Near C4506	3-Employee Common	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10661	Government Center		Interior	Owned	Restroom	Men's - Near C5506	3-Employee Common	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10662	Government Center		Interior	Owned	Restroom	Men's - Near C5506	3-Employee Common	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10664	Government Center		Interior	Owned	Restroom	Men's - Near E1203	1-Public Unsupervised	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10666	Government Center		Interior	Owned	Restroom	Men's - Near E2606	3-Employee Common	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10668	Government Center		Interior	Owned	Restroom	Men's - Near E3309	3-Employee Common	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10670	Government Center		Interior	Owned	Restroom	Men's - Near E4012	3-Employee Common	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10672	Government Center		Interior	Owned	Restroom	Men's - Near W2606	3-Employee Common	Dispenser	TP	Dimension from water closet seat	6	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2018	$ 100.00	Relocate or Replace Dispenser
F10673	Government Center		Interior	Owned	Restroom	Men's - Near W2606	3-Employee Common	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10674	Government Center		Interior	Owned	Restroom	Men's - Near W2606	3-Employee Common	Door Gate		Opening force	16	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F10680	Government Center		Interior	Owned	Restroom	Men's - Near W5007	1-Public Unsupervised	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10681	Government Center		Interior	Owned	Restroom	Men's - Near W5007	1-Public Unsupervised	Door Gate		Opening force	13	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F10700	Government Center		Interior	Owned	Restroom	Men's - Near W5522	1-Public Unsupervised	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10701	Government Center		Interior	Owned	Restroom	Men's - Near W5522	1-Public Unsupervised	Door Gate		Opening force	12	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F10702	Government Center		Interior	Owned	Restroom	Men's - Near W5522	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	5.5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2018	$ 100.00	Relocate or Replace Dispenser
F10715	Government Center		Interior	Owned	Restroom	Men's - Near W6504	3-Employee Common	Dispenser	TP	Dimension from water closet seat	5.5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2018	$ 100.00	Relocate or Replace Dispenser
F10716	Government Center		Interior	Owned	Restroom	Men's - Near W6504	3-Employee Common	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10717	Government Center		Interior	Owned	Restroom	Men's - Near W6504	3-Employee Common	Door Gate		Opening force	11	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F10730	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10731	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Urinal	Standard	Height, rim	23	No	Urinal rim is too high.	3-Restrooms	Where multiple urinals are installed, replace or remount at least one urinal to the correct height.	17 inches maximum	2018	$ 1,500.00	
F10732	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Door Gate		Opening force	10	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F10733	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	5.5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2018	$ 100.00	Relocate or Replace Dispenser
F10765	Government Center		Interior	Owned	Restroom	Men's - Near W8404	2-Public Supervised	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10766	Government Center		Interior	Owned	Restroom	Men's - Near W8404	2-Public Supervised	Door Gate		Opening force	11	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F10777	Government Center		Interior	Owned	Restroom	Women's - Near C1205	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	6	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2018	$ 100.00	Relocate or Replace Dispenser
F10778	Government Center		Interior	Owned	Restroom	Women's - Near C1205	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	6.5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2018	$ 100.00	Relocate or Replace Dispenser
F10779	Government Center		Interior	Owned	Restroom	Women's - Near C1205	1-Public Unsupervised	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10780	Government Center		Interior	Owned	Restroom	Women's - Near C1205	1-Public Unsupervised	Protrusion	Feminine product dispenser	Dimension, protruding	7.5	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10781	Government Center		Interior	Owned	Restroom	Women's - Near C1205	1-Public Unsupervised	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10782	Government Center		Interior	Owned	Restroom	Women's - Near C1205	1-Public Unsupervised	Protrusion	Feminine product dispenser	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10783	Government Center		Interior	Owned	Restroom	Women's - Near C1205	1-Public Unsupervised	Door Gate		Opening force	12	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F10795	Government Center		Interior	Owned	Restroom	Women's - Near C1304	3-Employee Common	Dispenser	TP	Dimension from water closet seat	-1.5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2018	$ 100.00	Relocate or Replace Dispenser

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10796	Government Center		Interior	Owned	Restroom	Women's - Near C1304	3-Employee Common	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10797	Government Center		Interior	Owned	Restroom	Women's - Near C1304	3-Employee Common	Door Gate		Opening force	13	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F10804	Government Center		Interior	Owned	Restroom	Women's - Near C2506	3-Employee Common	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10805	Government Center		Interior	Owned	Restroom	Women's - Near C2506	3-Employee Common	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10809	Government Center		Interior	Owned	Restroom	Women's - Near C3506	3-Employee Common	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10810	Government Center		Interior	Owned	Restroom	Women's - Near C3506	3-Employee Common	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10811	Government Center		Interior	Owned	Restroom	Women's - Near C3506	3-Employee Common	Protrusion	Feminine product dispenser	Dimension, protruding	7.5	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10813	Government Center		Interior	Owned	Restroom	Women's - Near C4506	3-Employee Common	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10816	Government Center		Interior	Owned	Restroom	Women's - Near C5506	3-Employee Common	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10817	Government Center		Interior	Owned	Restroom	Women's - Near C5506	3-Employee Common	Protrusion	Feminine product dispenser	Dimension, protruding	8	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10819	Government Center		Interior	Owned	Restroom	Women's - Near E1203	1-Public Unsupervised	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10821	Government Center		Interior	Owned	Restroom	Women's - Near E2606	3-Employee Common	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10823	Government Center		Interior	Owned	Restroom	Women's - Near E3309	3-Employee Common	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10825	Government Center		Interior	Owned	Restroom	Women's - Near W2606	3-Employee Common	Dispenser	TP	Dimension from water closet seat	-1.5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2018	$ 100.00	Relocate or Replace Dispenser
F10826	Government Center		Interior	Owned	Restroom	Women's - Near W2606	3-Employee Common	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10827	Government Center		Interior	Owned	Restroom	Women's - Near W2606	3-Employee Common	Door Gate		Opening force	12	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F10832	Government Center		Interior	Owned	Restroom	Women's - Near W5007	1-Public Unsupervised	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10833	Government Center		Interior	Owned	Restroom	Women's - Near W5007	1-Public Unsupervised	Door Gate		Opening force	14	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F10844	Government Center		Interior	Owned	Restroom	Women's - Near W5522	1-Public Unsupervised	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10845	Government Center		Interior	Owned	Restroom	Women's - Near W5522	1-Public Unsupervised	Door Gate		Opening force	13	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F10846	Government Center		Interior	Owned	Restroom	Women's - Near W5522	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	5.5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2018	$ 100.00	Relocate or Replace Dispenser
F10859	Government Center		Interior	Owned	Restroom	Women's - Near W6504	3-Employee Common	Dispenser	TP	Dimension from water closet seat	-2	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2018	$ 100.00	Relocate or Replace Dispenser

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10860	Government Center		Interior	Owned	Restroom	Women's - Near W6504	3-Employee Common	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10861	Government Center		Interior	Owned	Restroom	Women's - Near W6504	3-Employee Common	Door Gate		Opening force	11	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F10899	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	10	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2018	$ 100.00	Relocate or Replace Dispenser
F10900	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Grab Bar	Side	Dimension, between	5	No	Space above grab bar is interrupted.	3-Restrooms	Move the dispenser to a minimum of 12 inches above the grab bar or remount the object to another location.	12 inches minimum	2018	$ 250.00	
F10901	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Protrusion	Feminine product dispenser	Dimension, protruding	7.5	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10902	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F10903	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	9	No	Smooth surface at bottom edge of door is insufficient.	3-Restrooms	No action recommended - this element has safe harbor.	10 inches minimum	None	$ -	Within Tolerance (per Assessment)
F10904	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Signage		Height, top	63	No	Signage is too high.	3-Restrooms	Remount sign with tactile letters located 48 inches minimum and 60 inches maximum, above the finished floor, measured from the baseline of the tactile letters.	48 to 60 inches	2016	$ 100.00	Internal Staff - Operations
F10905	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2018	$ 150.00	
F10998	Government Center		Interior	Owned	Restroom	Women's - Near W8404	2-Public Supervised	Dispenser	TP	Dimension from water closet seat	-2.5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2018	$ 100.00	Relocate or Replace Dispenser
F10999	Government Center		Interior	Owned	Restroom	Women's - Near W8404	2-Public Supervised	Protrusion	Hand dryer	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F11000	Government Center		Interior	Owned	Restroom	Women's - Near W8404	2-Public Supervised	Door Gate		Opening force	11	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F16062	Government Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface		Slope, cross	2.5%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F16083	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	48	No	Clearance on pull side of door is insufficient.	1-Entry	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	2019	$ 5,000.00	
F16084	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Walking Surface		Slope, running	5.4%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	5.0% maximum	None	$ -	Within Tolerance (per Assessment)
F16114	Government Center		Exterior	Owned	Walkway	From Employee parking lot to Employee entrance	3-Employee Common	Walking Surface		Slope, running	6.1%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with compliant running and cross slopes, or install handrails, edge protection, and landings required for ramps.	5.0% maximum	2019	$ 5,000.00	Part of Annual Parking project
F16241	Government Center		Exterior	Owned	Walkway	West Parking Lot NW side	1-Public Unsupervised	Walking Surface		Slope, cross	2.1%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F16242	Government Center		Exterior	Owned	Walkway	West Parking Lot NW side	1-Public Unsupervised	Walking Surface		Slope, running	5.3%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	5.0% maximum	None	$ -	Within Tolerance (per Assessment)
F16246	Government Center		Exterior	Owned	Walkway	West Parking Lot SW side	1-Public Unsupervised	Walking Surface		Slope, cross	2.9%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F16247	Government Center		Exterior	Owned	Walkway	West Parking Lot SW side	1-Public Unsupervised	Walking Surface		Slope, running	5.4%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	5.0% maximum	None	$ -	Within Tolerance (per Assessment)
F16799	Government Center		Interior	Owned	Work Area	#E2504 - Map room	2-Public Supervised	Counter		Height	35	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2018	$ 2,500.00	
F00126	Honnen Building	Head Start	Interior	Owned	Assembly Area	Classroom A	2-Public Supervised	Door Gate		Clearance, push parallel	3.5	No	Clearance on push side of door is insufficient.	2-Services	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	22 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F00127	Honnen Building	Head Start	Interior	Owned	Assembly Area	Classroom A	2-Public Supervised	Door Gate		Closing speed	3	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F00128	Honnen Building	Head Start	Interior	Owned	Assembly Area	Classroom A	2-Public Supervised	Lavatory Sink	Children's	Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	2-Services	Wrap or insulate the drain and supply lines to protect against contact.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F00129	Honnen Building	Head Start	Interior	Owned	Assembly Area	Classroom A	2-Public Supervised	Door Gate		Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F00130	Honnen Building	Head Start	Interior	Owned	Assembly Area	Classroom B	2-Public Supervised	Door Gate		Clearance, push parallel	2.5	No	Clearance on push side of door is insufficient.	2-Services	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	22 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00131	Honnen Building	Head Start	Interior	Owned	Assembly Area	Classroom B	2-Public Supervised	Door Gate		Closing speed	3	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F00132	Honnen Building	Head Start	Interior	Owned	Assembly Area	Classroom B	2-Public Supervised	Door Gate		Opening force	9	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F00133	Honnen Building	Head Start	Interior	Owned	Assembly Area	Classroom C	2-Public Supervised	Signage		Braille?	N	No	Signage does not provide Braille.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F00134	Honnen Building	Head Start	Interior	Owned	Assembly Area	Classroom C	2-Public Supervised	Door Gate		Clearance, push parallel	7	No	Clearance on push side of door is insufficient.	2-Services	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	12 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F00135	Honnen Building	Head Start	Interior	Owned	Assembly Area	Classroom C	2-Public Supervised	Door Gate		Clearance, vertical	79	No	Vertical clearance is too low.	2-Services	Replace the doorway with a compliant vertical clearance.	80 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F00136	Honnen Building	Head Start	Interior	Owned	Assembly Area	Classroom C	2-Public Supervised	Door Gate		Closing speed	3	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F00137	Honnen Building	Head Start	Interior	Owned	Assembly Area	Classroom C	2-Public Supervised	Signage		Location	H	No	Sign is not mounted in the correct location.	2-Services	Move the sign to the latch side of the door.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F00138	Honnen Building	Head Start	Interior	Owned	Assembly Area	Classroom C	2-Public Supervised	Signage		Location	H	No	Sign is not mounted in the correct location.	2-Services	Move the sign to the latch side of the door.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F00139	Honnen Building	Head Start	Interior	Owned	Assembly Area	Classroom C	2-Public Supervised	Door Gate		Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F00140	Honnen Building	Head Start	Interior	Owned	Assembly Area	Classroom D	2-Public Supervised	Door Gate		Clearance, push parallel	3.5	No	Clearance on push side of door is insufficient.	2-Services	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	12 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F00141	Honnen Building	Head Start	Interior	Owned	Assembly Area	Classroom D	2-Public Supervised	Door Gate		Opening force	14	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F00142	Honnen Building	Head Start	Interior	Owned	Assembly Area	Classroom D	2-Public Supervised	Signage		Other attribute	None	No	Braille and raised letter signage is not provided.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F00494	Honnen Building	Food Pantry	Interior	Owned	Break Room	Warehouse area	3-Employee Common	Lavatory Sink	Wall mount	Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	2-Services	Wrap or insulate the drain and supply lines to protect against contact.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F00495	Honnen Building	Food Pantry	Interior	Owned	Break Room	Warehouse area	3-Employee Common	Lavatory Sink	Large utility sink	Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	2-Services	Wrap or insulate the drain and supply lines to protect against contact.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F00496	Honnen Building	Food Pantry	Interior	Owned	Break Room	Warehouse area	3-Employee Common	Dispenser	PT	Height	52	No	Dispenser is too high.	2-Services	Relocate the dispenser to the correct height.	48 inches maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F00497	Honnen Building	Food Pantry	Interior	Owned	Break Room	Warehouse area	3-Employee Common	Lavatory Sink	Large utility sink	Height	35.5	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F00509	Honnen Building		2nd Floor	Owned	Break Room		3-Employee Common	Protrusion	PT	Dimension, protruding	9	No	Object protrudes into the path of travel.	2-Services	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F00510	Honnen Building		2nd Floor	Owned	Break Room		3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F00511	Honnen Building		2nd Floor	Owned	Break Room		3-Employee Common	Dispenser	TP	Height	54	No	Dispenser is too high.	2-Services	Relocate the dispenser to the correct height.	48 inches maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F00512	Honnen Building		2nd Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Height	36	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F03806	Honnen Building	Food Pantry	Interior	Owned	Hallway	To secured office & classrooms	2-Public Supervised	Door Gate	Security keypad	Clearance, push parallel	4.5	No	Clearance on push side of door is insufficient.	2-Services	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	12 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F03807	Honnen Building	Food Pantry	Interior	Owned	Hallway	To secured office & classrooms	2-Public Supervised	Door Gate	Security keypad	Clearance, vertical	79.5	No	Vertical clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	80 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F03808	Honnen Building	Food Pantry	Interior	Owned	Hallway	To secured office & classrooms	2-Public Supervised	Door Gate	Security keypad	Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F04338	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Clearance, pull parallel	10.5	No	Clearance on pull side of door is insufficient.	2-Services	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F04339	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate	Into open office	Clearance, pull parallel	2	No	Clearance on pull side of door is insufficient.	2-Services	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F04340	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Clearance, push parallel	2	No	Clearance on push side of door is insufficient.	2-Services	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	12 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F04341	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate	Into open office	Hardware type	Knob	No	Hardware requires twisting of wrist.	2-Services	Install lever type door hardware.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F04342	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Height	43	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F04343	Honnen Building	Food Pantry	Exterior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	4.5	No	Smooth surface at bottom edge of door is insufficient.	1-Entry	No action recommended - this element has safe harbor.	10 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F04371	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Door Gate	Entry to Head Start #1	Clearance, pull parallel	10.5	No	Clearance on pull side of door is insufficient.	2-Services	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F04372	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Door Gate	Entry to Head Start #1	Clearance, push parallel	2	No	Clearance on push side of door is insufficient.	2-Services	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	12 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F04373	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Door Gate	Entry to Head Start #2	Clearance, push parallel	1	No	Clearance on push side of door is insufficient.	2-Services	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	12 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F04374	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Counter		Height	39.5	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F04375	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Door Gate	Entry to Head Start #2	Height, smooth surface (kick plate)	4.5	No	Smooth surface at bottom edge of door is insufficient.	2-Services	No action recommended - this element has safe harbor.	10 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F04981	Honnen Building	Food Pantry	Interior	Owned	Other Room	Pantry office to warehouse	3-Employee Common	Door Gate		Clearance, pull parallel	5	No	Clearance on pull side of door is insufficient.	2-Services	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F04982	Honnen Building	Food Pantry	Interior	Owned	Other Room	Pantry office to warehouse	3-Employee Common	Door Gate		Clearance, vertical	79.5	No	Vertical clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	80 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F04983	Honnen Building	Food Pantry	Interior	Owned	Other Room	Pantry office to warehouse	3-Employee Common	Door Gate		Closing speed	3	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F04984	Honnen Building	Food Pantry	Interior	Owned	Other Room	Pantry office to warehouse	3-Employee Common	Door Gate		Hardware type	Knob	No	Hardware requires twisting of wrist.	2-Services	Install lever type door hardware.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F04985	Honnen Building	Food Pantry	Interior	Owned	Other Room	Pantry office to warehouse	3-Employee Common	Door Gate		Opening force	9	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F06347	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Access aisle?	N	No	No access aisle provided.	1-Entry	Provide a marked access aisle adjacent to the parking space.	60 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F06348	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, van spaces	0	No	Too few van accessible parking spaces are provided.	1-Entry	Provide the minimum number of required van accessible parking spaces.	1 minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F06349	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Sign?	N	No	No accessible signage provided.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F06350	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#6	Sign?	N	No	No accessible signage provided.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F06351	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Slope, cross	3.1%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F06352	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Slope, running	2.1%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F06353	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#6	Slope, running	3.7%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06354	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Slope, running	4.4%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F06355	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Slope, running	6.1%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F06356	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#2	Width	57	No	Access aisle is too narrow.	1-Entry	Restripe the parking space and aisle to provide a compliant sized access aisle.	60 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F06392	Honnen Building	Head Start	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Slope, running	8.3%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F06393	Honnen Building	Head Start	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Width	58	No	Access aisle is too narrow.	1-Entry	Restripe the parking space and aisle to provide a compliant sized access aisle.	60 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F07411	Honnen Building		Exterior	Owned	Play Area	Ages 5 - 12	2-Public Supervised	Walking Surface		Surface material	EWF	No	Surface of ground level route to ground level play components or to transfer system is not an accessible surface.	2-Services	Provide an accessible route connecting the perimeter of the play area to the entry point of the elevated composite play structures.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F07415	Honnen Building		Exterior	Owned	Play Area		2-Public Supervised	Area Specifications		Number, ground components on accessible route	1	No	Too few ground level play components are provided on an accessible route.	2-Services	Provide not < 3 ground level play components of not < 3 different types with clear ground space at each. Provide an accessible route connecting perimeter of play area to each ground level component required to be accessible.	3 of 3	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11011	Honnen Building	Food distribution	2nd Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Side	Dimension, between	4.5	No	Space above grab bar is interrupted.	3-Restrooms	Move the dispenser to a minimum of 12 inches above the grab bar or remount the dispenser to a compliant location below the grab bar.	12 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11012	Honnen Building	Food distribution	2nd Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Side	Dimension, end to wall	7	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11013	Honnen Building	Food distribution	2nd Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	2	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11014	Honnen Building	Food distribution	2nd Floor	Owned	Restroom	Unisex	3-Employee Common	Protrusion	PT	Dimension, protruding	9	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11015	Honnen Building	Food distribution	2nd Floor	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Dimension, sidewall	18.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11016	Honnen Building	Food distribution	2nd Floor	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Dimension, wide side	19	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11017	Honnen Building	Food distribution	2nd Floor	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11018	Honnen Building	Food distribution	1st Floor	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Hardware type	Knob	No	Hardware requires twisting of wrist.	3-Restrooms	Install lever type door hardware.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11019	Honnen Building	Food distribution	2nd Floor	Owned	Restroom	Unisex	3-Employee Common	Dispenser	Soap	Height	51	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11020	Honnen Building	Food distribution	2nd Floor	Owned	Restroom	Unisex	3-Employee Common	Dispenser	PT	Height	52	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11021	Honnen Building	Food distribution	2nd Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Side	Height, top	36.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11022	Honnen Building	Food distribution	1st Floor	Owned	Restroom	Unisex	3-Employee Common	Signage		Location	On door	No	Sign is not mounted in the correct location.	3-Restrooms	Move the sign to the latch side of the door.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11046	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11047	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	2	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11048	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	6.5	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11049	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	26	No	Knee clearance is too low.	3-Restrooms	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11050	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Water Closet		Dimension, sidewall	19.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11051	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Water Closet		Dimension, wide side	19	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11052	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11053	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Door Gate		Hardware type	Knob	No	Hardware requires twisting of wrist.	3-Restrooms	Install lever type door hardware.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11054	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Dispenser	Soap	Height	51	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11055	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Dispenser	PT	Height	53	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11056	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Dispenser	TP	Over obstruction?	Y	No	Toilet paper dispenser is mounted above the grab bar.	3-Restrooms	Move the toilet paper dispenser to a compliant position under the grab bar.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11089	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Water Closet	Children's	Clearance, parallel	29	No	Clearance at water closet is too narrow.	3-Restrooms	Remodel the restroom to provide at least the minimum required width.	60 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11090	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Lavatory Sink		Clearance, perpendicular	27	No	Clear floor space is too short.	3-Restrooms	Reconfigure the lavatory sink to provide at least the minimum clear floor space.	48 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11091	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Water Closet	Children's	Clearance, perpendicular	35	No	Toilet compartment is not deep enough.	3-Restrooms	Reconfigure the stall to provide a minimum of 56 inches in depth.	56 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11092	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Protrusion	PT	Dimension, protruding	9	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11093	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Protrusion	PT	Dimension, protruding	9	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11094	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Water Closet	Children's	Dimension, wide side	14.25	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11095	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11096	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Signage		Location	H	No	Sign is not mounted in the correct location.	3-Restrooms	Move the sign to the latch side of the door.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11097	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Water Closet	Children's	Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11098	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Fixture Count		Number, accessible compartments	0	No	No accessible toilet compartment in restroom.	3-Restrooms	Rebuild or reconfigure the restroom, with a wheelchair accessible toilet compartment.	1 minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11117	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Door Gate		Clear opening	21.5	No	Clear opening is too narrow.	3-Restrooms	Reframe the doorway to provide a compliant clear opening width. Offset hinges may be used to facilitate the process.	32 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11118	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Lavatory Sink		Clearance, perpendicular	39	No	Clear floor space is too short.	3-Restrooms	Reconfigure the lavatory sink to provide at least the minimum clear floor space.	48 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11119	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Door Gate		Clearance, vertical	79	No	Vertical clearance is too low.	3-Restrooms	Replace the doorway with a compliant vertical clearance.	80 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11120	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Dispenser	TP	Dimension from water closet seat	5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11121	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Water Closet		Dimension, wide side	21.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11122	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11123	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Mirror		Height, bottom	47	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11124	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Water Closet		Height, seat	15	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11125	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Signage		Location	H	No	Sign is not mounted in the correct location.	3-Restrooms	Move the sign to the latch side of the door.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11126	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Fixture Count		Number, accessible compartments	0	No	No accessible toilet compartment in restroom.	3-Restrooms	Rebuild or reconfigure the restroom, with a wheelchair accessible toilet compartment.	1 minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11151	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Door Gate		Clear opening	21.5	No	Clear opening is too narrow.	3-Restrooms	Reframe the doorway to provide a compliant clear opening width. Offset hinges may be used to facilitate the process.	32 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11152	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Water Closet		Clearance, parallel	59.5	No	Clearance at water closet is too narrow.	5-Tolerance	No action recommended - within construction tolerance.	60 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11153	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Lavatory Sink		Clearance, perpendicular	39	No	Clear floor space is too short.	3-Restrooms	Reconfigure the lavatory sink to provide at least the minimum clear floor space.	48 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11154	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Door Gate		Clearance, vertical	79.5	No	Vertical clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	80 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11155	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Dispenser	TP	Dimension from water closet seat	6	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11156	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Water Closet		Dimension, wide side	20	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11157	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11158	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Mirror		Height, bottom	47	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11159	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Water Closet		Height, seat	15	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11160	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Signage		Location	H	No	Sign is not mounted in the correct location.	3-Restrooms	Move the sign to the latch side of the door.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11161	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Fixture Count		Number, accessible compartments	0	No	No accessible toilet compartment in restroom.	3-Restrooms	Rebuild or reconfigure the restroom, with a wheelchair accessible toilet compartment.	1 minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11188	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Door Gate		Clear opening	21	No	Clear opening is too narrow.	3-Restrooms	Reframe the doorway to provide a compliant clear opening width. Offset hinges may be used to facilitate the process.	32 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11189	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Water Closet		Clearance, perpendicular	39	No	Toilet compartment is not deep enough.	3-Restrooms	Reconfigure the stall to provide a minimum of 56 inches in depth.	56 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11190	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Door Gate		Clearance, pull perpendicular	39	No	Clearance on pull side of door is insufficient.	3-Restrooms	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11191	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	1-Public Unsupervised	Door Gate		Clearance, vertical	79.5	No	Vertical clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	80 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11192	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Water Closet		Dimension, wide side	22	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11193	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11194	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Dispenser	PT	Height	51	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11195	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Mirror		Height, bottom	47	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11217	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Door Gate		Clearance, vertical	79.25	No	Vertical clearance is too low.	3-Restrooms	Replace the doorway with a compliant vertical clearance.	80 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11218	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Grab Bar	Side	Dimension, end to wall	14	No	Side wall grab bar is located too far away from the back wall.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11219	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	4	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11220	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Water Closet		Dimension, sidewall	19.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11221	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Water Closet		Dimension, wide side	16	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11222	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11223	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Door Gate		Hardware type	Knob	No	Hardware requires twisting of wrist.	3-Restrooms	Install lever type door hardware.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11224	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Dispenser	Toilet seat covers	Height	60	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11225	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Mirror		Height, bottom	41.5	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11226	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Water Closet		Height, seat	16	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11227	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Grab Bar	Side	Height, top	36.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11228	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Grab Bar	Side	Length	36	No	Side grab bar length is too short.	3-Restrooms	Replace the grab bar with a 42 inch long minimum grab bar.	42 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11229	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Grab Bar	Rear	Length	32	No	Rear grab bar is too short.	3-Restrooms	Replace the grab bar with a 36 inch long minimum grab bar.	36 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11248	Honnen Building		2nd Floor	Owned	Restroom	Unisex - North	3-Employee Common	Door Gate		Clear opening	21	No	Clear opening is too narrow.	3-Restrooms	Reframe the doorway to provide a compliant clear opening width. Offset hinges may be used to facilitate the process.	32 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11249	Honnen Building		2nd Floor	Owned	Restroom	Unisex - North	3-Employee Common	Water Closet		Clearance, parallel	59.5	No	Clearance at water closet is too narrow.	5-Tolerance	No action recommended - within construction tolerance.	60 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11250	Honnen Building		2nd Floor	Owned	Restroom	Unisex - North	3-Employee Common	Water Closet		Clearance, perpendicular	55	No	Toilet compartment is not deep enough.	3-Restrooms	Reconfigure the stall to provide a minimum of 56 inches in depth.	56 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11251	Honnen Building		2nd Floor	Owned	Restroom	Unisex - North	3-Employee Common	Door Gate		Clearance, vertical	79	No	Vertical clearance is too low.	3-Restrooms	Replace the doorway with a compliant vertical clearance.	80 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11252	Honnen Building		2nd Floor	Owned	Restroom	Unisex - North	3-Employee Common	Water Closet		Dimension, sidewall	15	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11253	Honnen Building		2nd Floor	Owned	Restroom	Unisex - North	3-Employee Common	Water Closet		Dimension, wide side	20	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11254	Honnen Building		2nd Floor	Owned	Restroom	Unisex - North	3-Employee Common	Mirror		Height, bottom	47.5	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11255	Honnen Building		2nd Floor	Owned	Restroom	Unisex - North	3-Employee Common	Water Closet		Height, seat	16	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11256	Honnen Building		2nd Floor	Owned	Restroom	Unisex - North	3-Employee Common	Fixture Count		Number, accessible compartments	0	No	No accessible toilet compartment in restroom.	3-Restrooms	Rebuild or reconfigure the restroom, with a wheelchair accessible toilet compartment.	1 minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11261	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Northeast	3-Employee Common	Door Gate		Clear opening	21	No	Clear opening is too narrow.	3-Restrooms	Reframe the doorway to provide a compliant clear opening width. Offset hinges may be used to facilitate the process.	32 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11262	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Northeast	3-Employee Common	Water Closet		Clearance, parallel	59.5	No	Clearance at water closet is too narrow.	5-Tolerance	No action recommended - within construction tolerance.	60 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11263	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Northeast	3-Employee Common	Water Closet		Clearance, perpendicular	55	No	Toilet compartment is not deep enough.	3-Restrooms	Reconfigure the stall to provide a minimum of 56 inches in depth.	56 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11264	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Northeast	3-Employee Common	Door Gate		Clearance, vertical	79	No	Vertical clearance is too low.	3-Restrooms	Replace the doorway with a compliant vertical clearance.	80 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11265	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Northeast	3-Employee Common	Water Closet		Dimension, sidewall	14.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11266	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Northeast	3-Employee Common	Water Closet		Dimension, wide side	20	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11267	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Northeast	3-Employee Common	Dispenser	PT	Height	53	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11268	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Northeast	3-Employee Common	Mirror		Height, bottom	45	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11269	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Northeast	3-Employee Common	Water Closet		Height, seat	15	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11270	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Northeast	3-Employee Common	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11271	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Northeast	3-Employee Common	Fixture Count		Number, accessible compartments	0	No	No accessible toilet compartment in restroom.	3-Restrooms	Rebuild or reconfigure the restroom, with a wheelchair accessible toilet compartment.	1 minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11273	Honnen Building		2nd Floor	Owned	Restroom	Unisex - South	3-Employee Common	Fixture Count		Number, accessible compartments	0	No	No accessible toilet compartment in restroom.	3-Restrooms	Rebuild or reconfigure the restroom, with a wheelchair accessible toilet compartment.	1 minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11277	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Southeast	3-Employee Common	Door Gate		Clear opening	21	No	Clear opening is too narrow.	3-Restrooms	Reframe the doorway to provide a compliant clear opening width. Offset hinges may be used to facilitate the process.	32 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11278	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Southeast	3-Employee Common	Water Closet		Clearance, perpendicular	55	No	Toilet compartment is not deep enough.	3-Restrooms	Reconfigure the stall to provide a minimum of 56 inches in depth.	56 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11279	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Southeast	3-Employee Common	Door Gate		Clearance, vertical	79	No	Vertical clearance is too low.	3-Restrooms	Replace the doorway with a compliant vertical clearance.	80 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11280	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Southeast	3-Employee Common	Water Closet		Dimension, sidewall	14.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11281	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Southeast	3-Employee Common	Water Closet		Dimension, wide side	21	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11282	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Southeast	3-Employee Common	Mirror		Height, bottom	48	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11283	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Southeast	3-Employee Common	Water Closet		Height, seat	16	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11284	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Southeast	3-Employee Common	Fixture Count		Number, accessible compartments	0	No	No accessible toilet compartment in restroom.	3-Restrooms	Rebuild or reconfigure the restroom, with a wheelchair accessible toilet compartment.	1 minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F11288	Honnen Building		2nd Floor	Owned	Restroom	Women's	3-Employee Common	Fixture Count		Number, accessible compartments	0	No	No accessible toilet compartment in restroom.	3-Restrooms	Rebuild or reconfigure the restroom, with a wheelchair accessible toilet compartment.	1 minimum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F16252	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From East parking lot to entrance	1-Public Unsupervised	Curb Ramp		Accumulates water?	Y	No	Curb ramp accumulates water.	1-Entry	Resurface or regrade the area so that it does not accumulate water.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F16253	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From East parking lot to entrance	1-Public Unsupervised	Curb Ramp		Landing?	N	No	No landing provided at top of curb ramp.	1-Entry	Provide a landing at the top of the curb ramp that is the same width as the curb ramp and at least 36 inches long.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F16254	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From East parking lot to entrance	1-Public Unsupervised	Curb Ramp		Slope, left flare	26.4%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp with compliant side flares.	10% maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F16255	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From East parking lot to entrance	1-Public Unsupervised	Curb Ramp		Slope, right flare	41.0%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp with compliant side flares.	10% maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F16263	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From North side to parking lot	1-Public Unsupervised	Curb Ramp	West side of lot entry	Landing?	N	No	No landing provided at top of curb ramp.	1-Entry	Provide a landing at the top of the curb ramp that is the same width as the curb ramp and at least 36 inches long.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F16264	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From North side to parking lot	1-Public Unsupervised	Curb Ramp	West side of lot entry	Slope, cross	6.5%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp, curb, and gutter to provide a compliant cross slope.	2.08% maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F16265	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From North side to parking lot	1-Public Unsupervised	Curb Ramp	West side of lot entry	Slope, left flare	27.6%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp with compliant side flares.	10% maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F16266	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From North side to parking lot	1-Public Unsupervised	Curb Ramp	West side of lot entry	Slope, right flare	11.0%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp with compliant side flares.	10% maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F16267	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From North side to parking lot	1-Public Unsupervised	Curb Ramp		Slope, right flare	61.7%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp with compliant side flares.	10% maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F16282	Honnen Building	Food Pantry	Exterior	Owned	Walkway	To lobby entrance	1-Public Unsupervised	Door Gate		Slope, running	7.8%	No	Slope is too steep.	1-Entry	Regrade the maneuvering clearance, at the doorway, with a compliant slope.	2.08% maximum	When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F00148	Human Service Building		Interior	Owned	Assembly Area	Basement	2-Public Supervised	Door Gate		Clear opening	27.5	No	Clear opening is too narrow.	2-Services	Reframe the doorway to provide a compliant clear opening width. Offset hinges may be used to facilitate the process.	32 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F00149	Human Service Building		Interior	Owned	Assembly Area	Basement	2-Public Supervised	Door Gate		Clearance, vertical	78	No	Vertical clearance is too low.	2-Services	Replace the doorway with a compliant vertical clearance.	80 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F00150	Human Service Building		Interior	Owned	Assembly Area	Basement	2-Public Supervised	Door Gate		Closing speed	3	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F00151	Human Service Building		Interior	Owned	Assembly Area	Basement	2-Public Supervised	Door Gate		Opening force	8	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F00159	Human Service Building		Interior	Owned	Assembly Area	Basement - Conf Rm. #2	2-Public Supervised	Door Gate		Clearance, pull parallel	4	No	Clearance on pull side of door is insufficient.	2-Services	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F00160	Human Service Building		Interior	Owned	Assembly Area	Basement - Conf Rm. #2	2-Public Supervised	Door Gate		Clearance, pull parallel	5	No	Clearance on pull side of door is insufficient.	2-Services	Reverse the door to open into the room or install an interior automatic door opener.		None	n/a	New HSB Under Construction - Relocation in 2017
F00161	Human Service Building		Interior	Owned	Assembly Area	Basement - Conf Rm. #2	2-Public Supervised	Door Gate		Clearance, vertical	78	No	Vertical clearance is too low.	2-Services	Replace the doorway with a compliant vertical clearance.	80 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F00162	Human Service Building		Interior	Owned	Assembly Area	Basement - Conf Rm. #2	2-Public Supervised	Door Gate		Closing speed	3	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F00163	Human Service Building		Interior	Owned	Assembly Area	Basement - Conf Rm. #2	2-Public Supervised	Door Gate		Opening force	7	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F00172	Human Service Building		5th Floor	Owned	Assembly Area	Meeting room	2-Public Supervised	Door Gate		Clearance, vertical	79.5	No	Vertical clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	80 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F00516	Human Service Building	Investigations	3rd Floor	Owned	Break Room		3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F00527	Human Service Building		Interior	Owned	Break Room	Basement	3-Employee Common	Door Gate		Clearance, vertical	78	No	Vertical clearance is too low.	2-Services	Replace the doorway with a compliant vertical clearance.	80 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F00528	Human Service Building		Interior	Owned	Break Room	Basement	3-Employee Common	Appliance	Coffee dispenser	Height, control	53.5	No	Operable part is out of reach range.	4-Other	Relocate the appliance to within a compliant reach range.	48 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F00534	Human Service Building		5th Floor	Owned	Break Room	Child Support Services	3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	2-Services	Wrap or insulate the drain and supply lines to protect against contact.		None	n/a	New HSB Under Construction - Relocation in 2017
F00535	Human Service Building		5th Floor	Owned	Break Room	Child Support Services	3-Employee Common	Appliance	Refrig/Freezer	Height	48.5	No	50% of freezer space is not below 54" AFF.	5-Tolerance	No action recommended - within construction tolerance.		None	n/a	New HSB Under Construction - Relocation in 2017
F00540	Human Service Building		6th Floor	Owned	Break Room	Family Transition	3-Employee Common	Lavatory Sink		Height	34.5	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F00546	Human Service Building		6th Floor	Owned	Break Room	Housing Authority	3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	2-Services	Wrap or insulate the drain and supply lines to protect against contact.		None	n/a	New HSB Under Construction - Relocation in 2017
F00547	Human Service Building		6th Floor	Owned	Break Room	Housing Authority	3-Employee Common	Appliance	Refrig/Freezer	Height	49	No	50% of freezer space is not below 54" AFF.	4-Other	Replace the existing refrig/freezer with a compliant refrig/freezer.	Side by side Refrig/Freezer	None	n/a	New HSB Under Construction - Relocation in 2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00548	Human Service Building		6th Floor	Owned	Break Room	Housing Authority	3-Employee Common	Counter		Height	34.5	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F00549	Human Service Building		6th Floor	Owned	Break Room	Housing Authority	3-Employee Common	Lavatory Sink		Height	35	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F00552	Human Service Building		3rd Floor	Owned	Break Room	North	3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F00559	Human Service Building		4th Floor	Owned	Break Room	South	3-Employee Common	Door Gate		Clearance, vertical	79.25	No	Vertical clearance is too low.	2-Services	Replace the doorway with a compliant vertical clearance.	80 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F00560	Human Service Building		2nd Floor	Owned	Break Room	South	3-Employee Common	Appliance	Refrig/Freezer	Height	50	No	50% of freezer space is not below 54" AFF.	4-Other	Replace the existing refrig/freezer with a compliant refrig/freezer.	Side by side Refrig/Freezer	None	n/a	New HSB Under Construction - Relocation in 2017
F00561	Human Service Building		4th Floor	Owned	Break Room	South	3-Employee Common	Counter		Height	36.25	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F00562	Human Service Building		2nd Floor	Owned	Break Room	South	3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F00563	Human Service Building		4th Floor	Owned	Break Room	South	3-Employee Common	Lavatory Sink		Height	36.75	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F03108	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Car Controls		Height, emergency control	34.5	No	Emergency control is too low.	5-Tolerance	No action recommended - within construction tolerance.	35 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F03109	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Hoistway Sign		Star?	None	No	No tactile Star on Hoistway frame.	2-Services	Install a hoistway sign on both hoistway jams, with raised letters, Braille, and a tactile Star.		None	n/a	New HSB Under Construction - Relocation in 2017
F03145	Human Service Building		Interior	Owned	Elevator	#2 - South/East car	1-Public Unsupervised	Elevator Car		Dimension, back to front	50.5	No	Elevator car is not deep enough.	5-Tolerance	No action recommended - within construction tolerance.	51 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F03146	Human Service Building		Interior	Owned	Elevator	#2 - South/East car	1-Public Unsupervised	Hoistway Sign		Star?	None	No	No tactile Star on Hoistway frame.	2-Services	Install a hoistway sign on both hoistway jams, with raised letters, Braille, and a tactile Star.		None	n/a	New HSB Under Construction - Relocation in 2017
F03147	Human Service Building		Interior	Owned	Elevator	#2 - South/East car	1-Public Unsupervised	Car Controls		Height, emergency control	34.5	No	Emergency control is too low.	5-Tolerance	No action recommended - within construction tolerance.	35 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F03157	Human Service Building		Interior	Owned	Elevator	#3 - North/East car	1-Public Unsupervised	Elevator Car		Dimension, back to front	50.5	No	Elevator car is not deep enough.	5-Tolerance	No action recommended - within construction tolerance.	51 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F03158	Human Service Building		Interior	Owned	Elevator	#3 - North/East car	1-Public Unsupervised	Hoistway Sign		Star?	None	No	No tactile Star on Hoistway frame.	2-Services	Install a hoistway sign on both hoistway jams, with raised letters, Braille, and a tactile Star.		None	n/a	New HSB Under Construction - Relocation in 2017
F03815	Human Service Building		Basement	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near restrooms	Dimension, knee clearance	21	No	Knee clearance is too low.	4-Other	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F03816	Human Service Building		Basement	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near restrooms	Height	42.5	No	Drinking fountain spout height is too high.	4-Other	Replace the existing fountain with a high/low fountain. The low fountain spout height must be 36 inches minimum and the high fountain spout height must be 38 inches to 43 inches.		None	n/a	New HSB Under Construction - Relocation in 2017
F03817	Human Service Building		Basement	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near restrooms	Height, water flow	3	No	Water flow height is insufficient.	4-Other	Adjust the water flow on the drinking fountain.	4 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F04390	Human Service Building	Child Support Services	5th Floor	Owned	Lobby Reception		2-Public Supervised	Door Gate	Interview rooms #1 thru #6	Clearance, vertical	79.5	No	Vertical clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	80 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F04393	Human Service Building		5th Floor	Owned	Lobby Reception	Child Support Services	1-Public Unsupervised	Signage		Braille?	N	No	Signage does not provide Braille.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		None	n/a	New HSB Under Construction - Relocation in 2017
F04394	Human Service Building		5th Floor	Owned	Lobby Reception	Child Support Services	2-Public Supervised	Counter	Check-in	Height	41.5	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F04395	Human Service Building		5th Floor	Owned	Lobby Reception	Child Support Services	2-Public Supervised	Signage		Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		None	n/a	New HSB Under Construction - Relocation in 2017
F04398	Human Service Building		6th Floor	Owned	Lobby Reception	Housing Authority	1-Public Unsupervised	Counter	Check-in	Height	43	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05065	Human Service Building		4th Floor	Owned	Other Room	Adult Services	3-Employee Common	Door Gate		Clearance, vertical	78	No	Vertical clearance is too low.	2-Services	Replace the doorway with a compliant vertical clearance.	80 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F05066	Human Service Building		4th Floor	Owned	Other Room	Adult Services	2-Public Supervised	Door Gate		Opening force	9	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05073	Human Service Building		6th Floor	Owned	Other Room	Family Transition	2-Public Supervised	Door Gate		Clearance, vertical	79	No	Vertical clearance is too low.	2-Services	Replace the doorway with a compliant vertical clearance.	80 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F05074	Human Service Building		6th Floor	Owned	Other Room	Family Transition	2-Public Supervised	Door Gate		Opening force	6	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F05080	Human Service Building		6th Floor	Owned	Other Room	Housing Authority	1-Public Unsupervised	Signage		Braille?	N	No	Signage does not provide Braille.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		None	n/a	New HSB Under Construction - Relocation in 2017
F05081	Human Service Building		6th Floor	Owned	Other Room	Housing Authority	2-Public Supervised	Door Gate		Clearance, vertical	79.5	No	Vertical clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	80 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F05082	Human Service Building		6th Floor	Owned	Other Room	Housing Authority	3-Employee Common	Signage		Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		None	n/a	New HSB Under Construction - Relocation in 2017
F05091	Human Service Building		Interior	Owned	Other Room	Interview Room #1	2-Public Supervised	Door Gate		Clearance, vertical	79.25	No	Vertical clearance is too low.	2-Services	Replace the doorway with a compliant vertical clearance.	80 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05093	Human Service Building		Interior	Owned	Other Room	Interview Room #2	2-Public Supervised	Door Gate		Clearance, vertical	79.25	No	Vertical clearance is too low.	2-Services	Replace the doorway with a compliant vertical clearance.	80 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F06409	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #12 & #13	Slope, cross	2.5%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F06410	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #13 & #14	Slope, cross	2.7%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F06411	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#16	Slope, cross	2.3%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F06412	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#15	Slope, cross	3.3%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F06413	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#14	Slope, cross	4.6%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F06414	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #13 & #14	Slope, running	2.1%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F06415	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #11 & #12	Slope, running	2.3%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F06416	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #10 & #11	Slope, running	2.4%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F06417	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #12 & #13	Slope, running	2.6%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F06418	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #15 & #16	Slope, running	3.3%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F06419	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #16 & #17	Slope, running	3.8%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F06420	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #17 & #18	Slope, running	4.2%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F06421	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #18 & #19	Slope, running	4.3%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F06422	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#13	Slope, running	2.1%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F06423	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#12	Slope, running	2.3%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F06424	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#10	Slope, running	2.6%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F06425	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space		Slope, running	3.0%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F06426	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#15	Slope, running	3.8%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F06427	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#16	Slope, running	3.9%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F06428	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#17	Slope, running	4.6%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F06429	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#18	Slope, running	5.7%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F06513	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#5	Slope, running	2.1%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F06514	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#2	Slope, running	2.2%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F06515	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#8	Slope, running	3.0%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06516	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#9	Slope, running	3.6%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F06588	Human Service Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, van spaces	0	No	Too few van accessible parking spaces are provided.	1-Entry	Provide the minimum number of required van accessible parking spaces.	2 minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F06589	Human Service Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Width	49	No	Access aisle is too narrow.	1-Entry	Restripe the parking space and aisle to provide a compliant sized access aisle.	60 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F11314	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Braille?	N	No	Signage does not provide Braille.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		None	n/a	New HSB Under Construction - Relocation in 2017
F11315	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Ambulatory Compartment		Clearance, parallel	34.5	No	Ambulatory compartment is too narrow.	5-Tolerance	No action recommended - within construction tolerance.	60" deep and 35" to 37" wide	None	n/a	New HSB Under Construction - Relocation in 2017
F11316	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	59.5	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F11317	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Clearance, parallel	59.5	No	Clearance at water closet is too narrow.	5-Tolerance	No action recommended - within construction tolerance.	60 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F11318	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, pull parallel	13.25	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F11319	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Amb - Side #1	Clearance, to wall	3	No	Space between wall and grab bar is too wide.	3-Restrooms	Install a new grab bar with the correct spacing between the grab bar and the wall.	1.5 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F11320	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Amb - Side #2	Clearance, to wall	3	No	Space between wall and grab bar is too wide.	3-Restrooms	Install a new grab bar with the correct spacing between the grab bar and the wall.	1.5 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F11321	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, vertical	79	No	Vertical clearance is too low.	3-Restrooms	Replace the doorway with a compliant vertical clearance.	80 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F11322	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, vertical	79	No	Vertical clearance is too low.	3-Restrooms	Replace the doorway with a compliant vertical clearance.	80 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F11323	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Closing speed	3	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F11324	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	12	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	None	n/a	New HSB Under Construction - Relocation in 2017
F11325	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Amb - Side #1	Dimension, end to wall	18	No	Side wall grab bar is located too far away from the back wall.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F11326	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Amb - Side #2	Dimension, end to wall	18	No	Side wall grab bar is located too far away from the back wall.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F11327	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Protrusion	PT	Dimension, protruding	9	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		None	n/a	New HSB Under Construction - Relocation in 2017
F11328	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		None	n/a	New HSB Under Construction - Relocation in 2017
F11329	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		None	n/a	New HSB Under Construction - Relocation in 2017
F11330	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Alarm System		Height	79.5	No	Visible alarm is too low.	5-Tolerance	No action recommended - within construction tolerance.	80 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F11331	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Coat Hook	Ambulatory stall	Height	59	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F11332	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Coat Hook		Height	60	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F11333	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Height	35	No	Lavatory sink is too high.	3-Restrooms	Lower the lavatory sink to the correct height.	34 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F11334	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Height	34.5	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F11335	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Changing Station		Height	35	No	Work surface does not comply with height requirements.	3-Restrooms	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F11336	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Changing Station		Height	36	No	Work surface does not comply with height requirements.	3-Restrooms	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F11337	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Ambulatory	Height, top	36.25	No	Grab bar is too high.	5-Tolerance	No action recommended - within construction tolerance.	33-36 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F11338	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Height, top	36.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F11339	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Location	On door	No	Sign is not mounted in the correct location.	3-Restrooms	Move the sign to the latch side of the door.		None	n/a	New HSB Under Construction - Relocation in 2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11340	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Opening force	9	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F11341	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Opening force	14	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F11342	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		None	n/a	New HSB Under Construction - Relocation in 2017
F11343	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Hardware type	Twist lock	No	Hardware requires twisting of wrist.	3-Restrooms	Install lever type door hardware.		None	n/a	New HSB Under Construction - Relocation in 2017
F11412	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Braille?	N	No	Signage does not provide Braille.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		None	n/a	New HSB Under Construction - Relocation in 2017
F11413	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Ambulatory Compartment		Clearance, parallel	34	No	Ambulatory compartment is too narrow.	3-Restrooms	Reconfigure the toilet compartments to accommodate a correct sized ambulatory compartment.	60" deep and 35" to 37" wide	None	n/a	New HSB Under Construction - Relocation in 2017
F11414	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, pull parallel	9.5	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F11415	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Amb - Side #1	Clearance, to wall	3	No	Space between wall and grab bar is too wide.	3-Restrooms	Install a new grab bar with the correct spacing between the grab bar and the wall.	1.5 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F11416	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Amb - Side #2	Clearance, to wall	3	No	Space between wall and grab bar is too wide.	3-Restrooms	Install a new grab bar with the correct spacing between the grab bar and the wall.	1.5 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F11417	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, vertical	79.25	No	Vertical clearance is too low.	3-Restrooms	Replace the doorway with a compliant vertical clearance.	80 inches minimum	None	n/a	New HSB Under Construction - Relocation in 2017
F11418	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	4	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F11419	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Amb - Side #1	Dimension, end to wall	18	No	Side wall grab bar is located too far away from the back wall.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F11420	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Amb - Side #2	Dimension, end to wall	18	No	Side wall grab bar is located too far away from the back wall.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F11421	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Protrusion	PT	Dimension, protruding	9	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		None	n/a	New HSB Under Construction - Relocation in 2017
F11422	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Protrusion	Hand dryer	Dimension, protruding	8	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		None	n/a	New HSB Under Construction - Relocation in 2017
F11423	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, sidewall	18.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F11424	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		None	n/a	New HSB Under Construction - Relocation in 2017
F11425	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		None	n/a	New HSB Under Construction - Relocation in 2017
F11426	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Ambulatory Compartment		Hardware type	Twist	No	Hardware requires twisting of wrist.	3-Restrooms	Install lever type door hardware.		None	n/a	New HSB Under Construction - Relocation in 2017
F11427	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Ambulatory Compartment		Hardware type	Twist	No	Hardware requires twisting of wrist.	3-Restrooms	Install lever type door hardware.		None	n/a	New HSB Under Construction - Relocation in 2017
F11428	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Coat Hook	Ambulatory stall	Height	62	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F11429	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Height	35	No	Lavatory sink is too high.	3-Restrooms	Lower the lavatory sink to the correct height.	34 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F11430	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Height	34.25	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F11431	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Changing Station		Height	38	No	Work surface does not comply with height requirements.	3-Restrooms	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F11432	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Height, top	36.25	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F11433	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Height, top	36.25	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	None	n/a	New HSB Under Construction - Relocation in 2017
F11434	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Location	On door	No	Sign is not mounted in the correct location.	3-Restrooms	Move the sign to the latch side of the door.		None	n/a	New HSB Under Construction - Relocation in 2017
F11435	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Location	On door	No	Sign is not mounted in the correct location.	3-Restrooms	Move the sign to the latch side of the door.		None	n/a	New HSB Under Construction - Relocation in 2017
F11436	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, accessible compartments	0	No	No accessible toilet compartment in restroom.	3-Restrooms	Rebuild or reconfigure the restroom, with a wheelchair accessible toilet compartment.	1 minimum	None	n/a	New HSB Under Construction - Relocation in 2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11437	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Over obstruction?	Y	No	Toilet paper dispenser is mounted above the grab bar.	3-Restrooms	Move the toilet paper dispenser to a compliant position under the grab bar.		None	n/a	New HSB Under Construction - Relocation in 2017
F11438	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		None	n/a	New HSB Under Construction - Relocation in 2017
F16283	Human Service Building		Exterior	Owned	Walkway	From Bus Stop on 72nd Street	1-Public Unsupervised	Walking Surface		Slope, running	18.5%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with compliant running and cross slopes, or install handrails, edge protection, and landings required for ramps.	5.0% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F16287	Human Service Building		Exterior	Owned	Walkway	West parking lot	1-Public Unsupervised	Walking Surface		Slope, running	7.4%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with compliant running and cross slopes, or install handrails, edge protection, and landings required for ramps.	5.0% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F16290	Human Service Building		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	At corner crosswalk - North side	Landing?	N	No	No landing provided at top of curb ramp.	1-Entry	Provide a landing at the top of the curb ramp that is the same width as the curb ramp and at least 36 inches long.		None	n/a	New HSB Under Construction - Relocation in 2017
F16291	Human Service Building		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	At corner crosswalk - North side	Slope, cross	2.9%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F16292	Human Service Building		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	At corner crosswalk - North side	Slope, left flare	17.8%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp with compliant side flares.	10% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F16293	Human Service Building		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	At corner crosswalk - North side	Slope, right flare	27.7%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp with compliant side flares.	10% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F16294	Human Service Building		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	At corner crosswalk - North side	Slope, running	9.5%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp, curb, and gutter to provide compliant running slope.	8.33% maximum	None	n/a	New HSB Under Construction - Relocation in 2017
F03532	Jim Baker Reservoir		Exterior	Owned	Fishing Pier		1-Public Unsupervised	Railing		Length, 34 inch max. railing	0	No	Lowered railing is not provided on fishing pier.	2-Services	Provide and disperse at least 25% of the railing at a maximum of 34 inches above the pier surface.	45 feet at 34 inches	2018	$ 5,000.00	by Parks
F06597	Jim Baker Reservoir		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, accessible	0	No	Too few accessible parking spaces and van accessible parking spaces.	1-Entry	Provide a minimum of one accessible parking space, which should also be a van accessible size space.	1 minimum	2020	$ 10,000.00	by Parks
F06598	Jim Baker Reservoir		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, van spaces	0	No	Too few van accessible parking spaces are provided.	1-Entry	Provide the minimum number of required van accessible parking spaces.	1 minimum	2020	$ 10,000.00	by Parks
F06599	Jim Baker Reservoir		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Surface Material	Gravel	No	Walking surface is not stable, firm, and slip resistant.	1-Entry	Provide an accessible route connecting the bike path to the parking lot.		2020	$ 15,000.00	by Parks
F11492	Jim Baker Reservoir		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	10	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2017	$ 25.00	by Parks
F11493	Jim Baker Reservoir		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Hardware type	Knob	No	Hardware requires twisting of wrist.	3-Restrooms	Install lever type door hardware.		2017	$ 150.00	by Parks
F16298	Jim Baker Reservoir		Exterior	Owned	Walkway	Parking lot to restroom door	1-Public Unsupervised	Walking Surface		Height, level change	1.25	No	Vertical change in level is too high.	1-Entry	Grind the surface to provide a change in level no higher than 1/2 inch (beveled), with a slope not > 1:2.		2017	$ 50.00	by Parks
F16299	Jim Baker Reservoir		Exterior	Owned	Walkway	Parking lot to restroom door	1-Public Unsupervised	Walking Surface		Surface material	Gravel	No	Walking surface is not stable, firm, and slip resistant.	1-Entry	Provide an accessible route connecting the restroom to the parking lot.		2020	$ 15,000.00	by Parks
F00179	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S431	2-Public Supervised	Door Gate		Opening force	9	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00193	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S432	2-Public Supervised	Door Gate		Opening force	16	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00211	Justice Center	Self Help Resource Center	Interior	Owned	Assembly Area	Training Room	1-Public Unsupervised	Seating Area		Assistive listening systems?	None found - no sign	No	No Assistive Listening devices found and no instructional signage visible.	2-Services	Provide an assistive listening system and signage stating that an assistive listening system is provided.	1 sign and 4 ALS receivers	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F00212	Justice Center	Self Help Resource Center	Interior	Owned	Assembly Area	Training Room	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F00213	Justice Center	Self Help Resource Center	Interior	Owned	Assembly Area	Training Room	1-Public Unsupervised	Other Element	Changing station	Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F00214	Justice Center	Self Help Resource Center	Interior	Owned	Assembly Area	Training Room	2-Public Supervised	Door Gate		Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00231	Justice Center		Interior	Owned	Assembly Area	Jury Assembly Area	1-Public Unsupervised	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F00232	Justice Center		Interior	Owned	Assembly Area	Jury Assembly Area	1-Public Unsupervised	Lavatory Sink		Height	36	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F00233	Justice Center		Interior	Owned	Assembly Area	Jury Assembly Area	1-Public Unsupervised	Appliance	Coffee dispenser	Height, control	52.5	No	Operable part is out of reach range.	4-Other	Relocate the appliance to within a compliant reach range.	48 inches maximum	2017	$ 500.00	Planned as part of Renovation in 2016/2017
F00234	Justice Center		Interior	Owned	Assembly Area	Jury Assembly Area	1-Public Unsupervised	Vending Machine	Coke	Height, control	50	No	Operable part is out of reach range.	4-Other	Replace the Vending Machine with one that has operable parts within the reach range.	48 inches maximum	2017	$ -	Planned as part of Renovation in 2016/2017
F00235	Justice Center		Interior	Owned	Assembly Area	Jury Assembly Area	1-Public Unsupervised	Vending Machine	Snacks	Height, control	54.5	No	Operable part is out of reach range.	4-Other	Replace the Vending Machine with one that has operable parts within the reach range.	48 inches maximum	2017	$ -	Planned as part of Renovation in 2016/2017
F00236	Justice Center		Interior	Owned	Assembly Area	Jury Assembly Area	1-Public Unsupervised	Vending Machine	Aquafina	Height, control	50	No	Operable part is out of reach range.	4-Other	Replace the Vending Machine with one that has operable parts within the reach range.	48 inches maximum	2017	$ -	Planned as part of Renovation in 2016/2017
F00256	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Signage		Braille?	N	No	Signage does not provide Braille.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00257	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Protrusion	Angled beam #1	Dimension, protruding	36	No	Object protrudes into the path of travel.	2-Services	Install cane detection to prevent potential head injuries.		2017	$ 500.00	Planned as part of Renovation in 2016/2017
F00258	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Protrusion	Angled beam #2	Dimension, protruding	44	No	Object protrudes into the path of travel.	2-Services	Install cane detection to prevent potential head injuries.		2017	$ 500.00	Planned as part of Renovation in 2016/2017
F00259	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Opening force	13	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00260	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Signage		Other attribute	None	No	Braille and raised letter signage is not provided.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F00261	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Signage		Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F00573	Justice Center		Interior	Owned	Break Room	#105 - South wall	3-Employee Common	Counter		Height	35.75	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F00574	Justice Center		Interior	Owned	Break Room	#105 - South wall	3-Employee Common	Dispenser	PT	Height	49.25	No	Dispenser is too high.	2-Services	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Relocate or Replace Dispenser
F00575	Justice Center		Interior	Owned	Break Room	#105 - South wall	3-Employee Common	Lavatory Sink		Height	36	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F00587	Justice Center		Interior	Owned	Break Room	#105 - Work Area	3-Employee Common	Appliance	Electric can opener	Height	56	No	Operable part is out of reach range.	4-Other	Relocate the appliance to within a compliant reach range.	48 inches maximum	2017	$ -	Planned as part of Renovation in 2016/2017
F00588	Justice Center		Interior	Owned	Break Room	#105 - Work Area	3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F00589	Justice Center		Interior	Owned	Break Room	#105 - Work Area	3-Employee Common	Dispenser	PT	Height	49	No	Dispenser is too high.	2-Services	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Relocate or Replace Dispenser
F00590	Justice Center		Interior	Owned	Break Room	#105 - Work Area	3-Employee Common	Lavatory Sink		Height	36.25	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F00603	Justice Center		4th Floor	Owned	Break Room	#405 - Staff Area	3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F00604	Justice Center		4th Floor	Owned	Break Room	#405 - Staff Area	3-Employee Common	Lavatory Sink		Height	36.25	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F00621	Justice Center		6th Floor	Owned	Break Room	#605 - Staff Area	3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F00622	Justice Center		6th Floor	Owned	Break Room	#605 - Staff Area	3-Employee Common	Lavatory Sink		Height	36.25	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F00630	Justice Center		4th Floor	Owned	Break Room	#S437	3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	2-Services	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F00631	Justice Center		4th Floor	Owned	Break Room	#S437	3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F00632	Justice Center		4th Floor	Owned	Break Room	#S437	3-Employee Common	Dispenser	PT	Height	50	No	Dispenser is too high.	2-Services	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Relocate or Replace Dispenser
F00633	Justice Center		4th Floor	Owned	Break Room	#S437	3-Employee Common	Lavatory Sink		Height	36.5	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F00639	Justice Center		6th Floor	Owned	Break Room	Near #S640 AV Closet	3-Employee Common	Counter		Height	36.25	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F00640	Justice Center		6th Floor	Owned	Break Room	Near #S640 AV Closet	3-Employee Common	Lavatory Sink		Height	36.5	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F00646	Justice Center		5th Floor	Owned	Break Room	South	3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F00647	Justice Center		5th Floor	Owned	Break Room	South	3-Employee Common	Lavatory Sink		Height	36	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F00664	Justice Center		5th Floor	Owned	Break Room		3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F00665	Justice Center		Interior	Owned	Break Room		3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F00666	Justice Center		5th Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Height	36	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F00667	Justice Center		Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Height	36.25	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F00668	Justice Center		Interior	Owned	Break Room		3-Employee Common	Alarm System		Visible alarm	N	No	No visible alarm is provided.	4-Other	Install a visible wall fire alarm.	Between 80 and 96 inches AFF	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F00858	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate	To exterior Courtyard	Clearance, push parallel	2.75	No	Clearance on push side of door is insufficient.	2-Services	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	12 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F00859	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Vending Machine	Pepsi	Control force	7	No	Operating force is greater than the maximum force allowed.	4-Other	Adjust the controls to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00860	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Vending Machine	Snacks	Control force	11	No	Operating force is greater than the maximum force allowed.	4-Other	Adjust the controls to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00861	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Vending Machine	Snacks	Control force	10	No	Operating force is greater than the maximum force allowed.	4-Other	Adjust the controls to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00862	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Counter	At cash register	Height	36.25	No	Counter is too high. No equivalent facilitation is provided in the area.	5-Tolerance	No action recommended - within construction tolerance.	36 inches maximum	2017	$ -	Within Tolerance (per Assessment)
F00863	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Counter	Condiment countertop	Height	35.5	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00864	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Counter	Condiment countertop	Height	37.75	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F00865	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Appliance	Soft drink counter dispenser	Height, control	56	No	Operable part is out of reach range.	4-Other	Relocate the appliance to within a compliant reach range.	48 inches maximum	2017	$ -	Planned as part of Renovation in 2016/2017
F00866	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Vending Machine	Pepsi	Height, control	52.5	No	Operable part is out of reach range.	4-Other	Replace the Vending Machine with one that has operable parts within the reach range.	48 inches maximum	2016	$ -	Internal Staff - Operations
F00867	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Vending Machine	Snacks	Height, control	54	No	Operable part is out of reach range.	4-Other	Replace the Vending Machine with one that has operable parts within the reach range.	48 inches maximum	2016	$ -	Internal Staff - Operations
F00868	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate		Opening force	8	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00869	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate	To exterior Courtyard	Opening force	12	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00870	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F00994	Justice Center		2nd Floor	Owned	Conference Room	#254	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F00995	Justice Center		2nd Floor	Owned	Conference Room	#254	2-Public Supervised	Door Gate		Opening force	13	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00996	Justice Center		2nd Floor	Owned	Conference Room	#255	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F00997	Justice Center		2nd Floor	Owned	Conference Room	#255	2-Public Supervised	Door Gate		Opening force	13	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F00998	Justice Center		2nd Floor	Owned	Conference Room	#257	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F00999	Justice Center		2nd Floor	Owned	Conference Room	#257	2-Public Supervised	Door Gate		Opening force	13	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01005	Justice Center		2nd Floor	Owned	Conference Room	#258	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01006	Justice Center		2nd Floor	Owned	Conference Room	#258	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F01007	Justice Center		2nd Floor	Owned	Conference Room	#258	2-Public Supervised	Door Gate		Opening force	13	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01021	Justice Center		5th Floor	Owned	Conference Room	#511	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01031	Justice Center		5th Floor	Owned	Conference Room	#512	2-Public Supervised	Door Gate		Closing speed	1	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F01045	Justice Center		5th Floor	Owned	Conference Room	#512 - Family Court	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01046	Justice Center		5th Floor	Owned	Conference Room	#512 - Family Court	2-Public Supervised	Door Gate		Closing speed	1	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F01079	Justice Center		4th Floor	Owned	Conference Room	#S405	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F01080	Justice Center		4th Floor	Owned	Conference Room	#S405	2-Public Supervised	Door Gate		Opening force	14	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01085	Justice Center		4th Floor	Owned	Conference Room	#S410	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01086	Justice Center		4th Floor	Owned	Conference Room	#S410	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F01087	Justice Center		4th Floor	Owned	Conference Room	#S410	2-Public Supervised	Door Gate		Opening force	14	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01103	Justice Center		5th Floor	Owned	Conference Room	#S510	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01104	Justice Center		5th Floor	Owned	Conference Room	#S510	2-Public Supervised	Door Gate		Opening force	14	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01152	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01153	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Door Gate		Clearance, pull perpendicular	52	No	Clearance on pull side of door is insufficient.	2-Services	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F01154	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F01155	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	2-Services	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F01156	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01157	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Lavatory Sink		Height	36.25	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F01158	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Door Gate		Opening force	11	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01175	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 239	2-Public Supervised	Door Gate		Clearance, pull perpendicular	52	No	Clearance on pull side of door is insufficient.	2-Services	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F01176	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 239	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F01177	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 239	2-Public Supervised	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01178	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 239	2-Public Supervised	Lavatory Sink		Height	36.25	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F01179	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 239	2-Public Supervised	Door Gate		Opening force	11	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01181	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 325	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01182	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 325	2-Public Supervised	Door Gate		Clearance, pull perpendicular	55	No	Clearance on pull side of door is insufficient.	2-Services	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F01183	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 325	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F01184	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 325	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	2-Services	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F01185	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 325	2-Public Supervised	Counter		Height	35.75	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01186	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 325	2-Public Supervised	Lavatory Sink		Height	36	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F01187	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 325	2-Public Supervised	Door Gate		Opening force	9	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01188	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 329	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01189	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 329	2-Public Supervised	Door Gate		Clearance, pull perpendicular	56	No	Clearance on pull side of door is insufficient.	2-Services	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F01190	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 329	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F01191	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 329	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	2-Services	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F01192	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 329	2-Public Supervised	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01193	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 329	2-Public Supervised	Lavatory Sink		Height	36.25	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F01194	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 329	2-Public Supervised	Door Gate		Opening force	7	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01196	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 364	2-Public Supervised	Door Gate		Clearance, pull perpendicular	58	No	Clearance on pull side of door is insufficient.	2-Services	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F01197	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 364	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	2-Services	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F01198	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 364	2-Public Supervised	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01199	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 364	2-Public Supervised	Lavatory Sink		Height	36.25	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F01200	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 364	2-Public Supervised	Door Gate		Opening force	13	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01201	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 364	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01202	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 369	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01203	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 369	2-Public Supervised	Door Gate		Clearance, pull perpendicular	58	No	Clearance on pull side of door is insufficient.	2-Services	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F01204	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 369	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	2-Services	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F01205	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 369	2-Public Supervised	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01206	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 369	2-Public Supervised	Lavatory Sink		Height	36.25	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F01207	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 369	2-Public Supervised	Door Gate		Opening force	9	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01215	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01216	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Door Gate		Clearance, pull perpendicular	55	No	Clearance on pull side of door is insufficient.	2-Services	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F01217	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F01218	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	2-Services	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F01219	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Counter		Height	35.75	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F01220	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Lavatory Sink		Height	36	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F01221	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Door Gate		Opening force	9	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01251	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01252	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Door Gate		Clearance, pull perpendicular	56	No	Clearance on pull side of door is insufficient.	2-Services	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F01253	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	2-Services	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F01254	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01255	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Lavatory Sink		Height	36.25	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F01256	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Door Gate		Opening force	7	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01295	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Door Gate		Clearance, pull perpendicular	58	No	Clearance on pull side of door is insufficient.	2-Services	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F01296	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	2-Services	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F01297	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01298	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Lavatory Sink		Height	36.25	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F01299	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Door Gate		Opening force	13	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01327	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01328	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Door Gate		Clearance, pull perpendicular	58	No	Clearance on pull side of door is insufficient.	2-Services	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F01329	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	2-Services	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F01330	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01331	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Lavatory Sink		Height	36.25	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F01332	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Door Gate		Opening force	9	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01363	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01364	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Door Gate		Clearance, pull perpendicular	55	No	Clearance on pull side of door is insufficient.	2-Services	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F01365	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F01366	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01367	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Lavatory Sink		Height	36.25	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F01398	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01399	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Door Gate		Clearance, pull perpendicular	48	No	Clearance on pull side of door is insufficient.	2-Services	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F01400	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Door Gate		Closing speed	3	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F01401	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Lavatory Sink		Height	36	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F01402	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Door Gate		Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01428	Justice Center		6th Floor	Owned	Conference Room	Jury Room 627	2-Public Supervised	Dispenser	PT	Height	50	No	Dispenser is too high.	2-Services	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Relocate or Replace Dispenser
F01429	Justice Center		6th Floor	Owned	Conference Room	Jury Room 627	2-Public Supervised	Lavatory Sink		Height	36.25	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F01430	Justice Center		6th Floor	Owned	Conference Room	Jury Room 627	2-Public Supervised	Operable Part	Coat Rod	Height	66	No	Operable part is out of reach range.	2-Services	Relocate the coat rod to within a compliant reach range.	48 inches maximum	2017	$ 150.00	Planned as part of Renovation in 2016/2017
F01433	Justice Center		6th Floor	Owned	Conference Room	Jury Room 631	2-Public Supervised	Dispenser	PT	Height	50	No	Dispenser is too high.	2-Services	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Relocate or Replace Dispenser
F01434	Justice Center		6th Floor	Owned	Conference Room	Jury Room 631	2-Public Supervised	Lavatory Sink		Height	36.25	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F01435	Justice Center		6th Floor	Owned	Conference Room	Jury Room 631	2-Public Supervised	Operable Part	Coat Rod	Height	66	No	Operable part is out of reach range.	2-Services	Relocate the coat rod to within a compliant reach range.	48 inches maximum	2017	$ 150.00	Planned as part of Renovation in 2016/2017
F01451	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Clearance, pull perpendicular	57	No	Clearance on pull side of door is insufficient.	2-Services	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F01452	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Counter		Height	36.25	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01453	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Lavatory Sink		Height	36.5	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F01454	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Opening force	9	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01493	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01494	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01495	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Clearance, pull perpendicular	54.5	No	Clearance on pull side of door is insufficient.	2-Services	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F01496	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F01497	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F01498	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01499	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Dispenser	PT	Height	55.25	No	Dispenser is too high.	2-Services	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Relocate or Replace Dispenser
F01500	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Lavatory Sink		Height	36	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F01501	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Opening force	11	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01502	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Opening force	13	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01543	Justice Center		6th Floor	Owned	Conference Room	Jury Room S622	2-Public Supervised	Lavatory Sink		Height	36.25	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F01544	Justice Center		6th Floor	Owned	Conference Room	Jury Room S622	2-Public Supervised	Operable Part	Coat Rod	Height	51	No	Operable part is out of reach range.	2-Services	Relocate the coat rod to within a compliant reach range.	48 inches maximum	2017	$ 150.00	Planned as part of Renovation in 2016/2017
F01545	Justice Center		6th Floor	Owned	Conference Room	Jury Room S622	2-Public Supervised	Door Gate		Opening force	8	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01583	Justice Center	Traffic Court	2nd Floor	Owned	Courtroom	#251	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F01584	Justice Center	Traffic Court	2nd Floor	Owned	Courtroom	#251	2-Public Supervised	Counter		Height	43	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01585	Justice Center	Traffic Court	2nd Floor	Owned	Courtroom	#251	2-Public Supervised	Door Gate		Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01622	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Seating Area	Spectator	Assistive listening systems?	None found - no sign	No	No Assistive Listening devices found and no instructional signage visible.	2-Services	Provide an assistive listening system and signage stating that an assistive listening system is provided.	1 sign and 4 ALS receivers	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01623	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Court staff entrance	Clearance, push parallel	8	No	Clearance on push side of door is insufficient.	2-Services	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	12 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F01624	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Court staff entrance	Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F01625	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Jury entrance	Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F01626	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Counter	Clerk	Height	40	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01627	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Court staff entrance	Opening force	11	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01628	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Jury entrance	Opening force	15	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01629	Justice Center		2nd Floor	Owned	Courtroom	#201	3-Employee Common	Courtroom Station		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F01630	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Judge Bench		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F01632	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Witness Stand		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F01672	Justice Center		2nd Floor	Owned	Courtroom	#201 - Room 226	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01673	Justice Center		2nd Floor	Owned	Courtroom	#201 - Room 226	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F01689	Justice Center		2nd Floor	Owned	Courtroom	#202 - Room 220	2-Public Supervised	Counter	Clerk	Height	40	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01690	Justice Center		2nd Floor	Owned	Courtroom	#202 - Room 220	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F01691	Justice Center		2nd Floor	Owned	Courtroom	#202 - Room 220	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01692	Justice Center		2nd Floor	Owned	Courtroom	#202 - Room 220	2-Public Supervised	Witness Stand		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F01696	Justice Center		2nd Floor	Owned	Courtroom	#203 - Room 256	2-Public Supervised	Door Gate		Other attribute	7	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01697	Justice Center		2nd Floor	Owned	Courtroom	#203 - Room 256	2-Public Supervised	Seating Area	Spectator	Assistive listening systems?	None found - no sign	No	No Assistive Listening devices found and no instructional signage visible.	2-Services	Provide an assistive listening system and signage stating that an assistive listening system is provided.	1 sign and 4 ALS receivers	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01698	Justice Center		2nd Floor	Owned	Courtroom	#203 - Room 256	2-Public Supervised	Seating Area	Spectator	Number, ALS receivers	None found - no sign	No	No Assistive Listening devices found and no instructional signage visible.	2-Services	Provide an assistive listening system and signage stating that an assistive listening system is provided.	1 sign and 4 ALS receivers	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01699	Justice Center		2nd Floor	Owned	Courtroom	#203 - Room 256	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01700	Justice Center		2nd Floor	Owned	Courtroom	#203 - Room 256	2-Public Supervised	Witness Stand		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F01702	Justice Center		3rd Floor	Owned	Courtroom	#301 - Room 316	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01703	Justice Center		3rd Floor	Owned	Courtroom	#302 - Room 310	2-Public Supervised	Door Gate		Other attribute	7	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01707	Justice Center		3rd Floor	Owned	Courtroom	#303 - Room 350	2-Public Supervised	Counter	Clerk	Height	40	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01708	Justice Center		3rd Floor	Owned	Courtroom	#303 - Room 350	2-Public Supervised	Door Gate		Other attribute	7	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01709	Justice Center		3rd Floor	Owned	Courtroom	#303 - Room 350	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01710	Justice Center		3rd Floor	Owned	Courtroom	#303 - Room 350	2-Public Supervised	Witness Stand		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F01715	Justice Center		3rd Floor	Owned	Courtroom	#304 - Room 356	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01716	Justice Center		3rd Floor	Owned	Courtroom	#304 - Room 356	2-Public Supervised	Counter	Clerk	Height	40	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01717	Justice Center		3rd Floor	Owned	Courtroom	#304 - Room 356	2-Public Supervised	Seating Area	Spectator	Number, ALS receivers	None found - no sign	No	No Assistive Listening devices found and no instructional signage visible.	2-Services	Provide an assistive listening system and signage stating that an assistive listening system is provided.	1 sign and 4 ALS receivers	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01718	Justice Center		3rd Floor	Owned	Courtroom	#304 - Room 356	2-Public Supervised	Door Gate		Opening force	8	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01719	Justice Center		3rd Floor	Owned	Courtroom	#304 - Room 356	2-Public Supervised	Judge Bench		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F01721	Justice Center		3rd Floor	Owned	Courtroom	#304 - Room 356	2-Public Supervised	Witness Stand		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F01742	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Seating Area	Spectator	Assistive listening systems?	None found - no sign	No	No Assistive Listening devices found and no instructional signage visible.	2-Services	Provide an assistive listening system and signage stating that an assistive listening system is provided.	1 sign and 4 ALS receivers	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01743	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01744	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Counter	Clerk	Height	39.75	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01745	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Seating Area	Spectator	Number, ALS receivers	None found - no sign	No	No Assistive Listening devices found and no instructional signage visible.	2-Services	Provide an assistive listening system and signage stating that an assistive listening system is provided.	1 sign and 4 ALS receivers	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01746	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Door Gate		Opening force	11	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01747	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Judge Bench		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F01749	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Witness Stand		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F01791	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Seating Area	Spectator	Assistive listening systems?	None found - no sign	No	No Assistive Listening devices found and no instructional signage visible.	2-Services	Provide an assistive listening system and signage stating that an assistive listening system is provided.	1 sign and 4 ALS receivers	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01792	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01793	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Counter	Clerk	Height	39.75	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F01794	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Seating Area	Spectator	Number, ALS receivers	None found - no sign	No	No Assistive Listening devices found and no instructional signage visible.	2-Services	Provide an assistive listening system and signage stating that an assistive listening system is provided.	1 sign and 4 ALS receivers	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01795	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Door Gate		Opening force	7	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01796	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Judge Bench		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F01798	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Witness Stand		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F01846	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Seating Area	Spectator	Assistive listening systems?	None found - no sign	No	No Assistive Listening devices found and no instructional signage visible.	2-Services	Provide an assistive listening system and signage stating that an assistive listening system is provided.	1 sign and 4 ALS receivers	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01847	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01848	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Counter	Clerk	Height	40	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01849	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Seating Area	Spectator	Number, ALS receivers	None found - no sign	No	No Assistive Listening devices found and no instructional signage visible.	2-Services	Provide an assistive listening system and signage stating that an assistive listening system is provided.	1 sign and 4 ALS receivers	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01850	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Door Gate	Double door entrance	Opening force	7	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01851	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Judge Bench		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F01853	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Witness Stand		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F01899	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01900	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Counter	Clerk	Height	40	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01901	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Seating Area	Spectator	Number, ALS receivers	None found - no sign	No	No Assistive Listening devices found and no instructional signage visible.	2-Services	Provide an assistive listening system and signage stating that an assistive listening system is provided.	1 sign and 4 ALS receivers	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01902	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Door Gate		Opening force	8	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01903	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Judge Bench		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F01955	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F01956	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F01957	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Counter	Clerk	Height	40	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01958	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Seating Area	Spectator	Number, ALS receivers	None found - no sign	No	No Assistive Listening devices found and no instructional signage visible.	2-Services	Provide an assistive listening system and signage stating that an assistive listening system is provided.	1 sign and 4 ALS receivers	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F01959	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate	Jury entrance	Opening force	8	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01960	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Judge Bench		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F02021	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F02022	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F02023	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Counter	Clerk	Height	40	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F02024	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Seating Area	Spectator	Number, ALS receivers	None found - no sign	No	No Assistive Listening devices found and no instructional signage visible.	2-Services	Provide an assistive listening system and signage stating that an assistive listening system is provided.	1 sign and 4 ALS receivers	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F02025	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Judge Bench		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F02099	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F02100	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Court staff entrance	Clearance, push parallel	6	No	Clearance on push side of door is insufficient.	2-Services	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	12 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F02101	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate		Closing speed	3	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F02102	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	2nd set in series	Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F02103	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Court staff entrance	Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F02104	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Jury entrance	Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F02105	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Counter	Clerk	Height	40	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F02106	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Court staff entrance	Opening force	12	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F02107	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	2nd set in series	Opening force	13	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F02108	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate		Opening force	15	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F02109	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	3-Employee Common	Courtroom Station		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F02110	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Judge Bench		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F02112	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Witness Stand		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F02205	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F02206	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F02207	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Signage	Court staff entrance	Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F02208	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F02209	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F02210	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	Court staff entrance	Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F02211	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Wheelchair Space		Depth	44	No	Depth of wheelchair space is too short.	2-Services	Relocate or reconfigure the wheelchair space to provide at least the minimum clear floor space.	48 inches minimum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F02212	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Counter		Height	40	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F02215	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Seating Area		Number, ALS receivers	1	No	One Assistive Listening device found and no instructional signage visible.	2-Services	Provide 4 assistive listening receivers and signage stating that an assistive listening system is provided.	1 sign and 4 ALS receivers	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F02216	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	Court staff entrance	Opening force	11	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F02217	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	2nd set in series	Opening force	12	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F02218	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Opening force	15	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F02219	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Opening force	18	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F02220	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	3-Employee Common	Courtroom Station		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F02221	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Judge Bench		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F02222	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Witness Stand		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F02299	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 511	2-Public Supervised	Door Gate		Closing speed	1	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F02341	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	Court staff entrance	Clearance, push parallel	6	No	Clearance on push side of door is insufficient.	2-Services	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	12 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F02342	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	Court staff entrance	Closing speed	3	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F02343	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Wheelchair Space		Depth	45	No	Depth of wheelchair space is too short.	2-Services	Relocate or reconfigure the wheelchair space to provide at least the minimum clear floor space.	48 inches minimum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F02344	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Counter		Height	40	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F02348	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Seating Area		Number, ALS receivers	1	No	One Assistive Listening device found and no instructional signage visible.	2-Services	Provide 4 assistive listening receivers and signage stating that an assistive listening system is provided.	1 sign and 4 ALS receivers	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F02349	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	2nd set in series	Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F02350	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate		Opening force	13	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F02351	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	Court staff entrance	Opening force	13	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F02352	Justice Center		5th Floor	Owned	Courtroom	#503	3-Employee Common	Courtroom Station		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F02353	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Judge Bench		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F02354	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Witness Stand		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F02405	Justice Center		5th Floor	Owned	Courtroom	#503 - Room 506	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F02415	Justice Center		5th Floor	Owned	Courtroom	#503 - Room 507	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F02416	Justice Center		5th Floor	Owned	Courtroom	#503 - Room 507	2-Public Supervised	Door Gate		Closing speed	1	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F02471	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Seating Area	Spectator	Assistive listening systems?	None found - no sign	No	No Assistive Listening devices found and no instructional signage visible.	2-Services	Provide an assistive listening system and signage stating that an assistive listening system is provided.	1 sign and 4 ALS receivers	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F02472	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F02473	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Signage	Court staff entrance	Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F02474	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Court staff entrance	Clearance, push parallel	11	No	Clearance on push side of door is insufficient.	2-Services	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	12 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F02475	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Jury entrance	Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F02476	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Double door entrance	Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F02477	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Counter		Height	40	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F02482	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Seating Area	Spectator	Number, ALS receivers	None found - no sign	No	No Assistive Listening devices found and no instructional signage visible.	2-Services	Provide an assistive listening system and signage stating that an assistive listening system is provided.	1 sign and 4 ALS receivers	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F02483	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	2nd set in series	Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F02484	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Jury entrance	Opening force	11	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F02485	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Court staff entrance	Opening force	12	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F02486	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Double door entrance	Opening force	13	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F02487	Justice Center		5th Floor	Owned	Courtroom	#504	3-Employee Common	Courtroom Station		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F02488	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Judge Bench		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F02490	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Witness Stand		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F02579	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S505	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F02581	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S505	2-Public Supervised	Door Gate		Opening force	15	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F02600	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S507	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F02601	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S507	2-Public Supervised	Door Gate		Closing speed	0	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F02651	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Signage	Court staff entrance	Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F02652	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F02653	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Double door entrance	Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F02654	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F02655	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Jury entrance	Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F02656	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Counter		Height	40	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F02660	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	2nd set in series	Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F02661	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Double door entrance	Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F02662	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate		Opening force	13	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F02663	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Jury entrance	Opening force	15	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F02664	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Judge Bench		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F02762	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Courtroom Station		Clearance, perpendicular	47.5	No	Clear floor space is too short.	5-Tolerance	No action recommended - within construction tolerance.	48 inches minimum	2017	$ -	Within Tolerance (per Assessment)
F02763	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Counter		Height	40	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F02764	Justice Center		5th Floor	Owned	Courtroom	#507	3-Employee Common	Courtroom Station		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F02765	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Judge Bench		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F02795	Justice Center		5th Floor	Owned	Courtroom	#507 - Employee Entrance	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F02796	Justice Center		5th Floor	Owned	Courtroom	#507 - Employee Entrance	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F02797	Justice Center		5th Floor	Owned	Courtroom	#507 - Employee Entrance	3-Employee Common	Door Gate		Opening force	17	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F02811	Justice Center		5th Floor	Owned	Courtroom	#507 - Juror Entrance	2-Public Supervised	Door Gate		Opening force	12	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F02824	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S511	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F02841	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F02842	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate		Closing speed	3	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F02843	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate		Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F02844	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate	2nd set in series	Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F02870	Justice Center		6th Floor	Owned	Courtroom	#601	2-Public Supervised	Counter	Check-in	Height	40	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F02871	Justice Center		6th Floor	Owned	Courtroom	#601	2-Public Supervised	Witness Stand		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F02883	Justice Center		6th Floor	Owned	Courtroom	#602	2-Public Supervised	Seating Area	Spectator	Assistive listening systems?	None found - no sign	No	No Assistive Listening devices found and no instructional signage visible.	2-Services	Provide an assistive listening system and signage stating that an assistive listening system is provided.	1 sign and 4 ALS receivers	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F02884	Justice Center		6th Floor	Owned	Courtroom	#602	2-Public Supervised	Counter	Check-in	Height	40	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F02885	Justice Center		6th Floor	Owned	Courtroom	#602	2-Public Supervised	Judge Bench		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F02887	Justice Center		6th Floor	Owned	Courtroom	#602	2-Public Supervised	Witness Stand		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F02892	Justice Center		6th Floor	Owned	Courtroom	#603	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F02893	Justice Center		6th Floor	Owned	Courtroom	#603	2-Public Supervised	Witness Stand		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F02905	Justice Center		6th Floor	Owned	Courtroom	#604	2-Public Supervised	Seating Area	Spectator	Assistive listening systems?	None found - no sign	No	No Assistive Listening devices found and no instructional signage visible.	2-Services	Provide an assistive listening system and signage stating that an assistive listening system is provided.	1 sign and 4 ALS receivers	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F02906	Justice Center		6th Floor	Owned	Courtroom	#604	2-Public Supervised	Counter	Check-in	Height	39.75	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F02907	Justice Center		6th Floor	Owned	Courtroom	#604	2-Public Supervised	Judge Bench		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F02908	Justice Center		6th Floor	Owned	Courtroom	#604	2-Public Supervised	Witness Stand		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F02912	Justice Center		6th Floor	Owned	Courtroom	#605	2-Public Supervised	Signage		Location	No ALS sign	No	No signage provided.	2-Services	Install signage indicating that an assistive listening system is provided.		2016	$ 100.00	
F02913	Justice Center		6th Floor	Owned	Courtroom	#605	2-Public Supervised	Counter	Check-in	Height	40	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F02914	Justice Center		6th Floor	Owned	Courtroom	#605	2-Public Supervised	Witness Stand		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F02937	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Counter	Check-in	Height	40	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F02938	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Door Gate	Court staff entrance	Opening force	8	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F02939	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Door Gate		Opening force	8	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F02940	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Judge Bench		Ramp?	N	No	No accessible route provided.	2-Services	Install an accessible ramp or platform lift to provide a compliant access.		2017	$ -	Planned as part of Renovation in 2016/2017
F03170	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Hall Signal		Audible signal?	Single beep only	No	Elevator does not have compliant audible signals indicating elevators direction of travel.	2-Services	Change the audible signals to provide one beep for 'up' and two beeps for 'down'.		2017	$ 500.00	Planned as part of Renovation in 2016/2017
F03171	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Elevator Car		Dimension, gap	1.75	No	Platform to hoistway clearance is too wide.	2-Services	Adjust the gap between the platform sill and the edge of the hoistway landing.	1.25 inches maximum	2017	$ 500.00	Planned as part of Renovation in 2016/2017
F03172	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Car Controls		Height, emergency control	29.25	No	Emergency control is too low.	2-Services	Relocate the emergency control to provide centerline height of 35 inches.	35 inches	2017	$ 500.00	Planned as part of Renovation in 2016/2017
F03215	Justice Center		Interior	Owned	Elevator	#2 - Off main lobby	1-Public Unsupervised	Hall Signal		Audible signal?	Single beep only	No	Elevator does not have compliant audible signals indicating elevators direction of travel.	2-Services	Change the audible signals to provide one beep for 'up' and two beeps for 'down'.		2017	$ 500.00	Planned as part of Renovation in 2016/2017
F03216	Justice Center		Interior	Owned	Elevator	#2 - Off main lobby	1-Public Unsupervised	Elevator Car		Dimension, gap	1.75	No	Platform to hoistway clearance is too wide.	2-Services	Adjust the gap between the platform sill and the edge of the hoistway landing.	1.25 inches maximum	2017	$ 500.00	Planned as part of Renovation in 2016/2017
F03217	Justice Center		Interior	Owned	Elevator	#2 - Off main lobby	1-Public Unsupervised	Car Controls		Height, emergency control	29.25	No	Emergency control is too low.	2-Services	Relocate the emergency control to provide centerline height of 35 inches.	35 inches	2017	$ 500.00	Planned as part of Renovation in 2016/2017
F03219	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Hall Signal		Audible signal?	Single beep only	No	Elevator does not have compliant audible signals indicating elevators direction of travel.	2-Services	Change the audible signals to provide one beep for 'up' and two beeps for 'down'.		2017	$ 500.00	Planned as part of Renovation in 2016/2017
F03220	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Elevator Door		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F03257	Justice Center		Interior	Owned	Elevator	#4 - Off main lobby	1-Public Unsupervised	Hall Signal		Audible signal?	Single beep only	No	Elevator does not have compliant audible signals indicating elevators direction of travel.	2-Services	Change the audible signals to provide one beep for 'up' and two beeps for 'down'.		2017	$ 500.00	Planned as part of Renovation in 2016/2017
F03258	Justice Center		Interior	Owned	Elevator	#4 - Off main lobby	1-Public Unsupervised	Elevator Door		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F03261	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Elevator Car		Dimension, side to side	67.5	No	Elevator car is not wide enough.	5-Tolerance	No action recommended - within construction tolerance.	68 inches minimum	2017	$ -	Within Tolerance (per Assessment)
F03303	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Hoistway Sign		All floors?	None	No	Floor designation signs are not provided on either side of hoistway frame.	2-Services	Install a hoistway sign on both hoistway jams, with raised letters, Braille, and a tactile Star.		2017	$ 500.00	Planned as part of Renovation in 2016/2017
F03304	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Hoistway Sign		All floors?	None	No	Floor designation signs are not provided on either side of hoistway frame.	2-Services	Install a hoistway sign on both hoistway jams, with raised letters, Braille, and a tactile Star.		2017	$ 500.00	Planned as part of Renovation in 2016/2017
F03369	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Car Controls		Height, emergency control	32.5	No	Emergency control is too low.	2-Services	Relocate the emergency control to provide centerline height of 35 inches.	35 inches	2017	$ 500.00	Planned as part of Renovation in 2016/2017
F03827	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Signage	Conf Room A	Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F03828	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Signage	Conf Room B	Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F03829	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room B	Clearance, push parallel	18.5	No	Clearance on push side of door is insufficient.	2-Services	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	22 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F03830	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room A	Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F03831	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room B	Opening force	13	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F03832	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Signage	Conf Room A	Tactile letters?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F03858	Justice Center	CASA	Interior	Owned	Hallway	#152 - Office	1-Public Unsupervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F03859	Justice Center	CASA	Interior	Owned	Hallway	#152 - Office	1-Public Unsupervised	Door Gate		Clearance, pull parallel	15	No	Clearance on pull side of door is insufficient.	2-Services	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F03860	Justice Center	CASA	Interior	Owned	Hallway	#152 - Office	1-Public Unsupervised	Door Gate		Opening force	13	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F03861	Justice Center	CASA	Interior	Owned	Hallway	#152 - Office	1-Public Unsupervised	Signage	At entrance to hall	Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F03876	Justice Center	Self Help Resource Center	1st Floor	Owned	Hallway	Training Room	2-Public Supervised	Drinking Fountain	Between men's & women's restrooms	High-low fountain?	N	No	Fountain provided is not a hi/low fountain.	4-Other	No action recommended - this element has safe harbor.		2017		Planned as part of Renovation in 2016/2017
F03894	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F03895	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F03896	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Opening force	8	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F03897	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F03919	Justice Center		4th Floor	Owned	Hallway	#S412 - Back hall entrance	3-Employee Common	Door Gate		Opening force	8	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F03948	Justice Center		4th Floor	Owned	Hallway	#S437 - Back hall entrance	3-Employee Common	Door Gate		Opening force	8	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F03959	Justice Center		6th Floor	Owned	Hallway	Between restrooms	1-Public Unsupervised	Drinking Fountain		Control force	6	No	Operating force is greater than the maximum force allowed.	4-Other	Adjust the controls to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F03960	Justice Center		6th Floor	Owned	Hallway	Between restrooms	1-Public Unsupervised	Drinking Fountain		Dimension, knee clearance	26.75	No	Knee clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	27 inches	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F03961	Justice Center		6th Floor	Owned	Hallway	Between restrooms	1-Public Unsupervised	Protrusion	Drinking Fountain	Dimension, protruding	13.5	No	Object protrudes into the path of travel.	4-Other	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the fountain, recess the fountain into the wall, or install cane detection to prevent injury.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F03966	Justice Center		1st Floor	Owned	Hallway	Between rooms #108 & #109	1-Public Unsupervised	Drinking Fountain		High-low fountain?	N	No	Fountain provided is not a hi/low fountain.	4-Other	No action recommended - this element has safe harbor.		2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F03983	Justice Center		4th Floor	Owned	Hallway	Between rooms #410 & #411	1-Public Unsupervised	Protrusion	Drinking Fountain	Dimension, protruding	20	No	Object protrudes into the path of travel.	4-Other	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the fountain, recess the fountain into the wall, or install cane detection to prevent injury.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F03993	Justice Center		4th Floor	Owned	Hallway	Between rooms #454 & #455	1-Public Unsupervised	Protrusion	Drinking Fountain	Dimension, protruding	20	No	Object protrudes into the path of travel.	4-Other	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the fountain, recess the fountain into the wall, or install cane detection to prevent injury.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F04009	Justice Center		6th Floor	Owned	Hallway	Between rooms #616 & #617	1-Public Unsupervised	Protrusion	Drinking Fountain	Dimension, protruding	21	No	Object protrudes into the path of travel.	4-Other	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the fountain, recess the fountain into the wall, or install cane detection to prevent injury.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F04010	Justice Center		6th Floor	Owned	Hallway	Between rooms #616 & #617	1-Public Unsupervised	Drinking Fountain		Height, water flow	2	No	Water flow height is insufficient.	4-Other	Adjust the water flow on the drinking fountain.	4 inches minimum	2017	$ -	Internal Staff - Operations
F04016	Justice Center		6th Floor	Owned	Hallway	Between rooms #654 & #655	1-Public Unsupervised	Protrusion	Drinking Fountain	Dimension, protruding	19.5	No	Object protrudes into the path of travel.	4-Other	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the fountain, recess the fountain into the wall, or install cane detection to prevent injury.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F04017	Justice Center		6th Floor	Owned	Hallway	Between rooms #654 & #655	1-Public Unsupervised	Drinking Fountain		Height, water flow	1	No	Water flow height is insufficient.	4-Other	Adjust the water flow on the drinking fountain.	4 inches minimum	2016	$ -	Internal Staff - Operations
F04036	Justice Center		5th Floor	Owned	Hallway	Employee entrance	3-Employee Common	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F04037	Justice Center		5th Floor	Owned	Hallway	Employee entrance	3-Employee Common	Door Gate		Opening force	13	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F04048	Justice Center		Interior	Owned	Hallway		3-Employee Common	Drinking Fountain	Between rooms #111 & #112	Dimension, knee clearance	26.5	No	Knee clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	27 inches	2017	$ -	Within Tolerance (per Assessment)
F04049	Justice Center		Interior	Owned	Hallway		3-Employee Common	Protrusion	Drinking Fountain near restroom	Dimension, protruding	19	No	Object protrudes into the path of travel.	4-Other	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the fountain, recess the fountain into the wall, or install cane detection to prevent injury.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F04117	Justice Center		Interior	Owned	Holding Cell	Adult Female #4	2-Public Supervised	Lavatory Sink	Combination lav/toilet	Clearance, parallel	0	No	Clear floor space is too narrow.	3-Restrooms	Reconfigure the lavatory sink to provide at least the minimum clear floor space.	30 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F04118	Justice Center		Interior	Owned	Holding Cell	Adult Female #4	2-Public Supervised	Water Closet	Combination lav/toilet	Clearance, parallel	39	No	Clearance at water closet is too narrow.	3-Restrooms	Remodel the restroom to provide at least the minimum required width.	60 inches minimum	2017	$ 15,000.00	Planned as part of Renovation in 2016/2017
F04119	Justice Center		Interior	Owned	Holding Cell	Adult Female #4	2-Public Supervised	Lavatory Sink	Combination lav/toilet	Clearance, perpendicular	0	No	Clear floor space is too short.	3-Restrooms	Reconfigure the lavatory sink to provide at least the minimum clear floor space.	48 inches minimum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F04120	Justice Center		Interior	Owned	Holding Cell	Adult Female #4	2-Public Supervised	Water Closet	Combination lav/toilet	Control force	28	No	Operating force is greater than the maximum force allowed.	3-Restrooms	Adjust the control to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F04121	Justice Center		Interior	Owned	Holding Cell	Adult Female #4	2-Public Supervised	Lavatory Sink	Combination lav/toilet	Dimension, knee clearance	0	No	Knee clearance is too low.	3-Restrooms	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F04122	Justice Center		Interior	Owned	Holding Cell	Adult Female #4	2-Public Supervised	Water Closet	Combination lav/toilet	Dimension, sidewall	18.75	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F04123	Justice Center		Interior	Owned	Holding Cell	Adult Female #4	2-Public Supervised	Water Closet	Combination lav/toilet	Dimension, wide side	20	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F04124	Justice Center		Interior	Owned	Holding Cell	Adult Female #4	2-Public Supervised	Water Closet	Combination lav/toilet	Height, seat	14.75	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F04138	Justice Center		Interior	Owned	Holding Cell	Adult Male #1	2-Public Supervised	Water Closet		Clearance, parallel	39	No	Clearance at water closet is too narrow.	3-Restrooms	Remodel the restroom to provide at least the minimum required width.	60 inches minimum	2017	$ 15,000.00	Planned as part of Renovation in 2016/2017
F04139	Justice Center		Interior	Owned	Holding Cell	Adult Male #1	2-Public Supervised	Water Closet		Control force	25	No	Operating force is greater than the maximum force allowed.	3-Restrooms	Adjust the controls to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F04140	Justice Center		Interior	Owned	Holding Cell	Adult Male #1	2-Public Supervised	Water Closet		Dimension, wide side	18	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F04161	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Water Closet		Clearance, parallel	42	No	Clearance at water closet is too narrow.	3-Restrooms	Remodel the restroom to provide at least the minimum required width.	60 inches minimum	2017	$ 15,000.00	Planned as part of Renovation in 2016/2017
F04162	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Water Closet		Control force	18	No	Operating force is greater than the maximum force allowed.	3-Restrooms	Adjust the controls to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F04163	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Water Closet		Control force	32	No	Operating force is greater than the maximum force allowed.	3-Restrooms	Adjust the controls to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F04164	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Water Closet		Dimension, sidewall	20	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F04165	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Water Closet		Dimension, sidewall	23	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F04166	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Water Closet		Dimension, wide side	17	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F04167	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Water Closet		Dimension, wide side	16	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F04261	Justice Center	Self Help Resource Center	1st Floor	Owned	Kitchen	#159 - Training Room	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	2-Services	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F04262	Justice Center	Self Help Resource Center	1st Floor	Owned	Kitchen	#159 - Training Room	1-Public Unsupervised	Counter		Height	36.25	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F04263	Justice Center	Self Help Resource Center	1st Floor	Owned	Kitchen	#159 - Training Room	2-Public Supervised	Lavatory Sink		Height	36.5	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F04407	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception	Training Room	2-Public Supervised	Door Gate		Opening force	11	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F04423	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Height	42	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F04428	Justice Center		Interior	Owned	Lobby Reception	#605 - Juvenile Clerks Office	1-Public Unsupervised	Counter		Height	42	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F04429	Justice Center		Interior	Owned	Lobby Reception	#605 - Juvenile Clerks Office	1-Public Unsupervised	Public Phone		Height, operable part	62.5	No	Operable part is out of reach range.	2-Services	Lower the telephone to provide operable parts, within a compliant reach range.	36 to 48 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F04711	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Bench		Back support?	N	No	No back support provided on fixed bench seat.	3-Restrooms	Provide a bench with a back support that extends from a point 2 inches maximum above the seat surface to a point 18 inches minimum above the seat surface.		2017	$ 500.00	Planned as part of Renovation in 2016/2017
F04712	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F04713	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Bench		Depth	9.5	No	Bench is not deep enough.	3-Restrooms	Provide a bench with a seat that is a minimum of 20 inches deep and a maximum of 24 inches deep.	20 to 24 inches	2017	$ 500.00	Planned as part of Renovation in 2016/2017
F04714	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Coat Hook		Height	72.5	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2017	$ 150.00	Planned as part of Renovation in 2016/2017
F04715	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Door Gate		Opening force	8	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F04746	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Bench		Back support?	N	No	No back support provided on fixed bench seat.	3-Restrooms	Provide a bench with a back support that extends from a point 2 inches maximum above the seat surface to a point 18 inches minimum above the seat surface.		2017	$ 500.00	Planned as part of Renovation in 2016/2017
F04747	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F04748	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F04749	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Bench		Depth	9.5	No	Bench is not deep enough.	3-Restrooms	Provide a bench with a seat that is a minimum of 20 inches deep and a maximum of 24 inches deep.	20 to 24 inches	2017	$ 500.00	Planned as part of Renovation in 2016/2017
F04750	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Coat Hook		Height	70	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2017	$ 150.00	Planned as part of Renovation in 2016/2017
F04751	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Opening force	7	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F05100	Justice Center		5th Floor	Owned	Other Room	#501 - Room 516	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F05101	Justice Center		5th Floor	Owned	Other Room	#501 - Room 516	2-Public Supervised	Door Gate		Closing speed	1	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05120	Justice Center		5th Floor	Owned	Other Room	#501 - Room 517	2-Public Supervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F05121	Justice Center		5th Floor	Owned	Other Room	#501 - Room 517	2-Public Supervised	Door Gate		Closing speed	1	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F05144	Justice Center		5th Floor	Owned	Other Room	Domestic check-in	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F05145	Justice Center		5th Floor	Owned	Other Room	Domestic check-in	1-Public Unsupervised	Counter		Height	42	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F05146	Justice Center		5th Floor	Owned	Other Room	Domestic check-in	1-Public Unsupervised	Door Gate		Opening force	12	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F06617	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#3	Slope, cross	2.6%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06618	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#3	Slope, running	2.7%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06619	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#2	Slope, running	2.8%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06620	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#4	Slope, running	3.1%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking project
F06621	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Near curb ramp #11	Slope, running	3.4%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking project
F06622	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Row 2	Slope, running	3.9%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking project
F06623	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 1	Slope, running	2.1%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06624	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 2	Slope, running	2.6%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06625	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	Row 1 space #2	Slope, running	2.7%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06626	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#2 - Row 2	Slope, running	2.9%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06627	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 2	Slope, running	2.9%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06628	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	Row 1 space #1	Slope, running	3.2%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking project
F06629	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#5 - Row 2	Slope, running	3.2%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking project
F06630	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#1 - Row 2	Slope, running	3.6%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking project
F06734	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#3	Slope, cross	2.1%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06735	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 1	Slope, cross	2.1%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06736	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Row 2	Slope, running	2.3%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06737	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Row 1	Slope, running	2.7%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06738	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#3	Slope, running	2.8%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06739	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	Row 1 between spaces #2 & #3	Slope, running	3.5%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking project
F06740	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#4	Slope, running	4.3%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking project
F06741	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 2	Slope, running	2.1%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06742	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#5 - Row 1	Slope, running	2.2%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06743	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#1 - Row 2	Slope, running	2.8%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06744	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 1	Slope, running	3.0%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking project
F06745	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 2	Slope, running	3.0%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking project
F06746	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#1 - Row 1	Slope, running	3.1%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking project
F06747	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#5 - Row 2	Slope, running	3.1%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking project
F06748	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 1	Slope, running	3.2%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking project
F06749	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#2 - Row 2	Slope, running	3.2%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking project
F06750	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#2 - Row 1	Slope, running	3.7%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking project
F06751	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#6 - Row 2	Slope, running	4.1%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking project
F07448	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Door Gate		Clearance, pull parallel	Sink may intrude on pull clearance	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F11527	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Toilet Compartment		Clearance, parallel	59.5	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F11528	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Water Closet		Clearance, parallel	59.5	No	Clearance at water closet is too narrow.	5-Tolerance	No action recommended - within construction tolerance.	60 inches minimum	2017	$ -	Within Tolerance (per Assessment)
F11529	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F11530	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Water Closet		Control force	6	No	Operating force is greater than the maximum force allowed.	3-Restrooms	Adjust the controls to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F11531	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Toilet Compartment		Dimension, door to partition	5.5	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F11532	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Grab Bar	Side	Dimension, end to wall	10	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F11533	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Water Closet		Dimension, sidewall	18.25	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F11534	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F11535	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Coat Hook		Height	55.25	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2017	$ 150.00	Planned as part of Renovation in 2016/2017
F11536	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Lavatory Sink		Height	34.25	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	2017	$ -	Within Tolerance (per Assessment)
F11537	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Door Gate		Opening force	10	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11538	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F11599	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	1-Public Unsupervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F11600	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Water Closet		Clearance, parallel	59.5	No	Clearance at water closet is too narrow.	5-Tolerance	No action recommended - within construction tolerance.	60 inches minimum	2017	$ -	Within Tolerance (per Assessment)
F11601	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Water Closet		Control force	6	No	Operating force is greater than the maximum force allowed.	3-Restrooms	Adjust the controls to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F11602	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Toilet Compartment		Dimension, door to partition	4.75	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F11603	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	10	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F11604	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Water Closet		Dimension, sidewall	18.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F11605	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F11606	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Coat Hook		Height	55.25	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2017	$ 150.00	Planned as part of Renovation in 2016/2017
F11608	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Door Gate		Opening force	11	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F11609	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F11676	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F11677	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Door Gate		Clearance, push parallel	19	No	Clearance on push side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	12 inches minimum	2017	$ 350.00	Planned as part of Renovation in 2016/2017
F11678	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F11679	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Urinal		Control force	7	No	Operating force is greater than the maximum force allowed.	3-Restrooms	Adjust the controls to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F11680	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	6.5	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F11681	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	7	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F11682	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	10	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F11683	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Water Closet		Dimension, sidewall	19	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F11684	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Water Closet		Dimension, wide side	19.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F11685	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Coat Hook		Height	55	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2017	$ 150.00	Planned as part of Renovation in 2016/2017
F11686	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Lavatory Sink		Height	34.5	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	2017	$ -	Within Tolerance (per Assessment)
F11687	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Lavatory Sink		Height	34.25	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	2017	$ -	Within Tolerance (per Assessment)
F11688	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Changing Station		Height	38	No	Work surface does not comply with height requirements.	3-Restrooms	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11689	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Mirror		Height, bottom	41	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F11691	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Grab Bar	Rear	Length	24	No	Rear grab bar is too short.	3-Restrooms	Replace the grab bar with a 36 inch long minimum grab bar.	36 inches minimum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F11692	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Door Gate		Opening force	10	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F11693	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F11761	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F11762	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Toilet Compartment	Inaccessible	Clear opening	24.5	No	Clear opening is too narrow.	3-Restrooms	Reframe the doorway to provide a compliant clear opening width. Offset hinges may be used to facilitate the process.	32 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F11763	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Toilet Compartment	Inaccessible	Clearance, parallel	32.75	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F11764	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Toilet Compartment	Inaccessible	Clearance, perpendicular	58	No	Toilet compartment is not deep enough.	3-Restrooms	Reconfigure the stall to provide a minimum of 59 inches in depth.	59 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F11765	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Lavatory Sink		Dimension, knee clearance	24.5	No	Knee clearance is too low.	3-Restrooms	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F11766	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Water Closet		Dimension, wide side	16.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F11767	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F11768	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Toilet Compartment	Inaccessible	Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F11769	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Coat Hook		Height	67	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2017	$ 150.00	Planned as part of Renovation in 2016/2017
F11770	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Dispenser	Soap	Height	50.5	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 100.00	Planned as part of Renovation in 2016/2017
F11771	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Water Closet		Height, seat	16.5	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F11772	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Signage		Location	H	No	Sign is not mounted in the correct location.	3-Restrooms	Move the sign to the latch side of the door.		2016	$ 100.00	
F11773	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Fixture Count		Number, accessible compartments	0	No	No accessible toilet compartment in restroom.	3-Restrooms	Rebuild or reconfigure the restroom, with a wheelchair accessible toilet compartment.	1 minimum	2017	$ 15,000.00	Planned as part of Renovation in 2016/2017
F11774	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Door Gate		Opening force	12	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F11775	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Grab Bar		Other attribute	None Provided	No	No grab bars provided.	3-Restrooms	Install grab bars on the rear and side wall.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F11776	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Toilet Compartment	Inaccessible	Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F11777	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Signage		Tactile letters?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F11807	Justice Center		2nd Floor	Owned	Restroom	Men's - #224	1-Public Unsupervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F11808	Justice Center		2nd Floor	Owned	Restroom	Men's - #224	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F11810	Justice Center		2nd Floor	Owned	Restroom	Men's - #224	1-Public Unsupervised	Door Gate		Opening force	12	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F11812	Justice Center		2nd Floor	Owned	Restroom	Men's - #224	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4.25	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F11813	Justice Center		2nd Floor	Owned	Restroom	Men's - #224	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F11814	Justice Center		2nd Floor	Owned	Restroom	Men's - #224	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F11834	Justice Center		3rd Floor	Owned	Restroom	Men's - #354	1-Public Unsupervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F11847	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Door Gate		Closing speed	3	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11848	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4.25	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F11849	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	10	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F11850	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F11851	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Coat Hook		Height	56	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2017	$ 150.00	Planned as part of Renovation in 2016/2017
F11852	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Lavatory Sink		Height	34.25	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	2017	$ -	Within Tolerance (per Assessment)
F11853	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Grab Bar	Rear	Height, top	37.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F11855	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Door Gate		Opening force	8	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F11856	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F11912	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F11913	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	58.5	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F11914	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F11915	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4.5	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F11916	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	10	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F11917	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Water Closet		Dimension, sidewall	19	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F11918	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Water Closet		Dimension, wide side	40.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F11919	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F11920	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Coat Hook		Height	55.5	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2017	$ 150.00	Planned as part of Renovation in 2016/2017
F11921	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Changing Station		Height	39	No	Work surface does not comply with height requirements.	3-Restrooms	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F11923	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Door Gate		Opening force	10	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F11924	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F11979	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F11980	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4.5	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F11981	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	10	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F11982	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F11984	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Door Gate		Opening force	14	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11985	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F12043	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Door Gate		Closing speed	3	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F12044	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4.75	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F12045	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	10	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12046	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12047	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Lavatory Sink		Height	34.25	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	2017	$ -	Within Tolerance (per Assessment)
F12048	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Door Gate		Opening force	8	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F12049	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F12083	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4.75	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F12084	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	10	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12085	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Water Closet		Dimension, sidewall	20.75	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F12086	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12087	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Coat Hook		Height	55.5	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2017	$ 150.00	Planned as part of Renovation in 2016/2017
F12088	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Lavatory Sink		Height	34.25	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	2017	$ -	Within Tolerance (per Assessment)
F12089	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Changing Station		Height	39	No	Work surface does not comply with height requirements.	3-Restrooms	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F12090	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Door Gate		Opening force	9	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F12091	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F12136	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F12138	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4.5	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F12139	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	9	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12140	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	26.75	No	Knee clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	27 inches	2017	$ -	Within Tolerance (per Assessment)
F12141	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Water Closet		Dimension, sidewall	21.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F12142	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		2017	$ 500.00	Planned as part of Renovation in 2016/2017
F12143	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Door Gate		Opening force	9	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F12144	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12219	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F12220	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F12221	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4.25	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12222	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	11.5	No	Grab bar is not mounted in correct location.	5-Tolerance	No action recommended - within construction tolerance.	12 inches maximum	2017	$ -	Within Tolerance (per Assessment)
F12223	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	5.5	No	Grab bar is not mounted in correct location.	5-Tolerance	No action recommended - within construction tolerance.	6 inches	2017	$ -	Within Tolerance (per Assessment)
F12224	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12225	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Door Gate		Opening force	13	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F12226	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F12300	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F12301	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	50	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F12302	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Water Closet		Clearance, parallel	53.5	No	Clearance at water closet is too narrow.	3-Restrooms	Remodel the restroom to provide at least the minimum required width.	60 inches minimum	2017	$ 15,000.00	Planned as part of Renovation in 2016/2017
F12303	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F12304	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12305	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Urinal		Height, rim	17.75	No	Urinal rim is too high.	3-Restrooms	Where multiple urinals are installed, replace or remount at least one urinal to the correct height.	17 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F12306	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Door Gate		Opening force	15	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F12307	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F12386	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F12387	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	5.5	No	Grab bar is not mounted in correct location.	5-Tolerance	No action recommended - within construction tolerance.	6 inches	2017	$ -	Within Tolerance (per Assessment)
F12388	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12389	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Door Gate		Opening force	10	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F12390	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F12445	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F12446	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	59	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F12447	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Water Closet		Clearance, parallel	59.5	No	Clearance at water closet is too narrow.	5-Tolerance	No action recommended - within construction tolerance.	60 inches minimum	2017	$ -	Within Tolerance (per Assessment)
F12448	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	10	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12449	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Water Closet		Dimension, sidewall	19	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F12450	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12451	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Coat Hook		Height	64	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2017	$ 150.00	Planned as part of Renovation in 2016/2017
F12452	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Lavatory Sink		Height	34.5	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	2017	$ -	Within Tolerance (per Assessment)

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F12453	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Changing Station		Height	38	No	Work surface does not comply with height requirements.	3-Restrooms	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F12454	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Door Gate		Opening force	11	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F12455	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F12530	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F12531	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Water Closet		Clearance, parallel	56.5	No	Clearance at water closet is too narrow.	3-Restrooms	Remodel the restroom to provide at least the minimum required width.	60 inches minimum	2017	$ 15,000.00	Planned as part of Renovation in 2016/2017
F12532	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	7.25	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12533	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Water Closet		Dimension, sidewall	19	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F12534	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Water Closet		Dimension, wide side	37.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F12535	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Water Closet		Height, seat	19.25	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12588	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Clearance, pull parallel	13.5	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F12589	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Dimension, knee clearance	26.5	No	Knee clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	27 inches	2017	$ -	Within Tolerance (per Assessment)
F12649	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F12650	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Water Closet		Control force	8	No	Operating force is greater than the maximum force allowed.	3-Restrooms	Adjust the controls to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F12651	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Grab Bar	Side	Dimension, end to wall	10	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12652	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Water Closet		Dimension, wide side	22.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F12653	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F12654	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Coat Hook		Height	67.25	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2017	$ 150.00	Planned as part of Renovation in 2016/2017
F12655	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Lavatory Sink		Height	34.75	No	Lavatory sink is too high.	3-Restrooms	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F12656	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Mirror		Height, bottom	40.75	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12657	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Grab Bar	Rear	Length	24	No	Rear grab bar is too short.	3-Restrooms	Replace the grab bar with a 36 inch long minimum grab bar.	36 inches minimum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12692	Justice Center		3rd Floor	Owned	Restroom	Unisex - #302	3-Employee Common	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F12694	Justice Center		3rd Floor	Owned	Restroom	Unisex - #303	3-Employee Common	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F12711	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F12712	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Door Gate		Clearance, pull parallel	3	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F12713	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Grab Bar	Side	Dimension, end to wall	10	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12714	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Lavatory Sink		Dimension, knee clearance	25	No	Knee clearance is too low.	3-Restrooms	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F12715	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Water Closet		Dimension, sidewall	19	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F12716	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Water Closet		Dimension, sidewall	18.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F12717	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Water Closet		Dimension, wide side	23	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F12718	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Water Closet		Dimension, wide side	22.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F12719	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F12720	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F12721	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Lavatory Sink		Height	34.5	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	2017	$ -	Within Tolerance (per Assessment)
F12722	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Mirror		Height, bottom	43.5	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12723	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Mirror		Height, bottom	43	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12724	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Water Closet		Height, seat	16.25	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2017	$ 205.00	Planned as part of Renovation in 2016/2017
F12726	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Grab Bar	Rear	Length	24	No	Rear grab bar is too short.	3-Restrooms	Replace the grab bar with a 36 inch long minimum grab bar.	36 inches minimum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12727	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Grab Bar		Other attribute	None Provided	No	No grab bars provided.	3-Restrooms	Install grab bars on the rear and side wall.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12792	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F12793	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Water Closet		Clearance, parallel	38	No	Clearance at water closet is too narrow.	3-Restrooms	Remodel the restroom to provide at least the minimum required width.	60 inches minimum	2017	$ 15,000.00	Planned as part of Renovation in 2016/2017
F12794	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Door Gate		Clearance, pull parallel	9	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F12795	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Grab Bar	Side	Dimension, end to wall	10	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12796	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Water Closet		Dimension, sidewall	20	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F12797	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Water Closet		Dimension, wide side	22	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F12798	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Mirror		Height, bottom	44	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12799	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Grab Bar	Rear	Length	24	No	Rear grab bar is too short.	3-Restrooms	Replace the grab bar with a 36 inch long minimum grab bar.	36 inches minimum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12841	Justice Center		6th Floor	Owned	Restroom	Unisex - #603	3-Employee Common	Door Gate		Clearance, pull parallel	1.5	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F12842	Justice Center		6th Floor	Owned	Restroom	Unisex - #603	3-Employee Common	Lavatory Sink		Dimension, knee clearance	25	No	Knee clearance is too low.	3-Restrooms	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F12843	Justice Center		6th Floor	Owned	Restroom	Unisex - #603	3-Employee Common	Water Closet		Dimension, sidewall	19.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F12844	Justice Center		6th Floor	Owned	Restroom	Unisex - #603	3-Employee Common	Water Closet		Dimension, wide side	22.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F12845	Justice Center		6th Floor	Owned	Restroom	Unisex - #603	3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F12846	Justice Center		6th Floor	Owned	Restroom	Unisex - #603	3-Employee Common	Mirror		Height, bottom	44	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12847	Justice Center		6th Floor	Owned	Restroom	Unisex - #603	3-Employee Common	Water Closet		Height, seat	16	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12848	Justice Center		6th Floor	Owned	Restroom	Unisex - #603	3-Employee Common	Water Closet		Other attribute	None	No	Curb ramp accumulates water.	3-Restrooms	Remodel the restroom to provide at least one accessible toilet compartment.		2017	$ 15,000.00	Planned as part of Renovation in 2016/2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F12860	Justice Center		6th Floor	Owned	Restroom	Unisex - #604	3-Employee Common	Grab Bar	Side	Dimension, end to wall	10	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12861	Justice Center		6th Floor	Owned	Restroom	Unisex - #604	3-Employee Common	Water Closet		Dimension, sidewall	19.25	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F12862	Justice Center		6th Floor	Owned	Restroom	Unisex - #604	3-Employee Common	Water Closet		Dimension, wide side	22.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F12863	Justice Center		6th Floor	Owned	Restroom	Unisex - #604	3-Employee Common	Lavatory Sink		Height	34.5	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	2017	$ -	Within Tolerance (per Assessment)
F12864	Justice Center		6th Floor	Owned	Restroom	Unisex - #604	3-Employee Common	Mirror		Height, bottom	44.5	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12865	Justice Center		6th Floor	Owned	Restroom	Unisex - #604	3-Employee Common	Grab Bar	Rear	Length	24	No	Rear grab bar is too short.	3-Restrooms	Replace the grab bar with a 36 inch long minimum grab bar.	36 inches minimum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12895	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F12896	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Door Gate		Clearance, pull parallel	12	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F12945	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Door Gate		Clearance, pull parallel	13	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F12946	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	6.25	No	Grab bar is not mounted in correct location.	5-Tolerance	No action recommended - within construction tolerance.	6 inches	2017	$ -	Within Tolerance (per Assessment)
F12982	Justice Center		Interior	Owned	Restroom	Unisex - Holding cells	2-Public Supervised	Grab Bar	Side	Dimension, end to wall	11	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12983	Justice Center		Interior	Owned	Restroom	Unisex - Holding cells	2-Public Supervised	Mirror		Height, bottom	52	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12984	Justice Center		Interior	Owned	Restroom	Unisex - Holding cells	2-Public Supervised	Grab Bar	Rear	Length	24	No	Rear grab bar is too short.	3-Restrooms	Replace the grab bar with a 36 inch long minimum grab bar.	36 inches minimum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F12999	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	25	No	Knee clearance is too low.	3-Restrooms	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F13000	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	2-Public Supervised	Water Closet		Dimension, sidewall	15.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F13001	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	2-Public Supervised	Water Closet		Dimension, wide side	18	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F13002	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F13003	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Mirror		Height, bottom	44.5	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13004	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	2-Public Supervised	Water Closet		Height, seat	15.75	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13005	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	2-Public Supervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		2017	$ 500.00	Planned as part of Renovation in 2016/2017
F13006	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	2-Public Supervised	Grab Bar		Other attribute	None Provided	No	No grab bars provided.	3-Restrooms	Install grab bars on the rear and side wall.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13027	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 239	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	25	No	Knee clearance is too low.	3-Restrooms	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F13028	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 239	2-Public Supervised	Water Closet		Dimension, sidewall	15.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F13029	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 239	2-Public Supervised	Water Closet		Dimension, wide side	18	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F13030	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 239	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F13031	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 239	2-Public Supervised	Mirror		Height, bottom	44.5	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13032	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 239	2-Public Supervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		2017	$ 500.00	Planned as part of Renovation in 2016/2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13033	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 239	1-Public Unsupervised	Grab Bar		Other attribute	None Provided	No	No grab bars provided.	3-Restrooms	Install grab bars on the rear and side wall.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13035	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 325	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	25	No	Knee clearance is too low.	3-Restrooms	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F13036	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 325	2-Public Supervised	Water Closet		Dimension, wide side	18.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F13037	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 325	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F13038	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 325	2-Public Supervised	Mirror		Height, bottom	45	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13039	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 325	2-Public Supervised	Mirror		Height, bottom	45	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13040	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 325	2-Public Supervised	Water Closet		Height, seat	16	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13041	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 325	2-Public Supervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		2017	$ 500.00	Planned as part of Renovation in 2016/2017
F13042	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 325	2-Public Supervised	Grab Bar		Other attribute	None Provided	No	No grab bars provided.	3-Restrooms	Install grab bars on the rear and side wall.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13043	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 329	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	25	No	Knee clearance is too low.	3-Restrooms	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F13044	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 329	2-Public Supervised	Water Closet		Dimension, sidewall	15.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F13045	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 329	2-Public Supervised	Water Closet		Dimension, wide side	16	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F13046	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 329	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F13047	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 329	2-Public Supervised	Mirror		Height, bottom	44.5	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13048	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 329	2-Public Supervised	Water Closet		Height, seat	15.75	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13049	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 329	2-Public Supervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		2017	$ 500.00	Planned as part of Renovation in 2016/2017
F13050	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 329	2-Public Supervised	Grab Bar		Other attribute	None Provided	No	No grab bars provided.	3-Restrooms	Install grab bars on the rear and side wall.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13051	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 364	2-Public Supervised	Signage		Braille?	N	No	Signage does not provide Braille.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F13052	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 364	2-Public Supervised	Door Gate		Clearance, pull parallel	5.5	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F13053	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 364	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	25	No	Knee clearance is too low.	3-Restrooms	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F13054	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 364	2-Public Supervised	Water Closet		Dimension, sidewall	15.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F13055	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 364	2-Public Supervised	Water Closet		Dimension, wide side	19	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F13056	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 364	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F13057	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 364	2-Public Supervised	Mirror		Height, bottom	43.5	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13058	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 364	2-Public Supervised	Water Closet		Height, seat	16	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13059	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 364	2-Public Supervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		2017	$ 500.00	Planned as part of Renovation in 2016/2017
F13060	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 364	2-Public Supervised	Grab Bar		Other attribute	None Provided	No	No grab bars provided.	3-Restrooms	Install grab bars on the rear and side wall.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13061	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 369	2-Public Supervised	Grab Bar	Side	Dimension, end to wall	18	No	Side wall grab bar is located too far away from the back wall.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13062	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 369	2-Public Supervised	Water Closet		Dimension, wide side	20	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F13063	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 369	2-Public Supervised	Lavatory Sink		Height	34.5	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	2017	$ -	Within Tolerance (per Assessment)
F13064	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 369	2-Public Supervised	Mirror		Height, bottom	43.5	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13065	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 369	2-Public Supervised	Grab Bar	Rear	Length	24	No	Rear grab bar is too short.	3-Restrooms	Replace the grab bar with a 36 inch long minimum grab bar.	36 inches minimum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13066	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 369	2-Public Supervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		2017	$ 500.00	Planned as part of Renovation in 2016/2017
F13076	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	25	No	Knee clearance is too low.	3-Restrooms	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F13077	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Water Closet		Dimension, wide side	18.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F13078	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F13079	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Mirror		Height, bottom	45	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13080	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Mirror		Height, bottom	45	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13081	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Water Closet		Height, seat	16	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13082	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		2017	$ 500.00	Planned as part of Renovation in 2016/2017
F13083	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Grab Bar		Other attribute	None Provided	No	No grab bars provided.	3-Restrooms	Install grab bars on the rear and side wall.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13105	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 425	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	25	No	Knee clearance is too low.	3-Restrooms	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F13106	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 425	2-Public Supervised	Water Closet		Dimension, wide side	16	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F13107	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 425	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F13108	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 425	2-Public Supervised	Mirror		Height	43.5	No	The mirror is mounted too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13109	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 425	2-Public Supervised	Water Closet		Height, seat	15.75	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13110	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 425	2-Public Supervised	Grab Bar		Other attribute	None Provided	No	No grab bars provided.	3-Restrooms	Install grab bars on the rear and side wall.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13132	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Signage		Braille?	N	No	Signage does not provide Braille.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F13133	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Door Gate		Clearance, pull parallel	5.5	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F13134	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	25	No	Knee clearance is too low.	3-Restrooms	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F13135	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Water Closet		Dimension, sidewall	15.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F13136	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Water Closet		Dimension, wide side	19	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F13137	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F13138	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Mirror		Height, bottom	43.5	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13139	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Water Closet		Height, seat	16	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13140	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		2017	$ 500.00	Planned as part of Renovation in 2016/2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13141	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Grab Bar		Other attribute	None Provided	No	No grab bars provided.	3-Restrooms	Install grab bars on the rear and side wall.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13166	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Grab Bar	Side	Dimension, end to wall	18	No	Side wall grab bar is located too far away from the back wall.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13167	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Water Closet		Dimension, wide side	20	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F13168	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Lavatory Sink		Height	34.5	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	2017	$ -	Within Tolerance (per Assessment)
F13169	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Mirror		Height, bottom	43.5	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13170	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Grab Bar	Rear	Length	24	No	Rear grab bar is too short.	3-Restrooms	Replace the grab bar with a 36 inch long minimum grab bar.	36 inches minimum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13171	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		2017	$ 500.00	Planned as part of Renovation in 2016/2017
F13205	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 524	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	26	No	Knee clearance is too low.	3-Restrooms	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F13206	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 524	1-Public Unsupervised	Water Closet		Dimension, sidewall	15.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F13207	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 524	1-Public Unsupervised	Water Closet		Dimension, wide side	18	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F13208	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 524	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F13209	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 524	1-Public Unsupervised	Dispenser	Toilet seat covers	Height	49	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13210	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 524	1-Public Unsupervised	Mirror		Height, bottom	44	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13211	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 524	1-Public Unsupervised	Water Closet		Height, seat	16	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13212	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 524	1-Public Unsupervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		2017	$ 500.00	Planned as part of Renovation in 2016/2017
F13232	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Water Closet		Clearance, parallel	55	No	Clearance at water closet is too narrow.	3-Restrooms	Remodel the restroom to provide at least the minimum required width.	60 inches minimum	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F13233	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Grab Bar	Side	Dimension, end to wall	10	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13234	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Water Closet		Dimension, wide side	19	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F13235	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Mirror		Height, bottom	44.5	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13236	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Grab Bar	Rear	Length	24	No	Rear grab bar is too short.	3-Restrooms	Replace the grab bar with a 36 inch long minimum grab bar.	36 inches minimum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13266	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 627	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	10	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13267	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 627	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	25.5	No	Knee clearance is too low.	3-Restrooms	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F13268	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 627	1-Public Unsupervised	Water Closet		Dimension, sidewall	15	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F13269	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 627	1-Public Unsupervised	Water Closet		Dimension, wide side	18	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F13270	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 627	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F13271	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 627	1-Public Unsupervised	Dispenser	Soap	Height	51	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13272	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 627	1-Public Unsupervised	Dispenser	PT	Height	54.5	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13273	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 627	1-Public Unsupervised	Mirror		Height, bottom	44.5	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13274	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 627	1-Public Unsupervised	Water Closet		Height, seat	16	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13275	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 627	1-Public Unsupervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		2017	$ 500.00	Planned as part of Renovation in 2016/2017
F13276	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 627	1-Public Unsupervised	Fixture Count		Number, accessible compartments	0	No	No accessible toilet compartment in restroom.	3-Restrooms	Rebuild or reconfigure the restroom, with a wheelchair accessible toilet compartment.	1 minimum	2017	$ 15,000.00	Planned as part of Renovation in 2016/2017
F13287	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 631	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	25	No	Knee clearance is too low.	3-Restrooms	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F13288	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 631	1-Public Unsupervised	Water Closet		Dimension, sidewall	15	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F13289	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 631	1-Public Unsupervised	Water Closet		Dimension, wide side	16	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F13290	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 631	2-Public Supervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F13291	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 631	1-Public Unsupervised	Mirror		Height, bottom	44	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13292	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 631	1-Public Unsupervised	Water Closet		Height, seat	16	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13293	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 631	1-Public Unsupervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		2017	$ 500.00	Planned as part of Renovation in 2016/2017
F13294	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 631	1-Public Unsupervised	Fixture Count		Number, accessible compartments	0	No	No accessible toilet compartment in restroom.	3-Restrooms	Rebuild or reconfigure the restroom, with a wheelchair accessible toilet compartment.	1 minimum	2017	$ 15,000.00	Planned as part of Renovation in 2016/2017
F13318	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Door Gate		Clearance, pull parallel	11	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F13319	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	5.5	No	Grab bar is not mounted in correct location.	5-Tolerance	No action recommended - within construction tolerance.	6 inches	2017	$ -	Within Tolerance (per Assessment)
F13380	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Water Closet		Clearance, perpendicular	45	No	Toilet compartment is not deep enough.	3-Restrooms	Reconfigure the stall to provide a minimum of 56 inches in depth.	56 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F13381	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Water Closet		Clearance, perpendicular	44.5	No	Toilet compartment is not deep enough.	3-Restrooms	Reconfigure the stall to provide a minimum of 56 inches in depth.	56 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F13382	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Closing speed	0	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F13383	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	26.75	No	Knee clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	27 inches	2017	$ -	Within Tolerance (per Assessment)
F13384	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Water Closet		Dimension, sidewall	18.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F13385	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Water Closet		Dimension, sidewall	18.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F13475	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	5.5	No	Grab bar is not mounted in correct location.	5-Tolerance	No action recommended - within construction tolerance.	6 inches	2017	$ -	Within Tolerance (per Assessment)
F13476	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Water Closet		Dimension, wide side	41	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13503	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #1	2-Public Supervised	Grab Bar	Side	Dimension, end to wall	13	No	Side wall grab bar is located too far away from the back wall.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13504	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #1	2-Public Supervised	Grab Bar	Rear	Dimension, end to wall	7.5	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13505	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #1	2-Public Supervised	Grab Bar	Rear	Length	24	No	Rear grab bar is too short.	3-Restrooms	Replace the grab bar with a 36 inch long minimum grab bar.	36 inches minimum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13515	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #2	2-Public Supervised	Dispenser	TP	Dimension from water closet seat	13	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13516	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #2	2-Public Supervised	Dispenser	TP	Dimension from water closet seat	13	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13517	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #2	2-Public Supervised	Grab Bar	Side	Dimension, end to wall	13	No	Side wall grab bar is located too far away from the back wall.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13518	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #2	2-Public Supervised	Grab Bar	Rear	Dimension, end to wall	7	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13519	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #2	2-Public Supervised	Grab Bar	Rear	Length	24	No	Rear grab bar is too short.	3-Restrooms	Replace the grab bar with a 36 inch long minimum grab bar.	36 inches minimum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13534	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F13535	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Lavatory Sink		Clearance, perpendicular	43	No	Clear floor space is too short.	3-Restrooms	Reconfigure the lavatory sink to provide at least the minimum clear floor space.	48 inches minimum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F13536	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Door Gate		Clearance, pull parallel	2.5	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F13537	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Lavatory Sink		Dimension, knee clearance	25	No	Knee clearance is too low.	3-Restrooms	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F13538	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Water Closet		Dimension, wide side	22.25	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F13539	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F13540	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Coat Hook		Height	67	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2017	$ 150.00	Planned as part of Renovation in 2016/2017
F13541	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Mirror		Height, bottom	43.25	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13542	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Water Closet		Height, seat	16	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13583	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F13584	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Toilet Compartment	With sink	Clearance, parallel	58	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F13585	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Water Closet		Clearance, parallel	59.5	No	Clearance at water closet is too narrow.	5-Tolerance	No action recommended - within construction tolerance.	60 inches minimum	2017	$ -	Within Tolerance (per Assessment)
F13586	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Toilet Compartment	With sink	Dimension, door to partition	5.75	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F13587	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	7	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13588	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	10	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13589	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Water Closet		Dimension, sidewall	18.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F13590	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Water Closet		Dimension, wide side	20	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F13591	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Toilet Compartment	With sink	Hardware type	Twist	No	Hardware requires twisting of wrist.	3-Restrooms	Install lever type door hardware.		2017	$ 500.00	Planned as part of Renovation in 2016/2017
F13592	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Coat Hook		Height	65.75	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2017	$ 150.00	Planned as part of Renovation in 2016/2017
F13593	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Lavatory Sink		Height	34.5	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	2017	$ -	Within Tolerance (per Assessment)
F13594	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Changing Station		Height	39	No	Work surface does not comply with height requirements.	3-Restrooms	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F13595	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Mirror	In toilet compartment	Height, bottom	40.75	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13597	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Grab Bar	Rear	Length	24	No	Rear grab bar is too short.	3-Restrooms	Replace the grab bar with a 36 inch long minimum grab bar.	36 inches minimum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13598	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Door Gate		Opening force	13	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13599	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Toilet Compartment	With sink	Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F13663	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F13664	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Water Closet		Clearance, parallel	36	No	Clearance at water closet is too narrow.	3-Restrooms	Remodel the restroom to provide at least the minimum required width.	60 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F13665	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Door Gate		Closing speed	3	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F13666	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Dispenser	TP	Dimension from water closet seat	4.5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13667	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Lavatory Sink		Dimension, knee clearance	25	No	Knee clearance is too low.	3-Restrooms	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F13668	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Water Closet		Dimension, wide side	19.25	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F13669	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F13670	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Water Closet		Height, seat	16.5	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13672	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Signage		Location	H	No	Sign is not mounted in the correct location.	3-Restrooms	Move the sign to the latch side of the door.		2016	$ 100.00	
F13673	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Fixture Count		Number, accessible compartments	0	No	No accessible toilet compartment in restroom.	3-Restrooms	Rebuild or reconfigure the restroom, with a wheelchair accessible toilet compartment.	1 minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F13674	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Door Gate		Opening force	16	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F13698	Justice Center		2nd Floor	Owned	Restroom	Women's - #225	1-Public Unsupervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F13700	Justice Center		2nd Floor	Owned	Restroom	Women's - #225	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4.25	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F13701	Justice Center		2nd Floor	Owned	Restroom	Women's - #225	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13702	Justice Center		2nd Floor	Owned	Restroom	Women's - #225	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F13703	Justice Center		3rd Floor	Owned	Restroom	Women's - #314	1-Public Unsupervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F13709	Justice Center		3rd Floor	Owned	Restroom	Women's - #355	1-Public Unsupervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F13716	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F13717	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4.25	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F13718	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	10	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13719	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Water Closet		Dimension, sidewall	18.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F13720	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13721	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Lavatory Sink		Height	34.25	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	2017	$ -	Within Tolerance (per Assessment)
F13723	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F13774	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F13775	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Door Gate		Clearance, pull parallel	17	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13776	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4.5	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F13777	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	10	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13778	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Water Closet		Dimension, sidewall	18.75	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F13779	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Water Closet		Dimension, wide side	41.25	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F13780	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13781	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Toilet Compartment		Hardware type	Twist	No	Hardware requires twisting of wrist.	3-Restrooms	Install lever type door hardware.		2017	$ 500.00	Planned as part of Renovation in 2016/2017
F13782	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Lavatory Sink		Height	34.5	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	2017	$ -	Within Tolerance (per Assessment)
F13783	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Changing Station		Height	39	No	Work surface does not comply with height requirements.	3-Restrooms	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F13785	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Door Gate		Opening force	10	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F13786	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F13844	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F13845	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Water Closet		Clearance, parallel	55.5	No	Clearance at water closet is too narrow.	3-Restrooms	Remodel the restroom to provide at least the minimum required width.	60 inches minimum	2017	$ 7,500.00	Planned as part of Renovation in 2016/2017
F13846	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	29	No	Clearance on push side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	48 inches minimum	2017	$ 3,500.00	Planned as part of Renovation in 2016/2017
F13847	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F13848	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4.25	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F13849	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13850	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Door Gate		Opening force	10	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F13851	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F13917	Justice Center		5th Floor	Owned	Restroom	Women's - #514	1-Public Unsupervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F13918	Justice Center		5th Floor	Owned	Restroom	Women's - #514	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F13920	Justice Center		5th Floor	Owned	Restroom	Women's - #514	1-Public Unsupervised	Door Gate		Opening force	13	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F13952	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F13953	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Dispenser	PT	Clearance, perpendicular	35	No	Clear floor space is too short.	3-Restrooms	Relocate the dispenser to a location with compliant clear floor space.	48 inches minimum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13954	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F13955	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	10	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13956	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Water Closet		Dimension, sidewall	19	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F13957	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F13958	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Coat Hook		Height	56	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2017	$ 150.00	Planned as part of Renovation in 2016/2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13959	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Lavatory Sink		Height	34.25	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	2017	$ -	Within Tolerance (per Assessment)
F13960	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Changing Station		Height	38	No	Work surface does not comply with height requirements.	3-Restrooms	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F13961	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Door Gate		Opening force	12	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F13962	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F14031	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4.75	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F14032	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	10	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F14033	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F14034	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Coat Hook		Height	54.5	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2017	$ 150.00	Planned as part of Renovation in 2016/2017
F14035	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Lavatory Sink		Height	34.75	No	Lavatory sink is too high.	3-Restrooms	Lower the lavatory sink to the correct height.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F14036	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Door Gate		Opening force	10	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F14037	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F14076	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4.5	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F14077	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	10	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F14078	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Water Closet		Dimension, sidewall	21	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F14079	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F14080	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Lavatory Sink		Height	34.25	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	2017	$ 1,500.00	Planned as part of Renovation in 2016/2017
F14081	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Changing Station		Height	39	No	Work surface does not comply with height requirements.	3-Restrooms	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F14082	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Door Gate		Opening force	12	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F14083	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F14123	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	51	No	Toilet compartment is not deep enough.	3-Restrooms	Reconfigure the stall to provide a minimum of 56 inches in depth.	56 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F14124	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	23.5	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F14125	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F14181	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	3-Restrooms	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F14182	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F14183	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	5	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F14184	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2017	$ 250.00	Planned as part of Renovation in 2016/2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14185	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Door Gate		Opening force	13	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F14186	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F14255	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F14256	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F14257	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Door Gate		Opening force	10	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F14258	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2017	$ 150.00	Planned as part of Renovation in 2016/2017
F14307	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Water Closet		Clearance, parallel	56.25	No	Clearance at water closet is too narrow.	3-Restrooms	Remodel the restroom to provide at least the minimum required width.	60 inches minimum	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F14308	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	7	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F14309	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Water Closet		Dimension, sidewall	19	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F14310	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Water Closet		Dimension, wide side	37.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2017	$ 5,000.00	Planned as part of Renovation in 2016/2017
F14311	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Mirror		Height, bottom	40.5	No	Mirror is too high.	5-Tolerance	No action recommended - within construction tolerance.	40 inches maximum	2017	$ -	Within Tolerance (per Assessment)
F14312	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	1-Public Unsupervised	Door Gate		Opening force	10	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F15679	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Public Phone		TTY shelf?	N	No	No TTY shelf is provided.	2-Services	Provide a portable TTY shelf and an electrical outlet within/adjacent to the phone enclosure. The handset must be capable of being placed flush on the shelf surface accommodating the TTY with a 6 inch minimum vertical clearance above the TTY location.		2017	$ 750.00	Planned as part of Renovation in 2016/2017
F15680	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Public Phone		TTY?	N	No	No TTY provided.	2-Services	Provide and install a TTY, including a TTY shelf.		2017	$ 750.00	Planned as part of Renovation in 2016/2017
F15681	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Public Phone		Volume control?	N	No	Volume control is not present.	2-Services	Install a new telephone with volume a control.		2017	$ 250.00	Planned as part of Renovation in 2016/2017
F16312	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface		Height, level change	1	No	Vertical change in level is too high.	1-Entry	Grind the surface to provide a change in level no higher than 1/2 inch (beveled), with a slope not > 1:2.		2020	$ 500.00	Part of Annual Parking project
F16313	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#3	Slope, counter	5.6%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	5.0% maximum	2020	$ -	Within Tolerance (per Assessment)
F16314	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#1	Slope, counter	10.3%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp, curb, or gutter to provide compliant counter slope.	5.0% maximum	2020	$ 5,000.00	Part of Annual Parking project
F16315	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#10	Slope, cross	2.7%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	2020	$ -	Within Tolerance (per Assessment)
F16316	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#1	Slope, right flare	10.3%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	10% maximum	2020	$ -	Within Tolerance (per Assessment)
F16317	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#10	Slope, running	11.7%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp, curb, and gutter to provide compliant running slope.	8.33% maximum	2020	$ 2,500.00	Part of Annual Parking project
F16318	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#6	Slope, running	11.8%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp, curb, and gutter to provide compliant running slope.	8.33% maximum	2020	$ 5,000.00	Part of Annual Parking project
F16319	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Landing	Curb ramp #10	Slope, running	10.9%	No	Slope is too steep.	1-Entry	Rebuild the landing to provide compliant running and cross slopes.	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking project
F16320	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Landing	At curb ramp #10	Width, opening	0.75	No	Opening in walking surface is too wide.	5-Tolerance	No action recommended - within construction tolerance.	.05 inch maximum	2020	$ -	Within Tolerance (per Assessment)
F16321	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface	At curb ramp #2	Width, opening	0.75	No	Opening in walking surface is too wide.	5-Tolerance	No action recommended - within construction tolerance.	.05 inch maximum	2020	$ -	Within Tolerance (per Assessment)
F16322	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface	At curb ramp #3	Width, opening	1	No	Opening in walking surface is too wide.	1-Entry	Fill/patch the gaps in the walking surface.	0.5 inch maximum	2020	$ 2,500.00	Part of Annual Parking project
F16323	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface	At curb ramp #4	Width, opening	1	No	Opening in walking surface is too wide.	1-Entry	Fill/patch the gaps in the walking surface.	0.5 inch maximum	2020	$ 2,500.00	Part of Annual Parking project
F16324	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface	At curb ramp #4	Width, opening	2.5	No	Opening in walking surface is too wide.	1-Entry	Fill/patch the gaps in the walking surface.	0.5 inch maximum	2020	$ 2,500.00	Part of Annual Parking project
F16325	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface	At curb ramp #6	Width, opening	1.25	No	Opening in walking surface is too wide.	1-Entry	Fill/patch the gaps in the walking surface.	0.5 inch maximum	2020	$ 2,500.00	Part of Annual Parking project
F16326	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface	At curb ramp #7	Width, opening	1.5	No	Opening in walking surface is too wide.	1-Entry	Fill/patch the gaps in the walking surface.	0.5 inch maximum	2020	$ 2,500.00	Part of Annual Parking project

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16327	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface	At curb ramp #8	Width, opening	1.25	No	Opening in walking surface is too wide.	1-Entry	Fill/patch the gaps in the walking surface.	0.5 inch maximum	2020	$ 2,500.00	Part of Annual Parking project
F16328	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface	At curb ramp #9	Width, opening	1.25	No	Opening in walking surface is too wide.	1-Entry	Fill/patch the gaps in the walking surface.	0.5 inch maximum	2020	$ 2,500.00	Part of Annual Parking project
F16433	Justice Center		Exterior	Owned	Walkway	From North parking lot to entrance	1-Public Unsupervised	Walking Surface	At curb ramp #12	Width, opening	1	No	Opening in walking surface is too wide.	1-Entry	Fill/patch the gaps in the walking surface.	0.5 inch maximum	2020	$ 2,500.00	Part of Annual Parking project
F16434	Justice Center		Exterior	Owned	Walkway	From North parking lot to entrance	1-Public Unsupervised	Walking Surface	At curb ramp #13	Width, opening	1.25	No	Opening in walking surface is too wide.	1-Entry	Fill/patch the gaps in the walking surface.	0.5 inch maximum	2020	$ 2,500.00	Part of Annual Parking project
F16441	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#4	Slope, counter	8.2%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp, curb, or gutter to provide compliant counter slope.	5.0% maximum	2020	$ 7,500.00	Part of Annual Parking project
F16442	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#3	Slope, right flare	10.1%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	10% maximum	2020	$ -	Within Tolerance (per Assessment)
F16443	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#1	Slope, running	8.9%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	8.33% maximum	2020	$ -	Within Tolerance (per Assessment)
F16444	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#12	Slope, running	9.6%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp, curb, and gutter to provide compliant running slope.	8.33% maximum	2020	$ 5,000.00	Part of Annual Parking project
F16445	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#3	Slope, running	10.0%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp, curb, and gutter to provide compliant running slope.	8.33% maximum	2020	$ 5,000.00	Part of Annual Parking project
F16446	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Walking Surface	At curb ramp #1	Width, opening	2	No	Opening in walking surface is too wide.	1-Entry	Fill/patch the gaps in the walking surface.	0.5 inch maximum	2020	$ 2,500.00	Part of Annual Parking project
F16525	Justice Center		Exterior	Owned	Walkway	Same Bus Stop as DA Bldg	1-Public Unsupervised	Walking Surface		Slope, cross	3.0%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with a compliant cross slope.	2.08% maximum	2020	$ 2,500.00	Part of Annual Parking project
F16805	Justice Center	CASA	Interior	Owned	Work Area	#309 - Office	3-Employee Common	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F16806	Justice Center	CASA	Interior	Owned	Work Area	#309 - Office	3-Employee Common	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F16807	Justice Center	CASA	Interior	Owned	Work Area	#309 - Office	1-Public Unsupervised	Signage		Location	H	No	Sign is not mounted in the correct location.	2-Services	Move the sign to the latch side of the door.		2016	$ 100.00	
F16808	Justice Center	CASA	Interior	Owned	Work Area	#309 - Office	3-Employee Common	Door Gate		Opening force	9	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F16829	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Counter		Height	42	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F16830	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Counter	L-shaped	Height	42.75	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F16856	Justice Center		3rd Floor	Owned	Work Area	#305 - Staff Area	3-Employee Common	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F16857	Justice Center		3rd Floor	Owned	Work Area	#305 - Staff Area	3-Employee Common	Counter		Height	42	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F16858	Justice Center		3rd Floor	Owned	Work Area	#305 - Staff Area	3-Employee Common	Door Gate		Opening force	9	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F16884	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F16885	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F16886	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F16887	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate	Into Fire Vestibule	Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F16888	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Counter		Height	42	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F16889	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Operable Part	Wall mounted phone	Height	62.5	No	Operable part is out of reach range.	2-Services	Relocate the wall phone to within a compliant reach range.	48 inches maximum	2017	$ 250.00	Planned as part of Renovation in 2016/2017
F16890	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F16891	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate	Into Fire Vestibule	Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F16892	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Opening force	8	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F16949	Justice Center		Interior	Owned	Work Area	Off lobby	3-Employee Common	Door Gate		Clearance, pull parallel	16	No	Clearance on pull side of door is insufficient.	2-Services	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2017	$ 2,500.00	Planned as part of Renovation in 2016/2017
F16950	Justice Center		Interior	Owned	Work Area	Off lobby	3-Employee Common	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F16951	Justice Center		Interior	Owned	Work Area	Off lobby	3-Employee Common	Door Gate		Opening force	8	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F16952	Justice Center		Interior	Owned	Work Area	Off lobby	3-Employee Common	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F16963	Justice Center		Interior	Owned	Work Area	Off main lobby	3-Employee Common	Signage		Braille?	Above tactile	No	Braille positioned above tactile letters.	2-Services	Replace the signage with compliant Braille and tactile letters positioned correctly.		2016	$ 100.00	
F16966	Justice Center		Interior	Owned	Work Area		3-Employee Common	Door Gate		Opening force	11	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06853	Lowell Street Trailhead		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Height, sign	58	No	Accessible signage is too low.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	n/a		by Parks
F06854	Lowell Street Trailhead		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, van spaces	0	No	Too few van accessible parking spaces are provided.	1-Entry	Provide the minimum number of required van accessible parking spaces.	1 minimum	n/a		by Parks
F06855	Lowell Street Trailhead		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Width	None	No	No access aisle provided.	1-Entry	Provide a marked access aisle adjacent to the parking space.	60 inches minimum	n/a		by Parks
F00698	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Break Room		3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2019	$ 2,500.00	
F00699	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Break Room		3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2019	$ 2,500.00	
F00710	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Break Room	Coffee/copy room	3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2019	$ 2,500.00	
F00711	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Break Room	Copy Room	3-Employee Common	Appliance	Coffee dispenser	Height	51	No	Operable part is out of reach range.	4-Other	Relocate the appliance to within a compliant reach range.	48 inches maximum	2019	$ 500.00	
F00713	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Break Room		3-Employee Common	Counter		Clearance, perpendicular	36	No	Clear floor space is too short.	2-Services	Provide at least the minimum clear floor space at the counter.	48 inches minimum	2019	$ 2,500.00	
F00714	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Break Room		3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2019	$ 2,500.00	
F00715	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Height	36	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2019	$ 1,500.00	
F01560	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Conference Room	Coroner	2-Public Supervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F01561	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Conference Room	Coroner	2-Public Supervised	Door Gate		Opening force	11	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F01573	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Conference Room		2-Public Supervised	Door Gate		Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F04076	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Hallway	To exterior Break Area	3-Employee Common	Door Gate		Clearance, push perpendicular	24	No	Clearance on push side of door is insufficient.	2-Services	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	48 inches minimum	2019	$ 3,500.00	
F04077	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Hallway	To exterior Break Area	3-Employee Common	Door Gate		Closing speed	3	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F04078	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Hallway	To exterior Break Area	3-Employee Common	Door Gate		Opening force	15	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F04090	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Hallway		1-Public Unsupervised	Signage	All Signage	Braille?	N	No	Signage does not provide Braille.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F04091	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Hallway		3-Employee Common	Signage	All Signage	Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F04485	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception	Employee entrance	3-Employee Common	Door Gate	To locker/shower area	Closing speed	4	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F04505	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		3-Employee Common	Door Gate	From shared lobby to Coroner's Office	Clearance, push parallel	4	No	Clearance on push side of door is insufficient.	2-Services	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	12 inches minimum	2019	$ 3,500.00	
F04506	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		3-Employee Common	Door Gate	From shared lobby to Coroner's Office	Closing speed	3	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F04507	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		3-Employee Common	Door Gate	From shared lobby to Coroner's Office	Closing speed	3	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F04508	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Protrusion	Drinking Fountain	Dimension, protruding	13.5	No	Object protrudes into the path of travel.	4-Other	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the fountain, recess the fountain into the wall, or install cane detection to prevent injury.		2019	$ 250.00	
F04509	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter	Check-in	Height	41	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2019	$ 2,500.00	
F04510	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter	Check-in	Height	42.5	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2019	$ 2,500.00	
F04511	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Height	43	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2019	$ 2,500.00	
F04512	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate	From shared lobby to Coroner's Office	Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F04513	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate	From shared lobby to Coroner's Office	Opening force	13	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F04786	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Dimension, entry to back wall	35	No	Shower compartment depth is not compliant.	3-Restrooms	Remodel or replace the existing shower with a compliant sized shower.	36 inch depth	2019	$ 3,500.00	
F04787	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Dimension, side to side	35	No	Transfer shower too narrow.	3-Restrooms	Redesign and remodel the shower compartment with compliant grab bars, seat, hose, and shower controls.	36 inches wide by 36 inches deep	2019	$ 3,500.00	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F04799	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Locker Room	Women's	3-Employee Common	Shower Compartment		Dimension, entry to back wall	35	No	Shower compartment depth is not compliant.	3-Restrooms	Remodel or replace the existing shower with a compliant sized shower.	36 inch depth	2019	$ 3,500.00	
F04800	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Locker Room	Women's	3-Employee Common	Shower Compartment		Dimension, side to side	35	No	Transfer shower too narrow.	3-Restrooms	Redesign and remodel the shower compartment with compliant grab bars, seat, hose, and shower controls.	36 inches wide by 36 inches deep	2019	$ 3,500.00	
F06862	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility	Employee parking lot	3-Employee Common	Facility Specifications		Cars obstruct pathway	Y	No	Cars protrude into path of travel.	1-Entry	Install curb stops at the head of parking spaces to avoid obstruction in the path of travel.		2018	$ 500.00	Part of Annual Parking project
F06863	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility	Employee parking lot	1-Public Unsupervised	Facility Specifications		Number, accessible	1	No	Too few accessible parking spaces and van accessible parking spaces.	1-Entry	Provide a total of 3 accessible parking spaces, one of which should be a van accessible size parking space.	3 minimum	2018	$ 50.00	Part of Annual Parking project
F06864	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility	Employee parking lot	1-Public Unsupervised	Facility Specifications		Number, van spaces	0	No	Too few van accessible parking spaces are provided.	1-Entry	Provide the minimum number of required van accessible parking spaces.	1 minimum	2018	$ 50.00	Part of Annual Parking project
F06865	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility	Employee parking lot	1-Public Unsupervised	Access Aisle		Slope, running	2.7%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06876	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, van spaces	0	No	Too few van accessible parking spaces are provided.	1-Entry	Provide the minimum number of required van accessible parking spaces.	1 minimum	2018	$ 50.00	Part of Annual Parking project
F06877	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Slope, running	2.6%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06878	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Van sign?	N	No	Van Accessible' sign is not present.	1-Entry	Install a 'Van Accessible' sign.		2018	$ 150.00	Part of Annual Parking project
F14368	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Clearance, pull parallel	6	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2019	$ 3,500.00	
F14369	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	13	No	Side wall grab bar is located too far away from the back wall.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2019	$ 250.00	
F14370	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Dispenser	PT	Height	49	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F14371	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Dispenser	Soap	Height	51	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F14372	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Dispenser	Soap	Height	51	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F14373	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Opening force	15	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F14374	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2019	$ 150.00	
F14418	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Dispenser	Soap	Height	49	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F14419	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Dispenser	PT	Height	49	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F14420	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Grab Bar	Side	Dimension, end to wall	13	No	Side wall grab bar is located too far away from the back wall.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2019	$ 250.00	
F14421	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	3.5	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2019	$ 250.00	
F14427	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Door Gate		Clearance, push perpendicular	24	No	Clearance on push side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	48 inches minimum	2019	$ 3,500.00	
F14428	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Dispenser	TP	Dimension from water closet seat	12	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Relocate or Replace Dispenser
F14429	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Coat Hook		Height	62	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2019	$ 150.00	
F14430	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Dispenser	PT	Height	49	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F14431	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Dispenser	Toilet seat covers	Height	60	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F14432	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	3.5	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2019	$ 250.00	
F14444	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Clearance, pull parallel	6	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2019	$ 3,500.00	
F14445	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Dispenser	Soap	Height	49	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14446	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Opening force	13	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F14447	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	13	No	Side wall grab bar is located too far away from the back wall.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2019	$ 3,500.00	
F14448	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2019	$ 150.00	
F14453	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Women's - Locker Room	3-Employee Common	Dispenser	Soap	Height	49	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F14454	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Women's - Locker Room	3-Employee Common	Dispenser	PT	Height	49	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F14457	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	3	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2019	$ 250.00	
F14458	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Water Closet		Dimension, wide side	24.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2019	$ 5,000.00	
F14459	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Coat Hook		Height	65	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2019	$ 150.00	
F14460	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Dispenser	Soap	Height	49	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F14461	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Lavatory Sink		Height	35	No	Lavatory sink is too high.	3-Restrooms	Lower the lavatory sink to the correct height.	34 inches maximum	2019	$ 1,500.00	
F14462	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Mirror		Height, bottom	40.5	No	Mirror is too high.	5-Tolerance	No action recommended - within construction tolerance.	40 inches maximum	2019	$ 250.00	Relocate or Replace Mirror
F14481	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	3.5	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2019	$ 250.00	
F14482	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Dimension, wide side	25	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2019	$ 5,000.00	
F14483	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Unisex	3-Employee Common	Dispenser	Soap	Height	49.5	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F14484	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Unisex	3-Employee Common	Mirror		Height, bottom	40.5	No	Mirror is too high.	5-Tolerance	No action recommended - within construction tolerance.	40 inches maximum	2019	$ 250.00	Relocate or Replace Mirror
F14507	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Signage		Braille?	N	No	Signage does not provide Braille.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F14508	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Dispenser	TP	Dimension from water closet seat	10	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Relocate or Replace Dispenser
F14509	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Dimension, end to wall	13	No	Side wall grab bar is located too far away from the back wall.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2019	$ 250.00	
F14510	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	1.5	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2019	$ 250.00	
F14511	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Water Closet		Dimension, wide side	21	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2019	$ 7,500.00	
F14512	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Dispenser	Soap	Height	50	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F14513	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Lavatory Sink		Height	35	No	Lavatory sink is too high.	3-Restrooms	Lower the lavatory sink to the correct height.	34 inches maximum	2019	$ 1,500.00	
F14514	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Mirror		Height, bottom	40.5	No	Mirror is too high.	5-Tolerance	No action recommended - within construction tolerance.	40 inches maximum	2019	$ 250.00	Relocate or Replace Mirror
F14515	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Door Gate		Opening force	13	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F14516	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Signage		Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F14538	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's - End of hall	3-Employee Common	Dispenser	TP	Dimension from water closet seat	11	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Relocate or Replace Dispenser

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14539	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's - End of hall	3-Employee Common	Coat Hook		Height	62	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2019	$ 150.00	
F14540	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's - End of hall	3-Employee Common	Door Gate		Opening force	15	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F16529	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Walkway	From employee parking lot	1-Public Unsupervised	Landing		Slope, cross	3.2%	No	Slope is too steep.	1-Entry	Rebuild the landing to provide compliant running and cross slopes.	2.08% maximum	2018	$ 5,000.00	Part of Annual Parking project
F16530	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Walkway	From employee parking lot	1-Public Unsupervised	Walking Surface		Slope, running	8.2%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with compliant running and cross slopes, or install handrails, edge protection, and landings required for ramps.	5.0% maximum	2018	$ 5,000.00	Part of Annual Parking project
F16536	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Landing	At base of walkway	Slope, cross	2.4%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	2018	$ -	Within Tolerance (per Assessment)
F00278	Parks Admin Building		1st Floor	Owned	Assembly Area	Meeting Room	1-Public Unsupervised	Lavatory Sink		Height	36	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2019	$ 1,500.00	
F00719	Parks Admin Building		1st Floor	Owned	Break Room	Meeting Room	1-Public Unsupervised	Door Gate		Clearance, pull parallel	3	No	Clearance on pull side of door is insufficient.	2-Services	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2019	$ 3,500.00	
F00720	Parks Admin Building		1st Floor	Owned	Break Room	Meeting Room	1-Public Unsupervised	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2019	$ 2,500.00	
F00723	Parks Admin Building		2nd Floor	Owned	Break Room		3-Employee Common	Door Gate		Clearance, pull parallel	12	No	Clearance on pull side of door is insufficient.	2-Services	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2019	$ 3,500.00	
F00724	Parks Admin Building		1st Floor	Owned	Break Room		3-Employee Common	Appliance	Refrig/Freezer	Height	49	No	50% of freezer space is not below 54" AFF.	4-Other	Replace the existing refrig/freezer with a compliant refrig/freezer.	Side by side Refrig/Freezer	2019	$ 500.00	
F00725	Parks Admin Building		2nd Floor	Owned	Break Room		3-Employee Common	Appliance	Refrig/Freezer	Height	51	No	50% of freezer space is not below 54" AFF.	4-Other	Replace the existing refrig/freezer with a compliant refrig/freezer.	Side by side Refrig/Freezer	2019	$ 500.00	
F00726	Parks Admin Building		1st Floor	Owned	Break Room		1-Public Unsupervised	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2019	$ 2,500.00	
F00727	Parks Admin Building		2nd Floor	Owned	Break Room		1-Public Unsupervised	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2019	$ 2,500.00	
F00728	Parks Admin Building		2nd Floor	Owned	Break Room		3-Employee Common	Dispenser	PT	Height	51	No	Dispenser is too high.	2-Services	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F00729	Parks Admin Building		1st Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Height	36	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2019	$ 1,500.00	
F00730	Parks Admin Building		2nd Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Height	36	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2019	$ 1,500.00	
F01576	Parks Admin Building		2nd Floor	Owned	Conference Room		1-Public Unsupervised	Lavatory Sink		Height	36	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2019	$ 1,500.00	
F03409	Parks Admin Building		1st Floor	Owned	Elevator		1-Public Unsupervised	Hall Signal		Audible signal?	Single beep only	No	Elevator does not have compliant audible signals indicating elevators direction of travel.	2-Services	Change the audible signals to provide one beep for 'up' and two beeps for 'down'.		2019	$ 500.00	
F03410	Parks Admin Building		1st Floor	Owned	Elevator		1-Public Unsupervised	Hoistway Sign		Star?	None	No	No tactile Star on Hoistway frame.	2-Services	Install a hoistway sign on both hoistway jams, with raised letters, Braille, and a tactile Star.		2019	$ 350.00	
F04094	Parks Admin Building		1st Floor	Owned	Hallway	West	1-Public Unsupervised	Vending Machine	Pepsi	Height	52.5	No	Operable part is out of reach range.	4-Other	Replace the Vending Machine with one that has operable parts within the reach range.	48 inches maximum	2016	$ -	Internal Staff - Operations
F04095	Parks Admin Building		1st Floor	Owned	Hallway		1-Public Unsupervised	Protrusion	Drinking Fountain	Dimension, protruding	19	No	Object protrudes into the path of travel.	4-Other	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the fountain, recess the fountain into the wall, or install cane detection to prevent injury.		2019	$ 250.00	
F06912	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North of Park Admin building	1-Public Unsupervised	Parking Space	#2	Sign?	N	No	No accessible signage provided.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	2018	$ 150.00	Part of Annual Parking project
F06923	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Parking Space	#2	Access aisle?	N	No	No access aisle provided.	1-Entry	Provide a marked access aisle adjacent to the parking space.	60 inches minimum	2018	$ 150.00	Part of Annual Parking project
F06924	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Parking Space	#3	Access aisle?	N	No	No access aisle provided.	1-Entry	Provide a marked access aisle adjacent to the parking space.	60 inches minimum	2018	$ 150.00	Part of Annual Parking project
F06951	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	West side of North parking lot	1-Public Unsupervised	Access Aisle	#1	Slope, running	2.2%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F06952	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	West side of North parking lot	1-Public Unsupervised	Access Aisle	#1	Width	57.5	No	Access aisle is too narrow.	1-Entry	Restripe the parking space and aisle to provide a compliant sized access aisle.	60 inches minimum	2018	$ 150.00	Part of Annual Parking project
F06971	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Cars obstruct pathway	Y	No	Cars protrude into path of travel.	1-Entry	Install curb stops at the head of parking spaces to avoid obstruction in the path of travel.		2018	$ 500.00	Part of Annual Parking project
F06972	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Sign?	N	No	No accessible signage provided.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	2018	$ 150.00	Part of Annual Parking project
F06973	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Width	58	No	Access aisle is too narrow.	1-Entry	Restripe the parking space and aisle to provide a compliant sized access aisle.	60 inches minimum	2018	$ 50.00	Part of Annual Parking project

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14544	Parks Admin Building		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Clearance, parallel	53.5	No	Clearance at water closet is too narrow.	3-Restrooms	Remodel the restroom to provide at least the minimum required width.	60 inches minimum	2019	$ 5,000.00	
F14545	Parks Admin Building		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, pull parallel	2	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2019	$ 3,500.00	
F14546	Parks Admin Building		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	52	No	Clearance on pull side of door is insufficient.	3-Restrooms	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	2019	$ 3,500.00	
F14547	Parks Admin Building		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	17	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Relocate or Replace Dispenser
F14548	Parks Admin Building		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	2	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2019	$ 250.00	
F14549	Parks Admin Building		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, wide side	36.25	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2019	$ 5,000.00	
F14550	Parks Admin Building		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Height	35	No	Lavatory sink is too high.	3-Restrooms	Lower the lavatory sink to the correct height.	34 inches maximum	2019	$ 1,500.00	
F14551	Parks Admin Building		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Height, top	36.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	2019	$ 250.00	
F14552	Parks Admin Building		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Height, top	36.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	2019	$ 250.00	
F14553	Parks Admin Building		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Opening force	12	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F14554	Parks Admin Building		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Alarm System		Visible alarm	N	No	No visible alarm is provided.	3-Restrooms	Install a visible wall fire alarm.	Between 80 and 96 inches AFF	2019	$ 350.00	
F14564	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	18	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Relocate or Replace Dispenser
F14565	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	7.5	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2019	$ 2,500.00	
F14566	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	3	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2019	$ 250.00	
F14567	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2019	$ 250.00	
F14568	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Coat Hook		Height	49.5	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2019	$ 150.00	
F14569	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Dispenser	Soap	Height	49	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F14570	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Dispenser	PT	Height	55	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F14571	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Lavatory Sink		Height	35	No	Lavatory sink is too high.	3-Restrooms	Lower the lavatory sink to the correct height.	34 inches maximum	2019	$ 1,500.00	
F14572	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Grab Bar	Side	Height, top	36.75	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	2019	$ 250.00	
F14573	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Grab Bar	Rear	Height, top	36.75	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	2019	$ 250.00	
F14574	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Door Gate		Opening force	14	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F14575	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2019	$ 150.00	
F14592	Parks Admin Building		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, pull parallel	3	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2019	$ 3,500.00	
F14593	Parks Admin Building		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	14.5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Relocate or Replace Dispenser
F14594	Parks Admin Building		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	2	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2019	$ 250.00	
F14595	Parks Admin Building		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Coat Hook		Height	61	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2019	$ 150.00	
F14596	Parks Admin Building		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Height, top	36.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	2019	$ 250.00	
F14597	Parks Admin Building		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Height, top	36.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	2019	$ 250.00	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14598	Parks Admin Building		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Opening force	10	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F14599	Parks Admin Building		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Alarm System		Visible alarm	N	No	No visible alarm is provided.	3-Restrooms	Install a visible wall fire alarm.	Between 80 and 96 inches AFF	2019	$ 350.00	
F14609	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Toilet Compartment		Clearance, outside	0	No	No clearance provided on pull side of stall door.	3-Restrooms	Change the swing of the door.		2019	$ 3,500.00	
F14610	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	17	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2019	$ 100.00	Relocate or Replace Dispenser
F14611	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Grab Bar	Rear	Dimension, between	11	No	Space between the grab bar and dispenser above is too small.	3-Restrooms	Moving the dispenser to a minimum of 12 inches above the grab bar will place the dispenser out of reach range. Relocate the dispenser to another location.	Between 15 and 48 inches	2019	$ 250.00	
F14612	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	5	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2019	$ 2,500.00	
F14613	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	3	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2019	$ 250.00	
F14614	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Protrusion	Feminine product dispenser	Dimension, protruding	6.5	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2019	$ 250.00	
F14615	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2019	$ 250.00	
F14616	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Coat Hook		Height	49.5	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2019	$ 150.00	
F14617	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Dispenser	PT	Height	56	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F14618	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Dispenser	Toilet seat covers	Height	55	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2019	$ 100.00	Relocate or Replace Dispenser
F14619	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Lavatory Sink		Height	35	No	Lavatory sink is too high.	3-Restrooms	Lower the lavatory sink to the correct height.	34 inches maximum	2019	$ 1,500.00	
F14620	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Grab Bar	Side	Height, top	36.75	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	2019	$ 250.00	
F14621	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Grab Bar	Rear	Height, top	36.75	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	2019	$ 250.00	
F14622	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Door Gate		Opening force	14	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F14623	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2019	$ 150.00	
F16545	Parks Admin Building	North Parking Area	Exterior	Owned	Walkway	From 'New' North parking lot	1-Public Unsupervised	Curb Ramp		Slope, right flare	10.7%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	10% maximum	None	$ -	Within Tolerance (per Assessment)
F16556	Parks Admin Building		Exterior	Owned	Walkway	From parking lot	1-Public Unsupervised	Curb Ramp		Landing?	N	No	No landing provided at top of curb ramp.	1-Entry	Provide a landing at the top of the curb ramp that is the same width as the curb ramp and at least 36 inches long.		2019	$ 5,000.00	
F16557	Parks Admin Building		Exterior	Owned	Walkway	From parking lot	1-Public Unsupervised	Curb Ramp		Slope, counter	5.9%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	5.0% maximum	2019	$ -	Within Tolerance (per Assessment)
F16567	Parks Admin Building		Exterior	Owned	Walkway		1-Public Unsupervised	Protrusion	Fire/alarm box	Dimension, protruding	5.5	No	Object protrudes into the path of travel.	1-Entry	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2019	$ 250.00	
F16568	Parks Admin Building		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	8	No	Smooth surface at bottom edge of door is insufficient.	1-Entry	No action recommended - this element has safe harbor.	10 inches minimum	2019	$ -	Within Tolerance (per Assessment)
F00735	Public Works and Fleet		1st Floor	Owned	Break Room	Fleet	3-Employee Common	Appliance	Refrig/Freezer	Height	51	No	50% of freezer space is not below 54" AFF.	4-Other	Replace the existing refrig/freezer with a compliant refrig/freezer.	Side by side Refrig/Freezer	None	$ 500.00	Design in 2016/2017 -Renovation/New in 2018
F00736	Public Works and Fleet		1st Floor	Owned	Break Room	Fleet	3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	$ 2,500.00	Design in 2016/2017 -Renovation/New in 2018
F00737	Public Works and Fleet		1st Floor	Owned	Break Room	Fleet	3-Employee Common	Vending Machine	Snacks	Height, control	52.5	No	Operable part is out of reach range.	4-Other	Replace the Vending Machine with one that has operable parts within the reach range.	48 inches maximum	2016	$ -	Internal Staff - Operations
F00738	Public Works and Fleet		1st Floor	Owned	Break Room	Fleet	3-Employee Common	Vending Machine	Nesbitts	Height, control	52	No	Operable part is out of reach range.	4-Other	Replace the Vending Machine with one that has operable parts within the reach range.	48 inches maximum	2016	$ -	Internal Staff - Operations
F00740	Public Works and Fleet		2nd Floor	Owned	Break Room		3-Employee Common	Appliance	Refrig/Freezer	Height	50	No	50% of freezer space is not below 54" AFF.	4-Other	Replace the existing refrig/freezer with a compliant refrig/freezer.	Side by side Refrig/Freezer	None	$ 500.00	Design in 2016/2017 -Renovation/New in 2018
F00741	Public Works and Fleet		1st Floor	Owned	Break Room		1-Public Unsupervised	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	$ 2,500.00	Design in 2016/2017 -Renovation/New in 2018
F00742	Public Works and Fleet		2nd Floor	Owned	Break Room		3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	None	$ 2,500.00	Design in 2016/2017 -Renovation/New in 2018

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00743	Public Works and Fleet		1st Floor	Owned	Break Room		3-Employee Common	Dispenser	PT	Height	52	No	Operable part is out of reach range.	2-Services	Relocate the dispenser to within a compliant reach range.	48 inches maximum	None	$ 100.00	Design in 2016/2017 -Renovation/New in 2018
F00744	Public Works and Fleet		2nd Floor	Owned	Break Room		3-Employee Common	Dispenser	PT	Height	56	No	Dispenser is too high.	2-Services	Relocate the dispenser to the correct height.	48 inches maximum	None	$ 100.00	Design in 2016/2017 -Renovation/New in 2018
F00745	Public Works and Fleet		1st Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Height	36.5	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	None	$ 1,500.00	Design in 2016/2017 -Renovation/New in 2018
F00746	Public Works and Fleet		2nd Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Height	36.5	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	None	$ 1,500.00	Design in 2016/2017 -Renovation/New in 2018
F00747	Public Works and Fleet		2nd Floor	Owned	Break Room		3-Employee Common	Vending Machine	Coke	Height, control	50	No	Operable part is out of reach range.	4-Other	Replace the Vending Machine with one that has operable parts within the reach range.	48 inches maximum	2016	$ -	Internal Staff - Operations
F03430	Public Works and Fleet		1st Floor	Owned	Elevator		1-Public Unsupervised	Hoistway Sign		Height, top	41.5	No	Signage is too low.	2-Services	Remount sign with tactile letters located 48 inches minimum and 60 inches maximum, above the finished floor, measured from the baseline of the tactile letters.	48 to 60 inches	None	$ 100.00	Design in 2016/2017 -Renovation/New in 2018
F04547	Public Works and Fleet		Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Height	41.5	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	None	$ 2,500.00	Design in 2016/2017 -Renovation/New in 2018
F04550	Public Works and Fleet		Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Height, threshold	0.75	No	Threshold is too high.	2-Services	Provide a threshold which is 0.25 inch maximum, or a beveled threshold which is 0.5 inch maximum, at the door entrance.	0.5 inch maximum	None	$ 250.00	Design in 2016/2017 -Renovation/New in 2018
F04801	Public Works and Fleet		1st Floor	Owned	Locker Room	Near Restrooms	3-Employee Common	Locker		Hardware type	Twist	No	Hardware requires twisting of wrist.	3-Restrooms	Install lever type door hardware.		None	$ 500.00	Design in 2016/2017 -Renovation/New in 2018
F04802	Public Works and Fleet		1st Floor	Owned	Locker Room		3-Employee Common	Locker		Hardware type	Twist	No	Hardware requires twisting of wrist.	3-Restrooms	Install lever type door hardware.		None	$ 500.00	Design in 2016/2017 -Renovation/New in 2018
F05173	Public Works and Fleet		1st Floor	Owned	Other Room		1-Public Unsupervised	Door Gate	All doors	Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F07010	Public Works and Fleet		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Access aisle?	N	No	No access aisle provided.	1-Entry	Provide a marked access aisle adjacent to the parking space.	60 inches minimum	None	$ 50.00	Design in 2016/2017 -Renovation/New in 2018
F07011	Public Works and Fleet		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, accessible	3	No	Too few accessible parking spaces and van accessible parking spaces.	1-Entry	Provide a total of 4 accessible parking spaces, one of which should be a van accessible size parking space.	4 minimum	None	$ 50.00	Design in 2016/2017 -Renovation/New in 2018
F07012	Public Works and Fleet		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Slope, cross	3.3%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	None	$ 2,500.00	Design in 2016/2017 -Renovation/New in 2018
F07013	Public Works and Fleet		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Slope, running	2.2%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F14654	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Braille?	N	No	Signage does not provide Braille.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F14655	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Braille?	N	No	Signage does not provide Braille.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F14656	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	23	No	Clear floor space is too narrow.	3-Restrooms	Reconfigure the lavatory sink to provide at least the minimum clear floor space.	30 inches minimum	None	$ 1,500.00	Design in 2016/2017 -Renovation/New in 2018
F14657	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	23	No	Clear floor space is too narrow.	3-Restrooms	Reconfigure the lavatory sink to provide at least the minimum clear floor space.	30 inches minimum	None	$ 1,500.00	Design in 2016/2017 -Renovation/New in 2018
F14658	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	42.5	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	None	$ 5,000.00	Design in 2016/2017 -Renovation/New in 2018
F14659	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	34	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	None	$ 5,000.00	Design in 2016/2017 -Renovation/New in 2018
F14660	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	34	No	Clear floor space is too short.	3-Restrooms	Reconfigure the lavatory sink to provide at least the minimum clear floor space.	48 inches minimum	None	$ 1,500.00	Design in 2016/2017 -Renovation/New in 2018
F14661	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, pull parallel	4	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	None	$ 3,500.00	Design in 2016/2017 -Renovation/New in 2018
F14662	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, pull parallel	17	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	None	$ 3,500.00	Design in 2016/2017 -Renovation/New in 2018
F14663	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, pull parallel	15	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	None	$ 3,500.00	Design in 2016/2017 -Renovation/New in 2018
F14664	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	43	No	Clearance on push side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	48 inches minimum	None	$ 3,500.00	Design in 2016/2017 -Renovation/New in 2018
F14665	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, vertical	79.5	No	Vertical clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	80 inches minimum	None	$ -	Within Tolerance (per Assessment)
F14666	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F14667	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Urinal		Depth	12	No	Urinal is not deep enough.	3-Restrooms	Install a urinal with the correct depth.	13.5 inches	None	$ 1,500.00	Design in 2016/2017 -Renovation/New in 2018
F14668	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	10	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	None	$ 100.00	Design in 2016/2017 -Renovation/New in 2018

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14669	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Dimension, between	8.5	No	Space above grab bar is interrupted.	3-Restrooms	Move the dispenser to a minimum of 12 inches above the grab bar or remount the object to another location.	12 inches minimum	None	$ 250.00	Design in 2016/2017 -Renovation/New in 2018
F14670	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	6.5	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	None	$ 2,500.00	Design in 2016/2017 -Renovation/New in 2018
F14671	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4.75	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	None	$ 2,500.00	Design in 2016/2017 -Renovation/New in 2018
F14672	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	9	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	None	$ 250.00	Design in 2016/2017 -Renovation/New in 2018
F14673	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	3	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	None	$ 250.00	Design in 2016/2017 -Renovation/New in 2018
F14674	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	4.5	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	None	$ 250.00	Design in 2016/2017 -Renovation/New in 2018
F14675	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	21.5	No	Knee clearance is too low.	3-Restrooms	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	None	$ 1,500.00	Design in 2016/2017 -Renovation/New in 2018
F14676	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	26	No	Knee clearance is too low.	3-Restrooms	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	None	$ 1,500.00	Design in 2016/2017 -Renovation/New in 2018
F14677	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Protrusion	Hand dryer	Dimension, protruding	9	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		None	$ 250.00	Design in 2016/2017 -Renovation/New in 2018
F14678	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Protrusion	Hand dryer	Dimension, protruding	9	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		None	$ 250.00	Design in 2016/2017 -Renovation/New in 2018
F14679	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Protrusion	PT	Dimension, protruding	9	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		None	$ 250.00	Design in 2016/2017 -Renovation/New in 2018
F14680	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, sidewall	22	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	None	$ 5,000.00	Design in 2016/2017 -Renovation/New in 2018
F14681	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, wide side	21.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	None	$ 7,500.00	Design in 2016/2017 -Renovation/New in 2018
F14682	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		None	$ 150.00	Design in 2016/2017 -Renovation/New in 2018
F14683	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		None	$ 150.00	Design in 2016/2017 -Renovation/New in 2018
F14684	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		None	$ 150.00	Design in 2016/2017 -Renovation/New in 2018
F14685	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		None	$ 250.00	Design in 2016/2017 -Renovation/New in 2018
F14686	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		None	$ 250.00	Design in 2016/2017 -Renovation/New in 2018
F14687	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Coat Hook		Height	56	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	None	$ 150.00	Design in 2016/2017 -Renovation/New in 2018
F14688	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	PT	Height	52	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	None	$ 100.00	Design in 2016/2017 -Renovation/New in 2018
F14689	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	Hand dryer	Height	50	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	None	$ 100.00	Design in 2016/2017 -Renovation/New in 2018
F14690	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	PT	Height	49.5	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	None	$ 100.00	Design in 2016/2017 -Renovation/New in 2018
F14691	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	PT	Height	49.5	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	None	$ 100.00	Design in 2016/2017 -Renovation/New in 2018
F14692	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	Hand dryer	Height	50	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	None	$ 100.00	Design in 2016/2017 -Renovation/New in 2018
F14693	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Height	35	No	Lavatory sink is too high.	3-Restrooms	Lower the lavatory sink to the correct height.	34 inches maximum	None	$ 1,500.00	Design in 2016/2017 -Renovation/New in 2018
F14694	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Operable Part	Light switches	Height	52	No	Operable part is out of reach range.	3-Restrooms	Relocate the light switches to within a compliant reach range.	48 inches maximum	None	$ 350.00	Design in 2016/2017 -Renovation/New in 2018

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14695	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Urinal		Height, rim	24	No	Urinal rim is too high.	3-Restrooms	Where multiple urinals are installed, replace or remount at least one urinal to the correct height.	17 inches maximum	None	$ 1,500.00	Design in 2016/2017 -Renovation/New in 2018
F14696	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Height, top	37	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	None	$ 250.00	Design in 2016/2017 -Renovation/New in 2018
F14697	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Location	On door	No	Sign is not mounted in the correct location.	3-Restrooms	Move the sign to the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F14698	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		None	$ 500.00	Design in 2016/2017 -Renovation/New in 2018
F14699	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Fixture Count		Number, accessible compartments	0	No	No accessible toilet compartment in restroom.	3-Restrooms	Rebuild or reconfigure the restroom, with a wheelchair accessible toilet compartment.	1 minimum	None	$ 7,500.00	Design in 2016/2017 -Renovation/New in 2018
F14700	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Opening force	15	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F14701	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F14702	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F14743	Public Works and Fleet		1st Floor	Owned	Restroom	Men's - Fleet Break Room	3-Employee Common	Toilet Compartment		Clearance, parallel	37	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	None	$ 7,500.00	Design in 2016/2017 -Renovation/New in 2018
F14744	Public Works and Fleet		1st Floor	Owned	Restroom	Men's - Fleet Break Room	3-Employee Common	Urinal		Depth	13	No	Urinal is not deep enough.	5-Tolerance	No action recommended - within construction tolerance.	13.5 inches	None	$ -	Within Tolerance (per Assessment)
F14745	Public Works and Fleet		1st Floor	Owned	Restroom	Men's - Fleet Break Room	3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		None	$ 150.00	Design in 2016/2017 -Renovation/New in 2018
F14746	Public Works and Fleet		1st Floor	Owned	Restroom	Men's - Fleet Break Room	3-Employee Common	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		None	$ 250.00	Design in 2016/2017 -Renovation/New in 2018
F14747	Public Works and Fleet		1st Floor	Owned	Restroom	Men's - Fleet Break Room	3-Employee Common	Dispenser	PT	Height	62	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	None	$ 100.00	Design in 2016/2017 -Renovation/New in 2018
F14748	Public Works and Fleet		1st Floor	Owned	Restroom	Men's - Fleet Break Room	3-Employee Common	Mirror		Height, bottom	57	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	None	$ 250.00	Design in 2016/2017 -Renovation/New in 2018
F14749	Public Works and Fleet		1st Floor	Owned	Restroom	Men's - Fleet Break Room	3-Employee Common	Urinal		Height, rim	25	No	Urinal rim is too high.	3-Restrooms	Where multiple urinals are installed, replace or remount at least one urinal to the correct height.	17 inches maximum	None	$ 1,500.00	Design in 2016/2017 -Renovation/New in 2018
F14750	Public Works and Fleet		1st Floor	Owned	Restroom	Men's - Fleet Break Room	3-Employee Common	Fixture Count		Number, accessible compartments	0	No	No accessible toilet compartment in restroom.	3-Restrooms	Rebuild or reconfigure the restroom, with a wheelchair accessible toilet compartment.	1 minimum	None	$ 7,500.00	Design in 2016/2017 -Renovation/New in 2018
F14758	Public Works and Fleet		1st Floor	Owned	Restroom	Unisex - Fleet Area	1-Public Unsupervised	Signage		Braille?	N	No	Signage does not provide Braille.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F14759	Public Works and Fleet		1st Floor	Owned	Restroom	Unisex - Fleet Area	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	35.5	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	None	$ 7,500.00	Design in 2016/2017 -Renovation/New in 2018
F14760	Public Works and Fleet		1st Floor	Owned	Restroom	Unisex - Fleet Area	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	10	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	None	$ 100.00	Design in 2016/2017 -Renovation/New in 2018
F14761	Public Works and Fleet		1st Floor	Owned	Restroom	Unisex - Fleet Area	1-Public Unsupervised	Water Closet		Dimension, sidewall	18.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	None	$ 5,000.00	Design in 2016/2017 -Renovation/New in 2018
F14762	Public Works and Fleet		1st Floor	Owned	Restroom	Unisex - Fleet Area	1-Public Unsupervised	Dispenser	Gojo	Height	55	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	None	$ 100.00	Design in 2016/2017 -Renovation/New in 2018
F14763	Public Works and Fleet		1st Floor	Owned	Restroom	Unisex - Fleet Area	1-Public Unsupervised	Urinal		Height, rim	24	No	Urinal rim is too high.	3-Restrooms	Where multiple urinals are installed, replace or remount at least one urinal to the correct height.	17 inches maximum	None	$ 7,500.00	Design in 2016/2017 -Renovation/New in 2018
F14764	Public Works and Fleet		1st Floor	Owned	Restroom	Unisex - Fleet Area	1-Public Unsupervised	Signage		Location	H	No	Sign is not mounted in the correct location.	3-Restrooms	Move the sign to the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F14765	Public Works and Fleet		1st Floor	Owned	Restroom	Unisex - Fleet Area	1-Public Unsupervised	Fixture Count		Number, accessible compartments	0	No	No accessible toilet compartment in restroom.	3-Restrooms	Rebuild or reconfigure the restroom, with a wheelchair accessible toilet compartment.	1 minimum	None	$ 7,500.00	Design in 2016/2017 -Renovation/New in 2018
F14766	Public Works and Fleet		1st Floor	Owned	Restroom	Unisex - Fleet Area	1-Public Unsupervised	Signage		Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F14780	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Braille?	N	No	Signage does not provide Braille.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F14781	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Braille?	N	No	Signage does not provide Braille.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F14782	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Ambulatory Compartment		Clearance, parallel	43	No	Ambulatory compartment is too wide.	3-Restrooms	Reconfigure the toilet compartments to accommodate a correct sized ambulatory compartment.	60" deep and 35" to 37" wide	None	$ 5,000.00	Design in 2016/2017 -Renovation/New in 2018
F14783	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	35.5	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	None	$ 7,500.00	Design in 2016/2017 -Renovation/New in 2018

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14784	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Ambulatory Compartment		Clearance, perpendicular	59	No	Ambulatory compartment is too short.	3-Restrooms	Reconfigure the toilet compartments to accommodate a correct sized ambulatory compartment.	60" deep and 35" to 37" wide	None	$ 5,000.00	Design in 2016/2017 -Renovation/New in 2018
F14785	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, pull parallel	4	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	None	$ 3,500.00	Design in 2016/2017 -Renovation/New in 2018
F14786	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, pull parallel	7	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	None	$ 3,500.00	Design in 2016/2017 -Renovation/New in 2018
F14787	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	43	No	Clearance on push side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	48 inches minimum	None	$ 3,500.00	Design in 2016/2017 -Renovation/New in 2018
F14788	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Dimension, between	4.5	No	Space above grab bar is interrupted.	3-Restrooms	Move the dispenser to a minimum of 12 inches above the grab bar or remount the dispenser to a compliant location below the grab bar.	12 inches minimum	None	$ 250.00	Design in 2016/2017 -Renovation/New in 2018
F14789	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment	Ambulatory	Dimension, door to partition	7.5	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	None	$ 5,000.00	Design in 2016/2017 -Renovation/New in 2018
F14790	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	9.5	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	None	$ 250.00	Design in 2016/2017 -Renovation/New in 2018
F14791	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	3.5	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	None	$ 250.00	Design in 2016/2017 -Renovation/New in 2018
F14792	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	2	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	None	$ 250.00	Design in 2016/2017 -Renovation/New in 2018
F14793	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	21	No	Knee clearance is too low.	3-Restrooms	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	None	$ 1,500.00	Design in 2016/2017 -Renovation/New in 2018
F14794	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	21	No	Knee clearance is too low.	3-Restrooms	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	None	$ 1,500.00	Design in 2016/2017 -Renovation/New in 2018
F14795	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Protrusion	Hand dryer	Dimension, protruding	8	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		None	$ 250.00	Design in 2016/2017 -Renovation/New in 2018
F14796	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Protrusion	Feminine product dispenser	Dimension, protruding	7	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		None	$ 250.00	Design in 2016/2017 -Renovation/New in 2018
F14797	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, sidewall	21	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	None	$ 5,000.00	Design in 2016/2017 -Renovation/New in 2018
F14798	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, wide side	22	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	None	$ 5,000.00	Design in 2016/2017 -Renovation/New in 2018
F14799	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		None	$ 150.00	Design in 2016/2017 -Renovation/New in 2018
F14800	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		None	$ 150.00	Design in 2016/2017 -Renovation/New in 2018
F14801	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		None	$ 150.00	Design in 2016/2017 -Renovation/New in 2018
F14802	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment	Ambulatory	Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		None	$ 250.00	Design in 2016/2017 -Renovation/New in 2018
F14803	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		None	$ 250.00	Design in 2016/2017 -Renovation/New in 2018
F14804	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Coat Hook		Height	62	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	None	$ 150.00	Design in 2016/2017 -Renovation/New in 2018
F14805	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Coat Hook		Height	57	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	None	$ 150.00	Design in 2016/2017 -Renovation/New in 2018
F14806	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Height	53	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	None	$ 100.00	Design in 2016/2017 -Renovation/New in 2018
F14807	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Hand dryer	Height	52	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	None	$ 100.00	Design in 2016/2017 -Renovation/New in 2018
F14808	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Hand dryer	Height	49	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	None	$ 100.00	Design in 2016/2017 -Renovation/New in 2018

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14809	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Height	49.5	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	None	$ 100.00	Design in 2016/2017 -Renovation/New in 2018
F14810	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Height	50	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	None	$ 100.00	Design in 2016/2017 -Renovation/New in 2018
F14811	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Hand dryer	Height	49	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	None	$ 100.00	Design in 2016/2017 -Renovation/New in 2018
F14812	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Height	34.5	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	None	$ -	Within Tolerance (per Assessment)
F14813	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Height	34.5	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	None	$ -	Within Tolerance (per Assessment)
F14814	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Height, seat	19.5	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	None	$ 250.00	Design in 2016/2017 -Renovation/New in 2018
F14815	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Height, top	37	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	None	$ 250.00	Design in 2016/2017 -Renovation/New in 2018
F14816	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Height, top	37	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	None	$ 250.00	Design in 2016/2017 -Renovation/New in 2018
F14817	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Location	On door	No	Sign is not mounted in the correct location.	3-Restrooms	Move the sign to the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F14818	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Location	H	No	Sign is not mounted in the correct location.	3-Restrooms	Move the sign to the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F14819	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, accessible compartments	0	No	No accessible toilet compartment in restroom.	3-Restrooms	Rebuild or reconfigure the restroom, with a wheelchair accessible toilet compartment.	1 minimum	None	$ 7,500.00	Design in 2016/2017 -Renovation/New in 2018
F14820	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Opening force	14	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F14821	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F14822	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F15584	Public Works and Fleet		2nd Floor	Owned	Shower Room	Men's	3-Employee Common	Shower Compartment	Currently used as storage	Dimension, side to side	31	No	Transfer shower too narrow.	3-Restrooms	Redesign and remodel the shower compartment with compliant grab bars, seat, hose, and shower controls.	36 inches wide by 36 inches deep	None	$ 3,500.00	Design in 2016/2017 -Renovation/New in 2018
F15585	Public Works and Fleet		2nd Floor	Owned	Shower Room	Men's	3-Employee Common	Bench		Depth	11	No	Bench is not deep enough.	3-Restrooms	Provide a bench with a seat that is a minimum of 20 inches deep and a maximum of 24 inches deep.	20 to 24 inches	None	$ 500.00	Design in 2016/2017 -Renovation/New in 2018
F15586	Public Works and Fleet		2nd Floor	Owned	Shower Room	Men's	3-Employee Common	Shower Compartment	Currently used as storage	Dimension, side to side	33	No	Transfer shower too narrow.	3-Restrooms	Redesign and remodel the shower compartment with compliant grab bars, seat, hose, and shower controls.	36 inches wide by 36 inches deep	None	$ 3,500.00	Design in 2016/2017 -Renovation/New in 2018
F15592	Public Works and Fleet		2nd Floor	Owned	Shower Room	Women's	3-Employee Common	Shower Compartment		Dimension, side to side	31.5	No	Transfer shower too narrow.	3-Restrooms	Redesign and remodel the shower compartment with compliant grab bars, seat, hose, and shower controls.	36 inches wide by 36 inches deep	None	$ 3,500.00	Design in 2016/2017 -Renovation/New in 2018
F15593	Public Works and Fleet		2nd Floor	Owned	Shower Room	Women's	3-Employee Common	Door Gate		Clearance, pull parallel	9	No	Clearance on pull side of door is insufficient.	2-Services	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	None	$ 2,500.00	Design in 2016/2017 -Renovation/New in 2018
F15594	Public Works and Fleet		2nd Floor	Owned	Shower Room	Women's	3-Employee Common	Door Gate		Clearance, vertical	79.25	No	Vertical clearance is too low.	2-Services	Replace the doorway with a compliant vertical clearance.	80 inches minimum	None	$ 2,500.00	Design in 2016/2017 -Renovation/New in 2018
F15595	Public Works and Fleet		2nd Floor	Owned	Shower Room	Women's	3-Employee Common	Shower Compartment		Dimension, side to side	33	No	Transfer shower too narrow.	3-Restrooms	Redesign and remodel the shower compartment with compliant grab bars, seat, hose, and shower controls.	36 inches wide by 36 inches deep	None	$ 3,500.00	Design in 2016/2017 -Renovation/New in 2018
F16572	Public Works and Fleet		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Height, threshold	0.75	No	Threshold is too high.	1-Entry	Provide a threshold which is 0.25 inch maximum, or a beveled threshold which is 0.5 inch maximum, at the door entrance.	0.5 inch maximum	None	$ 250.00	Design in 2016/2017 -Renovation/New in 2018
F16574	Public Works and Fleet		Exterior	Owned	Walkway		1-Public Unsupervised	Walking Surface		Surface material	Dirt	No	Walking surface is not stable, firm, and slip resistant.	1-Entry	Provide an accessible route connecting the public sidewalk to the building entrance.		None	$ 5,000.00	Design in 2016/2017 -Renovation/New in 2018
F07032	Rotella Park		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Facility Specifications		Number, van spaces	0	No	Too few van accessible parking spaces are provided.	1-Entry	Provide the minimum number of required van accessible parking spaces.	1 minimum	2015	$ -	by Parks
F07060	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Slope, running	3.3%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2015	$ -	by Parks
F07061	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Van sign?	N	No	Van Accessible' sign is not present.	1-Entry	Install a 'Van Accessible' sign.		2015	$ -	by Parks
F07429	Rotella Park		Exterior	Owned	Play Area	#2 - Up the hill	1-Public Unsupervised	Area Specifications		Number, ground types on accessible route	0	No	Less than one of each type of ground level play component is on an accessible route.	2-Services	Provide not < 1 ground level play component of each (different) type with clear ground space at each. Provide an accessible route connecting perimeter of the play area to each ground level component required to be accessible.	1 of each type	2015	$ -	by Parks

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07430	Rotella Park		Exterior	Owned	Play Area	#2 - Up the hill	1-Public Unsupervised	Walking Surface		Surface material	Gravel	No	Surface of ground level route to ground level play components or to transfer system is not an accessible surface.	2-Services	Provide an accessible route connecting the perimeter of the play area to the entry point of the elevated composite play structures.		2015	$ -	by Parks
F07435	Rotella Park		Exterior	Owned	Play Area		1-Public Unsupervised	Area Specifications		Number, elevated components on accessible route	3	No	Too few elevated play components are provided on an accessible route.	2-Services	Provide not < 3 elevated play components on an accessible route. Alter structure or add an accessible Entry Point to composite structure so that not < 3 additional elevated components are on an accessible route, 36 inches wide.	5 minimum	2015	$ -	by Parks
F07436	Rotella Park		Exterior	Owned	Play Area		1-Public Unsupervised	Area Specifications		Number, ground types on accessible route	0	No	Less than one of each type of ground level play component is on an accessible route.	2-Services	Provide not < 3 ground level play components of each (different) type with clear ground space at each. Provide an accessible route connecting perimeter of play area to each ground level component required to be accessible.	3 of 3	2015	$ -	by Parks

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07437	Rotella Park		Exterior	Owned	Play Area		1-Public Unsupervised	Walking Surface		Surface material	Rubber tiles and sand	No	Surface of ground level route to ground level play components or to transfer system is not an accessible surface.	2-Services	Provide an accessible route connecting the perimeter of the play area to the entry point of the elevated composite play structures.		2015	$ -	by Parks
F14862	Rotella Park		Exterior	Owned	Restroom	Accessible Porta-Potty	1-Public Unsupervised	Water Closet		Dimension, wide side	41	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	n/a	$ -	by Parks
F15628	Rotella Park		Exterior	Owned	Sport Area	Basketball court	1-Public Unsupervised	Circulation Path		Surface material	Dirt	No	Walking surface is not stable, firm, and slip resistant.	2-Services	Provide an accessible route connecting the basketball court to the parking lot.		2015	$ -	by Parks
F15632	Rotella Park		Exterior	Owned	Sport Area	Volleyball Court	1-Public Unsupervised	Circulation Path		Surface material	Grass/Dirt	No	Walking surface is not stable, firm, and slip resistant.	2-Services	Provide an accessible route connecting the volleyball court to the parking lot.		2015	$ -	by Parks
F16575	Rotella Park		Exterior	Owned	Walkway	To play area #2 and Pavilion	1-Public Unsupervised	Ramp		Slope, running	9.7%	No	Slope is too steep.	1-Entry	Rebuild the ramp with a compliant running slope, cross slope, and landing.	8.33% maximum	2015	$ -	by Parks
F16576	Rotella Park		Exterior	Owned	Walkway	To play area #2 and Pavilion	1-Public Unsupervised	Walking Surface		Slope, running	9.7%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with compliant running and cross slopes, or install handrails, edge protection, and landings required for ramps.	5.0% maximum	2015	$ -	by Parks
F07116	Steele Street Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, van spaces	0	No	Too few van accessible parking spaces are provided.	1-Entry	Provide the minimum number of required van accessible parking spaces.	1 minimum	2020	$ 2,500.00	by Parks
F07117	Steele Street Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Slope, running	2.7%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	n/a	$ -	by Parks
F07118	Steele Street Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Slope, running	3.9%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2020	$ 5,000.00	by Parks
F07119	Steele Street Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Surface marking?	Faded	No	Paint is fading at parking space access aisle.	1-Entry	Repaint the faded access aisle to discourage use as a parking space.		2017	$ 100.00	by Parks
F00757	Strasburg Facility	Sheriff's Office	Interior	Owned	Break Room	North End	3-Employee Common	Appliance	Refrig/Freezer	Height	50	No	50% of freezer space is not below 54" AFF.	4-Other	Replace the existing refrig/freezer with a compliant refrig/freezer.	Side by side Refrig/Freezer	2020	$ 500.00	
F00758	Strasburg Facility	Sheriff's Office	Interior	Owned	Break Room	North End	2-Public Supervised	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2020	$ 2,500.00	
F00759	Strasburg Facility	Sheriff's Office	Interior	Owned	Break Room	North End	2-Public Supervised	Lavatory Sink		Height	36.5	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2020	$ 1,500.00	
F03486	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Signage		Braille?	N	No	Signage does not provide Braille.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F03487	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Exercise Equipment	Bench Press	Clear Floor Space	<30 by 48	No	Clear floor space is insufficient.	4-Other	Rearrange the exercise equipment to provide clear floor space between the exercise equipment.	30 inches wide by 48 inches long	2016	$ -	Internal Staff - Operations
F03488	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Exercise Equipment	Bowflex	Clear Floor Space	<30 by 48	No	Clear floor space is insufficient.	4-Other	Rearrange the exercise equipment to provide clear floor space between the exercise equipment.	30 inches wide by 48 inches long	2016	$ -	Internal Staff - Operations
F03489	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Exercise Equipment	Universal gym system	Clear Floor Space	<30 by 48	No	Clear floor space is insufficient.	4-Other	Rearrange the exercise equipment to provide clear floor space between the exercise equipment.	30 inches wide by 48 inches long	2016	$ -	Internal Staff - Operations
F03490	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Exercise Equipment	Sit up bench	Clear Floor Space	<30 by 48	No	Clear floor space is insufficient.	4-Other	Rearrange the exercise equipment to provide clear floor space between the exercise equipment.	30 inches wide by 48 inches long	2016	$ -	Internal Staff - Operations
F03491	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Exercise Equipment	Rotary Torso	Clear Floor Space	<30 by 48	No	Clear floor space is insufficient.	4-Other	Rearrange the exercise equipment to provide clear floor space between the exercise equipment.	30 inches wide by 48 inches long	2016	$ -	Internal Staff - Operations
F03492	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Exercise Equipment	Tread Mill	Clear Floor Space	<30 by 48	No	Clear floor space is insufficient.	4-Other	Rearrange the exercise equipment to provide clear floor space between the exercise equipment.	30 inches wide by 48 inches long	2016	$ -	Internal Staff - Operations
F03493	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Exercise Equipment	Elliptical	Clear Floor Space	<30 by 48	No	Clear floor space is insufficient.	4-Other	Rearrange the exercise equipment to provide clear floor space between the exercise equipment.	30 inches wide by 48 inches long	2016	$ -	Internal Staff - Operations
F03494	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Exercise Equipment	Curling machine	Clear Floor Space	<30 by 48	No	Clear floor space is insufficient.	4-Other	Rearrange the exercise equipment to provide clear floor space between the exercise equipment.	30 inches wide by 48 inches long	2016	$ -	Internal Staff - Operations
F03495	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Door Gate		Closing speed	3	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F03496	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Protrusion	Wall mounted TV	Dimension, protruding	18	No	Object protrudes into the path of travel.	4-Other	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2020	$ 250.00	
F03497	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Door Gate		Opening force	17	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F03498	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Signage		Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F03499	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Alarm System		Visible alarm	N	No	No visible alarm is provided.	4-Other	Install a visible wall fire alarm.	Between 80 and 96 inches AFF	2020	$ 250.00	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F04202	Strasburg Facility	Sheriff's Office	Interior	Owned	Holding Cell	Left of main entry	2-Public Supervised	Lavatory Sink	Combination lav/toilet	Clearance, parallel	24	No	Clear floor space is too narrow.	3-Restrooms	Reconfigure the lavatory sink to provide at least the minimum clear floor space.	30 inches minimum	2020	$ 5,000.00	
F04203	Strasburg Facility	Sheriff's Office	Interior	Owned	Holding Cell	Left of main entry	2-Public Supervised	Water Closet	Combination lav/toilet	Clearance, parallel	32	No	Clearance at water closet is too narrow.	3-Restrooms	Remodel the restroom to provide at least the minimum required width.	60 inches minimum	2020	$ 5,000.00	
F04204	Strasburg Facility	Sheriff's Office	Interior	Owned	Holding Cell	Left of main entry	2-Public Supervised	Bench		Clearance, perpendicular	34.5	No	Clear floor space is too short.	2-Services	Provide at least the minimum clear floor space at the bench.	48 inches minimum	2020	$ 5,000.00	
F04205	Strasburg Facility	Sheriff's Office	Interior	Owned	Holding Cell	Left of main entry	2-Public Supervised	Lavatory Sink	Combination lav/toilet	Clearance, perpendicular	34	No	Clear floor space is too short.	3-Restrooms	Reconfigure the lavatory sink to provide at least the minimum clear floor space.	48 inches minimum	2020	$ 5,000.00	
F04206	Strasburg Facility	Sheriff's Office	Interior	Owned	Holding Cell	Left of main entry	2-Public Supervised	Water Closet	Combination lav/toilet	Clearance, perpendicular	32	No	Toilet compartment is not deep enough.	3-Restrooms	Reconfigure the stall to provide a minimum of 56 inches in depth.	56 inches	2020	$ 5,000.00	
F04207	Strasburg Facility	Sheriff's Office	Interior	Owned	Holding Cell	Left of main entry	2-Public Supervised	Water Closet	Combination lav/toilet	Control force	18	No	Operating force is greater than the maximum force allowed.	3-Restrooms	Adjust the controls to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F04208	Strasburg Facility	Sheriff's Office	Interior	Owned	Holding Cell	Left of main entry	2-Public Supervised	Bench		Depth	18	No	Bench is not deep enough.	2-Services	Provide a bench with a seat that is a minimum of 20 inches deep and a maximum of 24 inches deep.	20 to 24 inches	2020	$ 1,000.00	
F04209	Strasburg Facility	Sheriff's Office	Interior	Owned	Holding Cell	Left of main entry	2-Public Supervised	Water Closet	Combination lav/toilet	Dimension, sidewall	14	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2020	$ 5,000.00	
F04210	Strasburg Facility	Sheriff's Office	Interior	Owned	Holding Cell	Left of main entry	2-Public Supervised	Bench		Height	20.25	No	Bench seat is too high.	3-Restrooms	Relocate the bench to the correct height.	17-19 inches	2020	$ 500.00	
F04211	Strasburg Facility	Sheriff's Office	Interior	Owned	Holding Cell	Left of main entry	2-Public Supervised	Water Closet	Combination lav/toilet	Height, seat	15.5	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2020	$ 250.00	
F04552	Strasburg Facility	Sheriff's Office	Interior	Owned	Lobby Reception	Within hallway at North side of building	2-Public Supervised	Vending Machine	Soda	Height, control	53	No	Operable part is out of reach range.	4-Other	Replace the Vending Machine with one that has operable parts within the reach range.	48 inches maximum	2016	$ -	Internal Staff - Operations
F04586	Strasburg Facility	Public Works Shops	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Height	42	No	Counter is too high.	2-Services	Provide a portion of the counter surface that is a minimum of 36 inches long and a maximum of 36 inches high above the finish floor.	36 inches	2020	$ 2,500.00	
F04803	Strasburg Facility	Public Works Shops	Interior	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Dimension, side to side	31	No	Transfer shower too narrow.	3-Restrooms	Redesign and remodel the shower compartment with compliant grab bars, seat, hose, and shower controls.	36 inches wide by 36 inches deep	2020	$ 5,000.00	
F04804	Strasburg Facility	Public Works Shops	Interior	Owned	Locker Room	Women's	3-Employee Common	Shower Compartment		Dimension, side to side	31	No	Transfer shower too narrow.	3-Restrooms	Redesign and remodel the shower compartment with compliant grab bars, seat, hose, and shower controls.	36 inches wide by 36 inches deep	2020	$ 5,000.00	
F04808	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Off weight room	3-Employee Common	Shower Compartment		Dimension, side to side	32.25	No	Transfer shower too narrow.	3-Restrooms	Redesign and remodel the shower compartment with compliant grab bars, seat, hose, and shower controls.	36 inches wide by 36 inches deep	2020	$ 5,000.00	
F04809	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Off weight room	3-Employee Common	Shower Compartment		Dimension, side to side	36.5	No	Transfer shower is too wide.	5-Tolerance	No action recommended - within construction tolerance.	36 inches	2020	$ -	Within Tolerance (per Assessment)
F04814	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Off weight room	3-Employee Common	Shower Compartment		Height, threshold	2	No	Threshold is too high.	3-Restrooms	Provide a threshold which is 0.25 inch maximum, or a beveled threshold which is 0.5 inch maximum, at the door entrance.	0.5 inch maximum	2020	$ 250.00	
F04835	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room		3-Employee Common	Bench		Back support?	N	No	No back support provided on fixed bench seat.	3-Restrooms	Provide a bench with a back support that extends from a point 2 inches maximum above the seat surface to a point 18 inches minimum above the seat surface.		2020	$ 500.00	
F04836	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room		3-Employee Common	Bench		Clearance, perpendicular	23.75	No	Clear floor space is too short.	3-Restrooms	Provide at least the minimum clear floor space at the bench.	48 inches minimum	2020	$ 250.00	
F04837	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room		3-Employee Common	Door Gate		Clearance, vertical	79.25	No	Vertical clearance is too low.	3-Restrooms	Replace the doorway with a compliant vertical clearance.	80 inches minimum	2020	$ 2,500.00	
F04838	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room		3-Employee Common	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F04839	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room		3-Employee Common	Bench		Depth	12	No	Bench is not deep enough.	3-Restrooms	Provide a bench with a seat that is a minimum of 20 inches deep and a maximum of 24 inches deep.	20 to 24 inches	2020	$ 250.00	
F04840	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room		3-Employee Common	Door Gate		Opening force	18	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F04841	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room		3-Employee Common	Signage		Other attribute	None	No	Braille and raised letter signage is not provided.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F04842	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room		3-Employee Common	Alarm System		Visible alarm	N	No	No visible alarm is provided.	3-Restrooms	Install a visible wall fire alarm.	Between 80 and 96 inches AFF	2020	$ 250.00	
F05178	Strasburg Facility	Sheriff's Office	Interior	Owned	Other Room	Processing/Intoxilyzer	2-Public Supervised	Signage		Braille?	N	No	Signage does not provide Braille.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F05179	Strasburg Facility	Sheriff's Office	Interior	Owned	Other Room	Processing/Intoxilyzer	2-Public Supervised	Door Gate		Clearance, pull parallel	3	No	Clearance on pull side of door is insufficient.	2-Services	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2020	$ 3,500.00	
F05180	Strasburg Facility	Sheriff's Office	Interior	Owned	Other Room	Processing/Intoxilyzer	2-Public Supervised	Door Gate		Clearance, vertical	79.25	No	Vertical clearance is too low.	2-Services	Replace the doorway with a compliant vertical clearance.	80 inches minimum	2020	$ 2,500.00	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05181	Strasburg Facility	Sheriff's Office	Interior	Owned	Other Room	Processing/Intoxilyzer	2-Public Supervised	Signage		Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	2-Services	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F07134	Strasburg Facility	Sheriff's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, van spaces	0	No	Too few van accessible parking spaces are provided.	1-Entry	Provide the minimum number of required van accessible parking spaces.	1 minimum	2017	$ 50.00	Part of Annual Parking project
F07135	Strasburg Facility	Sheriff's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Slope, running	2.6%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F07158	Strasburg Facility	Public Works Shops	Exterior	Owned	Parking Facility	Public Works Shops	1-Public Unsupervised	Facility Specifications		Number, accessible	0	No	Too few accessible parking spaces and van accessible parking spaces.	1-Entry	Provide a minimum of one accessible parking space, which should also be a van accessible size space.	1 minimum	2017	$ 50.00	Part of Annual Parking project
F07159	Strasburg Facility	Public Works Shops	Exterior	Owned	Parking Facility	Public Works Shops	1-Public Unsupervised	Facility Specifications		Number, van spaces	0	No	Too few van accessible parking spaces are provided.	1-Entry	Provide the minimum number of required van accessible parking spaces.	1 minimum	2017	$ 50.00	Part of Annual Parking project
F14870	Strasburg Facility	Public Works Shops	Interior	Owned	Restroom	Men's	3-Employee Common	Door Gate		Clear opening	31	No	Clear opening is too narrow.	3-Restrooms	Reframe the doorway to provide a compliant clear opening width. Offset hinges may be used to facilitate the process.	32 inches minimum	2020	$ 2,500.00	
F14871	Strasburg Facility	Public Works Shops	Interior	Owned	Restroom	Men's	3-Employee Common	Fixture Count		Number, accessible compartments	0	No	No accessible toilet compartment in restroom.	3-Restrooms	Rebuild or reconfigure the restroom, with a wheelchair accessible toilet compartment.	1 minimum	2020	$ 5,000.00	
F14872	Strasburg Facility	Public Works Shops	Interior	Owned	Restroom	Women's	3-Employee Common	Door Gate		Clear opening	31	No	Clear opening is too narrow.	3-Restrooms	Reframe the doorway to provide a compliant clear opening width. Offset hinges may be used to facilitate the process.	32 inches minimum	2020	$ 2,500.00	
F14873	Strasburg Facility	Public Works Shops	Interior	Owned	Restroom	Women's	3-Employee Common	Fixture Count		Number, accessible compartments	0	No	No accessible toilet compartment in restroom.	3-Restrooms	Rebuild or reconfigure the restroom, with a wheelchair accessible toilet compartment.	1 minimum	2020	$ 5,000.00	
F14887	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Signage		Braille?	N	No	Signage does not provide Braille.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F14888	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Door Gate		Clearance, push perpendicular	45	No	Clearance on push side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	48 inches minimum	2020	$ 3,500.00	
F14889	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Door Gate		Clearance, vertical	79.25	No	Vertical clearance is too low.	3-Restrooms	Replace the doorway with a compliant vertical clearance.	80 inches minimum	2020	$ 2,500.00	
F14890	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Door Gate		Closing speed	3	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F14891	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Rear	Dimension, end to wall	5.25	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2020	$ 250.00	
F14892	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Protrusion	PT	Dimension, protruding	10	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2020	$ 250.00	
F14893	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Water Closet		Dimension, wide side	26	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2020	$ 5,000.00	
F14895	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Door Gate		Opening force	11	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F14896	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Signage		Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F14897	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Alarm System		Visible alarm	N	No	No visible alarm is provided.	3-Restrooms	Install a visible wall fire alarm.	Between 80 and 96 inches AFF	2020	$ 250.00	
F14945	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Signage		Braille?	N	No	Signage does not provide Braille.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F14946	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Door Gate		Clearance, push perpendicular	45	No	Clearance on push side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	48 inches minimum	2020	$ 3,500.00	
F14947	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Door Gate		Clearance, vertical	79.25	No	Vertical clearance is too low.	3-Restrooms	Replace the doorway with a compliant vertical clearance.	80 inches minimum	2020	$ 3,500.00	
F14948	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Door Gate		Closing speed	3	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F14949	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Water Closet		Dimension, sidewall	15.25	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2020	$ 5,000.00	
F14951	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		2020	$ 500.00	
F14952	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Door Gate		Opening force	16	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F14953	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Signage		Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14954	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Alarm System		Visible alarm	N	No	No visible alarm is provided.	3-Restrooms	Install a visible wall fire alarm.	Between 80 and 96 inches AFF	2020	$ 350.00	Install Device
F16602	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	1-Entry	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F16603	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		2-Public Supervised	Door Gate	Secured double door entrance	Closing speed	3	No	Closing speed is too fast.	1-Entry	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F16604	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Opening force	13	No	Opening force is too high.	1-Entry	Although exterior door force is not covered under the ADA, it is recommended that this be adjusted or install an automatic door opener.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F16605	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		2-Public Supervised	Door Gate	Secured double door entrance	Opening force	8	No	Opening force is too high.	1-Entry	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F16606	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp		Slope, cross	2.4%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	2017	$ 5,000.00	Part of Annual Parking project
F16607	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Landing		Slope, cross	3.6%	No	Slope is too steep.	1-Entry	Rebuild the landing to provide compliant running and cross slopes.	2.08% maximum	2017	$ 2,500.00	Part of Annual Parking project
F16608	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp		Slope, left flare	10.7%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	10% maximum	2017	$ 5,000.00	Part of Annual Parking project
F16609	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp		Slope, right flare	14.0%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp with compliant side flares.	10% maximum	2017	$ 5,000.00	Part of Annual Parking project
F16610	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp		Slope, running	10.9%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp, curb, and gutter to provide compliant running slope.	8.33% maximum	2017	$ 5,000.00	Part of Annual Parking project
F16611	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Landing		Slope, running	2.3%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F07164	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, van spaces	0	No	Too few van accessible parking spaces are provided.	1-Entry	Provide the minimum number of required van accessible parking spaces.	1 minimum	2018	$ -	by Parks
F07165	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Slope, cross	2.2%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	2018	$ -	by Parks
F07446	Twin Lakes Park		Exterior	Owned	Play Area		1-Public Unsupervised	Area Specifications		Number, ground components	0	No	Too few ground level play components are provided on an accessible route.	2-Services	Provide not < 2 ground level play components of not < 2 different types with clear ground space at each. Provide an accessible route connecting the perimeter of the play area to each ground level component required to be accessible.	2 of 2	2018	$ -	by Parks
F07447	Twin Lakes Park		Exterior	Owned	Play Area		1-Public Unsupervised	Walking Surface		Surface material	Gravel	No	Surface of ground level route to ground level play components or to transfer system is not an accessible surface.	2-Services	Provide an accessible route connecting the perimeter of the play area to the entry point of the elevated composite play structures.		2018	$ -	by Parks
F14994	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2018	$ -	by Parks
F14995	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	PT	Height	55	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2018	$ -	by Parks
F14996	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Location	On door	No	Sign is not mounted in the correct location.	3-Restrooms	Move the sign to the latch side of the door.		2018	$ -	by Parks
F14997	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		2018	$ -	by Parks
F15027	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	39	No	Clearance on push side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	48 inches minimum	2018	$ -	by Parks
F15028	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	12	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2018	$ -	by Parks
F15029	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	5	No	Grab bar is not mounted in correct location.	3-Restrooms	Move grab bar: side wall grab bar must be a minimum of 42 inches long, located a minimum of 12 inches from the rear wall, and extending a minimum of 54 inches from the rear wall.	12 inches maximum	2018	$ -	by Parks
F15030	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	3	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2018	$ -	by Parks
F15031	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, wide side	27	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2018	$ -	by Parks
F15032	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2018	$ -	by Parks
F15033	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Height, bottom	64.25	No	Signage is too high.	3-Restrooms	Remount sign with tactile letters located 48 inches minimum and 60 inches maximum, above the finished floor, measured from the baseline of the tactile letters.	48 to 60 inches	2018	$ -	by Parks
F15034	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Height, seat	16.5	No	Toilet seat height is not compliant.	3-Restrooms	Adjust or modify the toilet so the seat height is at the required accessible height.	17-19 inches	2018	$ -	by Parks

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15035	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Length	30	No	Rear grab bar is too short.	3-Restrooms	Replace the grab bar with a 36 inch long minimum grab bar.	36 inches minimum	2018	$ -	by Parks
F15036	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Location	On door	No	Sign is not mounted in the correct location.	3-Restrooms	Move the sign to the latch side of the door.		2018	$ -	by Parks
F15037	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		2018	$ -	by Parks
F15038	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Over obstruction?	Y	No	Toilet paper dispenser is mounted above the grab bar.	3-Restrooms	Move the toilet paper dispenser to a compliant position under the grab bar.		2018	$ -	by Parks
F16638	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	#1	Landing?	N	No	No landing provided at top of curb ramp.	1-Entry	Provide a landing at the top of the curb ramp that is the same width as the curb ramp and at least 36 inches long.		2018	$ -	by Parks
F16639	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp		Slope, left flare	12.1%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp with compliant side flares.	10% maximum	2018	$ -	by Parks
F16640	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	#1	Slope, left flare	10.6%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	10% maximum	2018	$ -	by Parks
F16641	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp		Slope, right flare	15.4%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp with compliant side flares.	10% maximum	2018	$ -	by Parks
F16642	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	#2	Slope, right flare	15.7%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp with compliant side flares.	10% maximum	2018	$ -	by Parks
F16643	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	#1	Slope, right flare	14.7%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp with compliant side flares.	10% maximum	2018	$ -	by Parks
F00772	Western Service Center	ACED	1st Floor	Owned	Break Room		3-Employee Common	Door Gate		Clearance, pull parallel	3	No	Clearance on pull side of door is insufficient.	2-Services	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2018	$ 3,500.00	
F00780	Western Service Center	DMV	1st Floor	Owned	Break Room		3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2018	$ 2,500.00	
F00781	Western Service Center	DMV	1st Floor	Owned	Break Room		3-Employee Common	Dispenser	PT	Height	52	No	Dispenser is too high.	2-Services	Relocate the dispenser to the correct height.	48 inches maximum	2018	$ 100.00	Relocate or Replace Dispenser
F00782	Western Service Center	DMV	1st Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Height	36	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2018	$ 1,500.00	
F00785	Western Service Center		2nd Floor	Owned	Break Room		3-Employee Common	Door Gate		Clearance, pull parallel	3	No	Clearance on pull side of door is insufficient.	2-Services	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2018	$ 3,500.00	
F00786	Western Service Center		2nd Floor	Owned	Break Room		3-Employee Common	Counter		Height	36	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2018	$ 2,500.00	
F00787	Western Service Center		3rd Floor	Owned	Break Room		3-Employee Common	Dispenser	PT	Height	55	No	Dispenser is too high.	2-Services	Relocate the dispenser to the correct height.	48 inches maximum	2018	$ 100.00	Relocate or Replace Dispenser
F00788	Western Service Center		3rd Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Height	36	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2018	$ 1,500.00	
F00789	Western Service Center		2nd Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Height	36	No	Lavatory sink is too high.	2-Services	Lower the lavatory sink to the correct height.	34 inches maximum	2018	$ 1,500.00	
F00790	Western Service Center		3rd Floor	Owned	Break Room		3-Employee Common	Vending Machine	Snacks	Height, control	53	No	Operable part is out of reach range.	4-Other	Replace the Vending Machine with one that has operable parts within the reach range.	48 inches maximum	2016	$ -	Internal Staff - Operations
F00791	Western Service Center		3rd Floor	Owned	Break Room		3-Employee Common	Vending Machine	Coke	Height, control	50	No	Operable part is out of reach range.	4-Other	Replace the Vending Machine with one that has operable parts within the reach range.	48 inches maximum	2016	$ -	Internal Staff - Operations
F00792	Western Service Center		2nd Floor	Owned	Break Room		3-Employee Common	Vending Machine	Pepsi	Height, control	52	No	Operable part is out of reach range.	4-Other	Replace the Vending Machine with one that has operable parts within the reach range.	48 inches maximum	2016	$ -	Internal Staff - Operations
F00793	Western Service Center		2nd Floor	Owned	Break Room		3-Employee Common	Alarm System		Visible alarm	N	No	No visible alarm is provided.	4-Other	Install a visible wall fire alarm.	Between 80 and 96 inches AFF	2018	$ 350.00	
F03447	Western Service Center		1st Floor	Owned	Elevator		1-Public Unsupervised	Hoistway Sign		Both jambs?	N	No	Floor designation signs are not provided on either side of hoistway frame.	2-Services	Install a hoistway sign on both hoistway jams, with raised letters, Braille, and a tactile Star.		2018	$ 350.00	
F03448	Western Service Center		1st Floor	Owned	Elevator		1-Public Unsupervised	Hoistway Sign		Braille?	N	No	Signage does not provide Braille.	2-Services	Install a hoistway sign on both hoistway jams, with raised letters, Braille, and a tactile Star.		2018	$ 350.00	
F03449	Western Service Center		1st Floor	Owned	Elevator		1-Public Unsupervised	Car Controls		Height, emergency control	36	No	Emergency control is too high.	2-Services	Relocate the emergency control to provide centerline height of 35 inches.	35 inches	2018	$ 500.00	
F03450	Western Service Center		1st Floor	Owned	Elevator		1-Public Unsupervised	Hoistway Sign		Tactile letters?	N	No	Signage does not provide tactile letters.	2-Services	Install a hoistway sign on both hoistway jams, with raised letters, Braille, and a tactile Star.		2018	$ 350.00	
F03451	Western Service Center		1st Floor	Owned	Elevator		1-Public Unsupervised	Car Controls		Tactile?	N	No	Tactile characters are not provided.	2-Services	Install tactile characters to identify control buttons.		2018	$ 350.00	
F03703	Western Service Center	DMV	Interior	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near restrooms	Dimension, knee clearance	26	No	Knee clearance is too low.	4-Other	Provide 27 inches of knee clearance, 8 inches deep from the front edge.	27 inches	2018	$ 1,500.00	
F03704	Western Service Center	DMV	Interior	Owned	Hallway		1-Public Unsupervised	Protrusion	Drinking Fountain near restroom	Dimension, protruding	19	No	Object protrudes into the path of travel.	4-Other	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the fountain, recess the fountain into the wall, or install cane detection to prevent injury.		2018	$ 250.00	
F03705	Western Service Center	DMV	Interior	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near restrooms	High-low fountain?	N	No	Fountain provided is not a hi/low fountain.	4-Other	No action recommended - this element has safe harbor.		None	$ -	Within Tolerance (per Assessment)
F04100	Western Service Center		1st Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near rear restrooms	Dimension, knee clearance	26.5	No	Knee clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	27 inches	None	$ -	Within Tolerance (per Assessment)

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F04101	Western Service Center		1st Floor	Owned	Hallway		1-Public Unsupervised	Vending Machine	Snacks	Height	51	No	Operable part is out of reach range.	4-Other	Replace the Vending Machine with one that has operable parts within the reach range.	48 inches maximum	2016	$ -	Internal Staff - Operations
F04102	Western Service Center		1st Floor	Owned	Hallway		1-Public Unsupervised	Vending Machine	Coke	Height, control	50	No	Operable part is out of reach range.	4-Other	Replace the Vending Machine with one that has operable parts within the reach range.	48 inches maximum	2016	$ -	Internal Staff - Operations
F04103	Western Service Center		1st Floor	Owned	Hallway		1-Public Unsupervised	Protrusion	Under Stairs	Height	66.5	No	Object protrudes into the path of travel.	2-Services	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F04556	Western Service Center	DMV	1st Floor	Owned	Lobby Reception		1-Public Unsupervised	Counter	Info Counter	Height	42	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2018	$ 2,500.00	
F04559	Western Service Center		3rd Floor	Owned	Lobby Reception	Diversion	1-Public Unsupervised	Door Gate		Clearance, pull parallel	8	No	Clearance on pull side of door is insufficient.	2-Services	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2018	$ 3,500.00	
F04560	Western Service Center		3rd Floor	Owned	Lobby Reception	Diversion	1-Public Unsupervised	Door Gate		Opening force	17	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F04565	Western Service Center		2nd Floor	Owned	Lobby Reception	Probation	1-Public Unsupervised	Door Gate		Closing speed	3	No	Closing speed is too fast.	2-Services	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F04566	Western Service Center		2nd Floor	Owned	Lobby Reception	Probation	1-Public Unsupervised	Door Gate		Opening force	9	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F04574	Western Service Center		1st Floor	Owned	Lobby Reception		1-Public Unsupervised	Counter	Unused Lobby Counter	Height	42.5	No	Counter is too high. No equivalent facilitation is provided in the area.	2-Services	Provide a counter that is a minimum of 36 inches wide and a maximum of 36 inches high above the finished floor.	36 inches maximum	2018	$ 2,500.00	
F04856	Western Service Center		2nd Floor	Owned	Locker Room	Employee Showers	3-Employee Common	Bench		Back support?	N	No	No back support provided on fixed bench seat.	3-Restrooms	Provide a bench with a back support that extends from a point 2 inches maximum above the seat surface to a point 18 inches minimum above the seat surface.		2018	$ 500.00	
F04857	Western Service Center		2nd Floor	Owned	Locker Room	Employee Showers	3-Employee Common	Lavatory Sink		Clearance, parallel	27	No	Clear floor space is too narrow.	3-Restrooms	Reconfigure the lavatory sink to provide at least the minimum clear floor space.	30 inches minimum	2018	$ 1,500.00	
F04858	Western Service Center		2nd Floor	Owned	Locker Room	Employee Showers	3-Employee Common	Door Gate		Clearance, pull perpendicular	47	No	Clearance on pull side of door is insufficient.	3-Restrooms	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	2018	$ 3,500.00	
F04859	Western Service Center		2nd Floor	Owned	Locker Room	Employee Showers	3-Employee Common	Bench		Depth	9.5	No	Bench is not deep enough.	3-Restrooms	Provide a bench with a seat that is a minimum of 20 inches deep and a maximum of 24 inches deep.	20 to 24 inches	2018	$ 500.00	
F04860	Western Service Center		2nd Floor	Owned	Locker Room	Employee Showers	3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2018	$ 150.00	
F04861	Western Service Center		2nd Floor	Owned	Locker Room	Employee Showers	3-Employee Common	Lavatory Sink		Height	35	No	Lavatory sink is too high.	3-Restrooms	Lower the lavatory sink to the correct height.	34 inches maximum	2018	$ 1,500.00	
F04862	Western Service Center		2nd Floor	Owned	Locker Room	Employee Showers	3-Employee Common	Mirror		Height, bottom	42	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2018	$ 250.00	Relocate or Replace Mirror
F05689	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Sign?	N	No	No accessible signage provided.	1-Entry	Install a sign, at the head of the parking space, which includes an ISA symbol and measures 60 inches minimum above the ground surface, measured to the bottom of the sign.	60 inches minimum	2018	$ 150.00	Part of Annual Parking project
F05690	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#2	Slope, cross	2.4%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F05691	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Slope, running	3.5%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2018	$ 2,500.00	Part of Annual Parking project
F05692	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Slope, running	2.6%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F05693	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Slope, running	3.0%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2018	$ 2,500.00	Part of Annual Parking project
F05694	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Slope, running	3.5%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2018	$ 2,500.00	Part of Annual Parking project
F07216	Western Service Center	ACED	Exterior	Owned	Parking Facility	Underground parking	5-Tenant Common	Facility Specifications		Number, accessible	0	No	Too few accessible parking spaces and van accessible parking spaces.	1-Entry	Provide a minimum of one accessible parking space, which should also be a van accessible size space.	1 minimum	2018	$ 50.00	Part of Annual Parking project
F07217	Western Service Center	ACED	Exterior	Owned	Parking Facility	Underground parking	5-Tenant Common	Facility Specifications		Number, van spaces	0	No	Too few van accessible parking spaces are provided.	1-Entry	Provide the minimum number of required van accessible parking spaces.	1 minimum	2018	$ 50.00	Part of Annual Parking project
F07219	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Access Aisle	#2	Slope, running	3.5%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2018	$ 2,500.00	Part of Annual Parking project

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07220	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Access Aisle	Left space	Slope, running	4.1%	No	Slope is too steep.	1-Entry	Regrade the access aisle or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2018	$ 2,500.00	Part of Annual Parking project
F07221	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Parking Space	#4	Slope, running	2.3%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	2.08% maximum	None	$ -	Within Tolerance (per Assessment)
F07222	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Parking Space	#2	Slope, running	3.2%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2018	$ 2,500.00	Part of Annual Parking project
F07223	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Parking Space	#3	Slope, running	3.7%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2018	$ 2,500.00	Part of Annual Parking project
F07292	Western Service Center		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Slope, cross	4.2%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2018	$ 2,500.00	Part of Annual Parking project
F07293	Western Service Center		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Slope, running	6.1%	No	Slope is too steep.	1-Entry	Regrade the parking space or move accessible parking spaces and aisles to a level area of the parking lot (slopes not > 1:48, 2.08%).	2.08% maximum	2018	$ 2,500.00	Part of Annual Parking project
F09330	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, pull parallel	15.5	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2018	$ 3,500.00	
F09331	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	48	No	Clearance on pull side of door is insufficient.	3-Restrooms	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	2018	$ 3,500.00	
F09332	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	3.75	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2018	$ 250.00	
F09333	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Protrusion	PT	Dimension, protruding	9.5	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F09334	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, sidewall	18.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2018	$ 5,000.00	
F09335	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, wide side	39.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2018	$ 5,000.00	
F09336	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	Toilet seat covers	Height	55.5	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2018	$ 100.00	Relocate or Replace Dispenser
F09337	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Length	30	No	Rear grab bar is too short.	3-Restrooms	Replace the grab bar with a 36 inch long minimum grab bar.	36 inches minimum	2018	$ 250.00	
F09338	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Alarm System		Visible alarm	N	No	No visible alarm is provided.	3-Restrooms	Install a visible wall fire alarm.	Between 80 and 96 inches AFF	2018	$ 350.00	
F09379	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, pull parallel	16	No	Clearance on pull side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2018	$ 3,500.00	
F09380	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	48	No	Clearance on pull side of door is insufficient.	3-Restrooms	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	2018	$ 3,500.00	
F09381	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	4	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2018	$ 250.00	
F09382	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Protrusion	PT	Dimension, protruding	9.5	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F09383	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, wide side	38.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2018	$ 5,000.00	
F09384	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Toilet seat covers	Height	59.5	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2018	$ 100.00	Relocate or Replace Dispenser
F09385	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Height, top	36.25	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	2018	$ 250.00	
F09386	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Height, top	36.25	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	2018	$ 250.00	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09387	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Length	30	No	Rear grab bar is too short.	3-Restrooms	Replace the grab bar with a 36 inch long minimum grab bar.	36 inches minimum	2018	$ 250.00	
F09388	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		2018	$ 500.00	
F09389	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Alarm System		Visible alarm	N	No	No visible alarm is provided.	3-Restrooms	Install a visible wall fire alarm.	Between 80 and 96 inches AFF	2018	$ 350.00	
F15080	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Toilet Compartment		Dimension, door to partition	5	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2018	$ 2,500.00	
F15081	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Protrusion	PT	Dimension, protruding	9	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F15082	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Door Gate		Opening force	10	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F15083	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2018	$ 150.00	
F15124	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Protrusion	PT	Dimension, protruding	10	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	
F15125	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2018	$ 250.00	
F15126	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Mirror		Height, bottom	40.25	No	Mirror is too high.	5-Tolerance	No action recommended - within construction tolerance.	40 inches maximum	2018	$ 250.00	Relocate or Replace Mirror
F15127	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Opening force	13	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F15128	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2018	$ 150.00	
F15157	Western Service Center	DMV	1st Floor	Owned	Restroom	Unisex	3-Employee Common	Dispenser	TP	Dimension from water closet seat	10	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2018	$ 100.00	Relocate or Replace Dispenser
F15158	Western Service Center	DMV	1st Floor	Owned	Restroom	Unisex	3-Employee Common	Dispenser	PT	Height	54	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2018	$ 100.00	Relocate or Replace Dispenser
F15159	Western Service Center	DMV	1st Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Side	Other attribute	None Provided	No	No grab bars provided.	3-Restrooms	Install grab bars on the rear and side wall.		2018	$ 250.00	
F15160	Western Service Center	DMV	1st Floor	Owned	Restroom	Unisex	3-Employee Common	Alarm System		Visible alarm	N	No	No visible alarm is provided.	3-Restrooms	Install a visible wall fire alarm.	Between 80 and 96 inches AFF	2018	$ 350.00	
F15168	Western Service Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	45	No	Clearance on pull side of door is insufficient.	3-Restrooms	Alter the pull side of the door to provide a compliant clearance measured perpendicular to the door.	60 inches minimum	2018	$ 3,500.00	
F15169	Western Service Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Closing speed	3	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F15170	Western Service Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Hardware type	Twist	No	Hardware requires twisting of wrist.	3-Restrooms	Install lever type door hardware.		2018	$ 500.00	
F15171	Western Service Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Opening force	10	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F15172	Western Service Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2018	$ 150.00	
F15173	Western Service Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2018	$ 250.00	
F15188	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Signage	All Signage	Braille?	N	No	Signage does not provide Braille.	3-Restrooms	Install all room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	
F15189	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	43	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	2018	$ 2,500.00	
F15190	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	4	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2018	$ 100.00	Relocate or Replace Dispenser
F15191	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	5.5	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2018	$ 2,500.00	
F15192	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12.5	No	Grab bar is not mounted in correct location.	5-Tolerance	No action recommended - within construction tolerance.	12 inches maximum	2018	$ 250.00	Rework Grab bars

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15193	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	13	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2018	$ 250.00	Rework Grab bars
F15194	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Protrusion	PT	Dimension, protruding	9	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 150.00	Relocate or Replace Dispenser
F15195	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Water Closet		Dimension, sidewall	27.75	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2018	$ 5,000.00	Rework Toilet
F15196	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Water Closet		Dimension, wide side	16	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2018	$ 7,500.00	Rework Layout
F15197	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2018	$ 2,500.00	Rework Partition
F15198	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Dispenser	PT	Height	55.5	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2018	$ 100.00	Relocate or Replace Dispenser
F15199	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Height, top	37	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	2018	$ 250.00	Rework Grab bars
F15200	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Length	30	No	Rear grab bar is too short.	3-Restrooms	Replace the grab bar with a 36 inch long minimum grab bar.	36 inches minimum	2018	$ 250.00	Rework Grab bars
F15201	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Opening force	12	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F15202	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Signage	All Signage	Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	3-Restrooms	Install all room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F15246	Western Service Center		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	44	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	2018	$ 2,500.00	Rework Partition
F15247	Western Service Center		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Protrusion	PT	Dimension, protruding	9	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	Relocate or Replace Dispenser
F15248	Western Service Center		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, sidewall	27	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2018	$ 5,000.00	Rework Layout
F15249	Western Service Center		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, wide side	17.5	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2018	$ 7,500.00	Rework Layout
F15250	Western Service Center		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2018	$ 250.00	Rework Partition
F15251	Western Service Center		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Coat Hook		Height	66	No	Coat hook is too high.	3-Restrooms	Lower the coat hook to a compliant height.	48 inches maximum	2018	$ 150.00	Rework Coat Hook
F15252	Western Service Center		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Height	54	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2018	$ 100.00	Relocate or Replace Dispenser
F15253	Western Service Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2018	$ 250.00	Rework Partition
F15254	Western Service Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2018	$ 250.00	Rework Partition
F15260	Western Service Center		2nd Floor	Owned	Restroom	Women's - Employee	3-Employee Common	Lavatory Sink		Clearance, parallel	28	No	Clear floor space is too narrow.	3-Restrooms	Reconfigure the lavatory sink to provide at least the minimum clear floor space.	30 inches minimum	2018	$ 250.00	Rework Lavatory
F15261	Western Service Center		2nd Floor	Owned	Restroom	Women's - Employee	3-Employee Common	Toilet Compartment	Two identical stalls	Clearance, parallel	31	No	Toilet compartment is too narrow.	3-Restrooms	Provide a wheelchair accessible toilet compartment with the required width.	60 inches minimum	2018	$ 2,500.00	Rework Partition
F15262	Western Service Center		2nd Floor	Owned	Restroom	Women's - Employee	3-Employee Common	Toilet Compartment	Two identical stalls	Clearance, perpendicular	54	No	Toilet compartment is not deep enough.	3-Restrooms	Reconfigure the stall to provide a minimum of 56 inches in depth.	56 inches	2018	$ 2,500.00	Rework Partition
F15263	Western Service Center		2nd Floor	Owned	Restroom	Women's - Employee	3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2018	$ 150.00	Add Pipe Wrap
F15264	Western Service Center		2nd Floor	Owned	Restroom	Women's - Employee	3-Employee Common	Lavatory Sink		Height	35	No	Lavatory sink is too high.	3-Restrooms	Lower the lavatory sink to the correct height.	34 inches maximum	2018	$ 2,500.00	Rework Lavatory
F15265	Western Service Center		2nd Floor	Owned	Restroom	Women's - Employee	3-Employee Common	Mirror		Height, bottom	42	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2018	$ 250.00	Relocate or Replace Mirror
F15266	Western Service Center		2nd Floor	Owned	Restroom	Women's - Employee	3-Employee Common	Door Gate		Opening force	11	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F15274	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Signage		Braille?	N	No	Signage does not provide Braille.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15275	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	48	No	Toilet compartment is not deep enough.	3-Restrooms	Reconfigure the stall to provide a minimum of 56 inches in depth.	56 inches	2018	$ 2,500.00	Rework Partition
F15276	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Clearance, push parallel	7	No	Clearance on push side of door is insufficient.	3-Restrooms	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	22 inches minimum	2018	$ 2,500.00	Replace Door
F15277	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	10	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2018	$ 100.00	Relocate or Replace Dispenser
F15278	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Dimension, between	.25	No	Space between the grab bar and dispenser above is too small.	3-Restrooms	Moving the dispenser to a minimum of 12 inches above the grab bar will place the dispenser out of reach range. Relocate the dispenser to another location.	Between 15 and 48 inches	2018	$ 250.00	Relocate or Replace Dispenser
F15279	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	13	No	Door is located in front of water closet.	3-Restrooms	Reconfigure or relocate the toilet compartment door to the correct location.	4 inches maximum from wall or partition	2018	$ 2,500.00	Rework Partition
F15280	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2018	$ 250.00	Rework Partition
F15281	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Dispenser	PT	Height	55	No	Dispenser is too high.	3-Restrooms	Relocate the dispenser to the correct height.	48 inches maximum	2018	$ 100.00	Relocate or Replace Dispenser
F15282	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Grab Bar	Side	Length	30	No	Side grab bar length is too short.	3-Restrooms	Replace the grab bar with a 42 inch long minimum grab bar.	42 inches minimum	2018	$ 250.00	Rework Grab bars
F15283	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Opening force	10	No	Opening force is too high.	3-Restrooms	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F15284	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Signage		Tactile letters?	N	No	Tactile signage is not provided at this permanently designated room.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2016	$ 100.00	Internal Staff - Operations
F15285	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Alarm System		Visible alarm	N	No	No visible alarm is provided.	3-Restrooms	Install a visible wall fire alarm.	Between 80 and 96 inches AFF	2018	$ 350.00	Install Alarm Device
F15597	Western Service Center		2nd Floor	Owned	Shower Room	Employee Showers	3-Employee Common	Door Gate		Opening force	10	No	Opening force is too high.	2-Services	Adjust the door closer to the required amount of force allowed.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F15598	Western Service Center		2nd Floor	Owned	Shower Room	Employee Showers	3-Employee Common	Shower Compartment		Dimension, entry to back wall	28	No	No accessible shower provided.	3-Restrooms	Install an accessible transfer or roll-in shower.		2018	$ 3,500.00	Rework Shower
F15599	Western Service Center		2nd Floor	Owned	Shower Room	Employee Showers	3-Employee Common	Shower Compartment		Dimension, side to side	28	No	Transfer shower too narrow.	3-Restrooms	Redesign and remodel the shower compartment with compliant grab bars, seat, hose, and shower controls.	36 inches wide by 36 inches deep	2018	$ 3,500.00	Rework Shower
F15600	Western Service Center		2nd Floor	Owned	Shower Room	Employee Showers	3-Employee Common	Walking Surface	Path of travel to showers	Width	24	No	Walking surface is too narrow.	2-Services	Relocate or replace the bench to provide an accessible route to the shower.	36 inches minimum	2018	$ 2,500.00	Relocate Equipment
F15866	Western Service Center	DMV	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	7	No	Smooth surface at bottom edge of door is insufficient.	1-Entry	No action recommended - this element has safe harbor.	10 inches minimum	None	$ -	Within Tolerance (per Assessment)
F16671	Western Service Center	DMV	Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate		Clearance, push parallel	6.5	No	Clearance on push side of door is insufficient.	1-Entry	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	22 inches minimum	2018	$ 5,000.00	Replace Door
F16672	Western Service Center	DMV	Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate		Closing speed	3	No	Closing speed is too fast.	1-Entry	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F16673	Western Service Center	DMV	Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate		Opening force	14	No	Opening force is too high.	1-Entry	Although exterior door force is not covered under the ADA, it is recommended that this be adjusted or install an automatic door opener.	5 lbs maximum	2016	$ -	Internal Staff - Operations
F16674	Western Service Center	DMV	Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate		Height, threshold	0.75	No	Threshold is too high.	1-Entry	Provide a threshold which is 0.25 inch maximum, or a beveled threshold which is 0.5 inch maximum, at the door entrance.	0.5 inch maximum	2018	$ 250.00	Replace Threshold
F16682	Western Service Center		Exterior	Owned	Walkway	From East parking lot to entrance	3-Employee Common	Walking Surface		Slope, cross	3.8%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with a compliant cross slope.	2.08% maximum	2018	$ 5,000.00	Part of Annual Parking project
F16683	Western Service Center		Exterior	Owned	Walkway	From East parking lot to entrance	3-Employee Common	Walking Surface		Slope, running	5.6%	No	Slope is too steep.	5-Tolerance	No action recommended - within construction tolerance.	5.0% maximum	None	$ -	Within Tolerance (per Assessment)
F16687	Western Service Center		Exterior	Owned	Walkway	From nearest Bus Stop to entrance	1-Public Unsupervised	Curb Ramp	At 122nd & Pecos	Accumulates water?	Y	No	Curb ramp accumulates water.	1-Entry	Resurface or regrade the area so that it does not accumulate water.		2018	$ 2,500.00	Part of Annual Parking project
F16688	Western Service Center		Exterior	Owned	Walkway	From nearest Bus Stop to entrance	1-Public Unsupervised	Curb Ramp	At 122nd & Pecos	Landing?	N	No	No landing provided at top of curb ramp.	1-Entry	Provide a landing at the top of the curb ramp that is the same width as the curb ramp and at least 36 inches long.		2018	$ 5,000.00	Part of Annual Parking project
F16689	Western Service Center		Exterior	Owned	Walkway	From nearest Bus Stop to entrance	1-Public Unsupervised	Curb Ramp	At 122nd & Pecos	Slope, cross	6.3%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp, curb, and gutter to provide a compliant cross slope.	2.08% maximum	2018	$ 5,000.00	Part of Annual Parking project
F16690	Western Service Center		Exterior	Owned	Walkway	From nearest Bus Stop to entrance	1-Public Unsupervised	Walking Surface	Sidewalk	Slope, cross	3.0%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with a compliant cross slope.	2.08% maximum	2018	$ 5,000.00	Part of Annual Parking project
F16691	Western Service Center		Exterior	Owned	Walkway	From nearest Bus Stop to entrance	1-Public Unsupervised	Walking Surface	Sidewalk	Surface material	Dirt	No	Walking surface is not stable, firm, and slip resistant.	1-Entry	Provide an accessible route connecting the public sidewalk, bike path, and accessible parking area to the building entrance.		2018	$ 2,500.00	Part of Annual Parking project
F16701	Western Service Center		Exterior	Owned	Walkway	From North parking lot to East entrance	1-Public Unsupervised	Walking Surface	From drive to sidewalk	Height, level change	.75	No	Vertical change in level is too high.	5-Tolerance	No action recommended - within construction tolerance.	.05 inch maximum	None	$ -	Within Tolerance (per Assessment)

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16702	Western Service Center		Exterior	Owned	Walkway	From North parking lot to East entrance	1-Public Unsupervised	Walking Surface	At East entrance	Other attribute	8	No	Vertical drop off along sidewalk and entrance pad to East entrance is too high.	1-Entry	Install edge protection on both sides of sidewalk, including entrance pad, or install landscape materials level to concrete.		2018	$ 2,500.00	Part of Annual Parking project
F16703	Western Service Center		Exterior	Owned	Walkway	From North parking lot to East entrance	1-Public Unsupervised	Walking Surface	At East entrance	Slope, cross	3.2%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with a compliant cross slope.	2.08% maximum	2018	$ 5,000.00	Part of Annual Parking project
F16704	Western Service Center		Exterior	Owned	Walkway	From North parking lot to East entrance	1-Public Unsupervised	Walking Surface	From drive to sidewalk	Slope, cross	4.5%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with a compliant cross slope.	2.08% maximum	2018	$ 5,000.00	Part of Annual Parking project
F16705	Western Service Center		Exterior	Owned	Walkway	From North parking lot to East entrance	1-Public Unsupervised	Walking Surface	At East entrance	Slope, running	9.3%	No	Slope is too steep.	1-Entry	Rebuild the walking surface with compliant running and cross slopes, or install handrails, edge protection, and landings required for ramps.	5.0% maximum	2018	$ 5,000.00	Part of Annual Parking project
F16710	Western Service Center		Exterior	Owned	Walkway	Ramp to entrance	1-Public Unsupervised	Handrail		Continuous?	N	No	Handrail is not continuous.	1-Entry	Install handrails for the entire length of the ramp.		2018	$ 5,000.00	Part of Annual Parking project
F16711	Western Service Center		Exterior	Owned	Walkway	Ramp to entrance	1-Public Unsupervised	Handrail		Extension	N	No	Handrail extensions are not provided.	1-Entry	Provide handrail extensions that are returned and extended a minimum of 12 inches past the bottom and top of the ramp.		2018	$ 250.00	Part of Annual Parking project
F16712	Western Service Center		Exterior	Owned	Walkway	Ramp to entrance	1-Public Unsupervised	Ramp		Handrails?	N	No	No handrail on ramp.	1-Entry	Install handrails on both sides of the ramp.		2018	$ 5,000.00	Part of Annual Parking project
F16713	Western Service Center		Exterior	Owned	Walkway	Ramp to entrance	1-Public Unsupervised	Ramp		Handrails?	N	No	No handrail on ramp.	1-Entry	Install handrails on both sides of the ramp.		2018	$ 5,000.00	Part of Annual Parking project
F16717	Western Service Center		Exterior	Owned	Walkway		1-Public Unsupervised	Ramp		Edge protection?	N	No	No edge protection provided for ramp.	1-Entry	Install edge protection below ramp handrail.	4 inches maximum	2018	$ 2,500.00	Part of Annual Parking project
F16718	Western Service Center		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	At accessible parking spaces	Slope, cross	4.8%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp, curb, and gutter to provide a compliant cross slope.	2.08% maximum	2018	$ 5,000.00	Part of Annual Parking project
F00797	Westminster Motor Vehicle		Interior	Leased	Break Room		3-Employee Common	Lavatory Sink		Clearance, parallel	22	No	Clear floor space is too narrow.	2-Services	Reconfigure the lavatory sink to provide at least the minimum clear floor space.	30 inches minimum	2018	$ 1,500.00	Rework Lavatory
F00798	Westminster Motor Vehicle		Interior	Leased	Break Room		3-Employee Common	Appliance	Refrig/Freezer	Height	50.5	No	50% of freezer space is not below 54" AFF.	4-Other	Replace the existing refrig/freezer with a compliant refrig/freezer.	Side by side Refrig/Freezer	2018	$ 500.00	Replace Equipment
F00799	Westminster Motor Vehicle		Interior	Leased	Break Room		3-Employee Common	Counter		Height	36.25	No	Work surface does not comply with height requirements.	2-Services	Lower the work surface to a compliant height.	Between 28 and 34 inches	2018	$ 2,500.00	Rework Counter
F00800	Westminster Motor Vehicle		Interior	Leased	Break Room		3-Employee Common	Lavatory Sink		Height	34.5	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	None	$ -	Within Tolerance (per Assessment)
F04109	Westminster Motor Vehicle		Interior	Leased	Hallway	Near Public Restroom	1-Public Unsupervised	Drinking Fountain		Dimension, knee clearance	26.5	No	Knee clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	27 inches	None	$ -	Within Tolerance (per Assessment)
F07306	Westminster Motor Vehicle		Exterior	Leased	Parking Facility		1-Public Unsupervised	Access Aisle		Width	55	No	Access aisle is too narrow.	1-Entry	Restripe the parking space and aisle to provide a compliant sized access aisle.	60 inches minimum	2016	$ -	Letter to Landlord - Not County Owned Property
F15316	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	39	No	Clear floor space is too short.	3-Restrooms	Reconfigure the lavatory sink to provide at least the minimum clear floor space.	48 inches minimum	2018	$ 2,500.00	Rework Fixture
F15317	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F15318	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	11.5	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2018	$ 100.00	Relocate or Replace Dispenser
F15319	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Protrusion	PT	Dimension, protruding	9	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	Relocate or Replace Dispenser
F15320	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2018	$ 150.00	Add Pipe Wrap
F15321	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2018	$ 250.00	Rework Partition
F15322	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Height	34.5	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	None	$ -	Within Tolerance (per Assessment)
F15323	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2018	$ 150.00	Rework Partition
F15357	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	2	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2018	$ 100.00	Relocate or Replace Dispenser
F15358	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Water Closet		Dimension, sidewall	19.5	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2018	$ 5,000.00	Rework Toilet
F15359	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2018	$ 150.00	Add Pipe Wrap
F15360	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Lavatory Sink		Height	34.25	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	None	$ -	Within Tolerance (per Assessment)
F15361	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		2018	$ 500.00	Rework Flush Valve
F15391	Westminster Motor Vehicle		Interior	Leased	Restroom	Unisex	3-Employee Common	Dispenser	TP	Dimension from water closet seat	Behind	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2018	$ 100.00	Relocate or Replace Dispenser
F15392	Westminster Motor Vehicle		Interior	Leased	Restroom	Unisex	3-Employee Common	Water Closet		Dimension, sidewall	20	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2018	$ 5,000.00	Rework Toilet

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15393	Westminster Motor Vehicle		Interior	Leased	Restroom	Unisex	3-Employee Common	Water Closet		Dimension, wide side	19	No	Toilet is not located in a space which provides the minimum required distance from a fixture or the minimum required clear space from a wall at the wide side.	3-Restrooms	Relocate the toilet in a space which provides the required clearances.	42 inches minimum	2018	$ 5,000.00	Rework Toilet
F15394	Westminster Motor Vehicle		Interior	Leased	Restroom	Unisex	3-Employee Common	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2018	$ 150.00	Add Pipe Wrap
F15395	Westminster Motor Vehicle		Interior	Leased	Restroom	Unisex	3-Employee Common	Mirror		Height, bottom	44	No	Mirror is too high.	3-Restrooms	Lower the reflective surface of the mirror to the compliant height above the finished floor.	40 inches maximum	2018	$ 250.00	Relocate or Replace Mirror
F15396	Westminster Motor Vehicle		Interior	Leased	Restroom	Unisex	3-Employee Common	Water Closet		Location, flush control	Narrow	No	Flush control on narrow side of toilet.	3-Restrooms	Move the flush control to the open side of the toilet.		2018	$ 500.00	Rework Flush Valve
F15397	Westminster Motor Vehicle		Interior	Leased	Restroom	Unisex	3-Employee Common	Fixture Count		Number, accessible compartments	0	No	No accessible toilet compartment in restroom.	3-Restrooms	Rebuild or reconfigure the restroom, with a wheelchair accessible toilet compartment.	1 minimum	2018	$ 5,000.00	Rework Toilet
F15398	Westminster Motor Vehicle		Interior	Leased	Restroom	Unisex	3-Employee Common	Protrusion		Width	30	No	Walking surface is too narrow.	3-Restrooms	Relocate or replace the shelves to provide an accessible route to the restroom.	36 inches minimum	2018	$ 500.00	Replace Shelves
F15419	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Door Gate		Closing speed	4	No	Closing speed is too fast.	3-Restrooms	Adjust the door closer to the correct closing speed.	5 seconds minimum	2016	$ -	Internal Staff - Operations
F15420	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	13	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2018	$ 100.00	Relocate or Replace Dispenser
F15421	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Protrusion	PT	Dimension, protruding	9	No	Object protrudes into the path of travel.	3-Restrooms	Protrusions must not extend into the path of travel more than 4 inches, between 27 and 80 inches AFF. Relocate the protrusion or install cane detection to prevent injury.		2018	$ 250.00	Relocate or Replace Dispenser
F15422	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	N	No	The drain/supply lines are not wrapped properly.	3-Restrooms	Wrap or insulate the drain and supply lines to protect against contact.		2018	$ 150.00	Add Pipe Wrap
F15423	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	N	No	Door pull is not provided on both sides of toilet compartment door.	3-Restrooms	Install a door pull on both sides of the door.		2018	$ 250.00	Rework Partition
F15424	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Height	34.5	No	Lavatory sink is too high.	5-Tolerance	No action recommended - within construction tolerance.	34 inches maximum	2018	$ -	Within Tolerance (per Assessment)
F15425	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Height, top	36.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	2018	$ 250.00	Rework Grab bars
F15426	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Height, top	36.5	No	Grab bar is too high.	3-Restrooms	Relocate the grab bar to the correct height.	33-36 inches	2018	$ 250.00	Rework Grab bars
F15427	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Self-closing?	N	No	Toilet compartment door does not have self-closing hinges.	3-Restrooms	Install self-closing hinges on the toilet compartment door.		2018	$ 250.00	Rework Partition
F15457	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	4	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2018	$ 100.00	Relocate or Replace Dispenser
F15458	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	9	No	Grab bar is not mounted in correct location.	3-Restrooms	Relocate the grab bar to a location that extends a minimum of 12 inches from the centerline of the water closet on one side and a minimum of 24 inches on the other.	6 inches	2018	$ 250.00	Rework Grab bars
F15459	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Water Closet		Dimension, sidewall	18.75	No	Toilet is located too close to the side wall on the narrow side.	3-Restrooms	Relocate the toilet so that it is within the required distance from the side wall.	16 - 18 inches	2018	$ 2,500.00	Rework Toilet
F16731	Westminster Motor Vehicle		Exterior	Leased	Walkway	To employee entrance	3-Employee Common	Door Gate		Clearance, pull parallel	12	No	Clearance on pull side of door is insufficient.	1-Entry	Reframe and install a door which provides the correct pull side clearance, or install an automatic door opener.	18 inches minimum	2016	$ -	Letter to Landlord - Not County Owned Property
F16732	Westminster Motor Vehicle		Exterior	Leased	Walkway	To employee entrance	4-Employee Work Area	Walking Surface	Concrete pad	Height, level change	5	No	Vertical change in level is too high.	1-Entry	Provide a sloped surface to the concrete pad at the employee entrance.		2016	$ -	Letter to Landlord - Not County Owned Property
F16738	Westminster Motor Vehicle		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate	Main entrance	Height, smooth surface (kick plate)	6	No	Smooth surface at bottom edge of door is insufficient.	1-Entry	No action recommended - this element has safe harbor.	10 inches minimum	2016	$ -	Letter to Landlord - Not County Owned Property
F16739	Westminster Motor Vehicle		Exterior	Leased	Walkway		1-Public Unsupervised	Curb Ramp		Slope, left flare	21.0%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp with compliant side flares.	10% maximum	2016	$ -	Letter to Landlord - Not County Owned Property
F16740	Westminster Motor Vehicle		Exterior	Leased	Walkway		1-Public Unsupervised	Curb Ramp		Slope, right flare	19.0%	No	Slope is too steep.	1-Entry	Rebuild the curb ramp with compliant side flares.	10% maximum	2016	$ -	Letter to Landlord - Not County Owned Property
F04578	Whittier Public Works Support Facility		Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Clearance, vertical	79.5	No	Vertical clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	80 inches minimum	None	$ -	Within Tolerance (per Assessment)
F07318	Whittier Public Works Support Facility		Exterior	Owned	Parking Facility		3-Employee Common	Facility Specifications		Surface Material	Dirt	No	Walking surface is not stable, firm, and slip resistant.	1-Entry	Provide an accessible route connecting the parking lot to the building entrance.		2020	$ 5,000.00	Part of Annual Parking project
F15493	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Clearance, vertical	79.5	No	Vertical clearance is too low.	5-Tolerance	No action recommended - within construction tolerance.	80 inches minimum	None	$ -	Within Tolerance (per Assessment)
F15494	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	15	No	Toilet paper dispenser is not mounted at the correct location.	3-Restrooms	Move the dispenser to the correct distance from the front of the toilet seat.	7 - 9 inches	2020	$ 100.00	Relocate or Replace Dispenser
F15495	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Signage		Other attribute	None	No	Braille and raised letter signage is not provided.	3-Restrooms	Install room identification signage, with raised letters and Braille, on the latch side of the door.		2020	$ 100.00	Internal Staff - Operations

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16757	Whittier Public Works Support Facility		Exterior	Owned	Walkway		3-Employee Common	Door Gate	Main entrance	Clearance, push parallel	7	No	Clearance on push side of door is insufficient.	1-Entry	Reframe and install a door which provides the correct push side clearance, or install an automatic door opener.	12 inches minimum	2020	$ 2,500.00	Internal Staff - Operations
F16763	Whittier Public Works Support Facility		Exterior	Owned	Walkway		3-Employee Common	Door Gate	Main entrance	Height, threshold	0.75	No	Threshold is too high.	1-Entry	Provide a threshold which is 0.25 inch maximum, or a beveled threshold which is 0.5 inch maximum, at the door entrance.	0.5 inch maximum	2020	$ 250.00	Internal Staff - Operations
F05285	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		When Renovated	n/a	TBD - Pre-ADA
F05286	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		When Renovated	n/a	TBD - Pre-ADA
F05287	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		When Renovated	n/a	TBD - Pre-ADA
F05288	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #6 & #7	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		When Renovated	n/a	TBD - Pre-ADA
F05289	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #8 & #9	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		When Renovated	n/a	TBD - Pre-ADA
F05467	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Access Aisle	#1	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F05468	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Access Aisle	#2	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F05469	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Access Aisle	#3	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F05470	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Access Aisle	#4	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F05471	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Access Aisle	#5	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F05472	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Access Aisle	#6	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F05473	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Access Aisle	#7	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F05474	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Access Aisle	#8	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F05533	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F05534	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F05920	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 3 between spaces #1 & #2	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F05921	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 3 between spaces #3 & #4	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F05922	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 3 between spaces #5 & #6	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F05923	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 3 right of space #7	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F06357	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#2	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F06358	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#3	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		When Renovated (or N/A if Sold)	n/a	Sell or Renovate after HSB in 2017
F06430	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #10 & #11	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	New HSB Under Construction - Relocation in 2017
F06431	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #11 & #12	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	New HSB Under Construction - Relocation in 2017
F06432	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #12 & #13	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	New HSB Under Construction - Relocation in 2017
F06433	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #13 & #14	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	New HSB Under Construction - Relocation in 2017
F06434	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #16 & #17	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	New HSB Under Construction - Relocation in 2017
F06435	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #17 & #18	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	New HSB Under Construction - Relocation in 2017
F06436	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #18 & #19	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	New HSB Under Construction - Relocation in 2017
F06437	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	#19	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	New HSB Under Construction - Relocation in 2017
F06517	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	#1	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	New HSB Under Construction - Relocation in 2017
F06518	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	#3	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	New HSB Under Construction - Relocation in 2017
F06519	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #6 & #7	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	New HSB Under Construction - Relocation in 2017

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06520	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #7 & #8	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	New HSB Under Construction - Relocation in 2017
F06521	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #8 & #9	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	New HSB Under Construction - Relocation in 2017
F06631	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Near curb ramp #11	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F06632	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#2	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F06633	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#3	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F06634	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Row 2	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F06635	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#2	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F06636	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#3	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F06637	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#4	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F06752	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Row 1	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F06753	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	Row 1 between spaces #2 & #3	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F06754	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	Row 1 between spaces #4 & #5	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F06755	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Row 2	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F06756	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#2	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F06757	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#3	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F06758	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#4	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F12227	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Grab Bar	Vertical	Height, bottom (vertical)	42	Not best practice	Vertical grab bar is mounted too high.	3-Restrooms	Relocate the vertical grab bar to the correct height.	Between 39 and 41 inches AFF	None	n/a	
F12590	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Vertical	Height, bottom (vertical)	37	Not best practice	Vertical grab bar is mounted too low.	3-Restrooms	Relocate the vertical grab bar to the correct height.	Between 39 and 41 inches AFF	None	n/a	
F13386	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Vertical	Height, bottom (vertical)	41.5	Not best practice	Vertical grab bar is mounted too high.	3-Restrooms	Relocate the vertical grab bar to the correct height.	Between 39 and 41 inches AFF	None	n/a	
F14187	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	38	Not best practice	Vertical grab bar is mounted too far from wall.	3-Restrooms	Relocate the vertical grab bar to the correct position.	Between 39 and 41 inches	None	n/a	
F06953	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	West side of North parking lot	1-Public Unsupervised	Access Aisle	#1	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F07136	Strasburg Facility	Sheriff's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F07224	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Access Aisle	Left space	Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F07250	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Access Aisle		Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F07251	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Access Aisle		Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F15084	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Vertical	Height, bottom (vertical)	42	Not best practice	Vertical grab bar is mounted too high.	3-Restrooms	Relocate the vertical grab bar to the correct height.	Between 39 and 41 inches AFF	None	n/a	
F07307	Westminster Motor Vehicle		Exterior	Leased	Parking Facility		1-Public Unsupervised	Access Aisle		Pathway behind cars?	Y	Not best practice	No adjacent pathway for accessible parking spaces.	1-Entry	It is preferable that the accessible route not pass behind parked vehicles.		None	n/a	
F15362	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Grab Bar	Vertical	Height, bottom (vertical)	42	Not best practice	Vertical grab bar is mounted too high.	3-Restrooms	Relocate the vertical grab bar to the correct height.	Between 39 and 41 inches AFF	None	n/a	
F15460	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Grab Bar	Vertical	Height, bottom (vertical)	42	Not best practice	Vertical grab bar is mounted too high.	3-Restrooms	Relocate the vertical grab bar to the correct height.	Between 39 and 41 inches AFF	None	n/a	
F00007	Adams County Detention Center	Existing Jail	Interior	Owned	Assembly Area		3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F00008	Adams County Detention Center	Existing Jail	Interior	Owned	Assembly Area		3-Employee Common	Door Gate		Closing speed	OK	Yes					n/a	$ -	
F00009	Adams County Detention Center	Existing Jail	Interior	Owned	Assembly Area		3-Employee Common	Door Gate		Firm, stable, slip resistant	OK	Yes					n/a	$ -	
F00010	Adams County Detention Center	Existing Jail	Interior	Owned	Assembly Area		3-Employee Common	Door Gate		Opening force	2	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00013	Adams County Detention Center	F Module	2nd Floor	Owned	Assembly Area	Training - F Adm	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F00014	Adams County Detention Center	F Module	2nd Floor	Owned	Assembly Area	Training - F Adm	3-Employee Common	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F00015	Adams County Detention Center	F Module	2nd Floor	Owned	Assembly Area	Training - F Adm	3-Employee Common	Door Gate		Closing speed	7	Yes					n/a	$ -	
F00280	Adams County Detention Center	Existing Jail	Interior	Owned	Break Room	Medical Employee Area	3-Employee Common	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F00281	Adams County Detention Center	Existing Jail	Interior	Owned	Break Room	Medical Employee Area	3-Employee Common	Counter		Clearance, perpendicular	62	Yes					n/a	$ -	
F00282	Adams County Detention Center	Existing Jail	Interior	Owned	Break Room	Medical Employee Area	3-Employee Common	Counter		Dimension, knee clearance	0	Yes					n/a	$ -	
F00283	Adams County Detention Center	Existing Jail	Interior	Owned	Break Room	Medical Employee Area	3-Employee Common	Counter		Height	34	Yes					n/a	$ -	
F00284	Adams County Detention Center	Existing Jail	Interior	Owned	Break Room	Medical Employee Area	3-Employee Common	Counter		Length	48	Yes					n/a	$ -	
F00285	Adams County Detention Center	Existing Jail	Interior	Owned	Break Room		3-Employee Common	Appliance	Microwave	Height	45	Yes					n/a	$ -	
F00286	Adams County Detention Center	F Module	2nd Floor	Owned	Break Room	F Dorm	3-Employee Common	Appliance	Microwave	Height	41	Yes					n/a	$ -	
F00287	Adams County Detention Center	F Module	2nd Floor	Owned	Break Room	F Dorm	3-Employee Common	Counter		Height	34	Yes					n/a	$ -	
F02969	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Hoistway Sign		All floors?	Y	Yes					n/a	$ -	
F02970	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Elevator Car		Audible signal?	Y	Yes					n/a	$ -	
F02971	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Hall Signal		Audible signal?	Y	Yes					n/a	$ -	
F02972	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Hoistway Sign		Both jambs?	Y	Yes					n/a	$ -	
F02973	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Car Controls		Braille instructions	Y	Yes					n/a	$ -	
F02974	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Hoistway Sign		Braille?	Y	Yes					n/a	$ -	
F02975	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Elevator Door		Clear opening	41	Yes					n/a	$ -	
F02976	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Call Control		Clearance, parallel	99	Yes					n/a	$ -	
F02977	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Call Control		Clearance, perpendicular	99	Yes					n/a	$ -	
F02978	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Elevator Car		Dimension, back to front	73	Yes					n/a	$ -	
F02979	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Elevator Car		Dimension, side to side	81	Yes					n/a	$ -	
F02980	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Elevator Door		Distance to door	10	Yes					n/a	$ -	
F02981	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Car Controls		Height, bottom	18	Yes					n/a	$ -	
F02982	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Call Control		Height, top	42	Yes					n/a	$ -	
F02983	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Car Controls		Height, top	41.5	Yes					n/a	$ -	
F02984	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Car Controls		Lighted?	Y	Yes					n/a	$ -	
F02985	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Emergency Communications		Provided?	Y	Yes					n/a	$ -	
F02986	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Elevator Door		Reopen device?	Y	Yes					n/a	$ -	
F02987	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Call Control		Size	1	Yes					n/a	$ -	
F02988	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Car Controls		Size	1	Yes					n/a	$ -	
F02989	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Car Controls		Star?	Y	Yes					n/a	$ -	
F02990	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Hoistway Sign		Tactile letters?	Y	Yes					n/a	$ -	
F02991	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Car Controls		Tactile?	Y	Yes					n/a	$ -	
F02992	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Emergency Communications		Tactile?	Y	Yes					n/a	$ -	
F02993	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Call Control		Up above down?	Y	Yes					n/a	$ -	
F02994	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	#4	3-Employee Common	Call Control		Visible signal?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F02995	Adams County Detention Center	Existing Jail	Interior	Owned	Elevator	Serves Housing Dorms	3-Employee Common	Other Element		Other attribute	OK	Yes					n/a	$ -	
F03641	Adams County Detention Center	Existing Jail	Interior	Owned	Hallway	From lobby to video phone bank	1-Public Unsupervised	Handrail		Clearance to wall	2	Yes					n/a	$ -	
F03642	Adams County Detention Center	Existing Jail	Interior	Owned	Hallway	From lobby to video phone bank	1-Public Unsupervised	Ramp		Clearance, vertical	85	Yes					n/a	$ -	
F03643	Adams County Detention Center	Existing Jail	Interior	Owned	Hallway	From lobby to video phone bank	1-Public Unsupervised	Handrail		Continuous?	Y	Yes					n/a	$ -	
F03644	Adams County Detention Center	Existing Jail	Interior	Owned	Hallway	From lobby to video phone bank	1-Public Unsupervised	Handrail		Diameter	1.5	Yes					n/a	$ -	
F03645	Adams County Detention Center	Existing Jail	Interior	Owned	Hallway	From lobby to video phone bank	1-Public Unsupervised	Handrail		Extension	Y	Yes					n/a	$ -	
F03646	Adams County Detention Center	Existing Jail	Interior	Owned	Hallway	From lobby to video phone bank	1-Public Unsupervised	Handrail		Height, top	35	Yes					n/a	$ -	
F03647	Adams County Detention Center	Existing Jail	Interior	Owned	Hallway	From lobby to video phone bank	1-Public Unsupervised	Ramp		Length	25 feet	Yes					n/a	$ -	
F03648	Adams County Detention Center	Existing Jail	Interior	Owned	Hallway	From lobby to video phone bank	1-Public Unsupervised	Handrail		Rotates?	N	Yes					n/a	$ -	
F03649	Adams County Detention Center	Existing Jail	Interior	Owned	Hallway	From lobby to video phone bank	1-Public Unsupervised	Ramp		Slope, cross	1.0%	Yes					n/a	$ -	
F03650	Adams County Detention Center	Existing Jail	Interior	Owned	Hallway	From lobby to video phone bank	1-Public Unsupervised	Ramp		Width	36	Yes					n/a	$ -	
F03653	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Handrail	Ramp	Clearance to wall	2	Yes					n/a	$ -	
F03654	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Landing	#1	Clearance, parallel	60	Yes					n/a	$ -	
F03655	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Landing	#2	Clearance, parallel	95	Yes					n/a	$ -	
F03656	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Landing	#3	Clearance, parallel	99	Yes					n/a	$ -	
F03657	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Landing	#1	Clearance, perpendicular	95	Yes					n/a	$ -	
F03658	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Landing	#2	Clearance, perpendicular	60	Yes					n/a	$ -	
F03659	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Landing	#3	Clearance, perpendicular	96	Yes					n/a	$ -	
F03660	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Ramp	Section #1	Clearance, vertical	96	Yes					n/a	$ -	
F03661	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Ramp	Section #2	Clearance, vertical	96	Yes					n/a	$ -	
F03662	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Ramp	Section #3	Clearance, vertical	96	Yes					n/a	$ -	
F03663	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Handrail	Ramp	Continuous?	Y	Yes					n/a	$ -	
F03664	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Handrail	Ramp	Diameter	1.5	Yes					n/a	$ -	
F03665	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Landing	#1	Edge protection?	Y	Yes					n/a	$ -	
F03666	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Landing	#2	Edge protection?	Y	Yes					n/a	$ -	
F03667	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Landing	#3	Edge protection?	Y	Yes					n/a	$ -	
F03668	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Ramp	Section #1	Edge protection?	Y	Yes					n/a	$ -	
F03669	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Ramp	Section #2	Edge protection?	Y	Yes					n/a	$ -	
F03670	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Ramp	Section #3	Edge protection?	Y	Yes					n/a	$ -	
F03671	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Handrail	Ramp	Extension	Y	Yes					n/a	$ -	
F03672	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Handrail	Ramp	Height, top	34	Yes					n/a	$ -	
F03673	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Ramp	Section #1	Length	26 feet	Yes					n/a	$ -	
F03674	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Ramp	Section #2	Length	25 feet	Yes					n/a	$ -	
F03675	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Ramp	Section #3	Length	25 feet	Yes					n/a	$ -	
F03676	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Handrail	Ramp	Rotates?	N	Yes					n/a	$ -	
F03677	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Landing	#2	Slope, cross	0.8%	Yes					n/a	$ -	
F03678	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Landing	#3	Slope, cross	0.8%	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F03679	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Landing	#1	Slope, cross	0.3%	Yes					n/a	$ -	
F03680	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Ramp	Section #3	Slope, cross	0.0%	Yes					n/a	$ -	
F03681	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Ramp	Section #2	Slope, cross	0.2%	Yes					n/a	$ -	
F03682	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Ramp	Section #1	Slope, cross	0.3%	Yes					n/a	$ -	
F03683	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Landing	#3	Slope, running	0.3%	Yes					n/a	$ -	
F03684	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Landing	#2	Slope, running	0.5%	Yes					n/a	$ -	
F03685	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Landing	#1	Slope, running	1.5%	Yes					n/a	$ -	
F03686	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Ramp	Section #3	Slope, running	7.5%	Yes					n/a	$ -	
F03687	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Ramp	Section #1	Slope, running	7.8%	Yes					n/a	$ -	
F03688	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Ramp	Section #1	Surface material	Tile	Yes					n/a	$ -	
F03689	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Ramp	Section #3	Surface material	Tile	Yes					n/a	$ -	
F03690	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Ramp	Section #1	Width	95	Yes					n/a	$ -	
F03691	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Ramp	Section #2	Width	95	Yes					n/a	$ -	
F03692	Adams County Detention Center	F Module	Interior	Owned	Hallway	Upper hallway	2-Public Supervised	Ramp	Section #3	Width	95	Yes					n/a	$ -	
F04222	Adams County Detention Center	F Module	Interior	Owned	Housing Cell		3-Employee Common	Door Gate		Clear opening	34	Yes					n/a	$ -	
F04223	Adams County Detention Center	F Module	Interior	Owned	Housing Cell		3-Employee Common	Bed		Clearance, location	S	Yes					n/a	$ -	
F04224	Adams County Detention Center	F Module	Interior	Owned	Housing Cell		3-Employee Common	Bed		Clearance, parallel	99	Yes					n/a	$ -	
F04225	Adams County Detention Center	F Module	Interior	Owned	Housing Cell		3-Employee Common	Lavatory Sink		Clearance, parallel	99	Yes					n/a	$ -	
F04226	Adams County Detention Center	F Module	Interior	Owned	Housing Cell		3-Employee Common	Water Closet		Clearance, parallel	60	Yes					n/a	$ -	
F04227	Adams County Detention Center	F Module	Interior	Owned	Housing Cell		3-Employee Common	Lavatory Sink		Clearance, perpendicular	99	Yes					n/a	$ -	
F04228	Adams County Detention Center	F Module	Interior	Owned	Housing Cell		3-Employee Common	Water Closet		Clearance, perpendicular	99	Yes					n/a	$ -	
F04229	Adams County Detention Center	F Module	Interior	Owned	Housing Cell		3-Employee Common	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F04230	Adams County Detention Center	F Module	Interior	Owned	Housing Cell		3-Employee Common	Lavatory Sink		Dimension, knee clearance	30.5	Yes					n/a	$ -	
F04231	Adams County Detention Center	F Module	Interior	Owned	Housing Cell		3-Employee Common	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F04232	Adams County Detention Center	F Module	Interior	Owned	Housing Cell		3-Employee Common	Water Closet		Dimension, wide side	42.5	Yes					n/a	$ -	
F04233	Adams County Detention Center	F Module	Interior	Owned	Housing Cell		3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F04234	Adams County Detention Center	F Module	Interior	Owned	Housing Cell		3-Employee Common	Lavatory Sink		Height	34	Yes					n/a	$ -	
F04235	Adams County Detention Center	F Module	Interior	Owned	Housing Cell		3-Employee Common	Water Closet		Height, flush control	OK	Yes					n/a	$ -	
F04236	Adams County Detention Center	F Module	Interior	Owned	Housing Cell		3-Employee Common	Water Closet		Height, seat	19	Yes					n/a	$ -	
F04237	Adams County Detention Center	F Module	Interior	Owned	Housing Cell		3-Employee Common	Water Closet		Location, flush control	Rear	Yes					n/a	$ -	
F04238	Adams County Detention Center	F Module	Interior	Owned	Housing Cell		3-Employee Common	Bed		Number, beds with clear space	64	Yes					n/a	$ -	
F04288	Adams County Detention Center	Existing Jail	Interior	Owned	Lobby Reception	From parking lot to Main entrance	2-Public Supervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F04289	Adams County Detention Center	Existing Jail	Interior	Owned	Lobby Reception	From parking lot to Main entrance	2-Public Supervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F04290	Adams County Detention Center	Existing Jail	Interior	Owned	Lobby Reception	From parking lot to Main entrance	2-Public Supervised	Counter		Dimension, knee clearance	32.75	Yes					n/a	$ -	
F04291	Adams County Detention Center	Existing Jail	Interior	Owned	Lobby Reception	From parking lot to Main entrance	2-Public Supervised	Alarm System		Height	82.5	Yes					n/a	$ -	
F04292	Adams County Detention Center	Existing Jail	Interior	Owned	Lobby Reception	From parking lot to Main entrance	2-Public Supervised	Counter		Length	99	Yes					n/a	$ -	
F04293	Adams County Detention Center	Existing Jail	Interior	Owned	Lobby Reception	From parking lot to Main entrance	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F04617	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Clear opening	32	Yes					n/a	$ -	
F04618	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Clear opening	32	Yes					n/a	$ -	
F04619	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Shower Compartment		Clearance, parallel	36	Yes					n/a	$ -	
F04620	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Shower Compartment		Clearance, perpendicular	36	Yes					n/a	$ -	
F04621	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F04622	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Clearance, pull perpendicular	62	Yes					n/a	$ -	
F04623	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F04624	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F04625	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Clearance, push perpendicular	52	Yes					n/a	$ -	
F04626	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Clearance, push perpendicular	71	Yes					n/a	$ -	
F04627	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Clearance, vertical	82	Yes					n/a	$ -	
F04628	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F04629	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Shower Compartment		Control location	F	Yes					n/a	$ -	
F04630	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Shower Compartment		Dimension, entry to back wall	36	Yes					n/a	$ -	
F04631	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Shower Compartment		Dimension, side to side	36	Yes					n/a	$ -	
F04632	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F04633	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F04634	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Alarm System		Height	89	Yes					n/a	$ -	
F04635	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F04636	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F04639	Adams County Detention Center	F Module	2nd Floor	Owned	Locker Room	Women's	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F04875	Adams County Detention Center	Existing Jail	Interior	Owned	Other Room	Library	3-Employee Common	Door Gate		Clear opening	32	Yes					n/a	$ -	
F04876	Adams County Detention Center	Existing Jail	Interior	Owned	Other Room	Library	3-Employee Common	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F04877	Adams County Detention Center	Existing Jail	Interior	Owned	Other Room	Library	3-Employee Common	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F04878	Adams County Detention Center	Existing Jail	Interior	Owned	Other Room	Library	3-Employee Common	Door Gate		Closing speed	5	Yes					n/a	$ -	
F05209	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	#1	Access aisle?	Y	Yes					n/a	$ -	
F05210	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	Youth Services	Access aisle?	Y	Yes					n/a	$ -	
F05211	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Access Aisle	#1	Adjacent pathway?	Y	Yes					n/a	$ -	
F05212	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Access Aisle	#2	Adjacent pathway?	Y	Yes					n/a	$ -	
F05213	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Access Aisle	#3	Adjacent pathway?	Y	Yes					n/a	$ -	
F05214	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Access Aisle	Youth Services	Adjacent pathway?	Y	Yes					n/a	$ -	
F05215	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	#1	Sign?	Y	Yes					n/a	$ -	
F05216	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space		Sign?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05217	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Access Aisle	#1	Slope, cross	1.5%	Yes					n/a	$ -	
F05218	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Access Aisle	#2	Slope, cross	1.9%	Yes					n/a	$ -	
F05219	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Access Aisle	#3	Slope, cross	1.9%	Yes					n/a	$ -	
F05220	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space		Slope, cross	1.6%	Yes					n/a	$ -	
F05221	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	#3	Slope, cross	1.6%	Yes					n/a	$ -	
F05222	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	#1	Slope, cross	1.9%	Yes					n/a	$ -	
F05223	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Access Aisle	Youth Services	Slope, running	1.0%	Yes					n/a	$ -	
F05224	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Access Aisle	#3	Slope, running	7.0%	Yes					n/a	$ -	
F05225	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Access Aisle	#2	Slope, running	1.5%	Yes					n/a	$ -	
F05226	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	#5	Slope, running	6.0%	Yes					n/a	$ -	
F05227	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	#4	Slope, running	1.1%	Yes					n/a	$ -	
F05228	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	#6	Slope, running	1.2%	Yes					n/a	$ -	
F05229	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	Youth Services	Slope, running	1.2%	Yes					n/a	$ -	
F05230	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	#3	Slope, running	1.7%	Yes					n/a	$ -	
F05231	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	Youth Services	Type	Both	Yes					n/a	$ -	
F05232	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Access Aisle	#1	Width	60	Yes					n/a	$ -	
F05233	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Access Aisle	#3	Width	60.5	Yes					n/a	$ -	
F05234	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Access Aisle	Youth Services	Width	97	Yes					n/a	$ -	
F05235	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	#1	Width	97	Yes					n/a	$ -	
F05236	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	#3	Width	97	Yes					n/a	$ -	
F05237	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	#4	Width	98	Yes					n/a	$ -	
F05238	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	#5	Width	96	Yes					n/a	$ -	
F05239	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	#6	Width	96	Yes					n/a	$ -	
F05240	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space	Youth Services	Width	111	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05241	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility	South parking lot near Facilities Management	1-Public Unsupervised	Parking Space		Width	98	Yes					n/a	$ -	
F05290	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Access aisle?	Y	Yes					n/a	$ -	
F05291	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Access aisle?	Y	Yes					n/a	$ -	
F05292	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Access aisle?	Y	Yes					n/a	$ -	
F05293	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Access aisle?	Y	Yes					n/a	$ -	
F05294	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Access aisle?	Y	Yes					n/a	$ -	
F05295	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#6	Access aisle?	Y	Yes					n/a	$ -	
F05296	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#7	Access aisle?	Y	Yes					n/a	$ -	
F05297	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#8	Access aisle?	Y	Yes					n/a	$ -	
F05298	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#9	Access aisle?	Y	Yes					n/a	$ -	
F05299	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Cars obstruct pathway	N	Yes					n/a	$ -	
F05300	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Length	OK	Yes					n/a	$ -	
F05301	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Length	OK	Yes					n/a	$ -	
F05302	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Length	OK	Yes					n/a	$ -	
F05303	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #6 & #7	Length	OK	Yes					n/a	$ -	
F05304	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #8 & #9	Length	OK	Yes					n/a	$ -	
F05305	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, accessible	9	Yes					n/a	$ -	
F05306	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, van spaces	2	Yes					n/a	$ -	
F05307	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Sign?	Y	Yes					n/a	$ -	
F05308	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Sign?	Y	Yes					n/a	$ -	
F05309	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Sign?	Y	Yes					n/a	$ -	
F05310	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#6	Sign?	Y	Yes					n/a	$ -	
F05311	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#7	Sign?	Y	Yes					n/a	$ -	
F05312	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#8	Sign?	Y	Yes					n/a	$ -	
F05313	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#9	Sign?	Y	Yes					n/a	$ -	
F05314	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #6 & #7	Slope, running	0.8%	Yes					n/a	$ -	
F05315	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #8 & #9	Slope, running	1.1%	Yes					n/a	$ -	
F05316	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Slope, running	1.5%	Yes					n/a	$ -	
F05317	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#8	Slope, running	0.4%	Yes					n/a	$ -	
F05318	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#6	Slope, running	0.6%	Yes					n/a	$ -	
F05319	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Slope, running	0.8%	Yes					n/a	$ -	
F05320	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#9	Slope, running	0.8%	Yes					n/a	$ -	
F05321	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Slope, running	2.0%	Yes					n/a	$ -	
F05322	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Slope, running	2.0%	Yes					n/a	$ -	
F05323	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#7	Slope, running	2.0%	Yes					n/a	$ -	
F05324	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Surface marking?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05325	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Surface marking?	Y	Yes					n/a	$ -	
F05326	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Surface marking?	Y	Yes					n/a	$ -	
F05327	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #6 & #7	Surface marking?	Y	Yes					n/a	$ -	
F05328	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Surface material	Asphalt	Yes					n/a	$ -	
F05329	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Surface material	Asphalt	Yes					n/a	$ -	
F05330	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Surface material	Asphalt	Yes					n/a	$ -	
F05331	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#9	Surface material	Asphalt	Yes					n/a	$ -	
F05332	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#7	Van sign?	N	Yes					n/a	$ -	
F05333	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Width	62	Yes					n/a	$ -	
F05334	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Width	60	Yes					n/a	$ -	
F05335	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #6 & #7	Width	95	Yes					n/a	$ -	
F05336	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Width	110	Yes					n/a	$ -	
F05337	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Width	108	Yes					n/a	$ -	
F05338	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Width	109	Yes					n/a	$ -	
F05339	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Width	107	Yes					n/a	$ -	
F05340	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#6	Width	109	Yes					n/a	$ -	
F05341	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#7	Width	156	Yes					n/a	$ -	
F05342	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#8	Width	112	Yes					n/a	$ -	
F05343	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#9	Width	107	Yes					n/a	$ -	
F05344	Adams County Detention Center	Existing Jail	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Width	110	Yes					n/a	$ -	
F05371	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#1	Access aisle?	Y	Yes					n/a	$ -	
F05372	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#2	Access aisle?	Y	Yes					n/a	$ -	
F05373	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#3	Access aisle?	Y	Yes					n/a	$ -	
F05374	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#4	Access aisle?	Y	Yes					n/a	$ -	
F05375	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#5	Access aisle?	Y	Yes					n/a	$ -	
F05376	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#6	Access aisle?	Y	Yes					n/a	$ -	
F05377	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Access Aisle	#1	Adjacent pathway?	Y	Yes					n/a	$ -	
F05378	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Access Aisle	Between parking spaces #3 & #4	Adjacent pathway?	Y	Yes					n/a	$ -	
F05379	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Access Aisle	Between parking spaces #5 & #6	Adjacent pathway?	Y	Yes					n/a	$ -	
F05380	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Access Aisle	#1	Pathway behind cars?	N	Yes					n/a	$ -	
F05381	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#1	Sign?	Y	Yes					n/a	$ -	
F05382	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#2	Sign?	Y	Yes					n/a	$ -	
F05383	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#3	Sign?	Y	Yes					n/a	$ -	
F05384	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#4	Sign?	Y	Yes					n/a	$ -	
F05385	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#5	Sign?	Y	Yes					n/a	$ -	
F05386	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#6	Sign?	Y	Yes					n/a	$ -	
F05387	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Access Aisle	#1	Slope, cross	1.0%	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05388	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#3	Slope, cross	1.4%	Yes					n/a	$ -	
F05389	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#1	Slope, cross	1.5%	Yes					n/a	$ -	
F05390	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#2	Slope, cross	1.8%	Yes					n/a	$ -	
F05391	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Access Aisle	Between parking spaces #5 & #6	Slope, running	0.5%	Yes					n/a	$ -	
F05392	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Access Aisle	Between parking spaces #3 & #4	Slope, running	1.7%	Yes					n/a	$ -	
F05393	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#5	Slope, running	0.3%	Yes					n/a	$ -	
F05394	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#6	Slope, running	0.9%	Yes					n/a	$ -	
F05395	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Access Aisle	#1	Surface marking?	Y	Yes					n/a	$ -	
F05396	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Access Aisle	Between parking spaces #3 & #4	Surface marking?	Y	Yes					n/a	$ -	
F05397	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Access Aisle	Between parking spaces #5 & #6	Surface marking?	Y	Yes					n/a	$ -	
F05398	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#1	Surface material	Asphalt	Yes					n/a	$ -	
F05399	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#1	Van sign?	N	Yes					n/a	$ -	
F05400	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#2	Van sign?	N	Yes					n/a	$ -	
F05401	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#3	Van sign?	N	Yes					n/a	$ -	
F05402	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#4	Van sign?	N	Yes					n/a	$ -	
F05403	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#5	Van sign?	N	Yes					n/a	$ -	
F05404	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#6	Van sign?	N	Yes					n/a	$ -	
F05405	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Access Aisle	#1	Width	60	Yes					n/a	$ -	
F05406	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Access Aisle	Between parking spaces #5 & #6	Width	60	Yes					n/a	$ -	
F05407	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#1	Width	98	Yes					n/a	$ -	
F05408	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#2	Width	98	Yes					n/a	$ -	
F05409	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#3	Width	97	Yes					n/a	$ -	
F05410	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#4	Width	98	Yes					n/a	$ -	
F05411	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#5	Width	96	Yes					n/a	$ -	
F05412	Adams County Detention Center	F Module	Exterior	Owned	Parking Facility	Employee Parking - Lot F	3-Employee Common	Parking Space	#6	Width	96	Yes					n/a	$ -	
F07476	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	2-Public Supervised	Signage		Braille?	Y	Yes					n/a	$ -	
F07477	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F07478	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F07479	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F07480	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F07481	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Counter		Clearance, perpendicular	80	Yes					n/a	$ -	
F07482	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	99	Yes					n/a	$ -	
F07483	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Urinal		Clearance, perpendicular	99	Yes					n/a	$ -	
F07484	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Clearance, pull parallel	18	Yes					n/a	$ -	
F07485	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F07486	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Clearance, push parallel	67	Yes					n/a	$ -	
F07487	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	72	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07488	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F07489	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F07490	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F07491	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F07492	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F07493	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F07494	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	2-Public Supervised	Signage		Dimension, characters	4	Yes					n/a	$ -	
F07495	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F07496	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Counter		Dimension, knee clearance	29	Yes					n/a	$ -	
F07497	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F07498	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F07499	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Water Closet		Dimension, wide side	42	Yes					n/a	$ -	
F07500	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Door swing direction	Out	Yes					n/a	$ -	
F07501	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F07502	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	Y	Yes					n/a	$ -	
F07503	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F07504	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F07505	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Hardware type	L	Yes					n/a	$ -	
F07506	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Alarm System		Height	82	Yes					n/a	$ -	
F07507	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Counter		Height	34	Yes					n/a	$ -	
F07508	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Dispenser	TP	Height	18	Yes					n/a	$ -	
F07509	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Dispenser	Soap	Height	42	Yes					n/a	$ -	
F07510	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Dispenser	Hand dryer	Height	42	Yes					n/a	$ -	
F07511	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	2-Public Supervised	Signage		Height, bottom	57.5	Yes					n/a	$ -	
F07512	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Urinal		Height, flush control	Auto	Yes					n/a	$ -	
F07513	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Urinal		Height, rim	16.5	Yes					n/a	$ -	
F07514	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Water Closet		Height, seat	19	Yes					n/a	$ -	
F07515	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F07516	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Height, top	36	Yes					n/a	$ -	
F07517	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Side	Height, top	36	Yes					n/a	$ -	
F07518	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F07519	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Counter		Length	99	Yes					n/a	$ -	
F07520	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F07521	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F07522	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	
F07523	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07524	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F07525	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F07526	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F07534	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Medical Wing	3-Employee Common	Dispenser	TP	Height	18	Yes					n/a	$ -	
F07535	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Men's - Medical Wing	3-Employee Common	Signage		Location	L	Yes					n/a	$ -	
F07552	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F07553	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Dispenser	TP	Clearance, parallel	OK	Yes					n/a	$ -	
F07554	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Clearance, parallel	99	Yes					n/a	$ -	
F07555	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Clearance, parallel	36	Yes					n/a	$ -	
F07556	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Clearance, parallel	60	Yes					n/a	$ -	
F07557	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Dispenser	TP	Clearance, perpendicular	OK	Yes					n/a	$ -	
F07558	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Clearance, perpendicular	99	Yes					n/a	$ -	
F07559	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Clearance, perpendicular	62	Yes					n/a	$ -	
F07560	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Clearance, perpendicular	94	Yes					n/a	$ -	
F07561	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Clearance, pull parallel	30	Yes					n/a	$ -	
F07562	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Closing speed	OK	Yes					n/a	$ -	
F07563	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Dimension, knee clearance	31.5	Yes					n/a	$ -	
F07564	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F07565	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F07566	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Dispenser	TP	Height	30	Yes					n/a	$ -	
F07567	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Height	30.5	Yes					n/a	$ -	
F07568	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Height, flush control	Push button	Yes					n/a	$ -	
F07569	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Height, flush control	Auto	Yes					n/a	$ -	
F07570	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Height, seat	17	Yes					n/a	$ -	
F07571	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Height, seat	18	Yes					n/a	$ -	
F07572	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Location, flush control	Auto	Yes					n/a	$ -	
F07573	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Opening force	1	Yes					n/a	$ -	
F07583	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - East hallway	3-Employee Common	Water Closet		Clearance, parallel	96	Yes					n/a	$ -	
F07584	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - East hallway	3-Employee Common	Water Closet		Clearance, perpendicular	80	Yes					n/a	$ -	
F07585	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - East hallway	3-Employee Common	Lavatory Sink		Dimension, knee clearance	29.5	Yes					n/a	$ -	
F07586	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - East hallway	3-Employee Common	Dispenser	TP	Height	27	Yes					n/a	$ -	
F07587	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - East hallway	3-Employee Common	Lavatory Sink		Height	33	Yes					n/a	$ -	
F07588	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - East hallway	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F07599	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - Staff library	3-Employee Common	Dispenser	TP	Clearance, parallel	OK	Yes					n/a	$ -	
F07600	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - Staff library	3-Employee Common	Lavatory Sink		Clearance, parallel	72	Yes					n/a	$ -	
F07601	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - Staff library	3-Employee Common	Water Closet		Clearance, parallel	72	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07602	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - Staff library	3-Employee Common	Dispenser	TP	Clearance, perpendicular	OK	Yes					n/a	$ -	
F07603	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - Staff library	3-Employee Common	Lavatory Sink		Clearance, perpendicular	48	Yes					n/a	$ -	
F07604	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - Staff library	3-Employee Common	Water Closet		Clearance, perpendicular	72	Yes					n/a	$ -	
F07605	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - Staff library	3-Employee Common	Lavatory Sink		Dimension, knee clearance	28	Yes					n/a	$ -	
F07606	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - Staff library	3-Employee Common	Water Closet		Dimension, wide side	99	Yes					n/a	$ -	
F07607	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - Staff library	3-Employee Common	Dispenser	TP	Height	22	Yes					n/a	$ -	
F07608	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - Staff library	3-Employee Common	Lavatory Sink		Height	32	Yes					n/a	$ -	
F07609	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - Staff library	3-Employee Common	Water Closet		Height, seat	18	Yes					n/a	$ -	
F07610	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Unisex - Staff library	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F07635	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F07636	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F07637	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F07638	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Counter		Clearance, parallel	OK	Yes					n/a	$ -	
F07639	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F07640	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Counter		Clearance, perpendicular	OK	Yes					n/a	$ -	
F07641	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	59	Yes					n/a	$ -	
F07642	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	94	Yes					n/a	$ -	
F07643	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F07644	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	90	Yes					n/a	$ -	
F07645	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F07646	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F07647	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Clearance, vertical	80	Yes					n/a	$ -	
F07648	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F07649	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F07650	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	9	Yes					n/a	$ -	
F07651	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Signage		Dimension, characters	4	Yes					n/a	$ -	
F07652	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F07653	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F07654	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Counter		Dimension, knee clearance	29	Yes					n/a	$ -	
F07655	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F07656	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F07657	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Water Closet		Dimension, wide side	41.5	Yes					n/a	$ -	
F07658	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Toilet Compartment		Door swing direction	Out	Yes					n/a	$ -	
F07659	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F07660	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F07661	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Toilet Compartment		Hardware type	L	Yes					n/a	$ -	
F07662	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Alarm System		Height	80	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07663	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Coat Hook		Height	47.5	Yes					n/a	$ -	
F07664	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Counter		Height	34	Yes					n/a	$ -	
F07665	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Dispenser	TP	Height	21	Yes					n/a	$ -	
F07666	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Dispenser	Soap	Height	43	Yes					n/a	$ -	
F07667	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Dispenser	PT	Height	40	Yes					n/a	$ -	
F07668	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F07669	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Changing Station		Height	33	Yes					n/a	$ -	
F07670	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Signage		Height, bottom	57.5	Yes					n/a	$ -	
F07671	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Water Closet		Height, seat	19	Yes					n/a	$ -	
F07672	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12.25	Yes					n/a	$ -	
F07673	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Height, top	36	Yes					n/a	$ -	
F07674	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Grab Bar	Side	Height, top	36	Yes					n/a	$ -	
F07675	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F07676	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Counter		Length	70.5	Yes					n/a	$ -	
F07677	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F07678	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F07679	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F07680	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F07681	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F07682	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F07683	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Fixture Count		Number, toilet compartments	3	Yes					n/a	$ -	
F07684	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Fixture Count		Number, urinals	0	Yes					n/a	$ -	
F07685	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F07686	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F07695	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Door Gate		Clear opening	32.5	Yes					n/a	$ -	
F07696	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Lavatory Sink		Clearance, parallel	99	Yes					n/a	$ -	
F07697	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Water Closet		Clearance, parallel	71	Yes					n/a	$ -	
F07698	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Lavatory Sink		Clearance, perpendicular	99	Yes					n/a	$ -	
F07699	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Water Closet		Clearance, perpendicular	99	Yes					n/a	$ -	
F07700	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F07701	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F07702	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F07703	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Grab Bar	Rear	Diameter	1.25	Yes					n/a	$ -	
F07704	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F07705	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Lavatory Sink		Dimension, knee clearance	29.5	Yes					n/a	$ -	
F07706	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Water Closet		Dimension, sidewall	17.5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07707	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F07708	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Dispenser	TP	Height	21.5	Yes					n/a	$ -	
F07709	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Lavatory Sink		Height	33.5	Yes					n/a	$ -	
F07710	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Grab Bar	Side	Height, top	35.5	Yes					n/a	$ -	
F07711	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Grab Bar	Rear	Height, top	35.25	Yes					n/a	$ -	
F07712	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F07713	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F07714	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Medical Wing	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F07731	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Coat Hook		Clearance, parallel	OK	Yes					n/a	$ -	
F07732	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Dispenser	TP	Clearance, parallel	OK	Yes					n/a	$ -	
F07733	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Coat Hook		Clearance, perpendicular	OK	Yes					n/a	$ -	
F07734	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Lavatory Sink		Clearance, perpendicular	99	Yes					n/a	$ -	
F07735	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Water Closet		Clearance, perpendicular	77	Yes					n/a	$ -	
F07736	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Door Gate		Closing speed	OK	Yes					n/a	$ -	
F07737	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Dispenser	TP	Height	28.5	Yes					n/a	$ -	
F07738	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Lavatory Sink		Height	30	Yes					n/a	$ -	
F07739	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Water Closet		Height, seat	19	Yes					n/a	$ -	
F07740	Adams County Detention Center	Existing Jail	Interior	Owned	Restroom	Women's - Staff lower level	3-Employee Common	Water Closet		Location, flush control	Auto	Yes					n/a	$ -	
F07744	Adams County Detention Center	F Module	Interior	Owned	Restroom	Men's - F Adm locker room	3-Employee Common	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F07745	Adams County Detention Center	F Module	Interior	Owned	Restroom	Men's - F Adm locker room	3-Employee Common	Dispenser	TP	Clearance, parallel	99	Yes					n/a	$ -	
F07746	Adams County Detention Center	F Module	Interior	Owned	Restroom	Men's - F Adm locker room	3-Employee Common	Urinal		Clearance, parallel	30	Yes					n/a	$ -	
F07747	Adams County Detention Center	F Module	Interior	Owned	Restroom	Men's - F Adm locker room	3-Employee Common	Water Closet		Clearance, parallel	61	Yes					n/a	$ -	
F07748	Adams County Detention Center	F Module	Interior	Owned	Restroom	Men's - F Adm locker room	3-Employee Common	Dispenser	TP	Clearance, perpendicular	99	Yes					n/a	$ -	
F07749	Adams County Detention Center	F Module	Interior	Owned	Restroom	Men's - F Adm locker room	3-Employee Common	Urinal		Clearance, perpendicular	99	Yes					n/a	$ -	
F07750	Adams County Detention Center	F Module	Interior	Owned	Restroom	Men's - F Adm locker room	3-Employee Common	Water Closet		Clearance, perpendicular	99	Yes					n/a	$ -	
F07751	Adams County Detention Center	F Module	Interior	Owned	Restroom	Men's - F Adm locker room	3-Employee Common	Urinal		Depth	16	Yes					n/a	$ -	
F07752	Adams County Detention Center	F Module	Interior	Owned	Restroom	Men's - F Adm locker room	3-Employee Common	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F07753	Adams County Detention Center	F Module	Interior	Owned	Restroom	Men's - F Adm locker room	3-Employee Common	Water Closet		Dimension, wide side	42.5	Yes					n/a	$ -	
F07754	Adams County Detention Center	F Module	Interior	Owned	Restroom	Men's - F Adm locker room	3-Employee Common	Toilet Compartment		Door swing direction	Out	Yes					n/a	$ -	
F07755	Adams County Detention Center	F Module	Interior	Owned	Restroom	Men's - F Adm locker room	3-Employee Common	Toilet Compartment		Hardware both sides?	Y	Yes					n/a	$ -	
F07756	Adams County Detention Center	F Module	Interior	Owned	Restroom	Men's - F Adm locker room	3-Employee Common	Dispenser	TP	Height	22	Yes					n/a	$ -	
F07757	Adams County Detention Center	F Module	Interior	Owned	Restroom	Men's - F Adm locker room	3-Employee Common	Urinal		Height, flush control	44	Yes					n/a	$ -	
F07758	Adams County Detention Center	F Module	Interior	Owned	Restroom	Men's - F Adm locker room	3-Employee Common	Urinal		Height, rim	16	Yes					n/a	$ -	
F07759	Adams County Detention Center	F Module	Interior	Owned	Restroom	Men's - F Adm locker room	3-Employee Common	Water Closet		Height, seat	18.5	Yes					n/a	$ -	
F07760	Adams County Detention Center	F Module	Interior	Owned	Restroom	Men's - F Adm locker room	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F07768	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - #F1100 Housing Dorm	3-Employee Common	Shower Compartment	Stainless steel unit	Clearance, parallel	36	Yes					n/a	$ -	
F07769	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - #F1100 Housing Dorm	3-Employee Common	Shower Compartment	Stainless steel unit	Clearance, perpendicular	36	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07770	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - #F1100 Housing Dorm	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F07771	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - #F1100 Housing Dorm	3-Employee Common	Shower Compartment	Stainless steel unit	Control location	F	Yes					n/a	$ -	
F07772	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - #F1100 Housing Dorm	3-Employee Common	Grab Bar	Side	Cross section dimension, maximum	1.5	Yes					n/a	$ -	
F07773	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - #F1100 Housing Dorm	3-Employee Common	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F07774	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - #F1100 Housing Dorm	3-Employee Common	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F07775	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - #F1100 Housing Dorm	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F07776	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - #F1100 Housing Dorm	3-Employee Common	Shower Compartment	Stainless steel unit	Height, shower control	45	Yes					n/a	$ -	
F07777	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - #F1100 Housing Dorm	3-Employee Common	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F07778	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - #F1100 Housing Dorm	3-Employee Common	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F07789	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Lavatory Sink		Clearance, parallel	99	Yes					n/a	$ -	
F07790	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Water Closet		Clearance, parallel	99	Yes					n/a	$ -	
F07791	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Lavatory Sink		Clearance, perpendicular	99	Yes					n/a	$ -	
F07792	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Water Closet		Clearance, perpendicular	99	Yes					n/a	$ -	
F07793	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F07794	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F07795	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Grab Bar	Side	Diameter	1.25	Yes					n/a	$ -	
F07796	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Grab Bar	Rear	Diameter	1.25	Yes					n/a	$ -	
F07797	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F07798	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Dispenser	TP	Height	21	Yes					n/a	$ -	
F07799	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Lavatory Sink		Height	33	Yes					n/a	$ -	
F07800	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Water Closet		Height, seat	19	Yes					n/a	$ -	
F07801	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Grab Bar	Side	Height, top	36	Yes					n/a	$ -	
F07802	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Grab Bar	Rear	Height, top	36	Yes					n/a	$ -	
F07803	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F07804	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F07805	Adams County Detention Center	F Module	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F07836	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F07837	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Lavatory Sink		Clearance, parallel	36	Yes					n/a	$ -	
F07838	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F07839	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Toilet Compartment		Clearance, perpendicular	60	Yes					n/a	$ -	
F07840	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F07841	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F07842	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F07843	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F07844	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F07845	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07846	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F07847	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F07848	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Lavatory Sink		Dimension, knee clearance	28	Yes					n/a	$ -	
F07849	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F07850	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Water Closet		Dimension, wide side	42	Yes					n/a	$ -	
F07851	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Toilet Compartment		Door swing direction	O	Yes					n/a	$ -	
F07852	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F07853	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Toilet Compartment		Hardware both sides?	Y	Yes					n/a	$ -	
F07854	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F07855	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Toilet Compartment		Hardware type	L	Yes					n/a	$ -	
F07856	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Alarm System		Height	82	Yes					n/a	$ -	
F07857	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Dispenser	TP	Height	22	Yes					n/a	$ -	
F07858	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Dispenser	Soap	Height	38	Yes					n/a	$ -	
F07859	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Lavatory Sink		Height	34	Yes					n/a	$ -	
F07860	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Water Closet		Height, flush control	27	Yes					n/a	$ -	
F07861	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Water Closet		Height, seat	19	Yes					n/a	$ -	
F07862	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F07863	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Grab Bar	Continuous	Height, top	34	Yes					n/a	$ -	
F07864	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Grab Bar	Side	Height, top	34	Yes					n/a	$ -	
F07865	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Grab Bar	Rear	Height, top	36	Yes					n/a	$ -	
F07866	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Grab Bar	Side	Height, top	36	Yes					n/a	$ -	
F07867	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Grab Bar	Continuous	Length	28	Yes					n/a	$ -	
F07868	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Grab Bar	Side	Length	54	Yes					n/a	$ -	
F07869	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F07870	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F07871	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F07872	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F07873	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F07874	Adams County Detention Center	F Module	2nd Floor	Owned	Restroom	Women's - F Adm locker room	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F15602	Adams County Detention Center	Existing Jail	Interior	Owned	Sport Area		3-Employee Common	Door Gate		Clear opening	41	Yes					n/a	$ -	
F15603	Adams County Detention Center	Existing Jail	Interior	Owned	Sport Area		3-Employee Common	Door Gate		Clearance, pull parallel	23	Yes					n/a	$ -	
F15604	Adams County Detention Center	Existing Jail	Interior	Owned	Sport Area		3-Employee Common	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F15605	Adams County Detention Center	Existing Jail	Interior	Owned	Sport Area		3-Employee Common	Door Gate		Closing speed	5	Yes					n/a	$ -	
F15606	Adams County Detention Center	Existing Jail	Interior	Owned	Sport Area		3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F15607	Adams County Detention Center	Existing Jail	Interior	Owned	Sport Area		3-Employee Common	Exercise Equipment		Other attribute	OK	Yes					n/a	$ -	
F15702	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway	From parking lot	1-Public Unsupervised	Curb Ramp		Accumulates water?	N	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15703	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway	From parking lot	1-Public Unsupervised	Curb Ramp		Height, level change	OK	Yes					n/a	$ -	
F15704	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway	From parking lot	1-Public Unsupervised	Curb Ramp		Slope, counter	0.0%	Yes					n/a	$ -	
F15705	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway	From parking lot	1-Public Unsupervised	Curb Ramp		Slope, cross	0.1%	Yes					n/a	$ -	
F15706	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway	From parking lot	1-Public Unsupervised	Curb Ramp		Slope, left flare	7.5%	Yes					n/a	$ -	
F15707	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway	From parking lot	1-Public Unsupervised	Curb Ramp		Slope, right flare	4.9%	Yes					n/a	$ -	
F15708	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway	From parking lot	1-Public Unsupervised	Curb Ramp		Slope, running	7.1%	Yes					n/a	$ -	
F15709	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway	From parking lot	1-Public Unsupervised	Curb Ramp		Surface material	Concrete	Yes					n/a	$ -	
F15710	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway	From parking lot	1-Public Unsupervised	Curb Ramp		Width	48	Yes					n/a	$ -	
F15714	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway	Youth Services Public Entrance	1-Public Unsupervised	Curb Ramp		Slope, counter	1.3%	Yes					n/a	$ -	
F15715	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway	Youth Services Public Entrance	1-Public Unsupervised	Curb Ramp		Slope, cross	1.0%	Yes					n/a	$ -	
F15716	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway	Youth Services Public Entrance	1-Public Unsupervised	Curb Ramp		Slope, left flare	2.3%	Yes					n/a	$ -	
F15717	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway	Youth Services Public Entrance	1-Public Unsupervised	Curb Ramp		Slope, right flare	4.1%	Yes					n/a	$ -	
F15718	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway	Youth Services Public Entrance	1-Public Unsupervised	Curb Ramp		Width	57	Yes					n/a	$ -	
F15724	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Landing	Between sections #1 & #2	Clearance, parallel	75	Yes					n/a	$ -	
F15725	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Landing	Between sections #2 & #3	Clearance, parallel	72	Yes					n/a	$ -	
F15726	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Landing	At top of ramp	Clearance, parallel	99	Yes					n/a	$ -	
F15727	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Landing	Between sections #1 & #2	Clearance, perpendicular	96	Yes					n/a	$ -	
F15728	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Landing	Between sections #2 & #3	Clearance, perpendicular	96	Yes					n/a	$ -	
F15729	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Landing	At top of ramp	Clearance, perpendicular	96	Yes					n/a	$ -	
F15730	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Landing	Between sections #1 & #2	Edge protection?	Y	Yes					n/a	$ -	
F15731	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Landing	Between sections #2 & #3	Edge protection?	Y	Yes					n/a	$ -	
F15732	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Landing	At top of ramp	Edge protection?	Y	Yes					n/a	$ -	
F15733	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Ramp	Section #1	Edge protection?	Y	Yes					n/a	$ -	
F15734	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Ramp	Section #2	Edge protection?	Y	Yes					n/a	$ -	
F15735	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Ramp	Section #3	Edge protection?	Y	Yes					n/a	$ -	
F15736	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Ramp	Section #1	Length	30 feet	Yes					n/a	$ -	
F15737	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Ramp	Section #2	Length	30 feet	Yes					n/a	$ -	
F15738	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Ramp	Section #3	Length	30 feet	Yes					n/a	$ -	
F15739	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Landing	Between sections #1 & #2	Slope, cross	0.2%	Yes					n/a	$ -	
F15740	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Landing	Between sections #2 & #3	Slope, cross	0.3%	Yes					n/a	$ -	
F15741	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Landing	At top of ramp	Slope, cross	0.5%	Yes					n/a	$ -	
F15742	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Ramp	Section #2	Slope, cross	0.2%	Yes					n/a	$ -	
F15743	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Ramp	Section #3	Slope, cross	0.5%	Yes					n/a	$ -	
F15744	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Ramp	Section #1	Slope, cross	1.3%	Yes					n/a	$ -	
F15745	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Landing	At top of ramp	Slope, running	0.5%	Yes					n/a	$ -	
F15746	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Landing	Between sections #2 & #3	Slope, running	0.7%	Yes					n/a	$ -	
F15747	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Ramp	Section #2	Slope, running	8.3%	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15748	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Ramp	Section #1	Surface material	Concrete	Yes					n/a	$ -	
F15749	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F15750	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Ramp	Section #1	Width	90	Yes					n/a	$ -	
F15751	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Ramp	Section #2	Width	90	Yes					n/a	$ -	
F15752	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Ramp	Section #3	Width	96	Yes					n/a	$ -	
F15753	Adams County Detention Center	Existing Jail	Exterior	Owned	Walkway		1-Public Unsupervised	Walking Surface		Width	96	Yes					n/a	$ -	
F15755	Adams County Detention Center	F Module	Exterior	Owned	Walkway	Employee Parking - Lot F	3-Employee Common	Walking Surface		Slope, cross	2.0%	Yes					n/a	$ -	
F15756	Adams County Detention Center	F Module	Exterior	Owned	Walkway	Employee Parking - Lot F	3-Employee Common	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F15757	Adams County Detention Center	F Module	Exterior	Owned	Walkway	Employee Parking - Lot F	3-Employee Common	Walking Surface		Width	60	Yes					n/a	$ -	
F15759	Adams County Detention Center	F Module	Exterior	Owned	Walkway	From parking lot to Employee entrance	3-Employee Common	Walking Surface		Slope, cross	2.0%	Yes					n/a	$ -	
F15760	Adams County Detention Center	F Module	Exterior	Owned	Walkway	From parking lot to Employee entrance	3-Employee Common	Walking Surface		Width	60	Yes					n/a	$ -	
F00021	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F00022	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F00023	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Hardware type	Panic bar	Yes					n/a	$ -	
F00024	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	18	Yes					n/a	$ -	
F00025	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Threshold beveled?	Y	Yes					n/a	$ -	
F00030	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F00031	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Clearance, pull parallel	22	Yes					n/a	$ -	
F00032	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F00033	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Clearance, push parallel	20	Yes					n/a	$ -	
F00034	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F00035	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Clearance, vertical	81	Yes					n/a	$ -	
F00044	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Clear opening	OK	Yes					n/a	$ -	
F00046	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Assembly Area	#109 - Grand Hall	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F00047	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Assembly Area	#109 - Grand Hall	1-Public Unsupervised	Signage		Height, bottom	52.75	Yes					n/a	$ -	
F00048	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Assembly Area	#109 - Grand Hall	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F00049	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Assembly Area	#109 - Grand Hall	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F00055	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #1	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F00056	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #1	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F00057	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #1	1-Public Unsupervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F00058	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #1	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F00059	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #1	1-Public Unsupervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F00060	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #1	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F00061	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #1	1-Public Unsupervised	Door Gate		Clearance, vertical	93	Yes					n/a	$ -	
F00062	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #1	1-Public Unsupervised	Door Gate		Hardware type	Panic bar	Yes					n/a	$ -	
F00063	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #1	1-Public Unsupervised	Signage		Height, bottom	53	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00064	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #1	1-Public Unsupervised	Signage		ISA?	N	Yes					n/a	$ -	
F00065	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #1	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F00066	Adams County Fair Grounds		Interior	Owned	Assembly Area	Rendezvous #1	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F00292	Adams County Fair Grounds		Interior	Owned	Break Room	Rendezvous #1	1-Public Unsupervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F00293	Adams County Fair Grounds		Interior	Owned	Break Room	Rendezvous #1	1-Public Unsupervised	Dispenser	Soap	Clearance, parallel	99	Yes					n/a	$ -	
F00294	Adams County Fair Grounds		Interior	Owned	Break Room	Rendezvous #1	1-Public Unsupervised	Dispenser	PT	Clearance, parallel	99	Yes					n/a	$ -	
F00295	Adams County Fair Grounds		Interior	Owned	Break Room	Rendezvous #1	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	99	Yes					n/a	$ -	
F00296	Adams County Fair Grounds		Interior	Owned	Break Room	Rendezvous #1	1-Public Unsupervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F00297	Adams County Fair Grounds		Interior	Owned	Break Room	Rendezvous #1	1-Public Unsupervised	Dispenser	Soap	Clearance, perpendicular	99	Yes					n/a	$ -	
F00298	Adams County Fair Grounds		Interior	Owned	Break Room	Rendezvous #1	1-Public Unsupervised	Dispenser	PT	Clearance, perpendicular	99	Yes					n/a	$ -	
F00299	Adams County Fair Grounds		Interior	Owned	Break Room	Rendezvous #1	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	99	Yes					n/a	$ -	
F00300	Adams County Fair Grounds		Interior	Owned	Break Room	Rendezvous #1	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	In cabinet	Yes					n/a	$ -	
F00301	Adams County Fair Grounds		Interior	Owned	Break Room	Rendezvous #1	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F00302	Adams County Fair Grounds		Interior	Owned	Break Room	Rendezvous #1	1-Public Unsupervised	Dispenser	Soap	Height	40.5	Yes					n/a	$ -	
F00303	Adams County Fair Grounds		Interior	Owned	Break Room	Rendezvous #1	1-Public Unsupervised	Counter		Length	71	Yes					n/a	$ -	
F00910	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Concessions		1-Public Unsupervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F00911	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Concessions		1-Public Unsupervised	Drinking Fountain		Clearance, parallel	99	Yes					n/a	$ -	
F00912	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Concessions		1-Public Unsupervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F00913	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Concessions		1-Public Unsupervised	Drinking Fountain		Clearance, perpendicular	99	Yes					n/a	$ -	
F00914	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Concessions		1-Public Unsupervised	Drinking Fountain		Dimension, knee clearance	27	Yes					n/a	$ -	
F00915	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Concessions		1-Public Unsupervised	Counter		Height	36	Yes					n/a	$ -	
F00916	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Concessions		1-Public Unsupervised	Drinking Fountain		Height	34.5	Yes					n/a	$ -	
F00917	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Concessions		1-Public Unsupervised	Drinking Fountain		Height, water flow	37	Yes					n/a	$ -	
F00918	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Concessions		1-Public Unsupervised	Drinking Fountain		High-low fountain?	Y	Yes					n/a	$ -	
F00919	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Concessions		1-Public Unsupervised	Counter		Length	99	Yes					n/a	$ -	
F00920	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Concessions		1-Public Unsupervised	Drinking Fountain		Spout location	F	Yes					n/a	$ -	
F00923	Adams County Fair Grounds		Exterior	Owned	Concessions	Exterior of indoor arena	1-Public Unsupervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F00924	Adams County Fair Grounds		Exterior	Owned	Concessions	Exterior of indoor arena	1-Public Unsupervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F00925	Adams County Fair Grounds		Exterior	Owned	Concessions	Exterior of indoor arena	1-Public Unsupervised	Counter		Dimension, knee clearance	40	Yes					n/a	$ -	
F00926	Adams County Fair Grounds		Exterior	Owned	Concessions	Exterior of indoor arena	1-Public Unsupervised	Counter		Length	99	Yes					n/a	$ -	
F00930	Adams County Fair Grounds		Exterior	Owned	Concessions		1-Public Unsupervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F00931	Adams County Fair Grounds		Exterior	Owned	Concessions		1-Public Unsupervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F00932	Adams County Fair Grounds		Exterior	Owned	Concessions		1-Public Unsupervised	Counter		Length	73	Yes					n/a	$ -	
F03514	Adams County Fair Grounds		Exterior	Owned	Fishing Pier	#1	1-Public Unsupervised	Clear Space		Clearance, parallel	99	Yes					n/a	$ -	
F03515	Adams County Fair Grounds		Exterior	Owned	Fishing Pier	#1	1-Public Unsupervised	Turning Space		Diameter	120	Yes					n/a	$ -	
F03516	Adams County Fair Grounds		Exterior	Owned	Fishing Pier	#1	1-Public Unsupervised	Railing		Length, 34 inch max. railing	36	Yes					n/a	$ -	
F03517	Adams County Fair Grounds		Exterior	Owned	Fishing Pier	#1	1-Public Unsupervised	Railing		Length, total railing	36	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F03518	Adams County Fair Grounds		Exterior	Owned	Fishing Pier	#1	1-Public Unsupervised	Railing		Lowered sections dispersed?	Y	Yes					n/a	$ -	
F03519	Adams County Fair Grounds		Exterior	Owned	Fishing Pier	#1	1-Public Unsupervised	Edge Protection		Railings exist?	Y	Yes					n/a	$ -	
F03520	Adams County Fair Grounds		Exterior	Owned	Fishing Pier	#1	1-Public Unsupervised	Turning Space		T-space provided?	Ok	Yes					n/a	$ -	
F03695	Adams County Fair Grounds		Interior	Owned	Hallway		1-Public Unsupervised	Ramp		Slope, cross	1.3%	Yes					n/a	$ -	
F03696	Adams County Fair Grounds		Interior	Owned	Hallway		1-Public Unsupervised	Ramp		Slope, running	2.9%	Yes					n/a	$ -	
F03697	Adams County Fair Grounds		Interior	Owned	Hallway		1-Public Unsupervised	Ramp		Width	128	Yes					n/a	$ -	
F04246	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Kitchen		1-Public Unsupervised	Lavatory Sink		Clearance, parallel	40	Yes					n/a	$ -	
F04247	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Kitchen		1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	80	Yes					n/a	$ -	
F04248	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Kitchen		1-Public Unsupervised	Counter		Dimension, knee clearance	44	Yes					n/a	$ -	
F04249	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Kitchen		1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F04250	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Kitchen		1-Public Unsupervised	Kitchen Clearance		Kitchen type	Residential	Yes					n/a	$ -	
F04251	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Kitchen		1-Public Unsupervised	Counter		Length	63	Yes					n/a	$ -	
F04252	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Kitchen		1-Public Unsupervised	Counter		Length	94	Yes					n/a	$ -	
F04253	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Kitchen		3-Employee Common	Appliance	Refrig/Freezer	Other attribute	OK	Yes					n/a	$ -	
F05422	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Cars obstruct pathway	N	Yes					n/a	$ -	
F05423	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, accessible	2	Yes					n/a	$ -	
F05424	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Sign?	Y	Yes					n/a	$ -	
F05425	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Sign?	Y	Yes					n/a	$ -	
F05426	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Slope, cross	0.4%	Yes					n/a	$ -	
F05427	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Slope, cross	0.5%	Yes					n/a	$ -	
F05428	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Slope, running	0.4%	Yes					n/a	$ -	
F05429	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Slope, running	0.9%	Yes					n/a	$ -	
F05430	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Surface material	Concrete	Yes					n/a	$ -	
F05431	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Surface material	Concrete	Yes					n/a	$ -	
F05432	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Van sign?	N	Yes					n/a	$ -	
F05433	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Width	157	Yes					n/a	$ -	
F05434	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Width	156	Yes					n/a	$ -	
F05439	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Sign?	Y	Yes					n/a	$ -	
F05440	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Slope, cross	0.5%	Yes					n/a	$ -	
F05441	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Surface material	Concrete	Yes					n/a	$ -	
F05442	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Van sign?	N	Yes					n/a	$ -	
F05443	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Width	161	Yes					n/a	$ -	
F05457	Adams County Fair Grounds		Exterior	Owned	Parking Facility	At play area	1-Public Unsupervised	Facility Specifications		Number, accessible	2	Yes					n/a	$ -	
F05458	Adams County Fair Grounds		Exterior	Owned	Parking Facility	At play area	1-Public Unsupervised	Parking Space	#1	Sign?	Y	Yes					n/a	$ -	
F05459	Adams County Fair Grounds		Exterior	Owned	Parking Facility	At play area	1-Public Unsupervised	Parking Space	#2	Sign?	Y	Yes					n/a	$ -	
F05460	Adams County Fair Grounds		Exterior	Owned	Parking Facility	At play area	1-Public Unsupervised	Parking Space	#1	Width	96	Yes					n/a	$ -	
F05461	Adams County Fair Grounds		Exterior	Owned	Parking Facility	At play area	1-Public Unsupervised	Parking Space	#2	Width	144	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05476	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Parking Space	#1 - Row 1	Access aisle?	Y	Yes					n/a	$ -	
F05477	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Facility Specifications		Cars obstruct pathway	N	Yes					n/a	$ -	
F05478	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Parking Space	#1 - Row 1	Height, sign	74	Yes					n/a	$ -	
F05479	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Access Aisle	#1	Length	OK	Yes					n/a	$ -	
F05480	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Parking Space	#1 - Row 1	Sign?	Y	Yes					n/a	$ -	
F05481	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Access Aisle	#1	Slope, cross	0.2%	Yes					n/a	$ -	
F05482	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Parking Space	#1 - Row 1	Slope, cross	0.5%	Yes					n/a	$ -	
F05483	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Access Aisle	#1	Slope, running	0.7%	Yes					n/a	$ -	
F05484	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Parking Space	#1 - Row 1	Slope, running	1.1%	Yes					n/a	$ -	
F05485	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Access Aisle	#1	Surface marking?	Y	Yes					n/a	$ -	
F05486	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Access Aisle	#1	Surface material	Asphalt	Yes					n/a	$ -	
F05487	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Parking Space	#1 - Row 1	Surface material	Asphalt	Yes					n/a	$ -	
F05488	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Access Aisle		Width	60	Yes					n/a	$ -	
F05489	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Main parking lot North	1-Public Unsupervised	Parking Space	#1 - Row 1	Width	130	Yes					n/a	$ -	
F05494	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Parking Space	#1	Access aisle?	Y	Yes					n/a	$ -	
F05495	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Parking Space	#2	Access aisle?	Y	Yes					n/a	$ -	
F05496	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Access Aisle	#1	Adjacent pathway?	Y	Yes					n/a	$ -	
F05497	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Facility Specifications		Cars obstruct pathway	N	Yes					n/a	$ -	
F05498	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Parking Space	#1	Height, sign	78	Yes					n/a	$ -	
F05499	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Parking Space	#2	Height, sign	78	Yes					n/a	$ -	
F05500	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Access Aisle	#1	Length	OK	Yes					n/a	$ -	
F05501	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Facility Specifications		Number, accessible	2	Yes					n/a	$ -	
F05502	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Access Aisle	#1	Pathway behind cars?	N	Yes					n/a	$ -	
F05503	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Parking Space	#1	Sign?	Y	Yes					n/a	$ -	
F05504	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Parking Space	#2	Sign?	Y	Yes					n/a	$ -	
F05505	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Access Aisle	#1	Slope, cross	1.2%	Yes					n/a	$ -	
F05506	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Parking Space	#2	Slope, cross	0.4%	Yes					n/a	$ -	
F05507	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Parking Space	#1	Slope, cross	0.7%	Yes					n/a	$ -	
F05508	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Access Aisle	#1	Slope, running	0.8%	Yes					n/a	$ -	
F05509	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Parking Space	#2	Slope, running	0.6%	Yes					n/a	$ -	
F05510	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Parking Space	#1	Slope, running	0.7%	Yes					n/a	$ -	
F05511	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Access Aisle	#1	Surface marking?	Y	Yes					n/a	$ -	
F05512	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Access Aisle	#1	Surface material	Concrete	Yes					n/a	$ -	
F05513	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Parking Space	#1	Surface material	Concrete	Yes					n/a	$ -	
F05514	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Parking Space	#2	Surface material	Concrete	Yes					n/a	$ -	
F05515	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Parking Space	#1	Van sign?	N	Yes					n/a	$ -	
F05516	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Parking Space	#2	Van sign?	N	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05517	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Access Aisle	#1	Width	70	Yes					n/a	$ -	
F05518	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Parking Space	#1	Width	129	Yes					n/a	$ -	
F05519	Adams County Fair Grounds		Exterior	Owned	Parking Facility	Parking lot and Trail off 124th	1-Public Unsupervised	Parking Space	#2	Width	128	Yes					n/a	$ -	
F05536	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#1	Access aisle?	Y	Yes					n/a	$ -	
F05537	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space		Access aisle?	Y	Yes					n/a	$ -	
F05538	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#4	Access aisle?	Y	Yes					n/a	$ -	
F05539	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#5	Access aisle?	Y	Yes					n/a	$ -	
F05540	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Facility Specifications		Cars obstruct pathway	N	Yes					n/a	$ -	
F05541	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#1	Height, sign	74	Yes					n/a	$ -	
F05542	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space		Height, sign	84	Yes					n/a	$ -	
F05543	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#3	Height, sign	79	Yes					n/a	$ -	
F05544	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#4	Height, sign	79	Yes					n/a	$ -	
F05545	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#5	Height, sign	79	Yes					n/a	$ -	
F05546	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle		Length	OK	Yes					n/a	$ -	
F05547	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle		Length	OK	Yes					n/a	$ -	
F05548	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Length	OK	Yes					n/a	$ -	
F05549	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Length	OK	Yes					n/a	$ -	
F05550	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Facility Specifications		Number, accessible	9	Yes					n/a	$ -	
F05551	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#1	Sign?	Y	Yes					n/a	$ -	
F05552	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space		Sign?	Y	Yes					n/a	$ -	
F05553	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#2	Sign?	Y	Yes					n/a	$ -	
F05554	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#3	Sign?	Y	Yes					n/a	$ -	
F05555	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#4	Sign?	Y	Yes					n/a	$ -	
F05556	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#5	Sign?	Y	Yes					n/a	$ -	
F05557	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Slope, cross	0.0%	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05558	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Slope, cross	0.2%	Yes					n/a	$ -	
F05559	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle		Slope, cross	0.3%	Yes					n/a	$ -	
F05560	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle		Slope, cross	0.5%	Yes					n/a	$ -	
F05561	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#3	Slope, cross	0.1%	Yes					n/a	$ -	
F05562	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#4	Slope, cross	0.2%	Yes					n/a	$ -	
F05563	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#1	Slope, cross	0.3%	Yes					n/a	$ -	
F05564	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#2	Slope, cross	0.5%	Yes					n/a	$ -	
F05565	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space		Slope, cross	0.6%	Yes					n/a	$ -	
F05566	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#5	Slope, cross	1.2%	Yes					n/a	$ -	
F05567	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle		Slope, running	0.4%	Yes					n/a	$ -	
F05568	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Slope, running	0.4%	Yes					n/a	$ -	
F05569	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Slope, running	0.5%	Yes					n/a	$ -	
F05570	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle		Slope, running	0.7%	Yes					n/a	$ -	
F05571	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#3	Slope, running	0.2%	Yes					n/a	$ -	
F05572	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space		Slope, running	0.3%	Yes					n/a	$ -	
F05573	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#4	Slope, running	0.4%	Yes					n/a	$ -	
F05574	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#1	Slope, running	0.5%	Yes					n/a	$ -	
F05575	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#2	Slope, running	0.5%	Yes					n/a	$ -	
F05576	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#5	Slope, running	0.6%	Yes					n/a	$ -	
F05577	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle		Surface marking?	Y	Yes					n/a	$ -	
F05578	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle		Surface marking?	Y	Yes					n/a	$ -	
F05579	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Surface marking?	Y	Yes					n/a	$ -	
F05580	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle		Surface material	Asphalt	Yes					n/a	$ -	
F05581	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#1	Surface material	Asphalt	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05582	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space		Surface material	Asphalt	Yes					n/a	$ -	
F05583	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#2	Van sign?	N	Yes					n/a	$ -	
F05584	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#3	Van sign?	N	Yes					n/a	$ -	
F05585	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#5	Van sign?	N	Yes					n/a	$ -	
F05586	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle		Width	200	Yes					n/a	$ -	
F05587	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Width	148	Yes					n/a	$ -	
F05588	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle	#2 & #3	Width	61	Yes					n/a	$ -	
F05589	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Access Aisle	#1	Width	61	Yes					n/a	$ -	
F05590	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#1	Width	132	Yes					n/a	$ -	
F05591	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#2	Width	132	Yes					n/a	$ -	
F05592	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#3	Width	145	Yes					n/a	$ -	
F05593	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#4	Width	144	Yes					n/a	$ -	
F05594	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space	#5	Width	140	Yes					n/a	$ -	
F05595	Adams County Fair Grounds		Exterior	Owned	Parking Facility	South of Waymire Dome - East of Exhibit Hall	1-Public Unsupervised	Parking Space		Width	134	Yes					n/a	$ -	
F05597	Adams County Fair Grounds		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Cars obstruct pathway	N	Yes					n/a	$ -	
F05598	Adams County Fair Grounds		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, accessible	1	Yes					n/a	$ -	
F05599	Adams County Fair Grounds		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, total spaces	20	Yes					n/a	$ -	
F07325	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Landing		Clearance, parallel	36	Yes					n/a	$ -	
F07326	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Landing		Clearance, perpendicular	54	Yes					n/a	$ -	
F07327	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Play Table		Depth, knee clearance	99	Yes					n/a	$ -	
F07328	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Ramp	Section #1	Edge protection?	Y	Yes					n/a	$ -	
F07329	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Ramp	Section #2	Edge protection?	Y	Yes					n/a	$ -	
F07330	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Component Entry	Rocker	Height	22	Yes					n/a	$ -	
F07331	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Component Entry	Swings	Height	19	Yes					n/a	$ -	
F07332	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Play Table		Height	25	Yes					n/a	$ -	
F07333	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Play Table		Height, knee clearance	22.5	Yes					n/a	$ -	
F07334	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Ramp	Section #1	Height, level change	0.5	Yes					n/a	$ -	
F07335	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Ramp	Section #1	Length	144	Yes					n/a	$ -	
F07336	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Ramp	Section #2	Length	144	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07337	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Area Specifications		Number, elevated components connected by ramp	8	Yes					n/a	$ -	
F07338	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Area Specifications		Number, elevated components on accessible route	5	Yes					n/a	$ -	
F07339	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Area Specifications		Number, elevated types connected by ramp	4	Yes					n/a	$ -	
F07340	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Area Specifications		Number, ground components	5	Yes					n/a	$ -	
F07341	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Area Specifications		Number, ground types	3	Yes					n/a	$ -	
F07342	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Landing		Slope, cross	1.2%	Yes					n/a	$ -	
F07343	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Ramp	Section #2	Slope, cross	0.0%	Yes					n/a	$ -	
F07344	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Ramp	Section #1	Slope, cross	0.3%	Yes					n/a	$ -	
F07345	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Landing		Slope, running	0.3%	Yes					n/a	$ -	
F07346	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Ramp	Section #2	Slope, running	4.6%	Yes					n/a	$ -	
F07347	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Ramp	Section #1	Slope, running	5.0%	Yes					n/a	$ -	
F07348	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Ramp	Section #1	Surface material	Metal	Yes					n/a	$ -	
F07349	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Ramp	Section #2	Surface material	Metal	Yes					n/a	$ -	
F07350	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Ramp	Section #1	Width	36	Yes					n/a	$ -	
F07351	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Ramp	Section #2	Width	36	Yes					n/a	$ -	
F07352	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Walking Surface		Width	OK	Yes					n/a	$ -	
F07353	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Play Table		Width, knee clearance	99	Yes					n/a	$ -	
F07364	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Transfer		Clearance, parallel	36	Yes					n/a	$ -	
F07365	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Transfer		Clearance, perpendicular	99	Yes					n/a	$ -	
F07366	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Transfer		Depth, platform/step	18	Yes					n/a	$ -	
F07367	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Play Table	Under play components	Height	26	Yes					n/a	$ -	
F07368	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Play Table	Under play components	Height, knee clearance	23	Yes					n/a	$ -	
F07369	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Transfer		Height, platform/step	15	Yes					n/a	$ -	
F07370	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Door Gate	Under play structure	Other attribute	Open doorway	Yes					n/a	$ -	
F07371	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Transfer		Transfer support?	Y	Yes					n/a	$ -	
F07372	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Play Table	Under play components	Width, knee clearance	36	Yes					n/a	$ -	
F07373	Adams County Fair Grounds		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Transfer		Width, platform/step	36	Yes					n/a	$ -	
F07895	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Urinal		Depth	14	Yes					n/a	$ -	
F07915	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F07916	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	#1	Clear opening	34	Yes					n/a	$ -	
F07917	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	#2	Clear opening	34	Yes					n/a	$ -	
F07918	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Urinal		Clearance, parallel	36	Yes					n/a	$ -	
F07919	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Clearance, parallel	60	Yes					n/a	$ -	
F07920	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	Ambulatory	Clearance, perpendicular	70.5	Yes					n/a	$ -	
F07921	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Urinal		Clearance, perpendicular	99	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07922	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Clearance, perpendicular	64	Yes					n/a	$ -	
F07923	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear - #1 stall	Clearance, to wall	1.5	Yes					n/a	$ -	
F07924	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side - #1 stall	Clearance, to wall	1.5	Yes					n/a	$ -	
F07925	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear - #2 stall	Clearance, to wall	1.5	Yes					n/a	$ -	
F07926	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side - #2 stall	Clearance, to wall	1.5	Yes					n/a	$ -	
F07927	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Amb - Side #1	Clearance, to wall	1.5	Yes					n/a	$ -	
F07928	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Amb - Side #2	Clearance, to wall	1.5	Yes					n/a	$ -	
F07929	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear - #1 stall	Diameter	1.5	Yes					n/a	$ -	
F07930	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side - #1 stall	Diameter	1.5	Yes					n/a	$ -	
F07931	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear - #2 stall	Diameter	1.5	Yes					n/a	$ -	
F07932	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side - #2 stall	Diameter	1.5	Yes					n/a	$ -	
F07933	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Amb - Side #1	Diameter	1.5	Yes					n/a	$ -	
F07934	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Amb - Side #2	Diameter	1.5	Yes					n/a	$ -	
F07935	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Dimension, characters	3.5	Yes					n/a	$ -	
F07936	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	Ambulatory	Dimension, door to partition	3	Yes					n/a	$ -	
F07937	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear - #1 stall	Dimension, end to wall	6	Yes					n/a	$ -	
F07938	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side - #1 stall	Dimension, end to wall	12	Yes					n/a	$ -	
F07939	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side - #2 stall	Dimension, end to wall	12	Yes					n/a	$ -	
F07940	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Amb - Side #1	Dimension, end to wall	12	Yes					n/a	$ -	
F07941	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Amb - Side #2	Dimension, end to wall	12	Yes					n/a	$ -	
F07942	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Counter		Dimension, knee clearance	29.75	Yes					n/a	$ -	
F07943	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29.75	Yes					n/a	$ -	
F07944	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet	#2	Dimension, sidewall	18	Yes					n/a	$ -	
F07945	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet	Ambulatory	Dimension, sidewall	17.5	Yes					n/a	$ -	
F07946	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet	#1	Dimension, wide side	45.25	Yes					n/a	$ -	
F07947	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet	#2	Dimension, wide side	42.5	Yes					n/a	$ -	
F07948	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet	Ambulatory	Dimension, wide side	18	Yes					n/a	$ -	
F07949	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	#2	Door swing direction	Out	Yes					n/a	$ -	
F07950	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	Ambulatory	Door swing direction	Out	Yes					n/a	$ -	
F07951	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	Ambulatory	Hardware both sides?	Y	Yes					n/a	$ -	
F07952	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F07953	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	#1	Hardware type	PP	Yes					n/a	$ -	
F07954	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	#2	Hardware type	PP	Yes					n/a	$ -	
F07955	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	Ambulatory	Hardware type	PP	Yes					n/a	$ -	
F07956	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Counter		Height	33.5	Yes					n/a	$ -	
F07957	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP - #1	Height	42	Yes					n/a	$ -	
F07958	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP - #2	Height	42	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07959	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP - Amb	Height	42	Yes					n/a	$ -	
F07960	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	Soap	Height	37.5	Yes					n/a	$ -	
F07961	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F07962	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Mirror		Height, bottom	34.75	Yes					n/a	$ -	
F07963	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Height, bottom	56.5	Yes					n/a	$ -	
F07964	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Urinal		Height, flush control	39	Yes					n/a	$ -	
F07965	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Urinal		Height, rim	16.5	Yes					n/a	$ -	
F07966	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet	#1	Height, seat	18.5	Yes					n/a	$ -	
F07967	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet	#2	Height, seat	18.5	Yes					n/a	$ -	
F07968	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet	Ambulatory	Height, seat	18.5	Yes					n/a	$ -	
F07969	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	#1	Height, toe clearance	12	Yes					n/a	$ -	
F07970	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	#2	Height, toe clearance	12	Yes					n/a	$ -	
F07971	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	Ambulatory	Height, toe clearance	12	Yes					n/a	$ -	
F07972	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side - #1 stall	Height, top	34.75	Yes					n/a	$ -	
F07973	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side - #2 stall	Height, top	35	Yes					n/a	$ -	
F07974	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear - #1 stall	Height, top	34.75	Yes					n/a	$ -	
F07975	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear - #2 stall	Height, top	34.75	Yes					n/a	$ -	
F07976	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Amb - Side #1	Height, top	35	Yes					n/a	$ -	
F07977	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Amb - Side #2	Height, top	35	Yes					n/a	$ -	
F07978	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Counter		Length	99	Yes					n/a	$ -	
F07979	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side - #1 stall	Length	42	Yes					n/a	$ -	
F07980	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side - #2 stall	Length	42	Yes					n/a	$ -	
F07981	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Amb - Side #1	Length	42	Yes					n/a	$ -	
F07982	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Amb - Side #2	Length	42	Yes					n/a	$ -	
F07983	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F07984	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet	#1	Location, flush control	W	Yes					n/a	$ -	
F07985	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet	#2	Location, flush control	W	Yes					n/a	$ -	
F07986	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Fixture Count		Number, accessible compartments	2	Yes					n/a	$ -	
F07987	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	1	Yes					n/a	$ -	
F07988	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Fixture Count		Number, toilet compartments	6	Yes					n/a	$ -	
F07989	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Fixture Count		Number, urinals	5	Yes					n/a	$ -	
F07990	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	#2	Self-closing?	Y	Yes					n/a	$ -	
F07991	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment	Ambulatory	Self-closing?	Y	Yes					n/a	$ -	
F07992	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F07999	Adams County Fair Grounds	Exhibit Hall	Exterior	Owned	Restroom	Men's - Back side	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F08046	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08047	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment	#1	Clear opening	34	Yes					n/a	$ -	
F08048	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment	#2	Clear opening	34	Yes					n/a	$ -	
F08049	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F08050	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Clearance, parallel	OK	Yes					n/a	$ -	
F08051	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Feminine products	Clearance, parallel	OK	Yes					n/a	$ -	
F08052	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	99	Yes					n/a	$ -	
F08053	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment	#1	Clearance, parallel	60.5	Yes					n/a	$ -	
F08054	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment	#2	Clearance, parallel	60	Yes					n/a	$ -	
F08055	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Clearance, parallel	60.5	Yes					n/a	$ -	
F08056	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Ambulatory Compartment		Clearance, perpendicular	70	Yes					n/a	$ -	
F08057	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F08058	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Clearance, perpendicular	OK	Yes					n/a	$ -	
F08059	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Feminine products	Clearance, perpendicular	OK	Yes					n/a	$ -	
F08060	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	99	Yes					n/a	$ -	
F08061	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment	#1	Clearance, perpendicular	64.5	Yes					n/a	$ -	
F08062	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment	#2	Clearance, perpendicular	64.5	Yes					n/a	$ -	
F08063	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Clearance, perpendicular	64.5	Yes					n/a	$ -	
F08064	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side - #1 stall	Clearance, to wall	1.5	Yes					n/a	$ -	
F08065	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F08066	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side - #2 stall	Clearance, to wall	1.5	Yes					n/a	$ -	
F08067	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Amb - Side #1	Clearance, to wall	1.5	Yes					n/a	$ -	
F08068	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side - #1 stall	Diameter	1.5	Yes					n/a	$ -	
F08069	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F08070	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side - #2 stall	Diameter	1.5	Yes					n/a	$ -	
F08071	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Amb - Side #1	Diameter	1.5	Yes					n/a	$ -	
F08072	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Amb - Side #2	Diameter	1.5	Yes					n/a	$ -	
F08073	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Dimension, characters	3.5	Yes					n/a	$ -	
F08074	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side - #1 stall	Dimension, end to wall	12	Yes					n/a	$ -	
F08075	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Amb - Side #1	Dimension, end to wall	12	Yes					n/a	$ -	
F08076	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Amb - Side #2	Dimension, end to wall	12	Yes					n/a	$ -	
F08077	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Counter		Dimension, knee clearance	29.25	Yes					n/a	$ -	
F08078	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29.25	Yes					n/a	$ -	
F08079	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet	Ambulatory	Dimension, sidewall	17.75	Yes					n/a	$ -	
F08080	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet	#2	Dimension, sidewall	17.5	Yes					n/a	$ -	
F08081	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet	#1	Dimension, sidewall	16	Yes					n/a	$ -	
F08082	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet	#1	Dimension, wide side	43	Yes					n/a	$ -	
F08083	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet	#2	Dimension, wide side	42.75	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08084	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet	Ambulatory	Dimension, wide side	19.25	Yes					n/a	$ -	
F08085	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Ambulatory Compartment		Door swing direction	Out	Yes					n/a	$ -	
F08086	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment	#1	Door swing direction	Out	Yes					n/a	$ -	
F08087	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F08088	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment	#1	Hardware type	PP	Yes					n/a	$ -	
F08089	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment	#2	Hardware type	PP	Yes					n/a	$ -	
F08090	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Counter		Height	33	Yes					n/a	$ -	
F08091	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP - #1	Height	42	Yes					n/a	$ -	
F08092	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP - #2	Height	42	Yes					n/a	$ -	
F08093	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP - Amb	Height	43	Yes					n/a	$ -	
F08094	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Soap	Height	38	Yes					n/a	$ -	
F08095	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Height	48	Yes					n/a	$ -	
F08096	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F08097	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Mirror		Height, bottom	33.5	Yes					n/a	$ -	
F08098	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Height, bottom	55.25	Yes					n/a	$ -	
F08099	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet	#1	Height, seat	18	Yes					n/a	$ -	
F08100	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet	#2	Height, seat	18.5	Yes					n/a	$ -	
F08101	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment	#1	Height, toe clearance	12	Yes					n/a	$ -	
F08102	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment	#2	Height, toe clearance	12	Yes					n/a	$ -	
F08103	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side - #1 stall	Height, top	35	Yes					n/a	$ -	
F08104	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side - #2 stall	Height, top	35	Yes					n/a	$ -	
F08105	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear - #1 stall	Height, top	35	Yes					n/a	$ -	
F08106	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear - #2 stall	Height, top	35	Yes					n/a	$ -	
F08107	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Amb - Side #1	Height, top	35	Yes					n/a	$ -	
F08108	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Amb - Side #2	Height, top	35	Yes					n/a	$ -	
F08109	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Counter		Length	99	Yes					n/a	$ -	
F08110	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side - #1 stall	Length	42	Yes					n/a	$ -	
F08111	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side - #2 stall	Length	42	Yes					n/a	$ -	
F08112	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side - #1 stall	Length	42	Yes					n/a	$ -	
F08113	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side - #2 stall	Length	42	Yes					n/a	$ -	
F08114	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F08115	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, accessible compartments	2	Yes					n/a	$ -	
F08116	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	1	Yes					n/a	$ -	
F08117	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, toilet compartments	13	Yes					n/a	$ -	
F08118	Adams County Fair Grounds	Exhibit Hall	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F08124	Adams County Fair Grounds	Exhibit Hall	Exterior	Owned	Restroom	Women's - Back side	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08125	Adams County Fair Grounds	Exhibit Hall	Exterior	Owned	Restroom	Women's - Back side	1-Public Unsupervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F08126	Adams County Fair Grounds	Exhibit Hall	Exterior	Owned	Restroom	Women's - Back side	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F08127	Adams County Fair Grounds	Exhibit Hall	Exterior	Owned	Restroom	Women's - Back side	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F08128	Adams County Fair Grounds	Exhibit Hall	Exterior	Owned	Restroom	Women's - Back side	1-Public Unsupervised	Door Gate		Opening force	9	Yes					n/a	$ -	
F08148	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Urinal		Depth	14	Yes					n/a	$ -	
F08166	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F08167	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Clear opening	39	Yes					n/a	$ -	
F08168	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F08169	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	30	Yes					n/a	$ -	
F08170	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Urinal		Clearance, parallel	99	Yes					n/a	$ -	
F08171	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	99	Yes					n/a	$ -	
F08172	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	71	Yes					n/a	$ -	
F08173	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Urinal		Clearance, perpendicular	99	Yes					n/a	$ -	
F08174	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Clearance, pull parallel	99	Yes					n/a	$ -	
F08175	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Clearance, push parallel	21	Yes					n/a	$ -	
F08176	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Clearance, push perpendicular	99	Yes					n/a	$ -	
F08177	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Urinal		Control force	3	Yes					n/a	$ -	
F08178	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Control force	3	Yes					n/a	$ -	
F08179	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F08180	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F08181	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	9	Yes					n/a	$ -	
F08182	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Dimension, characters	4.5	Yes					n/a	$ -	
F08183	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Door swing direction	Out	Yes					n/a	$ -	
F08184	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Hardware type	PP	Yes					n/a	$ -	
F08185	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Height	35	Yes					n/a	$ -	
F08186	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Height	33.75	Yes					n/a	$ -	
F08187	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Height, bottom	58.5	Yes					n/a	$ -	
F08188	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Urinal		Height, flush control	48	Yes					n/a	$ -	
F08190	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	11.75	Yes					n/a	$ -	
F08191	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F08192	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F08193	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F08194	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F08195	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F08196	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F08197	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08198	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F08199	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Fixture Count		Number, toilet compartments	3	Yes					n/a	$ -	
F08200	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Fixture Count		Number, urinals	8	Yes					n/a	$ -	
F08201	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F08237	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F08238	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clear opening	39	Yes					n/a	$ -	
F08239	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F08240	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	70.5	Yes					n/a	$ -	
F08241	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Clearance, perpendicular	71.5	Yes					n/a	$ -	
F08242	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F08243	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, push parallel	21	Yes					n/a	$ -	
F08244	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F08245	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Control force	3	Yes					n/a	$ -	
F08246	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F08247	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F08248	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Dimension, characters	4.5	Yes					n/a	$ -	
F08249	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4	Yes					n/a	$ -	
F08250	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F08251	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Door swing direction	Out	Yes					n/a	$ -	
F08252	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	Y	Yes					n/a	$ -	
F08253	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F08254	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Height	34	Yes					n/a	$ -	
F08255	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Soap	Height	48	Yes					n/a	$ -	
F08256	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Height	33.5	Yes					n/a	$ -	
F08257	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Height, bottom	57	Yes					n/a	$ -	
F08258	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12.5	Yes					n/a	$ -	
F08259	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Height, top	34.75	Yes					n/a	$ -	
F08260	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Height, top	35.25	Yes					n/a	$ -	
F08261	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F08262	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F08263	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F08264	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F08265	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F08266	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, toilet compartments	10	Yes					n/a	$ -	
F08267	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, urinals	0	Yes					n/a	$ -	
F08268	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Opening force	5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08269	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F08270	Adams County Fair Grounds	Grandstand	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Height, threshold	0.5	Yes					n/a	$ -	
F08308	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F08309	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F08310	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Clear opening	32	Yes					n/a	$ -	
F08311	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Interior access	Clear opening	32	Yes					n/a	$ -	
F08312	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F08313	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	99	Yes					n/a	$ -	
F08314	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	81	Yes					n/a	$ -	
F08315	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Urinal		Clearance, parallel	60.5	Yes					n/a	$ -	
F08316	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	48	Yes					n/a	$ -	
F08317	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	60	Yes					n/a	$ -	
F08318	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Urinal		Clearance, perpendicular	90	Yes					n/a	$ -	
F08319	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Clearance, pull parallel	99	Yes					n/a	$ -	
F08320	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Interior access	Clearance, pull parallel	99	Yes					n/a	$ -	
F08321	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Clearance, push parallel	27	Yes					n/a	$ -	
F08322	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Interior access	Clearance, push parallel	99	Yes					n/a	$ -	
F08323	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Clearance, push perpendicular	99	Yes					n/a	$ -	
F08324	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Interior access	Clearance, push perpendicular	99	Yes					n/a	$ -	
F08325	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F08326	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Closing speed	5	Yes					n/a	$ -	
F08327	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F08328	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Dimension, characters	4.5	Yes					n/a	$ -	
F08329	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Dimension, characters	3.5	Yes					n/a	$ -	
F08330	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4	Yes					n/a	$ -	
F08331	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Counter		Dimension, knee clearance	24.5	Yes					n/a	$ -	
F08332	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F08333	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, wide side	63	Yes					n/a	$ -	
F08334	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F08335	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Interior access	Hardware type	PP	Yes					n/a	$ -	
F08336	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F08337	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Counter		Height	32	Yes					n/a	$ -	
F08338	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Height	42	Yes					n/a	$ -	
F08339	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	Soap	Height	46	Yes					n/a	$ -	
F08340	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Height	33	Yes					n/a	$ -	
F08341	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Height, bottom	57.5	Yes					n/a	$ -	
F08342	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Urinal		Height, flush control	42	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08343	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Height, seat	19	Yes					n/a	$ -	
F08344	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Threshold beveled?	Y	Yes					n/a	$ -	
F08345	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F08346	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F08347	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Height, top	35.5	Yes					n/a	$ -	
F08348	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Height, top	57	Yes					n/a	$ -	
F08349	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F08350	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Exterior access	Kick plate?	SD	Yes					n/a	$ -	
F08351	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate	Interior access	Kick plate?	SD	Yes					n/a	$ -	
F08352	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Counter		Length	69	Yes					n/a	$ -	
F08353	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F08354	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F08355	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F08356	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F08357	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F08358	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F08359	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F08360	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Fixture Count		Number, toilet compartments	2	Yes					n/a	$ -	
F08361	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Fixture Count		Number, urinals	2	Yes					n/a	$ -	
F08362	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F08363	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F08405	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage	Interior access	Braille?	Y	Yes					n/a	$ -	
F08406	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F08407	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Interior access	Clear opening	32	Yes					n/a	$ -	
F08408	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Exterior access	Clear opening	32	Yes					n/a	$ -	
F08409	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F08410	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F08411	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	84	Yes					n/a	$ -	
F08412	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	60	Yes					n/a	$ -	
F08413	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Interior access	Clearance, pull parallel	99	Yes					n/a	$ -	
F08414	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Exterior access	Clearance, pull parallel	99	Yes					n/a	$ -	
F08415	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Interior access	Clearance, pull perpendicular	48	Yes					n/a	$ -	
F08416	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Interior access	Clearance, push parallel	99	Yes					n/a	$ -	
F08417	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Exterior access	Clearance, push parallel	25	Yes					n/a	$ -	
F08418	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Interior access	Clearance, push perpendicular	99	Yes					n/a	$ -	
F08419	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Exterior access	Clearance, push perpendicular	99	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08420	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F08421	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F08422	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F08423	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F08424	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage	Interior access	Dimension, characters	3.5	Yes					n/a	$ -	
F08425	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Dimension, characters	4.5	Yes					n/a	$ -	
F08426	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F08427	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F08428	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, wide side	85	Yes					n/a	$ -	
F08429	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F08430	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Interior access	Hardware type	PP	Yes					n/a	$ -	
F08431	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F08432	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Hardware type	PP	Yes					n/a	$ -	
F08433	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Counter		Height	32	Yes					n/a	$ -	
F08434	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Height	44.5	Yes					n/a	$ -	
F08435	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Height	33	Yes					n/a	$ -	
F08436	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage	Interior access	Height, bottom	57	Yes					n/a	$ -	
F08437	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F08438	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Height, flush control	27	Yes					n/a	$ -	
F08439	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Height, seat	19	Yes					n/a	$ -	
F08440	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F08441	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F08442	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F08443	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F08444	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate	Exterior access	Kick plate?	SD	Yes					n/a	$ -	
F08445	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F08446	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F08447	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage	Interior access	Location	L	Yes					n/a	$ -	
F08448	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F08449	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F08450	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F08451	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, toilet compartments	4	Yes					n/a	$ -	
F08452	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, urinals	0	Yes					n/a	$ -	
F08453	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage	Interior access	Tactile letters?	Y	Yes					n/a	$ -	
F08454	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F08455	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Threshold beveled?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08456	Adams County Fair Grounds	Indoor Arena	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Alarm System		Visible alarm	N	Yes					n/a	$ -	
F08463	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F08464	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	88	Yes					n/a	$ -	
F08465	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, sidewall	16.5	Yes					n/a	$ -	
F08466	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F08467	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Height, seat	19	Yes					n/a	$ -	
F08468	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Height, top	34.5	Yes					n/a	$ -	
F08469	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F08484	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F08485	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F08486	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	97	Yes					n/a	$ -	
F08487	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, pull parallel	29	Yes					n/a	$ -	
F08488	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	66	Yes					n/a	$ -	
F08489	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, push parallel	26	Yes					n/a	$ -	
F08490	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F08491	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F08492	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Dimension, characters	5	Yes					n/a	$ -	
F08493	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	27	Yes					n/a	$ -	
F08494	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F08495	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F08496	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Height	47	Yes					n/a	$ -	
F08497	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Height	33.5	Yes					n/a	$ -	
F08498	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Height, bottom	55.5	Yes					n/a	$ -	
F08499	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Height, seat	19	Yes					n/a	$ -	
F08500	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F08501	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F08502	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F08503	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, toilet compartments	4	Yes					n/a	$ -	
F08504	Adams County Fair Grounds	Lesser Bldg	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F08510	Adams County Fair Grounds	Mann-Nyholt Lake Parking	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Clearance, parallel	62	Yes					n/a	$ -	
F08511	Adams County Fair Grounds	Mann-Nyholt Lake Parking	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Clearance, perpendicular	66	Yes					n/a	$ -	
F08512	Adams County Fair Grounds	Mann-Nyholt Lake Parking	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F08513	Adams County Fair Grounds	Mann-Nyholt Lake Parking	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, wide side	44.75	Yes					n/a	$ -	
F08514	Adams County Fair Grounds	Mann-Nyholt Lake Parking	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Height	22	Yes					n/a	$ -	
F08515	Adams County Fair Grounds	Mann-Nyholt Lake Parking	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F08517	Adams County Fair Grounds	Mann-Nyholt Lake Parking	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Other attribute	OK	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08518	Adams County Fair Grounds	Mann-Nyholt Lake Parking	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Other attribute	OK	Yes					n/a	$ -	
F08523	Adams County Fair Grounds	Mann-Nyholt Lake Parking	Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Height	22	Yes					n/a	$ -	
F08546	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F08547	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Clearance, parallel	99	Yes					n/a	$ -	
F08548	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Clearance, perpendicular	99	Yes					n/a	$ -	
F08549	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F08550	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, push parallel	2	Yes					n/a	$ -	
F08551	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F08552	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar		Diameter	1.5	Yes					n/a	$ -	
F08553	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F08554	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F08555	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Height	22	Yes					n/a	$ -	
F08556	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	Soap	Height	39	Yes					n/a	$ -	
F08557	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Height	32	Yes					n/a	$ -	
F08558	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Height, seat	18.5	Yes					n/a	$ -	
F08559	Adams County Fair Grounds	Old Red Cross Bldg	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F08566	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F08567	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Dimension, characters	4.5	Yes					n/a	$ -	
F08568	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar		Dimension, end to wall	6	Yes					n/a	$ -	
F08569	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F08570	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F08571	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, wide side	44.25	Yes					n/a	$ -	
F08572	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Height, bottom	58.5	Yes					n/a	$ -	
F08573	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Height, seat	18.5	Yes					n/a	$ -	
F08574	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar		Height, top	33.75	Yes					n/a	$ -	
F08575	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Height, top	34.5	Yes					n/a	$ -	
F08576	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F08577	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F08578	Adams County Fair Grounds	Picnic Site B	Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F08595	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Urinal		Depth	14	Yes					n/a	$ -	
F08602	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F08603	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F08604	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F08605	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Clearance, parallel	64.5	Yes					n/a	$ -	
F08606	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Urinal		Clearance, perpendicular	66	Yes					n/a	$ -	
F08607	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Clearance, perpendicular	58.75	Yes					n/a	$ -	
F08608	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, pull parallel	68	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08609	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, push parallel	19	Yes					n/a	$ -	
F08610	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F08611	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F08612	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F08613	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, vertical	92	Yes					n/a	$ -	
F08614	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Urinal		Control force	Auto	Yes					n/a	$ -	
F08615	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F08616	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F08617	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	9	Yes					n/a	$ -	
F08618	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Dimension, characters	4	Yes					n/a	$ -	
F08619	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F08620	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F08621	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Counter		Dimension, knee clearance	29	Yes					n/a	$ -	
F08622	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F08623	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, sidewall	17.75	Yes					n/a	$ -	
F08624	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, wide side	46.5	Yes					n/a	$ -	
F08625	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Door swing direction	Out	Yes					n/a	$ -	
F08626	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F08627	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F08628	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Hardware type	Auto	Yes					n/a	$ -	
F08629	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Hardware type	PP	Yes					n/a	$ -	
F08630	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Alarm System		Height	86	Yes					n/a	$ -	
F08631	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Counter		Height	33.25	Yes					n/a	$ -	
F08632	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Height	19	Yes					n/a	$ -	
F08633	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	Soap	Height	40.5	Yes					n/a	$ -	
F08634	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F08635	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Changing Station		Height	34	Yes					n/a	$ -	
F08636	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Changing Station		Height	48	Yes					n/a	$ -	
F08637	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Mirror		Height, bottom	39.25	Yes					n/a	$ -	
F08638	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Height, bottom	51.5	Yes					n/a	$ -	
F08639	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Urinal		Height, flush control	Auto	Yes					n/a	$ -	
F08640	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Urinal		Height, rim	16.75	Yes					n/a	$ -	
F08641	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F08642	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F08643	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Height, top	35.5	Yes					n/a	$ -	
F08644	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Height, top	35.5	Yes					n/a	$ -	
F08645	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08646	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Counter		Length	99	Yes					n/a	$ -	
F08647	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F08648	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F08649	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F08650	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Location, flush control	Auto	Yes					n/a	$ -	
F08651	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F08652	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Fixture Count		Number, toilet compartments	3	Yes					n/a	$ -	
F08653	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Fixture Count		Number, urinals	7	Yes					n/a	$ -	
F08654	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F08655	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F08683	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F08684	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F08685	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F08686	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F08687	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	99	Yes					n/a	$ -	
F08688	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Counter		Clearance, perpendicular	59	Yes					n/a	$ -	
F08689	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	59	Yes					n/a	$ -	
F08690	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	59.5	Yes					n/a	$ -	
F08691	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, pull parallel	44	Yes					n/a	$ -	
F08692	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F08693	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, push parallel	24	Yes					n/a	$ -	
F08694	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	59	Yes					n/a	$ -	
F08695	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F08696	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F08697	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, vertical	94	Yes					n/a	$ -	
F08698	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F08699	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F08700	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	9	Yes					n/a	$ -	
F08701	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Dimension, characters	4	Yes					n/a	$ -	
F08702	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F08703	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F08704	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Counter		Dimension, knee clearance	29.5	Yes					n/a	$ -	
F08705	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29.25	Yes					n/a	$ -	
F08706	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F08707	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, wide side	42	Yes					n/a	$ -	
F08708	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08709	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F08710	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F08711	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Hardware type	Auto	Yes					n/a	$ -	
F08712	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Hardware type	PP	Yes					n/a	$ -	
F08713	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Alarm System		Height	85.5	Yes					n/a	$ -	
F08714	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Coat Hook		Height	48	Yes					n/a	$ -	
F08715	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Counter		Height	33.5	Yes					n/a	$ -	
F08716	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Height	19	Yes					n/a	$ -	
F08717	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Soap	Height	40.5	Yes					n/a	$ -	
F08718	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F08719	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Changing Station		Height	34	Yes					n/a	$ -	
F08720	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Mirror		Height, bottom	39.5	Yes					n/a	$ -	
F08721	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Height, bottom	52	Yes					n/a	$ -	
F08722	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Height, seat	19	Yes					n/a	$ -	
F08723	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F08724	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Height, top	35.75	Yes					n/a	$ -	
F08725	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F08726	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Counter		Length	99	Yes					n/a	$ -	
F08727	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F08728	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F08729	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F08730	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Location, flush control	Auto	Yes					n/a	$ -	
F08731	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F08732	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, toilet compartments	9	Yes					n/a	$ -	
F08733	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, urinals	0	Yes					n/a	$ -	
F08734	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F08735	Adams County Fair Grounds	Waymire Dome	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F08736	Adams County Fair Grounds		Exterior	Owned	Restroom	Accessible Porta-Potty	1-Public Unsupervised	Door Gate		Threshold beveled?	Y	Yes					n/a	$ -	
F08739	Adams County Fair Grounds		Exterior	Owned	Restroom	Accessible Porta-Potty	1-Public Unsupervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F08740	Adams County Fair Grounds		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F08741	Adams County Fair Grounds		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, push parallel	17	Yes					n/a	$ -	
F08742	Adams County Fair Grounds		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F08771	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Shower Compartment		Control location	S	Yes					n/a	$ -	
F08772	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Shower Compartment		Dimension, side to side	80	Yes					n/a	$ -	
F08773	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F08774	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Dispenser	TP	Height	42	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08775	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Dispenser	Soap	Height	39.5	Yes					n/a	$ -	
F08776	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Mirror		Height, bottom	39.5	Yes					n/a	$ -	
F08777	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F08778	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Grab Bar	Side	Height, top	35.5	Yes					n/a	$ -	
F08779	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Grab Bar	Side	Length	36	Yes					n/a	$ -	
F08780	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F08781	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Fixture Count		Number, toilet compartments	3	Yes					n/a	$ -	
F08782	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Fixture Count		Number, urinals	2	Yes					n/a	$ -	
F08783	Adams County Fair Grounds		Interior	Owned	Restroom	Men's - Exhibit Hall rear	1-Public Unsupervised	Shower Compartment		Seat?	N	Yes					n/a	$ -	
F08786	Adams County Fair Grounds		Exterior	Owned	Restroom	Men's - Picnic Site B	1-Public Unsupervised	Dispenser	TP	Height	22	Yes					n/a	$ -	
F08812	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F08813	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F08814	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F08815	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, push parallel	38	Yes					n/a	$ -	
F08816	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F08817	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	66	Yes					n/a	$ -	
F08818	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, vertical	80.5	Yes					n/a	$ -	
F08819	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	9	Yes					n/a	$ -	
F08820	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	2	Yes					n/a	$ -	
F08821	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, sidewall	17	Yes					n/a	$ -	
F08822	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Door swing direction	Out	Yes					n/a	$ -	
F08823	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	In cabinet	Yes					n/a	$ -	
F08824	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F08825	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Hardware type	PP	Yes					n/a	$ -	
F08826	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Height	22	Yes					n/a	$ -	
F08827	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Soap	Height	39	Yes					n/a	$ -	
F08828	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Height	32	Yes					n/a	$ -	
F08829	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F08830	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, accessible compartments	0	Yes					n/a	$ -	
F08831	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F08832	Adams County Fair Grounds		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, toilet compartments	2	Yes					n/a	$ -	
F08858	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F08859	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Shower Compartment		Control location	F	Yes					n/a	$ -	
F08860	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4	Yes					n/a	$ -	
F08861	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Shower Compartment		Dimension, entry to back wall	36	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08862	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	In cabinet	Yes					n/a	$ -	
F08863	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F08864	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Toilet Compartment		Hardware type	PP	Yes					n/a	$ -	
F08865	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Dispenser	TP	Height	40	Yes					n/a	$ -	
F08866	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Dispenser	PT	Height	48	Yes					n/a	$ -	
F08867	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Dispenser	Soap	Height	40	Yes					n/a	$ -	
F08868	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Mirror		Height, bottom	40	Yes					n/a	$ -	
F08869	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F08870	Adams County Fair Grounds		Interior	Owned	Restroom	Women's - Exhibit Hall Rear	1-Public Unsupervised	Fixture Count		Number, toilet compartments	3	Yes					n/a	$ -	
F08881	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's - Picnic Site B	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F08882	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's - Picnic Site B	1-Public Unsupervised	Dispenser	TP	Clearance, parallel	62	Yes					n/a	$ -	
F08883	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's - Picnic Site B	1-Public Unsupervised	Dispenser	TP	Clearance, perpendicular	65	Yes					n/a	$ -	
F08884	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's - Picnic Site B	1-Public Unsupervised	Door Gate		Clearance, vertical	80	Yes					n/a	$ -	
F08885	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's - Picnic Site B	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F08886	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's - Picnic Site B	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F08887	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's - Picnic Site B	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F08888	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's - Picnic Site B	1-Public Unsupervised	Water Closet		Dimension, wide side	45	Yes					n/a	$ -	
F08889	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's - Picnic Site B	1-Public Unsupervised	Dispenser	TP	Height	OK	Yes					n/a	$ -	
F08890	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's - Picnic Site B	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F08891	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's - Picnic Site B	1-Public Unsupervised	Grab Bar	Rear	Height, top	33.5	Yes					n/a	$ -	
F08892	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's - Picnic Site B	1-Public Unsupervised	Grab Bar	Side	Height, top	33.5	Yes					n/a	$ -	
F08893	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's - Picnic Site B	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F08894	Adams County Fair Grounds		Exterior	Owned	Restroom	Women's - Picnic Site B	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F15616	Adams County Fair Grounds		Exterior	Owned	Sport Area	Open rodeo grandstand	1-Public Unsupervised	Wheelchair Space	Typical for all 20	Adjacent wheelchair space?	Y	Yes					n/a	$ -	
F15617	Adams County Fair Grounds		Exterior	Owned	Sport Area	Open rodeo grandstand	1-Public Unsupervised	Wheelchair Space	Typical for all 20	Companion seat?	Y	Yes					n/a	$ -	
F15618	Adams County Fair Grounds		Exterior	Owned	Sport Area	Open rodeo grandstand	1-Public Unsupervised	Wheelchair Space	Typical for all 20	Depth	48	Yes					n/a	$ -	
F15619	Adams County Fair Grounds		Exterior	Owned	Sport Area	Open rodeo grandstand	1-Public Unsupervised	Wheelchair Space	Typical for all 20	Line of sight?	OK	Yes					n/a	$ -	
F15620	Adams County Fair Grounds		Exterior	Owned	Sport Area	Open rodeo grandstand	1-Public Unsupervised	Seating Area	Grandstands	Number, wheelchair spaces	20	Yes					n/a	$ -	
F15621	Adams County Fair Grounds		Exterior	Owned	Sport Area	Open rodeo grandstand	1-Public Unsupervised	Wheelchair Space	Typical for all 20	On access route?	Y	Yes					n/a	$ -	
F15622	Adams County Fair Grounds		Exterior	Owned	Sport Area	Open rodeo grandstand	1-Public Unsupervised	Seating Area	Grandstands	Seating dispersed?	Y	Yes					n/a	$ -	
F15623	Adams County Fair Grounds		Exterior	Owned	Sport Area	Open rodeo grandstand	1-Public Unsupervised	Wheelchair Space	Typical for all 20	Slope, cross	0.0%	Yes					n/a	$ -	
F15624	Adams County Fair Grounds		Exterior	Owned	Sport Area	Open rodeo grandstand	1-Public Unsupervised	Wheelchair Space	Typical for all 20	Slope, parallel	OK	Yes					n/a	$ -	
F15625	Adams County Fair Grounds		Exterior	Owned	Sport Area	Open rodeo grandstand	1-Public Unsupervised	Wheelchair Space	Typical for all 20	Surface material	Metal	Yes					n/a	$ -	
F15626	Adams County Fair Grounds		Exterior	Owned	Sport Area	Open rodeo grandstand	1-Public Unsupervised	Wheelchair Space	Typical for all 20	Width	33	Yes					n/a	$ -	
F15761	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Walkway	From parking lot to Pier	1-Public Unsupervised	Walking Surface		Slope, cross	1.0%	Yes					n/a	$ -	
F15762	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Walkway	From parking lot to Pier	1-Public Unsupervised	Walking Surface		Slope, running	1.7%	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15763	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Walkway	From parking lot to Pier	1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F15764	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Walkway	From parking lot to Pier	1-Public Unsupervised	Walking Surface		Width	120	Yes					n/a	$ -	
F15765	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Walkway		1-Public Unsupervised	Walking Surface	To restrooms	Slope, cross	0.6%	Yes					n/a	$ -	
F15766	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Walkway		1-Public Unsupervised	Walking Surface	To restrooms	Slope, running	0.4%	Yes					n/a	$ -	
F15767	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Walkway		1-Public Unsupervised	Walking Surface	To restrooms	Surface material	Concrete	Yes					n/a	$ -	
F15768	Adams County Fair Grounds	Mann-Nyholt Lake	Exterior	Owned	Walkway		1-Public Unsupervised	Walking Surface	To restrooms	Width	84	Yes					n/a	$ -	
F15770	Adams County Fair Grounds	Waymire Dome	Exterior	Owned	Walkway	From North parking lot	1-Public Unsupervised	Curb Ramp		Accumulates water?	N	Yes					n/a	$ -	
F15771	Adams County Fair Grounds	Waymire Dome	Exterior	Owned	Walkway	From North parking lot	1-Public Unsupervised	Curb Ramp		Slope, counter	0.4%	Yes					n/a	$ -	
F15772	Adams County Fair Grounds	Waymire Dome	Exterior	Owned	Walkway	From North parking lot	1-Public Unsupervised	Curb Ramp		Slope, cross	0.1%	Yes					n/a	$ -	
F15773	Adams County Fair Grounds	Waymire Dome	Exterior	Owned	Walkway	From North parking lot	1-Public Unsupervised	Curb Ramp		Slope, left flare	0.9%	Yes					n/a	$ -	
F15774	Adams County Fair Grounds	Waymire Dome	Exterior	Owned	Walkway	From North parking lot	1-Public Unsupervised	Curb Ramp		Slope, right flare	1.2%	Yes					n/a	$ -	
F15775	Adams County Fair Grounds	Waymire Dome	Exterior	Owned	Walkway	From North parking lot	1-Public Unsupervised	Curb Ramp		Slope, running	3.6%	Yes					n/a	$ -	
F15776	Adams County Fair Grounds	Waymire Dome	Exterior	Owned	Walkway	From North parking lot	1-Public Unsupervised	Curb Ramp		Width	120	Yes					n/a	$ -	
F15777	Adams County Fair Grounds		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Threshold beveled?	Y	Yes					n/a	$ -	
F15779	Adams County Fair Grounds		Exterior	Owned	Walkway	From parking lot to play area	1-Public Unsupervised	Walking Surface		Slope, cross	0.9%	Yes					n/a	$ -	
F15780	Adams County Fair Grounds		Exterior	Owned	Walkway	From parking lot to play area	1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F15781	Adams County Fair Grounds		Exterior	Owned	Walkway	From parking lot to play area	1-Public Unsupervised	Walking Surface		Width	60	Yes					n/a	$ -	
F15787	Adams County Fair Grounds		Exterior	Owned	Walkway	South of Waymire Dome	1-Public Unsupervised	Landing	East ramp	Clearance, parallel	84	Yes					n/a	$ -	
F15788	Adams County Fair Grounds		Exterior	Owned	Walkway	South of Waymire Dome	1-Public Unsupervised	Landing	East ramp	Clearance, perpendicular	99	Yes					n/a	$ -	
F15789	Adams County Fair Grounds		Exterior	Owned	Walkway	South of Waymire Dome	1-Public Unsupervised	Ramp		Edge protection?	Y	Yes					n/a	$ -	
F15790	Adams County Fair Grounds		Exterior	Owned	Walkway	South of Waymire Dome	1-Public Unsupervised	Ramp	East ramp	Length	22 feet	Yes					n/a	$ -	
F15791	Adams County Fair Grounds		Exterior	Owned	Walkway	South of Waymire Dome	1-Public Unsupervised	Landing	East ramp	Slope, cross	0.9%	Yes					n/a	$ -	
F15792	Adams County Fair Grounds		Exterior	Owned	Walkway	South of Waymire Dome	1-Public Unsupervised	Ramp	East ramp	Slope, cross	0.0%	Yes					n/a	$ -	
F15793	Adams County Fair Grounds		Exterior	Owned	Walkway	South of Waymire Dome	1-Public Unsupervised	Ramp		Slope, cross	2.0%	Yes					n/a	$ -	
F15794	Adams County Fair Grounds		Exterior	Owned	Walkway	South of Waymire Dome	1-Public Unsupervised	Landing	East ramp	Slope, running	1.3%	Yes					n/a	$ -	
F15795	Adams County Fair Grounds		Exterior	Owned	Walkway	South of Waymire Dome	1-Public Unsupervised	Ramp		Slope, running	3.4%	Yes					n/a	$ -	
F15796	Adams County Fair Grounds		Exterior	Owned	Walkway	South of Waymire Dome	1-Public Unsupervised	Ramp	East ramp	Slope, running	5.9%	Yes					n/a	$ -	
F15797	Adams County Fair Grounds		Exterior	Owned	Walkway	South of Waymire Dome	1-Public Unsupervised	Ramp		Surface material	Concrete	Yes					n/a	$ -	
F15798	Adams County Fair Grounds		Exterior	Owned	Walkway	South of Waymire Dome	1-Public Unsupervised	Ramp	East ramp	Width	58	Yes					n/a	$ -	
F15799	Adams County Fair Grounds		Exterior	Owned	Walkway	South of Waymire Dome	1-Public Unsupervised	Ramp		Width	78	Yes					n/a	$ -	
F15801	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Handrail	Ramp to grandstand seats	Clearance to wall	OK	Yes					n/a	$ -	
F15802	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Landing	Between sections #1 & #2	Clearance, parallel	71	Yes					n/a	$ -	
F15803	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Landing	Between sections #1 & #2	Clearance, perpendicular	60	Yes					n/a	$ -	
F15804	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Handrail	Ramp to grandstand seats	Continuous?	Y	Yes					n/a	$ -	
F15805	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Handrail	Ramp to grandstand seats	Diameter	1.5	Yes					n/a	$ -	
F15806	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Landing	Between sections #1 & #2	Edge protection?	Y	Yes					n/a	$ -	
F15807	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Ramp	Section #1	Edge protection?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15808	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Ramp	Section #2	Edge protection?	Y	Yes					n/a	$ -	
F15809	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Handrail	Ramp to grandstand seats	Extension	12	Yes					n/a	$ -	
F15810	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Handrail	Ramp to grandstand seats	Height, top	36.5	Yes					n/a	$ -	
F15811	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Ramp	Section #1	Length	21 feet	Yes					n/a	$ -	
F15812	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Landing	Between sections #1 & #2	Slope, cross	0.6%	Yes					n/a	$ -	
F15813	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Ramp	Section #2	Slope, cross	0.0%	Yes					n/a	$ -	
F15814	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Ramp	Section #1	Slope, cross	0.8%	Yes					n/a	$ -	
F15815	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Walking Surface		Slope, cross	0.0%	Yes					n/a	$ -	
F15816	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Landing	Between sections #1 & #2	Slope, running	0.0%	Yes					n/a	$ -	
F15817	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Ramp	Section #1	Slope, running	1.9%	Yes					n/a	$ -	
F15818	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Ramp	Section #2	Slope, running	4.5%	Yes					n/a	$ -	
F15819	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Walking Surface		Slope, running	0.0%	Yes					n/a	$ -	
F15820	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Ramp	Section #1	Surface material	Metal	Yes					n/a	$ -	
F15821	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Ramp	Section #2	Surface material	Metal	Yes					n/a	$ -	
F15822	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Walking Surface		Surface material	Asphalt	Yes					n/a	$ -	
F15823	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Ramp	Section #1	Width	47.5	Yes					n/a	$ -	
F15824	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Ramp	Section #2	Width	47.5	Yes					n/a	$ -	
F15825	Adams County Fair Grounds		Exterior	Owned	Walkway	To Grandstand seating	1-Public Unsupervised	Walking Surface		Width	96	Yes					n/a	$ -	
F15826	Adams County Fair Grounds		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Other attribute	Auto	Yes					n/a	$ -	
F03539	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#1	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03540	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#2	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03541	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#2	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03542	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#3	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03543	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#4	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03544	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#5	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03545	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#6	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03546	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#7	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03547	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#8	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03548	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#9	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03549	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#10	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03550	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#11	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03551	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#12	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03552	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#13	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03553	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#14	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03554	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#15	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03555	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#16	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03556	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#17	Connected to golf car passage?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F03557	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#18	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03558	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Weather Shelter	Near Hole #13	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03559	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Weather Shelter	Near Hole #13	Dimension, back to front	63	Yes					n/a	$ -	
F03560	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Weather Shelter	Near Hole #13	Dimension, side to side	67.5	Yes					n/a	$ -	
F03561	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#1	Is forward tee ground connected to golf car passage?	Y	Yes					n/a	$ -	
F03562	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#1	Number, connected to golf car passage	3	Yes					n/a	$ -	
F03563	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#3	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03564	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#4	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03565	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#5	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03566	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#6	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03567	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#7	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03568	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#8	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03569	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#10	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03570	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#11	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03571	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#12	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03572	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#13	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03573	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#14	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03574	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#14	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03575	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#15	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03576	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#16	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03577	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#17	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03578	Adams County Golf Course	Dunes	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#18	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03585	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#2	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03586	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#11	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03587	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#12	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03588	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#13	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03589	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#14	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03590	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#15	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03591	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#16	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03592	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#17	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03593	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#18	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03594	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Weather Shelter	Near 4th fairway	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03595	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Weather Shelter	Near 4th fairway	Dimension, back to front	99	Yes					n/a	$ -	
F03596	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Weather Shelter	Near 4th fairway	Dimension, side to side	99	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F03597	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#1	Is forward tee ground connected to golf car passage?	Y	Yes					n/a	$ -	
F03598	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#2	Is forward tee ground connected to golf car passage?	Y	Yes					n/a	$ -	
F03599	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#3	Is forward tee ground connected to golf car passage?	Y	Yes					n/a	$ -	
F03600	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Golf car Passage	#1	Length, fairway barrier	OK	Yes					n/a	$ -	
F03601	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Golf car Passage		Length, fairway barrier	OK	Yes					n/a	$ -	
F03602	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#1	Number, connected to golf car passage	3	Yes					n/a	$ -	
F03603	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#2	Number, connected to golf car passage	3	Yes					n/a	$ -	
F03604	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#3	Number, connected to golf car passage	3	Yes					n/a	$ -	
F03605	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#4	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03606	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#11	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03607	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#12	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03608	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#13	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03609	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#14	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03610	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#15	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03611	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#16	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03612	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#17	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03613	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#18	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03614	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Golf car Passage	#3	Other attribute	TYP	Yes					n/a	$ -	
F03615	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Golf car Passage		Other attribute	TYP	Yes					n/a	$ -	
F03616	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Golf car Passage	#1	Width	OK	Yes					n/a	$ -	
F03617	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Golf car Passage		Width	OK	Yes					n/a	$ -	
F03618	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Golf car Passage	#1	Width, opening	OK	Yes					n/a	$ -	
F03619	Adams County Golf Course	Knolls	Exterior	Owned	Golf Facility		1-Public Unsupervised	Golf car Passage		Width, opening	OK	Yes					n/a	$ -	
F03620	Adams County Golf Course		Exterior	Owned	Golf Facility	Open field driving range	2-Public Supervised	Teeing Stations		Number, connected to golf car passage	1	Yes					n/a	$ -	
F03621	Adams County Golf Course		Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green		Connected to golf car passage?	Y	Yes					n/a	$ -	
F03622	Adams County Golf Course		Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green		Connected to golf car passage?	Y	Yes					n/a	$ -	
F03623	Adams County Golf Course		Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green		Connected to golf car passage?	Y	Yes					n/a	$ -	
F03624	Adams County Golf Course		Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green		Connected to golf car passage?	Y	Yes					n/a	$ -	
F03625	Adams County Golf Course		Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#8	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03626	Adams County Golf Course		Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#9	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03627	Adams County Golf Course		Exterior	Owned	Golf Facility		1-Public Unsupervised	Putting Green	#10	Connected to golf car passage?	Y	Yes					n/a	$ -	
F03628	Adams County Golf Course		Exterior	Owned	Golf Facility		1-Public Unsupervised	Weather Shelter	Near Hole #8	Connected to golf car passage?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F03629	Adams County Golf Course		Exterior	Owned	Golf Facility		1-Public Unsupervised	Weather Shelter	Near Hole #8	Dimension, back to front	80	Yes					n/a	$ -	
F03630	Adams County Golf Course		Exterior	Owned	Golf Facility		1-Public Unsupervised	Weather Shelter	Near Hole #8	Dimension, side to side	67	Yes					n/a	$ -	
F03631	Adams County Golf Course		Exterior	Owned	Golf Facility		2-Public Supervised	Practice Green	Putting greens	Number, connected to golf car passage	2	Yes					n/a	$ -	
F03632	Adams County Golf Course		Exterior	Owned	Golf Facility		2-Public Supervised	Practice Green	Chipping greens	Number, connected to golf car passage	2	Yes					n/a	$ -	
F03633	Adams County Golf Course		Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground		Number, teeing grounds	TYP	Yes					n/a	$ -	
F03634	Adams County Golf Course		Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground		Number, teeing grounds	TYP	Yes					n/a	$ -	
F03635	Adams County Golf Course		Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#8	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03636	Adams County Golf Course		Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#9	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03637	Adams County Golf Course		Exterior	Owned	Golf Facility		1-Public Unsupervised	Teeing Ground	#10	Number, teeing grounds	TYP	Yes					n/a	$ -	
F03700	Adams County Golf Course		Interior	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Between men's & women's restrooms	Height	34.5	Yes					n/a	$ -	
F03701	Adams County Golf Course		Interior	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Between men's & women's restrooms	Height, water flow	38	Yes					n/a	$ -	
F03702	Adams County Golf Course		Interior	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Between men's & women's restrooms	Spout location	3	Yes					n/a	$ -	
F04294	Adams County Golf Course		Interior	Owned	Lobby Reception		1-Public Unsupervised	Vending Machine	ATM	Height, control	48	Yes					n/a	$ -	
F04295	Adams County Golf Course		Interior	Owned	Lobby Reception		1-Public Unsupervised	Vending Machine	ATM	Height, control	Y	Yes					n/a	$ -	
F04886	Adams County Golf Course		Interior	Owned	Other Room	Pro shop	1-Public Unsupervised	Door Gate		Clear opening	71.5	Yes					n/a	$ -	
F04887	Adams County Golf Course		Interior	Owned	Other Room	Pro shop	1-Public Unsupervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F04888	Adams County Golf Course		Interior	Owned	Other Room	Pro shop	1-Public Unsupervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F04889	Adams County Golf Course		Interior	Owned	Other Room	Pro shop	1-Public Unsupervised	Door Gate		Clearance, vertical	94	Yes					n/a	$ -	
F04890	Adams County Golf Course		Interior	Owned	Other Room	Pro shop	1-Public Unsupervised	Counter		Dimension, knee clearance	0	Yes					n/a	$ -	
F04891	Adams County Golf Course		Interior	Owned	Other Room	Pro shop	1-Public Unsupervised	Counter		Length	36	Yes					n/a	$ -	
F04892	Adams County Golf Course		Interior	Owned	Other Room	Pro shop	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F04896	Adams County Golf Course		Interior	Owned	Other Room	Pub/dining room	1-Public Unsupervised	Door Gate		Clear opening	71.5	Yes					n/a	$ -	
F04897	Adams County Golf Course		Interior	Owned	Other Room	Pub/dining room	1-Public Unsupervised	Door Gate		Clearance, vertical	94	Yes					n/a	$ -	
F04908	Adams County Golf Course		Interior	Owned	Other Room	Public use computer room	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F04909	Adams County Golf Course		Interior	Owned	Other Room	Public use computer room	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F04910	Adams County Golf Course		Interior	Owned	Other Room	Public use computer room	1-Public Unsupervised	Door Gate		Clearance, push parallel	15	Yes					n/a	$ -	
F04911	Adams County Golf Course		Interior	Owned	Other Room	Public use computer room	1-Public Unsupervised	Door Gate		Clearance, vertical	82	Yes					n/a	$ -	
F04912	Adams County Golf Course		Interior	Owned	Other Room	Public use computer room	1-Public Unsupervised	Signage		Dimension, characters	1	Yes					n/a	$ -	
F04913	Adams County Golf Course		Interior	Owned	Other Room	Public use computer room	1-Public Unsupervised	Counter		Dimension, knee clearance	30.25	Yes					n/a	$ -	
F04914	Adams County Golf Course		Interior	Owned	Other Room	Public use computer room	1-Public Unsupervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F04915	Adams County Golf Course		Interior	Owned	Other Room	Public use computer room	1-Public Unsupervised	Counter		Height	33.75	Yes					n/a	$ -	
F04916	Adams County Golf Course		Interior	Owned	Other Room	Public use computer room	1-Public Unsupervised	Signage		ISA?	N	Yes					n/a	$ -	
F04917	Adams County Golf Course		Interior	Owned	Other Room	Public use computer room	1-Public Unsupervised	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F04918	Adams County Golf Course		Interior	Owned	Other Room	Public use computer room	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F04919	Adams County Golf Course		Interior	Owned	Other Room	Public use computer room	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F05618	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Access aisle?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05619	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Access aisle?	Y	Yes					n/a	$ -	
F05620	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Access aisle?	Y	Yes					n/a	$ -	
F05621	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Access aisle?	Y	Yes					n/a	$ -	
F05622	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Access aisle?	Y	Yes					n/a	$ -	
F05623	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#6	Access aisle?	Y	Yes					n/a	$ -	
F05624	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#7	Access aisle?	Y	Yes					n/a	$ -	
F05625	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Adjacent pathway?	Y	Yes					n/a	$ -	
F05626	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Adjacent pathway?	Y	Yes					n/a	$ -	
F05627	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #6 & #7	Adjacent pathway?	Y	Yes					n/a	$ -	
F05628	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Adjacent pathway?	Y	Yes					n/a	$ -	
F05629	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Height, sign	77	Yes					n/a	$ -	
F05630	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Height, sign	72	Yes					n/a	$ -	
F05631	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Height, sign	72	Yes					n/a	$ -	
F05632	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Height, sign	72	Yes					n/a	$ -	
F05633	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Height, sign	72	Yes					n/a	$ -	
F05634	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#6	Height, sign	72	Yes					n/a	$ -	
F05635	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#7	Height, sign	72	Yes					n/a	$ -	
F05636	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Length	OK	Yes					n/a	$ -	
F05637	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, accessible	7	Yes					n/a	$ -	
F05638	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Pathway behind cars?	N	Yes					n/a	$ -	
F05639	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Pathway behind cars?	N	Yes					n/a	$ -	
F05640	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Pathway behind cars?	N	Yes					n/a	$ -	
F05641	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #6 & #7	Pathway behind cars?	N	Yes					n/a	$ -	
F05642	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Sign?	Y	Yes					n/a	$ -	
F05643	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Sign?	Y	Yes					n/a	$ -	
F05644	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Sign?	Y	Yes					n/a	$ -	
F05645	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Sign?	Y	Yes					n/a	$ -	
F05646	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Sign?	Y	Yes					n/a	$ -	
F05647	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#6	Sign?	Y	Yes					n/a	$ -	
F05648	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#7	Sign?	Y	Yes					n/a	$ -	
F05649	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Slope, cross	0.0%	Yes					n/a	$ -	
F05650	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Slope, cross	1.0%	Yes					n/a	$ -	
F05651	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #6 & #7	Slope, cross	1.0%	Yes					n/a	$ -	
F05652	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Slope, cross	1.1%	Yes					n/a	$ -	
F05653	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Slope, cross	0.5%	Yes					n/a	$ -	
F05654	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Slope, cross	0.6%	Yes					n/a	$ -	
F05655	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Slope, cross	0.7%	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05656	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Slope, cross	0.7%	Yes					n/a	$ -	
F05657	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#7	Slope, cross	1.0%	Yes					n/a	$ -	
F05658	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Slope, cross	1.1%	Yes					n/a	$ -	
F05659	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #6 & #7	Slope, running	0.8%	Yes					n/a	$ -	
F05660	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Slope, running	1.2%	Yes					n/a	$ -	
F05661	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Slope, running	1.7%	Yes					n/a	$ -	
F05662	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Slope, running	0.3%	Yes					n/a	$ -	
F05663	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#6	Slope, running	0.4%	Yes					n/a	$ -	
F05664	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#7	Slope, running	0.7%	Yes					n/a	$ -	
F05665	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Slope, running	0.9%	Yes					n/a	$ -	
F05666	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Slope, running	1.2%	Yes					n/a	$ -	
F05667	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Slope, running	1.2%	Yes					n/a	$ -	
F05668	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Slope, running	1.4%	Yes					n/a	$ -	
F05669	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Surface marking?	Y	Yes					n/a	$ -	
F05670	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Surface marking?	Y	Yes					n/a	$ -	
F05671	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Surface marking?	Y	Yes					n/a	$ -	
F05672	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #6 & #7	Surface marking?	Y	Yes					n/a	$ -	
F05673	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Surface material	Asphalt	Yes					n/a	$ -	
F05674	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Surface material	Asphalt	Yes					n/a	$ -	
F05675	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Van sign?	N	Yes					n/a	$ -	
F05676	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Van sign?	N	Yes					n/a	$ -	
F05677	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Van sign?	N	Yes					n/a	$ -	
F05678	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Van sign?	N	Yes					n/a	$ -	
F05679	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#6	Van sign?	N	Yes					n/a	$ -	
F05680	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#7	Van sign?	N	Yes					n/a	$ -	
F05682	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Width	145	Yes					n/a	$ -	
F05683	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Width	152	Yes					n/a	$ -	
F05684	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Width	137	Yes					n/a	$ -	
F05685	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Width	135	Yes					n/a	$ -	
F05686	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#6	Width	112	Yes					n/a	$ -	
F05687	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#7	Width	111	Yes					n/a	$ -	
F05688	Adams County Golf Course		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Width	132	Yes					n/a	$ -	
F08910	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F08911	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Water Closet		Clearance, parallel	65	Yes					n/a	$ -	
F08912	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Water Closet		Clearance, perpendicular	89	Yes					n/a	$ -	
F08913	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F08914	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08915	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	OK	Yes					n/a	$ -	
F08916	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F08917	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F08918	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Door Gate		Clearance, vertical	82.25	Yes					n/a	$ -	
F08919	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F08920	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F08921	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F08922	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Water Closet		Dimension, wide side	47	Yes					n/a	$ -	
F08923	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F08924	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Dispenser	Hand sanitizer	Height	47.75	Yes					n/a	$ -	
F08925	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F08926	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Grab Bar	Rear	Height, top	34.25	Yes					n/a	$ -	
F08927	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Grab Bar	Side	Height, top	35.75	Yes					n/a	$ -	
F08928	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F08929	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Grab Bar	Rear	Length	42	Yes					n/a	$ -	
F08930	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex - Near #4 teeing grounds	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F08952	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F08953	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Water Closet		Clearance, parallel	99	Yes					n/a	$ -	
F08954	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Water Closet		Clearance, perpendicular	81.5	Yes					n/a	$ -	
F08955	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F08956	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F08957	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Clearance, push parallel	OK	Yes					n/a	$ -	
F08958	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	OK	Yes					n/a	$ -	
F08959	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F08960	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F08961	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Clearance, vertical	81.5	Yes					n/a	$ -	
F08962	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F08963	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F08964	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	28.5	Yes					n/a	$ -	
F08965	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Dispenser	PT	Height	48	Yes					n/a	$ -	
F08966	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Dispenser	Soap	Height	44.75	Yes					n/a	$ -	
F08967	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F08969	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Grab Bar	Rear	Height, top	34.25	Yes					n/a	$ -	
F08970	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Grab Bar	Side	Height, top	34.75	Yes					n/a	$ -	
F08971	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F08972	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F08973	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #1 - Near hole 9 shelter	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F08992	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F08993	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Water Closet		Clearance, parallel	99	Yes					n/a	$ -	
F08994	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Water Closet		Clearance, perpendicular	83.5	Yes					n/a	$ -	
F08995	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F08996	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F08997	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Clearance, push parallel	OK	Yes					n/a	$ -	
F08998	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	OK	Yes					n/a	$ -	
F08999	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F09000	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F09001	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Clearance, vertical	81.75	Yes					n/a	$ -	
F09002	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F09003	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F09004	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	28	Yes					n/a	$ -	
F09005	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Water Closet		Dimension, sidewall	16.75	Yes					n/a	$ -	
F09006	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F09007	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Dispenser	PT	Height	46.5	Yes					n/a	$ -	
F09008	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Water Closet		Height, seat	18.5	Yes					n/a	$ -	
F09009	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Grab Bar	Side	Height, top	34.5	Yes					n/a	$ -	
F09010	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Grab Bar	Rear	Height, top	34.75	Yes					n/a	$ -	
F09011	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F09012	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F09013	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F09014	Adams County Golf Course	Dunes	Exterior	Owned	Restroom	Unisex #2 - Near hole 9 shelter	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F09021	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex - Near #10 teeing grounds	1-Public Unsupervised	Water Closet		Clearance, parallel	64	Yes					n/a	$ -	
F09022	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex - Near #10 teeing grounds	1-Public Unsupervised	Water Closet		Clearance, perpendicular	88	Yes					n/a	$ -	
F09023	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex - Near #10 teeing grounds	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F09024	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex - Near #10 teeing grounds	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F09025	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex - Near #10 teeing grounds	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F09026	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex - Near #10 teeing grounds	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F09027	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex - Near #10 teeing grounds	1-Public Unsupervised	Water Closet		Dimension, sidewall	17.5	Yes					n/a	$ -	
F09028	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex - Near #10 teeing grounds	1-Public Unsupervised	Water Closet		Dimension, wide side	46.5	Yes					n/a	$ -	
F09029	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex - Near #10 teeing grounds	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F09030	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex - Near #10 teeing grounds	1-Public Unsupervised	Grab Bar	Rear	Height, top	35.5	Yes					n/a	$ -	
F09031	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex - Near #10 teeing grounds	1-Public Unsupervised	Grab Bar	Side	Height, top	36	Yes					n/a	$ -	
F09032	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex - Near #10 teeing grounds	1-Public Unsupervised	Grab Bar	Rear	Length	42	Yes					n/a	$ -	
F09033	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex - Near #10 teeing grounds	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F09055	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09056	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F09057	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Water Closet		Clearance, parallel	99	Yes					n/a	$ -	
F09058	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Water Closet		Clearance, perpendicular	84	Yes					n/a	$ -	
F09059	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F09060	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F09061	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Clearance, push parallel	OK	Yes					n/a	$ -	
F09062	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	OK	Yes					n/a	$ -	
F09063	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F09064	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F09065	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Clearance, vertical	82.25	Yes					n/a	$ -	
F09066	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F09067	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F09068	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Signage		Dimension, characters	.75	Yes					n/a	$ -	
F09069	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	27	Yes					n/a	$ -	
F09070	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F09071	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Dispenser	Soap	Height	46	Yes					n/a	$ -	
F09072	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Lavatory Sink		Height	33.75	Yes					n/a	$ -	
F09073	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F09074	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Grab Bar	Rear	Height, top	34.5	Yes					n/a	$ -	
F09075	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Grab Bar	Side	Height, top	34.5	Yes					n/a	$ -	
F09076	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F09077	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F09078	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F09079	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F09080	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #1 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Opening force	8	Yes					n/a	$ -	
F09099	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F09100	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	OK	Yes					n/a	$ -	
F09101	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Water Closet		Clearance, parallel	99	Yes					n/a	$ -	
F09102	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	OK	Yes					n/a	$ -	
F09103	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Water Closet		Clearance, perpendicular	83	Yes					n/a	$ -	
F09104	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F09105	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F09106	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Clearance, push parallel	OK	Yes					n/a	$ -	
F09107	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F09108	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F09109	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Clearance, vertical	82	Yes					n/a	$ -	
F09110	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09111	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F09112	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F09113	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	28	Yes					n/a	$ -	
F09114	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F09115	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F09116	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Dispenser	Soap	Height	46	Yes					n/a	$ -	
F09117	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F09118	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F09119	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Grab Bar	Side	Height, top	34.75	Yes					n/a	$ -	
F09120	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Grab Bar	Rear	Height, top	34.75	Yes					n/a	$ -	
F09121	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F09122	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F09123	Adams County Golf Course	Knolls	Exterior	Owned	Restroom	Unisex #2 - Near hole 4 shelter	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F09160	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F09161	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F09162	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Toilet Compartment		Clear opening	32	Yes					n/a	$ -	
F09163	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Toilet Compartment		Clearance, outside	50.5	Yes					n/a	$ -	
F09164	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	49	Yes					n/a	$ -	
F09165	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	70	Yes					n/a	$ -	
F09166	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Urinal		Clearance, perpendicular	99	Yes					n/a	$ -	
F09167	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F09168	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F09169	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Grab Bar	Front wall	Clearance, to wall	1.5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09170	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F09171	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Door Gate		Clearance, vertical	81.5	Yes					n/a	$ -	
F09172	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F09173	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Urinal		Control force	Auto	Yes					n/a	$ -	
F09174	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Shower Compartment		Control location	F	Yes					n/a	$ -	
F09175	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F09176	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F09177	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Grab Bar	Front wall	Diameter	1.5	Yes					n/a	$ -	
F09178	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F09179	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Signage		Dimension, characters	1	Yes					n/a	$ -	
F09180	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4	Yes					n/a	$ -	
F09181	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F09182	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F09183	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Shower Compartment		Dimension, entry to back wall	36	Yes					n/a	$ -	
F09184	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Counter		Dimension, knee clearance	28.5	Yes					n/a	$ -	
F09185	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Counter		Dimension, knee clearance	28.5	Yes					n/a	$ -	
F09186	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	28.5	Yes					n/a	$ -	
F09187	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Shower Compartment		Dimension, side to side	36	Yes					n/a	$ -	
F09188	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Water Closet		Dimension, wide side	41.5	Yes					n/a	$ -	
F09189	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Toilet Compartment		Door swing direction	Out	Yes					n/a	$ -	
F09190	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Shower Compartment		Hand spray unit?	Y	Yes					n/a	$ -	
F09191	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F09192	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F09193	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Toilet Compartment		Hardware type	PP	Yes					n/a	$ -	
F09194	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Alarm System		Height	81.25	Yes					n/a	$ -	
F09195	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Counter		Height	33.5	Yes					n/a	$ -	
F09196	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Counter		Height	33.5	Yes					n/a	$ -	
F09197	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Dispenser	Soap	Height	42	Yes					n/a	$ -	
F09198	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F09199	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Signage		Height, bottom	57	Yes					n/a	$ -	
F09200	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Urinal		Height, flush control	Auto	Yes					n/a	$ -	
F09201	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Urinal		Height, rim	15.75	Yes					n/a	$ -	
F09202	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Water Closet		Height, seat	18.5	Yes					n/a	$ -	
F09203	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Shower Compartment		Height, shower control	45	Yes					n/a	$ -	
F09204	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F09205	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F09206	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Grab Bar	Front wall	Height, top	35.5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09207	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Grab Bar	Side	Height, top	35.5	Yes					n/a	$ -	
F09208	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F09209	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Door Gate		Kick plate?	Y	Yes					n/a	$ -	
F09210	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F09211	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F09212	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Shower Compartment		Length, hose	72	Yes					n/a	$ -	
F09213	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F09214	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F09215	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Fixture Count		Number, toilet compartments	3	Yes					n/a	$ -	
F09216	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Fixture Count		Number, urinals	5	Yes					n/a	$ -	
F09217	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Shower Compartment		Seat location	Rear	Yes					n/a	$ -	
F09218	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Shower Compartment		Seat type	F	Yes					n/a	$ -	
F09219	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F09220	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F09225	Adams County Golf Course		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F09226	Adams County Golf Course		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F09227	Adams County Golf Course		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F09228	Adams County Golf Course		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Clearance, push parallel	OK	Yes					n/a	$ -	
F09229	Adams County Golf Course		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	OK	Yes					n/a	$ -	
F09230	Adams County Golf Course		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Clearance, vertical	81.5	Yes					n/a	$ -	
F09231	Adams County Golf Course		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F09263	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F09264	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F09265	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Toilet Compartment		Clear opening	32	Yes					n/a	$ -	
F09266	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Water Closet		Clearance, parallel	60	Yes					n/a	$ -	
F09267	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Water Closet		Clearance, perpendicular	64	Yes					n/a	$ -	
F09268	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Door Gate		Clearance, pull parallel	24	Yes					n/a	$ -	
F09269	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F09270	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Door Gate		Clearance, push parallel	24	Yes					n/a	$ -	
F09271	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F09272	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F09273	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F09274	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Grab Bar	Front wall	Clearance, to wall	1.5	Yes					n/a	$ -	
F09275	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F09276	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Door Gate		Clearance, vertical	82	Yes					n/a	$ -	
F09277	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Shower Compartment		Control location	F	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09278	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F09279	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F09280	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Grab Bar	Front wall	Diameter	1.5	Yes					n/a	$ -	
F09281	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F09282	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Signage		Dimension, characters	1	Yes					n/a	$ -	
F09283	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F09284	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F09285	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Shower Compartment		Dimension, entry to back wall	36	Yes					n/a	$ -	
F09286	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Counter		Dimension, knee clearance	28.5	Yes					n/a	$ -	
F09287	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	28.25	Yes					n/a	$ -	
F09288	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F09289	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Water Closet		Dimension, wide side	42	Yes					n/a	$ -	
F09290	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Toilet Compartment		Door swing direction	Out	Yes					n/a	$ -	
F09291	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F09292	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Shower Compartment		Hand spray unit?	Y	Yes					n/a	$ -	
F09293	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F09294	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F09295	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Alarm System		Height	81	Yes					n/a	$ -	
F09296	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Counter		Height	33.25	Yes					n/a	$ -	
F09297	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Dispenser	Soap	Height	43	Yes					n/a	$ -	
F09298	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Lavatory Sink		Height	33.5	Yes					n/a	$ -	
F09299	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Signage		Height, bottom	56.5	Yes					n/a	$ -	
F09300	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Water Closet		Height, seat	18.5	Yes					n/a	$ -	
F09301	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Shower Compartment		Height, shower control	45	Yes					n/a	$ -	
F09302	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F09303	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Grab Bar	Front wall	Height, top	35.5	Yes					n/a	$ -	
F09304	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Grab Bar	Side	Height, top	35.5	Yes					n/a	$ -	
F09305	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F09306	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F09307	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F09308	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F09309	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Shower Compartment		Length, hose	72	Yes					n/a	$ -	
F09310	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F09311	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Water Closet		Location, flush control	Window	Yes					n/a	$ -	
F09312	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F09313	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Fixture Count		Number, toilet compartments	5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09314	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Shower Compartment		Seat location	Rear	Yes					n/a	$ -	
F09315	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Shower Compartment		Seat type	Y	Yes					n/a	$ -	
F09316	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F09317	Adams County Golf Course		Interior	Owned	Restroom	Men's - Clubhouse	1-Public Unsupervised	Shower Compartment		Threshold beveled?	Y	Yes					n/a	$ -	
F09318	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F09319	Adams County Golf Course		Interior	Owned	Restroom	Women's - Clubhouse	1-Public Unsupervised	Shower Compartment		Threshold beveled?	Y	Yes					n/a	$ -	
F15525	Adams County Golf Course	Dunes	Exterior	Owned	Shelter	Near #9 teeing grounds	1-Public Unsupervised	Drinking Fountain	Concession side of shelter	Clearance, parallel	OK	Yes					n/a	$ -	
F15526	Adams County Golf Course	Dunes	Exterior	Owned	Shelter	Near #9 teeing grounds	1-Public Unsupervised	Drinking Fountain	Concession side of shelter	Clearance, perpendicular	OK	Yes					n/a	$ -	
F15527	Adams County Golf Course	Dunes	Exterior	Owned	Shelter	Near #9 teeing grounds	1-Public Unsupervised	Drinking Fountain	Concession side of shelter	Height, water flow	46	Yes					n/a	$ -	
F15528	Adams County Golf Course	Dunes	Exterior	Owned	Shelter	Near #9 teeing grounds	1-Public Unsupervised	Drinking Fountain	Concession side of shelter	Spout location	3	Yes					n/a	$ -	
F15531	Adams County Golf Course		Interior	Owned	Shower Room	Men's - Clubhouse	1-Public Unsupervised	Grab Bar	Front wall	Dimension, end to wall	6	Yes					n/a	$ -	
F15532	Adams County Golf Course		Interior	Owned	Shower Room	Men's - Clubhouse	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	2.5	Yes					n/a	$ -	
F15533	Adams County Golf Course		Interior	Owned	Shower Room	Men's - Clubhouse	1-Public Unsupervised	Grab Bar	Front wall	Length	26	Yes					n/a	$ -	
F15534	Adams County Golf Course		Interior	Owned	Shower Room	Men's - Clubhouse	1-Public Unsupervised	Grab Bar	Side	Length	15.5	Yes					n/a	$ -	
F15535	Adams County Golf Course		Interior	Owned	Shower Room	Women's - Clubhouse	1-Public Unsupervised	Grab Bar	Front wall	Dimension, end to wall	6	Yes					n/a	$ -	
F15536	Adams County Golf Course		Interior	Owned	Shower Room	Women's - Clubhouse	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	2.5	Yes					n/a	$ -	
F15537	Adams County Golf Course		Interior	Owned	Shower Room	Women's - Clubhouse	1-Public Unsupervised	Grab Bar	Front wall	Length	26	Yes					n/a	$ -	
F15538	Adams County Golf Course		Interior	Owned	Shower Room	Women's - Clubhouse	1-Public Unsupervised	Grab Bar	Side	Length	16	Yes					n/a	$ -	
F15827	Adams County Golf Course		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate	Main Entrance	Threshold beveled?	Y	Yes					n/a	$ -	
F15833	Adams County Golf Course		Exterior	Owned	Walkway	From parking lot to Pro Shop	1-Public Unsupervised	Handrail		Continuous?	Y	Yes					n/a	$ -	
F15834	Adams County Golf Course		Exterior	Owned	Walkway	From parking lot to Pro Shop	1-Public Unsupervised	Handrail		Diameter	1.5	Yes					n/a	$ -	
F15835	Adams County Golf Course		Exterior	Owned	Walkway	From parking lot to Pro Shop	1-Public Unsupervised	Handrail		Extension	Y	Yes					n/a	$ -	
F15836	Adams County Golf Course		Exterior	Owned	Walkway	From parking lot to Pro Shop	1-Public Unsupervised	Handrail		Height, top	36.75	Yes					n/a	$ -	
F15837	Adams County Golf Course		Exterior	Owned	Walkway	From parking lot to Pro Shop	1-Public Unsupervised	Ramp		Slope, cross	0.6%	Yes					n/a	$ -	
F15838	Adams County Golf Course		Exterior	Owned	Walkway	From parking lot to Pro Shop	1-Public Unsupervised	Walking Surface		Slope, running	2.9%	Yes					n/a	$ -	
F15839	Adams County Golf Course		Exterior	Owned	Walkway	From parking lot to Pro Shop	1-Public Unsupervised	Ramp		Surface material	Concrete	Yes					n/a	$ -	
F15840	Adams County Golf Course		Exterior	Owned	Walkway	From parking lot to Pro Shop	1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F15841	Adams County Golf Course		Exterior	Owned	Walkway	From parking lot to Pro Shop	1-Public Unsupervised	Ramp		Width	53	Yes					n/a	$ -	
F15842	Adams County Golf Course		Exterior	Owned	Walkway	From parking lot to Pro Shop	1-Public Unsupervised	Walking Surface		Width	60	Yes					n/a	$ -	
F15844	Adams County Golf Course		Exterior	Owned	Walkway	From Pro Shop to golf cart area	1-Public Unsupervised	Walking Surface		Slope, running	3.5%	Yes					n/a	$ -	
F15845	Adams County Golf Course		Exterior	Owned	Walkway	From Pro Shop to golf cart area	1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F15846	Adams County Golf Course		Exterior	Owned	Walkway	From Pro Shop to golf cart area	1-Public Unsupervised	Walking Surface		Width	99	Yes					n/a	$ -	
F15853	Adams County Golf Course		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate	Main Entrance	Clear opening	32.75	Yes					n/a	$ -	
F15854	Adams County Golf Course		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate	Main Entrance	Clearance, pull parallel	99	Yes					n/a	$ -	
F15855	Adams County Golf Course		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate	Main Entrance	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F15856	Adams County Golf Course		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate	Main Entrance	Clearance, push parallel	99	Yes					n/a	$ -	
F15857	Adams County Golf Course		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate	Main Entrance	Clearance, push perpendicular	99	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15858	Adams County Golf Course		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate	Main Entrance	Clearance, vertical	99	Yes					n/a	$ -	
F15859	Adams County Golf Course		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate	Main Entrance	Closing speed	15	Yes					n/a	$ -	
F15860	Adams County Golf Course		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate	Main Entrance	Hardware type	PP	Yes					n/a	$ -	
F15861	Adams County Golf Course		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate	Main Entrance	Height, smooth surface (kick plate)	15	Yes					n/a	$ -	
F15862	Adams County Golf Course		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate	Main Entrance	Opening force	Auto	Yes					n/a	$ -	
F00308	Adams County Service Center	Sheriff's Substation	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Clearance, parallel	OK	Yes					n/a	$ -	
F00309	Adams County Service Center	Sheriff's Substation	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Clearance, parallel	OK	Yes					n/a	$ -	
F00310	Adams County Service Center	Sheriff's Substation	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Clearance, perpendicular	OK	Yes					n/a	$ -	
F00311	Adams County Service Center	Sheriff's Substation	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Clearance, perpendicular	OK	Yes					n/a	$ -	
F00312	Adams County Service Center	Sheriff's Substation	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Dimension, knee clearance	30	Yes					n/a	$ -	
F00313	Adams County Service Center	Sheriff's Substation	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Dimension, knee clearance	30	Yes					n/a	$ -	
F00314	Adams County Service Center	Sheriff's Substation	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F00315	Adams County Service Center	Sheriff's Substation	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F00316	Adams County Service Center	Sheriff's Substation	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F00317	Adams County Service Center	Sheriff's Substation	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Height	34	Yes					n/a	$ -	
F00318	Adams County Service Center	Sheriff's Substation	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Height	34	Yes					n/a	$ -	
F00320	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Clearance, parallel	99	Yes					n/a	$ -	
F00321	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Clearance, perpendicular	60	Yes					n/a	$ -	
F00322	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Dimension, knee clearance	29.5	Yes					n/a	$ -	
F00323	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F00324	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F00325	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Height	34	Yes					n/a	$ -	
F00330	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Break Room		3-Employee Common	Appliance	Refrig/Freezer	Clearance, parallel	OK	Yes					n/a	$ -	
F00331	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Break Room		3-Employee Common	Counter		Clearance, parallel	OK	Yes					n/a	$ -	
F00332	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Clearance, parallel	99	Yes					n/a	$ -	
F00333	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Break Room		3-Employee Common	Appliance	Refrig/Freezer	Clearance, perpendicular	OK	Yes					n/a	$ -	
F00334	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Break Room		3-Employee Common	Counter		Clearance, perpendicular	OK	Yes					n/a	$ -	
F00335	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Dimension, knee clearance	9	Yes					n/a	$ -	
F00336	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Break Room		3-Employee Common	Appliance	Refrig/Freezer	Height	47	Yes					n/a	$ -	
F00337	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Height	34	Yes					n/a	$ -	
F00339	Adams County Service Center	Work Release	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Dimension, knee clearance	29.5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00340	Adams County Service Center	Work Release	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F00341	Adams County Service Center	Work Release	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Height	34	Yes					n/a	$ -	
F00352	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F00353	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Appliance	Refrig/Freezer	Clearance, parallel	OK	Yes					n/a	$ -	
F00354	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Counter		Clearance, parallel	OK	Yes					n/a	$ -	
F00355	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Lavatory Sink		Clearance, parallel	OK	Yes					n/a	$ -	
F00356	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Appliance	Refrig/Freezer	Clearance, perpendicular	OK	Yes					n/a	$ -	
F00357	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Counter		Clearance, perpendicular	OK	Yes					n/a	$ -	
F00358	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Lavatory Sink		Clearance, perpendicular	OK	Yes					n/a	$ -	
F00359	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F00360	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F00361	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F00362	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F00363	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F00364	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F00365	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F00366	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Lavatory Sink		Height	34	Yes					n/a	$ -	
F00367	Adams County Service Center		Interior	Owned	Break Room	Conf/Break room	3-Employee Common	Counter		Length	61	Yes					n/a	$ -	
F00370	Adams County Service Center		2nd Floor	Owned	Break Room	Sheriff's #2	3-Employee Common	Lavatory Sink		Clearance, parallel	OK	Yes					n/a	$ -	
F00371	Adams County Service Center		2nd Floor	Owned	Break Room	Sheriff's #2	3-Employee Common	Lavatory Sink		Clearance, perpendicular	OK	Yes					n/a	$ -	
F00372	Adams County Service Center		2nd Floor	Owned	Break Room	Sheriff's #2	3-Employee Common	Lavatory Sink		Dimension, knee clearance	30	Yes					n/a	$ -	
F00373	Adams County Service Center		2nd Floor	Owned	Break Room	Sheriff's #2	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F00374	Adams County Service Center		2nd Floor	Owned	Break Room	Sheriff's #2	3-Employee Common	Lavatory Sink		Height	34	Yes					n/a	$ -	
F02998	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Hoistway Sign		All floors?	Y	Yes					n/a	$ -	
F02999	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Elevator Car		Audible signal?	Y	Yes					n/a	$ -	
F03000	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Hoistway Sign		Both jambs?	Y	Yes					n/a	$ -	
F03001	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Car Controls		Braille instructions	Y	Yes					n/a	$ -	
F03002	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Hoistway Sign		Braille?	Y	Yes					n/a	$ -	
F03003	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Elevator Door		Clear opening	36	Yes					n/a	$ -	
F03004	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Elevator Car		Dimension, back to front	51	Yes					n/a	$ -	
F03005	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Elevator Car		Dimension, gap	1.25	Yes					n/a	$ -	
F03006	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Elevator Car		Dimension, side to side	68	Yes					n/a	$ -	
F03007	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Elevator Door		Distance to door	10.5	Yes					n/a	$ -	
F03008	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Car Controls		Height, bottom	35	Yes					n/a	$ -	
F03009	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Emergency Communications		Height, bottom	25	Yes					n/a	$ -	
F03010	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Car Controls		Height, emergency control	35	Yes					n/a	$ -	
F03011	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Call Control		Height, top	41.5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F03012	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Car Controls		Height, top	39	Yes					n/a	$ -	
F03013	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Car Controls		Lighted?	Y	Yes					n/a	$ -	
F03014	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Emergency Communications		Provided?	Y	Yes					n/a	$ -	
F03015	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Elevator Door		Reopen device?	Y	Yes					n/a	$ -	
F03016	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Call Control		Size	1	Yes					n/a	$ -	
F03017	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Car Controls		Size	1	Yes					n/a	$ -	
F03018	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Car Controls		Star?	Y	Yes					n/a	$ -	
F03019	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Hoistway Sign		Tactile letters?	59.5	Yes					n/a	$ -	
F03020	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Car Controls		Tactile?	Y	Yes					n/a	$ -	
F03021	Adams County Service Center		2nd Floor	Owned	Elevator		1-Public Unsupervised	Emergency Communications		Tactile?	Y	Yes					n/a	$ -	
F03471	Adams County Service Center		Interior	Owned	Exercise Room	Men's	3-Employee Common	Signage		Location	L	Yes					n/a	$ -	
F03479	Adams County Service Center		Interior	Owned	Exercise Room		3-Employee Common	Door Gate		Clear opening	32	Yes					n/a	$ -	
F03714	Adams County Service Center	DMV	Interior	Owned	Hallway	Suite A	1-Public Unsupervised	Door Gate		Clear opening	34	Yes					n/a	$ -	
F03715	Adams County Service Center	DMV	Interior	Owned	Hallway	Suite A	1-Public Unsupervised	Door Gate		Clearance, vertical	90	Yes					n/a	$ -	
F03716	Adams County Service Center	DMV	Interior	Owned	Hallway	Suite A	1-Public Unsupervised	Door Gate		Closing speed	10	Yes					n/a	$ -	
F03717	Adams County Service Center	DMV	Interior	Owned	Hallway	Suite A	1-Public Unsupervised	Door Gate		Threshold beveled?	Y	Yes					n/a	$ -	
F03718	Adams County Service Center	DMV	Interior	Owned	Hallway	Suite A	1-Public Unsupervised	Door Gate		Opening force	9	Yes					n/a	$ -	
F03724	Adams County Service Center		2nd Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	In emergency area	Height	34	Yes					n/a	$ -	
F03725	Adams County Service Center		2nd Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	In emergency area	Height	39.5	Yes					n/a	$ -	
F03726	Adams County Service Center		2nd Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	In emergency area	Height, water flow	7	Yes					n/a	$ -	
F04303	Adams County Service Center		Interior	Owned	Lobby Reception	Central entrance	3-Employee Common	Counter	Traffic & Comm. Service	Dimension, knee clearance	30	Yes					n/a	$ -	
F04304	Adams County Service Center		Interior	Owned	Lobby Reception	Central entrance	3-Employee Common	Counter	Traffic & Comm. Service	Height	36	Yes					n/a	$ -	
F04644	Adams County Service Center		2nd Floor	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Clearance, parallel	66	Yes					n/a	$ -	
F04645	Adams County Service Center		2nd Floor	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Clearance, perpendicular	60	Yes					n/a	$ -	
F04646	Adams County Service Center		2nd Floor	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Control location	F	Yes					n/a	$ -	
F04647	Adams County Service Center		2nd Floor	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Height, shower control	46	Yes					n/a	$ -	
F04648	Adams County Service Center		2nd Floor	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Seat location	Rear	Yes					n/a	$ -	
F04649	Adams County Service Center		2nd Floor	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Seat type	F	Yes					n/a	$ -	
F04931	Adams County Service Center	Sheriff's Substation	Interior	Owned	Other Room	Equipment lockers	3-Employee Common	Door Gate		Clear opening	32	Yes					n/a	$ -	
F04932	Adams County Service Center	Sheriff's Substation	Interior	Owned	Other Room	Equipment lockers	3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F04933	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Other Room		3-Employee Common	Lavatory Sink		Clearance, parallel	OK	Yes					n/a	$ -	
F04934	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Other Room		3-Employee Common	Lavatory Sink		Clearance, perpendicular	OK	Yes					n/a	$ -	
F04935	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Other Room		3-Employee Common	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F04936	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Other Room		3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F04937	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Other Room		3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F05737	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#1	Access aisle?	Y	Yes					n/a	$ -	
F05738	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#2	Access aisle?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05739	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#3	Access aisle?	Y	Yes					n/a	$ -	
F05740	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#4	Access aisle?	Y	Yes					n/a	$ -	
F05741	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#5	Access aisle?	Y	Yes					n/a	$ -	
F05742	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#6	Access aisle?	Y	Yes					n/a	$ -	
F05743	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#7	Access aisle?	Y	Yes					n/a	$ -	
F05744	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#1	Adjacent pathway?	Y	Yes					n/a	$ -	
F05745	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#2	Adjacent pathway?	Y	Yes					n/a	$ -	
F05746	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#3	Adjacent pathway?	Y	Yes					n/a	$ -	
F05747	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#4	Adjacent pathway?	Y	Yes					n/a	$ -	
F05748	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#5	Adjacent pathway?	Y	Yes					n/a	$ -	
F05749	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#6	Adjacent pathway?	Y	Yes					n/a	$ -	
F05750	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#2	Height, sign	84	Yes					n/a	$ -	
F05751	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#3	Height, sign	82	Yes					n/a	$ -	
F05752	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#5	Height, sign	76	Yes					n/a	$ -	
F05753	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#6	Height, sign	76	Yes					n/a	$ -	
F05754	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#7	Height, sign	76	Yes					n/a	$ -	
F05755	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#2	Pathway behind cars?	N	Yes					n/a	$ -	
F05756	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#3	Pathway behind cars?	N	Yes					n/a	$ -	
F05757	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#4	Pathway behind cars?	N	Yes					n/a	$ -	
F05758	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#5	Pathway behind cars?	N	Yes					n/a	$ -	
F05759	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#6	Pathway behind cars?	N	Yes					n/a	$ -	
F05760	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#5	Sign?	Y	Yes					n/a	$ -	
F05761	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#6	Sign?	Y	Yes					n/a	$ -	
F05762	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#7	Sign?	Y	Yes					n/a	$ -	
F05763	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#6	Slope, cross	0.2%	Yes					n/a	$ -	
F05764	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#5	Slope, cross	0.5%	Yes					n/a	$ -	
F05765	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#3	Slope, cross	0.7%	Yes					n/a	$ -	
F05766	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#4	Slope, cross	1.0%	Yes					n/a	$ -	
F05767	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#1	Slope, cross	1.1%	Yes					n/a	$ -	
F05768	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#2	Slope, cross	1.7%	Yes					n/a	$ -	
F05769	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#5	Slope, cross	0.1%	Yes					n/a	$ -	
F05770	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#2	Slope, cross	0.3%	Yes					n/a	$ -	
F05771	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#4	Slope, cross	0.6%	Yes					n/a	$ -	
F05772	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#7	Slope, cross	0.9%	Yes					n/a	$ -	
F05773	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#1	Slope, cross	1.3%	Yes					n/a	$ -	
F05774	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#6	Slope, cross	1.7%	Yes					n/a	$ -	
F05775	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#3	Slope, cross	1.8%	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05776	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#2	Slope, running	0.0%	Yes					n/a	$ -	
F05777	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#3	Slope, running	0.8%	Yes					n/a	$ -	
F05778	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#5	Slope, running	1.1%	Yes					n/a	$ -	
F05779	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#6	Slope, running	1.2%	Yes					n/a	$ -	
F05780	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#1	Slope, running	1.3%	Yes					n/a	$ -	
F05781	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#4	Slope, running	1.7%	Yes					n/a	$ -	
F05782	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#2	Slope, running	0.6%	Yes					n/a	$ -	
F05783	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#7	Slope, running	0.6%	Yes					n/a	$ -	
F05784	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#3	Slope, running	0.9%	Yes					n/a	$ -	
F05785	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#1	Slope, running	1.4%	Yes					n/a	$ -	
F05786	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#6	Slope, running	1.7%	Yes					n/a	$ -	
F05787	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#4	Slope, running	0.5%	Yes					n/a	$ -	
F05788	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#1	Surface material	Asphalt	Yes					n/a	$ -	
F05789	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#2	Van sign?	Y	Yes					n/a	$ -	
F05790	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#5	Van sign?	N	Yes					n/a	$ -	
F05791	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#6	Van sign?	N	Yes					n/a	$ -	
F05792	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#7	Van sign?	N	Yes					n/a	$ -	
F05793	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#1	Width	61	Yes					n/a	$ -	
F05794	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#1	Width	OK	Yes					n/a	$ -	
F05795	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#2	Width	62	Yes					n/a	$ -	
F05796	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#3	Width	60	Yes					n/a	$ -	
F05797	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#5	Width	60	Yes					n/a	$ -	
F05798	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	#6	Width	60	Yes					n/a	$ -	
F05799	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#2	Width	142	Yes					n/a	$ -	
F05800	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#3	Width	142	Yes					n/a	$ -	
F05801	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#4	Width	139	Yes					n/a	$ -	
F05802	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#5	Width	137	Yes					n/a	$ -	
F05803	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#6	Width	132	Yes					n/a	$ -	
F05804	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#7	Width	135	Yes					n/a	$ -	
F05805	Adams County Service Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#1	Width	144	Yes					n/a	$ -	
F09432	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F09433	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F09434	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F09435	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F09436	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	99	Yes					n/a	$ -	
F09437	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Urinal		Depth	15	Yes					n/a	$ -	
F09438	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09439	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	31.5	Yes					n/a	$ -	
F09440	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F09441	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, wide side	42	Yes					n/a	$ -	
F09442	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Door swing direction	Out	Yes					n/a	$ -	
F09443	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F09444	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F09445	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Height	19	Yes					n/a	$ -	
F09446	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F09447	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Height, bottom	57	Yes					n/a	$ -	
F09448	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Height, flush control	Auto	Yes					n/a	$ -	
F09449	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	13.5	Yes					n/a	$ -	
F09450	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Self-closing?	Y	Yes					n/a	$ -	
F09451	Adams County Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F09464	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F09465	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F09466	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	59	Yes					n/a	$ -	
F09467	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F09468	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F09469	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F09470	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F09471	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F09472	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F09473	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Door swing direction	Out	Yes					n/a	$ -	
F09474	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	13	Yes					n/a	$ -	
F09475	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Height, top	35.5	Yes					n/a	$ -	
F09476	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Height, top	35.5	Yes					n/a	$ -	
F09477	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F09478	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F09479	Adams County Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Self-closing?	Y	Yes					n/a	$ -	
F09488	Adams County Service Center	Sheriff's Substation	Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Clear opening	32	Yes					n/a	$ -	
F09489	Adams County Service Center	Sheriff's Substation	Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Clearance, parallel	99	Yes					n/a	$ -	
F09490	Adams County Service Center	Sheriff's Substation	Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Clearance, perpendicular	50	Yes					n/a	$ -	
F09491	Adams County Service Center	Sheriff's Substation	Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F09492	Adams County Service Center	Sheriff's Substation	Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F09493	Adams County Service Center	Sheriff's Substation	Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Dimension, knee clearance	32	Yes					n/a	$ -	
F09494	Adams County Service Center	Sheriff's Substation	Interior	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Dimension, wide side	59	Yes					n/a	$ -	
F09495	Adams County Service Center	Sheriff's Substation	Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09496	Adams County Service Center	Sheriff's Substation	Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F09497	Adams County Service Center	Sheriff's Substation	Interior	Owned	Restroom	Unisex	3-Employee Common	Dispenser	TP	Height	19	Yes					n/a	$ -	
F09498	Adams County Service Center	Sheriff's Substation	Interior	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Height, flush control	Auto	Yes					n/a	$ -	
F09499	Adams County Service Center	Sheriff's Substation	Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Opening force	1	Yes					n/a	$ -	
F09500	Adams County Service Center	Sheriff's Substation - Property Evidence	Interior	Owned	Restroom	Unisex	3-Employee Common	Signage		Braille?	Y	Yes					n/a	$ -	
F09501	Adams County Service Center	Sheriff's Substation - Property Evidence	Interior	Owned	Restroom	Unisex	3-Employee Common	Signage		Height, bottom	57	Yes					n/a	$ -	
F09502	Adams County Service Center	Sheriff's Substation - Property Evidence	Interior	Owned	Restroom	Unisex	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F09515	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Clear opening	32	Yes					n/a	$ -	
F09516	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Clearance, parallel	99	Yes					n/a	$ -	
F09517	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Clearance, parallel	80	Yes					n/a	$ -	
F09518	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Clearance, perpendicular	48	Yes					n/a	$ -	
F09519	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Clearance, perpendicular	74	Yes					n/a	$ -	
F09520	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F09521	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F09522	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F09523	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F09524	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F09525	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F09526	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Dimension, knee clearance	32	Yes					n/a	$ -	
F09527	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09528	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Side	Height, top	34.5	Yes					n/a	$ -	
F09529	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Rear	Height, top	34.5	Yes					n/a	$ -	
F09530	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F09531	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F09532	Adams County Service Center	Sheriff's Substation - Records & Warrants	Interior	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Location, flush control	Auto	Yes					n/a	$ -	
F09552	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F09553	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F09554	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Dispenser	Hand dryer	Clearance, parallel	OK	Yes					n/a	$ -	
F09555	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Lavatory Sink		Clearance, parallel	OK	Yes					n/a	$ -	
F09556	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F09557	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Dispenser	Hand dryer	Clearance, perpendicular	OK	Yes					n/a	$ -	
F09558	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Lavatory Sink		Clearance, perpendicular	OK	Yes					n/a	$ -	
F09559	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Toilet Compartment		Clearance, perpendicular	99	Yes					n/a	$ -	
F09560	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F09561	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F09562	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F09563	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Urinal		Depth	15	Yes					n/a	$ -	
F09564	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F09565	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Side	Dimension, between	1.5	Yes					n/a	$ -	
F09566	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F09567	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F09568	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	31	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09569	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F09570	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Water Closet		Dimension, wide side	42	Yes					n/a	$ -	
F09571	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Toilet Compartment		Door swing direction	Out	Yes					n/a	$ -	
F09572	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F09573	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Urinal		Height, flush control	Auto	Yes					n/a	$ -	
F09574	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Urinal		Height, rim	17	Yes					n/a	$ -	
F09575	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Water Closet		Height, seat	19	Yes					n/a	$ -	
F09576	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F09577	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Side	Height, top	34.5	Yes					n/a	$ -	
F09578	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F09579	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F09580	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F09581	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Men's	2-Public Supervised	Water Closet		Location, flush control	Auto	Yes					n/a	$ -	
F09582	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Unisex	2-Public Supervised	Signage		Braille?	Y	Yes					n/a	$ -	
F09583	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Unisex	2-Public Supervised	Signage		Height, bottom	57.5	Yes					n/a	$ -	
F09584	Adams County Service Center	Sheriff's Substation - Secured Area	1st Floor	Owned	Restroom	Unisex	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F09604	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Signage		Braille?	Y	Yes					n/a	$ -	
F09605	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Door Gate		Clear opening	32	Yes					n/a	$ -	
F09606	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F09607	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Water Closet		Clearance, parallel	OK	Yes					n/a	$ -	
F09608	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Toilet Compartment		Clearance, perpendicular	60	Yes					n/a	$ -	
F09609	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Water Closet		Clearance, perpendicular	OK	Yes					n/a	$ -	
F09610	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F09611	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F09612	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Door Gate		Clearance, push parallel	49	Yes					n/a	$ -	
F09613	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F09614	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F09615	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F09616	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09617	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F09618	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F09619	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F09620	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F09621	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Water Closet		Dimension, wide side	42	Yes					n/a	$ -	
F09622	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Toilet Compartment		Door swing direction	Out	Yes					n/a	$ -	
F09623	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F09624	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Dispenser	TP	Height	19	Yes					n/a	$ -	
F09625	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Signage		Height, bottom	57	Yes					n/a	$ -	
F09626	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F09627	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Rear	Height, top	34.5	Yes					n/a	$ -	
F09628	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Side	Height, top	34.5	Yes					n/a	$ -	
F09629	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F09630	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F09631	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Signage		Location	L	Yes					n/a	$ -	
F09632	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Water Closet		Location, flush control	Auto	Yes					n/a	$ -	
F09633	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Men's	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F09645	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Signage		Braille?	Y	Yes					n/a	$ -	
F09646	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Door Gate		Clear opening	32	Yes					n/a	$ -	
F09647	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Lavatory Sink		Clearance, parallel	OK	Yes					n/a	$ -	
F09648	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Water Closet		Clearance, parallel	72	Yes					n/a	$ -	
F09649	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Lavatory Sink		Clearance, perpendicular	48	Yes					n/a	$ -	
F09650	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Water Closet		Clearance, perpendicular	78	Yes					n/a	$ -	
F09651	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F09652	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F09653	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Door Gate		Clearance, push parallel	OK	Yes					n/a	$ -	
F09654	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Door Gate		Clearance, push perpendicular	OK	Yes					n/a	$ -	
F09655	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F09656	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F09657	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F09658	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F09659	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F09660	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F09661	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Lavatory Sink		Dimension, knee clearance	31.5	Yes					n/a	$ -	
F09662	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F09663	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F09664	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09665	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Lavatory Sink		Height	34	Yes					n/a	$ -	
F09666	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F09667	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F09668	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Signage		Height, top	57	Yes					n/a	$ -	
F09669	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F09670	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F09671	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Signage		Location	L	Yes					n/a	$ -	
F09672	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Water Closet		Location, flush control	Auto	Yes					n/a	$ -	
F09673	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F09674	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Unisex - Break Room	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F09704	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Signage		Braille?	Y	Yes					n/a	$ -	
F09705	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Signage		Braille?	Y	Yes					n/a	$ -	
F09706	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F09707	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Door Gate	WIC	Clear opening	33	Yes					n/a	$ -	
F09708	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Dispenser	TP	Clearance, parallel	OK	Yes					n/a	$ -	
F09709	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Dispenser	TP	Clearance, parallel	OK	Yes					n/a	$ -	
F09710	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Lavatory Sink		Clearance, parallel	30	Yes					n/a	$ -	
F09711	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Lavatory Sink	WIC	Clearance, parallel	OK	Yes					n/a	$ -	
F09712	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Lavatory Sink		Clearance, parallel	OK	Yes					n/a	$ -	
F09713	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Water Closet		Clearance, parallel	OK	Yes					n/a	$ -	
F09714	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Dispenser	TP	Clearance, perpendicular	OK	Yes					n/a	$ -	
F09715	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Dispenser	TP	Clearance, perpendicular	OK	Yes					n/a	$ -	
F09716	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Lavatory Sink	WIC	Clearance, perpendicular	OK	Yes					n/a	$ -	
F09717	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Lavatory Sink		Clearance, perpendicular	OK	Yes					n/a	$ -	
F09718	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Water Closet		Clearance, perpendicular	OK	Yes					n/a	$ -	
F09719	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F09720	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F09721	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Door Gate		Clearance, push parallel	0	Yes					n/a	$ -	
F09722	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F09723	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F09724	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F09725	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F09726	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Door Gate		Clearance, vertical	OK	Yes					n/a	$ -	
F09727	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Water Closet		Control force	Auto	Yes					n/a	$ -	
F09728	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Cross section dimension, maximum	1.5	Yes					n/a	$ -	
F09729	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09730	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F09731	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F09732	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F09733	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F09734	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F09735	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F09736	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Lavatory Sink		Dimension, knee clearance	30	Yes					n/a	$ -	
F09737	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Lavatory Sink	WIC	Dimension, knee clearance	30	Yes					n/a	$ -	
F09738	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Lavatory Sink		Dimension, knee clearance	32	Yes					n/a	$ -	
F09739	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Water Closet		Dimension, sidewall	17.5	Yes					n/a	$ -	
F09740	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F09741	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Water Closet		Dimension, wide side	51	Yes					n/a	$ -	
F09742	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F09743	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Lavatory Sink	WIC	Drain wrapped?	Y	Yes					n/a	$ -	
F09744	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F09745	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F09746	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Lavatory Sink	WIC	Hardware type	L	Yes					n/a	$ -	
F09747	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F09748	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Dispenser	TP	Height	20	Yes					n/a	$ -	
F09749	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Dispenser	TP	Height	20	Yes					n/a	$ -	
F09750	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Lavatory Sink		Height	34	Yes					n/a	$ -	
F09751	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Lavatory Sink	WIC	Height	34	Yes					n/a	$ -	
F09752	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Lavatory Sink		Height	34	Yes					n/a	$ -	
F09753	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Signage		Height, bottom	58.25	Yes					n/a	$ -	
F09754	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Signage		Height, bottom	57	Yes					n/a	$ -	
F09755	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Water Closet		Height, flush control	Auto	Yes					n/a	$ -	
F09756	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F09757	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F09758	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Height, top	35.5	Yes					n/a	$ -	
F09759	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Height, top	35.5	Yes					n/a	$ -	
F09760	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Length	54	Yes					n/a	$ -	
F09761	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Length	42	Yes					n/a	$ -	
F09762	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Length	42	Yes					n/a	$ -	
F09763	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Length	54	Yes					n/a	$ -	
F09764	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Signage		Location	L	Yes					n/a	$ -	
F09765	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F09766	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09767	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F09768	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F09769	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Restroom	Women's	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F09778	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Client	2-Public Supervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F09779	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Client	2-Public Supervised	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F09780	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Client	2-Public Supervised	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F09781	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Client	2-Public Supervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F09782	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Client	2-Public Supervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F09783	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Client	2-Public Supervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F09784	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Client	2-Public Supervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F09785	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Client	2-Public Supervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F09786	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Client	2-Public Supervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F09787	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Client	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	33	Yes					n/a	$ -	
F09788	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Client	2-Public Supervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F09789	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Client	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F09790	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Client	2-Public Supervised	Dispenser	TP	Height	20	Yes					n/a	$ -	
F09791	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Client	2-Public Supervised	Grab Bar	Rear	Height, top	36	Yes					n/a	$ -	
F09792	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Client	2-Public Supervised	Grab Bar	Side	Height, top	36	Yes					n/a	$ -	
F09793	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Client	2-Public Supervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F09794	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Client	2-Public Supervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F09800	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Door Gate		Clear opening	32	Yes					n/a	$ -	
F09801	Adams County Service Center	Work Release	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Dispenser	TP	Height	19	Yes					n/a	$ -	
F09805	Adams County Service Center		Interior	Owned	Restroom	Men's	3-Employee Common	Signage		Braille?	Y	Yes					n/a	$ -	
F09806	Adams County Service Center		Interior	Owned	Restroom	Men's	3-Employee Common	Lavatory Sink		Clearance, parallel	OK	Yes					n/a	$ -	
F09807	Adams County Service Center		Interior	Owned	Restroom	Men's	3-Employee Common	Lavatory Sink		Clearance, perpendicular	OK	Yes					n/a	$ -	
F09808	Adams County Service Center		Interior	Owned	Restroom	Men's	3-Employee Common	Urinal		Depth	15	Yes					n/a	$ -	
F09809	Adams County Service Center		Interior	Owned	Restroom	Men's	3-Employee Common	Lavatory Sink		Dimension, knee clearance	32	Yes					n/a	$ -	
F09810	Adams County Service Center		Interior	Owned	Restroom	Men's	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F09811	Adams County Service Center		Interior	Owned	Restroom	Men's	3-Employee Common	Signage		Height, bottom	56	Yes					n/a	$ -	
F09812	Adams County Service Center		Interior	Owned	Restroom	Men's	3-Employee Common	Urinal		Height, flush control	Auto	Yes					n/a	$ -	
F09813	Adams County Service Center		Interior	Owned	Restroom	Men's	3-Employee Common	Signage		Location	L	Yes					n/a	$ -	
F09814	Adams County Service Center		Interior	Owned	Restroom	Men's	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F09828	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	99	Yes					n/a	$ -	
F09829	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Urinal		Depth	15	Yes					n/a	$ -	
F09830	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	3.5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09831	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F09832	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F09833	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	30	Yes					n/a	$ -	
F09834	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Water Closet		Dimension, sidewall	16.5	Yes					n/a	$ -	
F09835	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Water Closet		Dimension, wide side	43	Yes					n/a	$ -	
F09836	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Urinal		Height, rim	17	Yes					n/a	$ -	
F09837	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Grab Bar	Side	Height, top	35.25	Yes					n/a	$ -	
F09838	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Grab Bar	Rear	Height, top	35.25	Yes					n/a	$ -	
F09839	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F09840	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F09841	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F09842	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Fixture Count		Number, toilet compartments	2	Yes					n/a	$ -	
F09843	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Fixture Count		Number, urinals	2	Yes					n/a	$ -	
F09844	Adams County Service Center		2nd Floor	Owned	Restroom	Men's - Emergency Operations	1-Public Unsupervised	Toilet Compartment		Self-closing?	Y	Yes					n/a	$ -	
F09864	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Signage		Braille?	Y	Yes					n/a	$ -	
F09865	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Door Gate		Clear opening	33.5	Yes					n/a	$ -	
F09866	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Lavatory Sink		Clearance, parallel	OK	Yes					n/a	$ -	
F09867	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Water Closet		Clearance, parallel	OK	Yes					n/a	$ -	
F09868	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Lavatory Sink		Clearance, perpendicular	OK	Yes					n/a	$ -	
F09869	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Water Closet		Clearance, perpendicular	OK	Yes					n/a	$ -	
F09870	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F09871	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F09872	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Door Gate		Clearance, push parallel	OK	Yes					n/a	$ -	
F09873	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Door Gate		Clearance, push perpendicular	OK	Yes					n/a	$ -	
F09874	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F09875	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F09876	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Turning Space		Diameter	60	Yes					n/a	$ -	
F09877	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F09878	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Lavatory Sink		Dimension, knee clearance	30.5	Yes					n/a	$ -	
F09879	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Turning Space		Door swing?	Out	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09880	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F09881	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F09882	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F09883	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Alarm System		Height	85.5	Yes					n/a	$ -	
F09884	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Dispenser	Soap	Height	38.5	Yes					n/a	$ -	
F09885	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Dispenser	TP	Height	19	Yes					n/a	$ -	
F09886	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Signage		Height, bottom	57.25	Yes					n/a	$ -	
F09887	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Water Closet		Height, flush control	Auto	Yes					n/a	$ -	
F09888	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Grab Bar	Rear	Height, top	35.5	Yes					n/a	$ -	
F09889	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Grab Bar	Rear	Length	42	Yes					n/a	$ -	
F09890	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Signage		Location	L	Yes					n/a	$ -	
F09891	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F09892	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Turning Space		T-space provided?	Y	Yes					n/a	$ -	
F09893	Adams County Service Center		Interior	Owned	Restroom	Unisex - Conf/Break Room	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F09915	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F09916	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Dispenser	Soap	Clearance, parallel	OK	Yes					n/a	$ -	
F09917	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Dispenser	PT	Clearance, parallel	OK	Yes					n/a	$ -	
F09918	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Dispenser	TP	Clearance, parallel	OK	Yes					n/a	$ -	
F09919	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Lavatory Sink		Clearance, parallel	OK	Yes					n/a	$ -	
F09920	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Water Closet		Clearance, parallel	OK	Yes					n/a	$ -	
F09921	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Dispenser	Soap	Clearance, perpendicular	OK	Yes					n/a	$ -	
F09922	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Dispenser	PT	Clearance, perpendicular	OK	Yes					n/a	$ -	
F09923	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Door Gate		Clearance, pull parallel	23	Yes					n/a	$ -	
F09924	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F09925	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Door Gate		Clearance, push perpendicular	OK	Yes					n/a	$ -	
F09926	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F09927	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F09928	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F09929	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F09930	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F09931	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F09932	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Lavatory Sink		Dimension, knee clearance	30.5	Yes					n/a	$ -	
F09933	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F09934	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Water Closet		Dimension, wide side	46	Yes					n/a	$ -	
F09935	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F09936	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F09937	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09938	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Alarm System		Height	85.5	Yes					n/a	$ -	
F09939	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Dispenser	Soap	Height	38	Yes					n/a	$ -	
F09940	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Dispenser	TP	Height	20	Yes					n/a	$ -	
F09941	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Grab Bar	Rear	Height, top	36	Yes					n/a	$ -	
F09942	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Grab Bar	Side	Height, top	35.5	Yes					n/a	$ -	
F09943	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Grab Bar	Rear	Length	42	Yes					n/a	$ -	
F09944	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Grab Bar	Side	Length	54	Yes					n/a	$ -	
F09945	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Water Closet		Location, flush control	Auto	Yes					n/a	$ -	
F09946	Adams County Service Center		Interior	Owned	Restroom	Unisex - Crime Prevention	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F09957	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F09958	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Water Closet		Clearance, parallel	72	Yes					n/a	$ -	
F09959	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Water Closet		Clearance, perpendicular	99	Yes					n/a	$ -	
F09960	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Door Gate		Clearance, pull perpendicular	72	Yes					n/a	$ -	
F09961	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F09962	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Door Gate		Clearance, push perpendicular	46	Yes					n/a	$ -	
F09963	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Door Gate		Clearance, series doors	99	Yes					n/a	$ -	
F09964	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F09965	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F09966	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F09967	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Lavatory Sink		Dimension, knee clearance	29.5	Yes					n/a	$ -	
F09968	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F09969	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Lavatory Sink		Height	34	Yes					n/a	$ -	
F09970	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Grab Bar	Side	Height, top	35.25	Yes					n/a	$ -	
F09971	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Grab Bar	Rear	Height, top	35.25	Yes					n/a	$ -	
F09972	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F09973	Adams County Service Center		2nd Floor	Owned	Restroom	Unisex - Near Interview Room 4	3-Employee Common	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F09974	Adams County Service Center		Interior	Owned	Restroom	Women's	3-Employee Common	Water Closet		Clearance, parallel	OK	Yes					n/a	$ -	
F09975	Adams County Service Center		Interior	Owned	Restroom	Women's	3-Employee Common	Water Closet		Clearance, perpendicular	OK	Yes					n/a	$ -	
F09976	Adams County Service Center		Interior	Owned	Restroom	Women's	3-Employee Common	Coat Hook		Height	48	Yes					n/a	$ -	
F09977	Adams County Service Center		Interior	Owned	Restroom	Women's	3-Employee Common	Water Closet		Height, flush control	Auto	Yes					n/a	$ -	
F09978	Adams County Service Center		Interior	Owned	Restroom	Women's	3-Employee Common	Water Closet		Height, seat	19	Yes					n/a	$ -	
F09979	Adams County Service Center		Interior	Owned	Restroom	Women's	3-Employee Common	Water Closet		Location, flush control	Auto	Yes					n/a	$ -	
F09999	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F10000	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F10001	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	99	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10002	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F10003	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F10004	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	60	Yes					n/a	$ -	
F10005	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Door Gate		Clearance, vertical	80	Yes					n/a	$ -	
F10006	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F10007	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F10008	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F10009	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F10010	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Water Closet		Dimension, sidewall	17.5	Yes					n/a	$ -	
F10011	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Water Closet		Dimension, wide side	42.5	Yes					n/a	$ -	
F10012	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Alarm System		Height	85	Yes					n/a	$ -	
F10013	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Grab Bar	Side	Height, top	35.5	Yes					n/a	$ -	
F10014	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Grab Bar	Rear	Height, top	35.5	Yes					n/a	$ -	
F10015	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F10016	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F10017	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Emergency Operations	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F10031	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F10032	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F10033	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Toilet Compartment		Clearance, perpendicular	60	Yes					n/a	$ -	
F10034	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F10035	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F10036	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F10037	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F10038	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Toilet Compartment		Dimension, door to partition	4	Yes					n/a	$ -	
F10039	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F10040	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F10041	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Lavatory Sink		Dimension, knee clearance	32	Yes					n/a	$ -	
F10042	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Toilet Compartment		Door swing direction	Out	Yes					n/a	$ -	
F10043	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10044	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F10045	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Dispenser		Height	20	Yes					n/a	$ -	
F10046	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Water Closet		Height, flush control	Auto	Yes					n/a	$ -	
F10047	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Toilet Compartment		Height, toe clearance	13	Yes					n/a	$ -	
F10048	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Grab Bar	Rear	Height, top	35.5	Yes					n/a	$ -	
F10049	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Grab Bar	Side	Height, top	35.5	Yes					n/a	$ -	
F10050	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F10051	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F10052	Adams County Service Center		2nd Floor	Owned	Restroom	Women's - Locker Room	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F15529	Adams County Service Center		Exterior	Owned	Shelter	At bus stop on 72nd Street	1-Public Unsupervised	Other Element	Bench	Other attribute	OK	Yes					n/a	$ -	
F15530	Adams County Service Center		Exterior	Owned	Shelter	At bus stop on 72nd Street	1-Public Unsupervised	Other Element		Width	59	Yes					n/a	$ -	
F15544	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Shower Room		3-Employee Common	Shower Compartment		Clearance, parallel	36	Yes					n/a	$ -	
F15545	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Shower Room		3-Employee Common	Shower Compartment		Clearance, perpendicular	36	Yes					n/a	$ -	
F15546	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Shower Room		3-Employee Common	Grab Bar	Continuous	Clearance, to wall	1.5	Yes					n/a	$ -	
F15547	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Shower Room		3-Employee Common	Shower Compartment		Control location	F	Yes					n/a	$ -	
F15548	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Shower Room		3-Employee Common	Grab Bar	Continuous	Diameter	1.5	Yes					n/a	$ -	
F15549	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Shower Room		3-Employee Common	Shower Compartment		Dimension, entry to back wall	36	Yes					n/a	$ -	
F15550	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Shower Room		3-Employee Common	Shower Compartment		Dimension, side to side	36	Yes					n/a	$ -	
F15551	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Shower Room		3-Employee Common	Shower Compartment		Height, shower control	46	Yes					n/a	$ -	
F15552	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Shower Room		3-Employee Common	Grab Bar	Continuous	Length	60	Yes					n/a	$ -	
F15553	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Shower Room		3-Employee Common	Shower Compartment		Seat location	Rear	Yes					n/a	$ -	
F15554	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Shower Room		3-Employee Common	Shower Compartment		Seat type	F	Yes					n/a	$ -	
F15558	Adams County Service Center		2nd Floor	Owned	Shower Room	Women's - Locker Room	3-Employee Common	Shower Compartment		Clearance, parallel	66	Yes					n/a	$ -	
F15559	Adams County Service Center		2nd Floor	Owned	Shower Room	Women's - Locker Room	3-Employee Common	Shower Compartment		Clearance, perpendicular	60	Yes					n/a	$ -	
F15560	Adams County Service Center		2nd Floor	Owned	Shower Room	Women's - Locker Room	3-Employee Common	Shower Compartment		Control location	F	Yes					n/a	$ -	
F15561	Adams County Service Center		2nd Floor	Owned	Shower Room	Women's - Locker Room	3-Employee Common	Shower Compartment		Height, shower control	45	Yes					n/a	$ -	
F15562	Adams County Service Center		2nd Floor	Owned	Shower Room	Women's - Locker Room	3-Employee Common	Shower Compartment		Seat location	Rear	Yes					n/a	$ -	
F15563	Adams County Service Center		2nd Floor	Owned	Shower Room	Women's - Locker Room	3-Employee Common	Shower Compartment		Seat type	F	Yes					n/a	$ -	
F15881	Adams County Service Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	North end of island/walk into parking lot	Accumulates water?	N	Yes					n/a	$ -	
F15882	Adams County Service Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	Center walkway island	Accumulates water?	N	Yes					n/a	$ -	
F15883	Adams County Service Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	North end of island/walk into parking lot	Slope, counter	0.2%	Yes					n/a	$ -	
F15884	Adams County Service Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	North end of island/walk into parking lot	Slope, cross	0.6%	Yes					n/a	$ -	
F15885	Adams County Service Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	Center walkway island	Slope, cross	1.3%	Yes					n/a	$ -	
F15886	Adams County Service Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface		Slope, cross	0.1%	Yes					n/a	$ -	
F15887	Adams County Service Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	Center walkway island	Slope, running	7.9%	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15888	Adams County Service Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface	At bus stop	Slope, running	0.2%	Yes					n/a	$ -	
F15889	Adams County Service Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface	At bus stop	Surface material	Concrete	Yes					n/a	$ -	
F15890	Adams County Service Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	North end of island/walk into parking lot	Width	96	Yes					n/a	$ -	
F15891	Adams County Service Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	Center walkway island	Width	96	Yes					n/a	$ -	
F15892	Adams County Service Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface	At bus stop	Width	48	Yes					n/a	$ -	
F15893	Adams County Service Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface		Width	96	Yes					n/a	$ -	
F15895	Adams County Service Center		Exterior	Owned	Walkway	North side of South parking lot to entrance	1-Public Unsupervised	Walking Surface		Slope, cross	1.1%	Yes					n/a	$ -	
F15896	Adams County Service Center		Exterior	Owned	Walkway	North side of South parking lot to entrance	1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F15897	Adams County Service Center		Exterior	Owned	Walkway	North side of South parking lot to entrance	1-Public Unsupervised	Walking Surface		Width	70.5	Yes					n/a	$ -	
F16770	Adams County Service Center	Crime Prevention	Interior	Owned	Work Area		3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F16771	Adams County Service Center	Crime Prevention	Interior	Owned	Work Area		3-Employee Common	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F16772	Adams County Service Center	Crime Prevention	Interior	Owned	Work Area		3-Employee Common	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F16773	Adams County Service Center	Crime Prevention	Interior	Owned	Work Area		3-Employee Common	Door Gate		Closing speed	5	Yes					n/a	$ -	
F16775	Adams County Service Center	DMV	Interior	Owned	Work Area	Suite A	1-Public Unsupervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F16776	Adams County Service Center	DMV	Interior	Owned	Work Area	Suite A	1-Public Unsupervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F16777	Adams County Service Center	DMV	Interior	Owned	Work Area	Suite A	1-Public Unsupervised	Counter		Dimension, knee clearance	3	Yes					n/a	$ -	
F16778	Adams County Service Center	DMV	Interior	Owned	Work Area	Suite A	1-Public Unsupervised	Counter		Height	34	Yes					n/a	$ -	
F16787	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Work Area		3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F16788	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Work Area		3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F16789	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Work Area		3-Employee Common	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F16790	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Work Area		3-Employee Common	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F16791	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Work Area		3-Employee Common	Door Gate		Clearance, push parallel	OK	Yes					n/a	$ -	
F16792	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Work Area		3-Employee Common	Door Gate		Clearance, push perpendicular	OK	Yes					n/a	$ -	
F16793	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Work Area		3-Employee Common	Door Gate		Clearance, vertical	82	Yes					n/a	$ -	
F16794	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Work Area		3-Employee Common	Door Gate		Closing speed	6	Yes					n/a	$ -	
F16795	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Work Area		3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F16796	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Work Area		3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F16797	Adams County Service Center	Tri-County Health Dept	Interior	Owned	Work Area		3-Employee Common	Door Gate		Opening force	5	Yes					n/a	$ -	
F00088	Adams County Workforce Center		Interior	Leased	Assembly Area		1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F00089	Adams County Workforce Center		Interior	Leased	Assembly Area		1-Public Unsupervised	Door Gate		Clearance, pull parallel	28.5	Yes					n/a	$ -	
F00090	Adams County Workforce Center		Interior	Leased	Assembly Area		1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	86	Yes					n/a	$ -	
F00091	Adams County Workforce Center		Interior	Leased	Assembly Area		1-Public Unsupervised	Door Gate		Clearance, push parallel	26	Yes					n/a	$ -	
F00092	Adams County Workforce Center		Interior	Leased	Assembly Area		1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F00093	Adams County Workforce Center		Interior	Leased	Assembly Area		1-Public Unsupervised	Door Gate		Clearance, vertical	84.5	Yes					n/a	$ -	
F00094	Adams County Workforce Center		Interior	Leased	Assembly Area		1-Public Unsupervised	Door Gate		Hardware type	L	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00095	Adams County Workforce Center		Interior	Leased	Assembly Area		1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F03729	Adams County Workforce Center		Interior	Leased	Hallway	Between restrooms	1-Public Unsupervised	Drinking Fountain		Clearance, parallel	80	Yes					n/a	$ -	
F03730	Adams County Workforce Center		Interior	Leased	Hallway	Between restrooms	1-Public Unsupervised	Drinking Fountain		Clearance, perpendicular	99	Yes					n/a	$ -	
F03731	Adams County Workforce Center		Interior	Leased	Hallway	Between restrooms	1-Public Unsupervised	Drinking Fountain		Control force	3	Yes					n/a	$ -	
F03732	Adams County Workforce Center		Interior	Leased	Hallway	Between restrooms	1-Public Unsupervised	Drinking Fountain		Height	35	Yes					n/a	$ -	
F03733	Adams County Workforce Center		Interior	Leased	Hallway	Between restrooms	1-Public Unsupervised	Drinking Fountain		Height, water flow	38	Yes					n/a	$ -	
F03734	Adams County Workforce Center		Interior	Leased	Hallway	Between restrooms	1-Public Unsupervised	Drinking Fountain		Spout location	F	Yes					n/a	$ -	
F03735	Adams County Workforce Center		Interior	Leased	Hallway	At main entry	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F03736	Adams County Workforce Center		Interior	Leased	Hallway	At main entry	1-Public Unsupervised	Signage		Dimension, characters	0.5	Yes					n/a	$ -	
F03737	Adams County Workforce Center		Interior	Leased	Hallway	At main entry	1-Public Unsupervised	Signage		Height, bottom	58.75	Yes					n/a	$ -	
F03738	Adams County Workforce Center		Interior	Leased	Hallway	At main entry	1-Public Unsupervised	Signage		ISA?	N	Yes					n/a	$ -	
F03739	Adams County Workforce Center		Interior	Leased	Hallway	At main entry	1-Public Unsupervised	Signage		Location	H	Yes					n/a	$ -	
F03740	Adams County Workforce Center		Interior	Leased	Hallway	At main entry	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F03749	Adams County Workforce Center		Interior	Leased	Hallway		1-Public Unsupervised	Door Gate	Into suite	Clear opening	33.5	Yes					n/a	$ -	
F03750	Adams County Workforce Center		Interior	Leased	Hallway		1-Public Unsupervised	Door Gate	Into suite	Clearance, pull parallel	57	Yes					n/a	$ -	
F03751	Adams County Workforce Center		Interior	Leased	Hallway		1-Public Unsupervised	Door Gate	Into suite	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F03752	Adams County Workforce Center		Interior	Leased	Hallway		1-Public Unsupervised	Door Gate	Into suite	Clearance, push parallel	99	Yes					n/a	$ -	
F03753	Adams County Workforce Center		Interior	Leased	Hallway		1-Public Unsupervised	Door Gate	Into suite	Clearance, push perpendicular	99	Yes					n/a	$ -	
F03754	Adams County Workforce Center		Interior	Leased	Hallway		1-Public Unsupervised	Door Gate	Into suite	Clearance, vertical	81.5	Yes					n/a	$ -	
F03755	Adams County Workforce Center		Interior	Leased	Hallway		1-Public Unsupervised	Door Gate	Into suite	Hardware type	PP	Yes					n/a	$ -	
F03756	Adams County Workforce Center		Interior	Leased	Hallway		1-Public Unsupervised	Door Gate	Into suite	Threshold beveled?	Y	Yes					n/a	$ -	
F04306	Adams County Workforce Center		Interior	Leased	Lobby Reception		1-Public Unsupervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F04307	Adams County Workforce Center		Interior	Leased	Lobby Reception		1-Public Unsupervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F04308	Adams County Workforce Center		Interior	Leased	Lobby Reception		1-Public Unsupervised	Counter		Dimension, knee clearance	28.5	Yes					n/a	$ -	
F04309	Adams County Workforce Center		Interior	Leased	Lobby Reception		1-Public Unsupervised	Counter		Height	30	Yes					n/a	$ -	
F04310	Adams County Workforce Center		Interior	Leased	Lobby Reception		1-Public Unsupervised	Counter		Length	40	Yes					n/a	$ -	
F10070	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F10071	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F10072	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F10073	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	40.5	Yes					n/a	$ -	
F10074	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	82.5	Yes					n/a	$ -	
F10075	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	59	Yes					n/a	$ -	
F10076	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, push parallel	25	Yes					n/a	$ -	
F10077	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	72	Yes					n/a	$ -	
F10078	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F10079	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F10080	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Vertical	Clearance, to wall	1.5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10081	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F10082	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Water Closet		Control force	2	Yes					n/a	$ -	
F10083	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F10084	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F10085	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Vertical	Diameter	1.5	Yes					n/a	$ -	
F10086	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	9	Yes					n/a	$ -	
F10087	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Vertical	Dimension, between	5	Yes					n/a	$ -	
F10088	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	40	Yes					n/a	$ -	
F10089	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Signage		Dimension, characters	4.5	Yes					n/a	$ -	
F10090	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F10091	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F10092	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	28.25	Yes					n/a	$ -	
F10093	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F10094	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, wide side	65.25	Yes					n/a	$ -	
F10095	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Door swing direction	Out	Yes					n/a	$ -	
F10096	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F10097	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	Y	Yes					n/a	$ -	
F10098	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F10099	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Hardware type	Auto	Yes					n/a	$ -	
F10100	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Hardware type	OK	Yes					n/a	$ -	
F10101	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Coat Hook		Height	48	Yes					n/a	$ -	
F10102	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Height	21	Yes					n/a	$ -	
F10103	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Dispenser	Soap	Height	41	Yes					n/a	$ -	
F10104	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Dispenser	PT	Height	47	Yes					n/a	$ -	
F10105	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Changing Station		Height	34	Yes					n/a	$ -	
F10106	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Signage		Height, bottom	57.5	Yes					n/a	$ -	
F10107	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Water Closet		Height, flush control	27	Yes					n/a	$ -	
F10108	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Water Closet		Height, seat	17.5	Yes					n/a	$ -	
F10109	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F10110	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Height, top	35.5	Yes					n/a	$ -	
F10111	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Height, top	36	Yes					n/a	$ -	
F10112	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F10113	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F10114	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F10115	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F10116	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Vertical	Length	18	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10117	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F10118	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F10119	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F10120	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Fixture Count		Number, toilet compartments	1	Yes					n/a	$ -	
F10121	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Fixture Count		Number, urinals	1	Yes					n/a	$ -	
F10122	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Perimeter	1.5	Yes					n/a	$ -	
F10123	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Self-closing?	Y	Yes					n/a	$ -	
F10124	Adams County Workforce Center		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F10144	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F10145	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F10146	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F10147	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	60	Yes					n/a	$ -	
F10148	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Changing Station		Clearance, parallel	99	Yes					n/a	$ -	
F10149	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	70	Yes					n/a	$ -	
F10150	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	77	Yes					n/a	$ -	
F10151	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, push parallel	25	Yes					n/a	$ -	
F10152	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	74	Yes					n/a	$ -	
F10153	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F10154	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F10155	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Grab Bar	Vertical	Clearance, to wall	1.5	Yes					n/a	$ -	
F10156	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F10157	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Water Closet		Control force	3	Yes					n/a	$ -	
F10158	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F10159	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F10160	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Grab Bar	Vertical	Diameter	1.5	Yes					n/a	$ -	
F10161	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Grab Bar	Vertical	Dimension, between	5	Yes					n/a	$ -	
F10162	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	40	Yes					n/a	$ -	
F10163	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Signage		Dimension, characters	4.5	Yes					n/a	$ -	
F10164	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4	Yes					n/a	$ -	
F10165	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F10166	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F10167	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	28.25	Yes					n/a	$ -	
F10168	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, sidewall	16	Yes					n/a	$ -	
F10169	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, wide side	53.5	Yes					n/a	$ -	
F10170	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Door swing direction	Out	Yes					n/a	$ -	
F10171	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10172	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	Y	Yes					n/a	$ -	
F10173	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F10174	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Hardware type	Auto	Yes					n/a	$ -	
F10175	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Hardware type	PP	Yes					n/a	$ -	
F10176	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Alarm System		Height	Ceiling mount	Yes					n/a	$ -	
F10177	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Coat Hook		Height	48	Yes					n/a	$ -	
F10178	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Height	47	Yes					n/a	$ -	
F10179	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Dispenser	Soap	Height	40	Yes					n/a	$ -	
F10180	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Changing Station		Height	34	Yes					n/a	$ -	
F10181	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Mirror		Height, bottom	38.5	Yes					n/a	$ -	
F10182	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Signage		Height, bottom	57.5	Yes					n/a	$ -	
F10183	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Water Closet		Height, flush control	28	Yes					n/a	$ -	
F10184	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Water Closet		Height, seat	17.5	Yes					n/a	$ -	
F10185	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F10186	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Height, top	35.5	Yes					n/a	$ -	
F10187	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F10188	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F10189	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F10190	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F10191	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Grab Bar	Vertical	Length	18	Yes					n/a	$ -	
F10192	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F10193	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F10194	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F10195	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, toilet compartments	2	Yes					n/a	$ -	
F10196	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Self-closing?	Y	Yes					n/a	$ -	
F10197	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F10198	Adams County Workforce Center		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F15905	Adams County Workforce Center		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate		Clear opening	33.5	Yes					n/a	$ -	
F15906	Adams County Workforce Center		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F15907	Adams County Workforce Center		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F15908	Adams County Workforce Center		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate		Clearance, push parallel	60	Yes					n/a	$ -	
F15909	Adams County Workforce Center		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F15910	Adams County Workforce Center		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate		Clearance, series doors	53.5	Yes					n/a	$ -	
F15911	Adams County Workforce Center		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate		Clearance, vertical	82	Yes					n/a	$ -	
F15912	Adams County Workforce Center		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F15913	Adams County Workforce Center		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate		Opening force	8	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15914	Adams County Workforce Center		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate		Height, threshold	OK	Yes					n/a	$ -	
F15915	Adams County Workforce Center		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate		Threshold beveled?	Y	Yes					n/a	$ -	
F16798	Adams County Workforce Center		Interior	Leased	Work Area	Computer work area	1-Public Unsupervised	Circulation Path		Other attribute	OK	Yes					n/a	$ -	
F00102	Animal Shelter		Interior	Owned	Assembly Area		3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F00103	Animal Shelter		Interior	Owned	Assembly Area		3-Employee Common	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F00104	Animal Shelter		Interior	Owned	Assembly Area		3-Employee Common	Door Gate		Clearance, push parallel	18	Yes					n/a	$ -	
F00105	Animal Shelter		Interior	Owned	Assembly Area		3-Employee Common	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F00106	Animal Shelter		Interior	Owned	Assembly Area		3-Employee Common	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F00107	Animal Shelter		Interior	Owned	Assembly Area		3-Employee Common	Door Gate		Closing speed	5	Yes					n/a	$ -	
F00108	Animal Shelter		Interior	Owned	Assembly Area		3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F00109	Animal Shelter		Interior	Owned	Assembly Area		3-Employee Common	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F00382	Animal Shelter		Interior	Owned	Break Room		3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F00383	Animal Shelter		Interior	Owned	Break Room		3-Employee Common	Door Gate		Closing speed	12	Yes					n/a	$ -	
F00384	Animal Shelter		Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Dimension, knee clearance	12	Yes					n/a	$ -	
F00385	Animal Shelter		Interior	Owned	Break Room		3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F00386	Animal Shelter		Interior	Owned	Break Room		3-Employee Common	Appliance	Microwave	Height	45	Yes					n/a	$ -	
F00387	Animal Shelter		Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Height	33.5	Yes					n/a	$ -	
F00388	Animal Shelter		Interior	Owned	Break Room		3-Employee Common	Counter		Length	99	Yes					n/a	$ -	
F04312	Animal Shelter		Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Dimension, knee clearance	6.75	Yes					n/a	$ -	
F04313	Animal Shelter		Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Height	36	Yes					n/a	$ -	
F04314	Animal Shelter		Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Length	99	Yes					n/a	$ -	
F04652	Animal Shelter		Interior	Owned	Locker Room	Men's	3-Employee Common	Signage		Braille?	Y	Yes					n/a	$ -	
F04653	Animal Shelter		Interior	Owned	Locker Room	Men's	3-Employee Common	Signage		Height, bottom	56	Yes					n/a	$ -	
F04654	Animal Shelter		Interior	Owned	Locker Room	Men's	3-Employee Common	Signage		ISA?	Y	Yes					n/a	$ -	
F04655	Animal Shelter		Interior	Owned	Locker Room	Men's	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F04658	Animal Shelter		Interior	Owned	Locker Room	women's	3-Employee Common	Mirror		Height, bottom	Full length	Yes					n/a	$ -	
F04666	Animal Shelter		Interior	Owned	Locker Room		3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F04667	Animal Shelter		Interior	Owned	Locker Room		3-Employee Common	Shower Compartment		Clearance, parallel	95	Yes					n/a	$ -	
F04668	Animal Shelter		Interior	Owned	Locker Room		3-Employee Common	Shower Compartment		Clearance, perpendicular	48.5	Yes					n/a	$ -	
F04669	Animal Shelter		Interior	Owned	Locker Room		3-Employee Common	Door Gate		Clearance, vertical	82	Yes					n/a	$ -	
F04670	Animal Shelter		Interior	Owned	Locker Room		3-Employee Common	Door Gate		Closing speed	8	Yes					n/a	$ -	
F04671	Animal Shelter		Interior	Owned	Locker Room		3-Employee Common	Shower Compartment		Control location	F	Yes					n/a	$ -	
F04672	Animal Shelter		Interior	Owned	Locker Room		3-Employee Common	Door Gate		Hardware type	OK	Yes					n/a	$ -	
F04673	Animal Shelter		Interior	Owned	Locker Room		3-Employee Common	Bench		Height	18	Yes					n/a	$ -	
F04674	Animal Shelter		Interior	Owned	Locker Room		3-Employee Common	Shower Compartment		Height, shower control	43	Yes					n/a	$ -	
F04675	Animal Shelter		Interior	Owned	Locker Room		3-Employee Common	Shower Compartment	Folding Seat	Other attribute	OK	Yes					n/a	$ -	
F04676	Animal Shelter		Interior	Owned	Locker Room		3-Employee Common	Shower Compartment		Seat location	Back wall	Yes					n/a	$ -	
F04677	Animal Shelter		Interior	Owned	Locker Room		3-Employee Common	Bench		Slip resistant?	OK	Yes					n/a	$ -	
F05813	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Access aisle?	Y	Yes					n/a	$ -	
F05814	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Access aisle?	Y	Yes					n/a	$ -	
F05815	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #1 & #2	Adjacent pathway?	Y	Yes					n/a	$ -	
F05816	Animal Shelter		Exterior	Owned	Parking Facility		3-Employee Common	Facility Specifications		Cars obstruct pathway	OK	Yes					n/a	$ -	
F05817	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Height, sign	78	Yes					n/a	$ -	
F05818	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Height, sign	75	Yes					n/a	$ -	
F05819	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #1 & #2	Length	OK	Yes					n/a	$ -	
F05820	Animal Shelter		Exterior	Owned	Parking Facility		3-Employee Common	Other Element		Other attribute	OK	Yes					n/a	$ -	
F05821	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #1 & #2	Pathway behind cars?	N	Yes					n/a	$ -	
F05822	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Sign?	Y	Yes					n/a	$ -	
F05823	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Sign?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05824	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #1 & #2	Slope, cross	1.1%	Yes					n/a	$ -	
F05825	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Slope, cross	0.4%	Yes					n/a	$ -	
F05826	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Slope, cross	0.7%	Yes					n/a	$ -	
F05827	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #1 & #2	Slope, running	1.4%	Yes					n/a	$ -	
F05828	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Slope, running	1.5%	Yes					n/a	$ -	
F05829	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #1 & #2	Surface marking?	Y	Yes					n/a	$ -	
F05830	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #1 & #2	Surface material	Concrete	Yes					n/a	$ -	
F05831	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Surface material	Concrete	Yes					n/a	$ -	
F05832	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Surface material	Concrete	Yes					n/a	$ -	
F05833	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Van sign?	N	Yes					n/a	$ -	
F05834	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #1 & #2	Width	68	Yes					n/a	$ -	
F05835	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Width	131	Yes					n/a	$ -	
F05836	Animal Shelter		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Width	146	Yes					n/a	$ -	
F10210	Animal Shelter		Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F10211	Animal Shelter		Interior	Owned	Restroom	Men's	3-Employee Common	Lavatory Sink		Clearance, parallel	99	Yes					n/a	$ -	
F10212	Animal Shelter		Interior	Owned	Restroom	Men's	3-Employee Common	Lavatory Sink		Clearance, perpendicular	99	Yes					n/a	$ -	
F10213	Animal Shelter		Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F10214	Animal Shelter		Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F10215	Animal Shelter		Interior	Owned	Restroom	Men's	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F10216	Animal Shelter		Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Height	40.5	Yes					n/a	$ -	
F10217	Animal Shelter		Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Height	33.5	Yes					n/a	$ -	
F10218	Animal Shelter		Interior	Owned	Restroom	Men's	3-Employee Common	Lavatory Sink		Height	30	Yes					n/a	$ -	
F10219	Animal Shelter		Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F10220	Animal Shelter		Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F10229	Animal Shelter		Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Toilet Compartment		Clear opening	32	Yes					n/a	$ -	
F10230	Animal Shelter		Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Toilet Compartment		Clearance, outside	OK	Yes					n/a	$ -	
F10231	Animal Shelter		Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F10232	Animal Shelter		Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Toilet Compartment		Clearance, perpendicular	99	Yes					n/a	$ -	
F10233	Animal Shelter		Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F10234	Animal Shelter		Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F10235	Animal Shelter		Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F10236	Animal Shelter		Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F10237	Animal Shelter		Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F10238	Animal Shelter		Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Water Closet		Dimension, wide side	42.5	Yes					n/a	$ -	
F10239	Animal Shelter		Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F10240	Animal Shelter		Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Toilet Compartment		Hardware type	L	Yes					n/a	$ -	
F10241	Animal Shelter		Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Water Closet		Height, seat	19	Yes					n/a	$ -	
F10242	Animal Shelter		Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Toilet Compartment		Height, toe clearance	11.5	Yes					n/a	$ -	
F10243	Animal Shelter		Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Grab Bar	Rear	Height, top	34.5	Yes					n/a	$ -	
F10244	Animal Shelter		Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F10245	Animal Shelter		Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F10258	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Clear opening	33.5	Yes					n/a	$ -	
F10259	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Dispenser	TP	Clearance, parallel	OK	Yes					n/a	$ -	
F10260	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Clearance, parallel	49	Yes					n/a	$ -	
F10261	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Dispenser	TP	Clearance, perpendicular	OK	Yes					n/a	$ -	
F10262	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Toilet Compartment		Clearance, perpendicular	69	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10263	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F10264	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Clearance, pull perpendicular	61	Yes					n/a	$ -	
F10265	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Clearance, vertical	80	Yes					n/a	$ -	
F10266	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Closing speed	OK	Yes					n/a	$ -	
F10267	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Dimension, knee clearance	30.5	Yes					n/a	$ -	
F10268	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F10269	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F10270	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Toilet Compartment		Hardware both sides?	Y	Yes					n/a	$ -	
F10271	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F10272	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F10273	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Dispenser	TP	Height	40	Yes					n/a	$ -	
F10274	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Height	33.5	Yes					n/a	$ -	
F10275	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Height, seat	19	Yes					n/a	$ -	
F10276	Animal Shelter		Interior	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F10294	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F10295	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clear opening	33.5	Yes					n/a	$ -	
F10296	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clear opening	OK	Yes					n/a	$ -	
F10297	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	OK	Yes					n/a	$ -	
F10298	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	76.5	Yes					n/a	$ -	
F10299	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Clearance, parallel	78.5	Yes					n/a	$ -	
F10300	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	OK	Yes					n/a	$ -	
F10301	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	82	Yes					n/a	$ -	
F10302	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Clearance, perpendicular	82.5	Yes					n/a	$ -	
F10303	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F10304	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F10305	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Closing speed	OK	Yes					n/a	$ -	
F10306	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F10307	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F10308	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Dimension, characters	.75	Yes					n/a	$ -	
F10309	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29.5	Yes					n/a	$ -	
F10310	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	Y	Yes					n/a	$ -	
F10311	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F10312	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Hardware type	OK	Yes					n/a	$ -	
F10313	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Feminine Products	Height	40	Yes					n/a	$ -	
F10314	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Height	33.5	Yes					n/a	$ -	
F10315	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Height, bottom	57.5	Yes					n/a	$ -	
F10316	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Height, seat	19	Yes					n/a	$ -	
F10317	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	OK	Yes					n/a	$ -	
F10318	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Height, top	33.75	Yes					n/a	$ -	
F10319	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Height, top	33.5	Yes					n/a	$ -	
F10320	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F10321	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F10322	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F10323	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Location, flush control	OK	Yes					n/a	$ -	
F10324	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Self-closing?	OK	Yes					n/a	$ -	
F10325	Animal Shelter		Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F10332	Animal Shelter		Interior	Owned	Restroom	Women's - Locker Room	3-Employee Common	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F10333	Animal Shelter		Interior	Owned	Restroom	Women's - Locker Room	3-Employee Common	Toilet Compartment		Clearance, perpendicular	99	Yes					n/a	$ -	
F10334	Animal Shelter		Interior	Owned	Restroom	Women's - Locker Room	3-Employee Common	Door Gate		Closing speed	7	Yes					n/a	$ -	
F10335	Animal Shelter		Interior	Owned	Restroom	Women's - Locker Room	3-Employee Common	Alarm System		Visible alarm	N	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15564	Animal Shelter		Interior	Owned	Shower Room	Men's - Locker Room	3-Employee Common	Grab Bar	Side	Dimension, end to wall	2	Yes					n/a	$ -	
F15568	Animal Shelter		Interior	Owned	Shower Room	Roll-in	3-Employee Common	Grab Bar	Front wall	Clearance, to wall	1.5	Yes					n/a	$ -	
F15569	Animal Shelter		Interior	Owned	Shower Room	Roll-in	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F15570	Animal Shelter		Interior	Owned	Shower Room	Roll-in	3-Employee Common	Grab Bar	Front wall	Cross section dimension, maximum	1.5	Yes					n/a	$ -	
F15571	Animal Shelter		Interior	Owned	Shower Room	Roll-in	3-Employee Common	Grab Bar	Front wall	Diameter	1.5	Yes					n/a	$ -	
F15572	Animal Shelter		Interior	Owned	Shower Room	Roll-in	3-Employee Common	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F15573	Animal Shelter		Interior	Owned	Shower Room	Roll-in	3-Employee Common	Grab Bar	Front wall	Height, top	35	Yes					n/a	$ -	
F15574	Animal Shelter		Interior	Owned	Shower Room	Roll-in	3-Employee Common	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F15575	Animal Shelter		Interior	Owned	Shower Room	Roll-in	3-Employee Common	Grab Bar	Front wall	Length	42	Yes					n/a	$ -	
F15576	Animal Shelter		Interior	Owned	Shower Room	Roll-in	3-Employee Common	Grab Bar	Side	Length	36	Yes					n/a	$ -	
F15666	Animal Shelter		Interior	Owned	Visiting Area	Lost dogs	2-Public Supervised	Door Gate		Clear opening	33.5	Yes					n/a	$ -	
F15667	Animal Shelter		Interior	Owned	Visiting Area	Lost dogs	2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F15668	Animal Shelter		Interior	Owned	Visiting Area	Lost dogs	2-Public Supervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F15669	Animal Shelter		Interior	Owned	Visiting Area	Lost dogs	2-Public Supervised	Door Gate		Clearance, vertical	82	Yes					n/a	$ -	
F15670	Animal Shelter		Interior	Owned	Visiting Area	Lost dogs	2-Public Supervised	Door Gate		Closing speed	7	Yes					n/a	$ -	
F15671	Animal Shelter		Interior	Owned	Visiting Area	Lost dogs	2-Public Supervised	Door Gate		Hardware type	OK	Yes					n/a	$ -	
F15918	Animal Shelter	Adoption Area	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Closing speed	10	Yes					n/a	$ -	
F15919	Animal Shelter	Adoption Area	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Other attribute	Auto	Yes					n/a	$ -	
F15920	Animal Shelter	Adoption Area	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Threshold beveled?	Y	Yes					n/a	$ -	
F15923	Animal Shelter	Lost and Found	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Clear opening	32.5	Yes					n/a	$ -	
F15924	Animal Shelter	Lost and Found	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Clearance, pull parallel	20	Yes					n/a	$ -	
F15925	Animal Shelter	Lost and Found	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Clearance, pull parallel	60	Yes					n/a	$ -	
F15926	Animal Shelter	Lost and Found	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F15927	Animal Shelter	Lost and Found	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Clearance, vertical	81	Yes					n/a	$ -	
F15928	Animal Shelter	Lost and Found	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Closing speed	7	Yes					n/a	$ -	
F15929	Animal Shelter	Lost and Found	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Hardware type	OK	Yes					n/a	$ -	
F15930	Animal Shelter	Lost and Found	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Threshold beveled?	Y	Yes					n/a	$ -	
F00391	Aurora Motor Vehicle		Interior	Leased	Break Room		3-Employee Common	Lavatory Sink		Dimension, knee clearance	27	Yes					n/a	$ -	
F00392	Aurora Motor Vehicle		Interior	Leased	Break Room		3-Employee Common	Counter		Height	34	Yes					n/a	$ -	
F00393	Aurora Motor Vehicle		Interior	Leased	Break Room		3-Employee Common	Lavatory Sink		Height	34	Yes					n/a	$ -	
F10340	Aurora Motor Vehicle		Interior	Leased	Restroom	Unisex - Employee	3-Employee Common	Signage		Braille?	Y	Yes					n/a	$ -	
F10341	Aurora Motor Vehicle		Interior	Leased	Restroom	Unisex - Employee	3-Employee Common	Water Closet		Clearance, parallel	75	Yes					n/a	$ -	
F10342	Aurora Motor Vehicle		Interior	Leased	Restroom	Unisex - Employee	3-Employee Common	Water Closet		Clearance, perpendicular	80	Yes					n/a	$ -	
F10343	Aurora Motor Vehicle		Interior	Leased	Restroom	Unisex - Employee	3-Employee Common	Dispenser	TP	Dimension from water closet seat	8	Yes					n/a	$ -	
F10344	Aurora Motor Vehicle		Interior	Leased	Restroom	Unisex - Employee	3-Employee Common	Signage		Dimension, characters	1	Yes					n/a	$ -	
F10345	Aurora Motor Vehicle		Interior	Leased	Restroom	Unisex - Employee	3-Employee Common	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F10346	Aurora Motor Vehicle		Interior	Leased	Restroom	Unisex - Employee	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F10347	Aurora Motor Vehicle		Interior	Leased	Restroom	Unisex - Employee	3-Employee Common	Lavatory Sink		Dimension, knee clearance	27	Yes					n/a	$ -	
F10348	Aurora Motor Vehicle		Interior	Leased	Restroom	Unisex - Employee	3-Employee Common	Water Closet		Dimension, sidewall	17	Yes					n/a	$ -	
F10349	Aurora Motor Vehicle		Interior	Leased	Restroom	Unisex - Employee	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F10350	Aurora Motor Vehicle		Interior	Leased	Restroom	Unisex - Employee	3-Employee Common	Lavatory Sink		Height	32	Yes					n/a	$ -	
F10351	Aurora Motor Vehicle		Interior	Leased	Restroom	Unisex - Employee	3-Employee Common	Mirror		Height, bottom	37	Yes					n/a	$ -	
F10352	Aurora Motor Vehicle		Interior	Leased	Restroom	Unisex - Employee	3-Employee Common	Water Closet		Height, seat	18	Yes					n/a	$ -	
F10353	Aurora Motor Vehicle		Interior	Leased	Restroom	Unisex - Employee	3-Employee Common	Grab Bar	Side	Height, top	36	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10354	Aurora Motor Vehicle		Interior	Leased	Restroom	Unisex - Employee	3-Employee Common	Grab Bar	Rear	Height, top	36	Yes					n/a	$ -	
F10355	Aurora Motor Vehicle		Interior	Leased	Restroom	Unisex - Employee	3-Employee Common	Signage		Height, top	58	Yes					n/a	$ -	
F10356	Aurora Motor Vehicle		Interior	Leased	Restroom	Unisex - Employee	3-Employee Common	Signage		ISA?	Y	Yes					n/a	$ -	
F10357	Aurora Motor Vehicle		Interior	Leased	Restroom	Unisex - Employee	3-Employee Common	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F10358	Aurora Motor Vehicle		Interior	Leased	Restroom	Unisex - Employee	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F00396	Children and Family Center		1st Floor	Owned	Break Room	Childcare Area	3-Employee Common	Lavatory Sink		Other attribute	In Cabinet	Yes					n/a	$ -	
F00399	Children and Family Center		4th Floor	Owned	Break Room	East	3-Employee Common	Lavatory Sink		Other attribute	In Cabinet	Yes					n/a	$ -	
F00405	Children and Family Center		3rd Floor	Owned	Break Room	West	3-Employee Common	Lavatory Sink		Other attribute	In Cabinet	Yes					n/a	$ -	
F00406	Children and Family Center		4th Floor	Owned	Break Room	West	3-Employee Common	Lavatory Sink		Other attribute	In Cabinet	Yes					n/a	$ -	
F00413	Children and Family Center		2nd Floor	Owned	Break Room		1-Public Unsupervised	Lavatory Sink		Other attribute	In Cabinet	Yes					n/a	$ -	
F00414	Children and Family Center		2nd Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Other attribute	In Cabinet	Yes					n/a	$ -	
F00415	Children and Family Center		3rd Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Other attribute	In Cabinet	Yes					n/a	$ -	
F03022	Children and Family Center		1st Floor	Owned	Elevator	Smaller	3-Employee Common	Elevator Car		Audible signal?	Y	Yes					n/a	$ -	
F03023	Children and Family Center		1st Floor	Owned	Elevator	Smaller	3-Employee Common	Elevator Car		Dimension, back to front	60	Yes					n/a	$ -	
F03024	Children and Family Center		1st Floor	Owned	Elevator	Smaller	3-Employee Common	Elevator Car		Dimension, side to side	69	Yes					n/a	$ -	
F03025	Children and Family Center		1st Floor	Owned	Elevator		3-Employee Common	Elevator Car		Dimension, back to front	60	Yes					n/a	$ -	
F03026	Children and Family Center		1st Floor	Owned	Elevator		3-Employee Common	Elevator Car		Dimension, gap	1.25	Yes					n/a	$ -	
F03027	Children and Family Center		1st Floor	Owned	Elevator		3-Employee Common	Elevator Car		Dimension, side to side	81	Yes					n/a	$ -	
F03028	Children and Family Center		1st Floor	Owned	Elevator		3-Employee Common	Car Controls		Height, bottom	35	Yes					n/a	$ -	
F03029	Children and Family Center		1st Floor	Owned	Elevator		3-Employee Common	Car Controls		Height, emergency control	35	Yes					n/a	$ -	
F03030	Children and Family Center		1st Floor	Owned	Elevator		3-Employee Common	Car Controls		Height, top	43	Yes					n/a	$ -	
F03774	Children and Family Center		3rd Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near Restrooms	Height	34	Yes					n/a	$ -	
F03775	Children and Family Center		4th Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near Restrooms	Height	34	Yes					n/a	$ -	
F05865	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Facility Specifications		Number, accessible	8	Yes					n/a	$ -	
F05866	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Facility Specifications		Number, van spaces	8	Yes					n/a	$ -	
F05867	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	#4	Slope, cross	1.9%	Yes					n/a	$ -	
F05868	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	#3	Slope, cross	2.0%	Yes					n/a	$ -	
F05869	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#5	Slope, running	2.0%	Yes					n/a	$ -	
F05870	Children and Family Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#4	Van sign?	N	Yes					n/a	$ -	
F05878	Children and Family Center		Exterior	Owned	Parking Facility	Visitors	1-Public Unsupervised	Parking Space	#1	Access aisle?	Y	Yes					n/a	$ -	
F05879	Children and Family Center		Exterior	Owned	Parking Facility	Visitors	1-Public Unsupervised	Parking Space	#2	Height, sign	60	Yes					n/a	$ -	
F05880	Children and Family Center		Exterior	Owned	Parking Facility	Visitors	1-Public Unsupervised	Parking Space	#3	Height, sign	63	Yes					n/a	$ -	
F05881	Children and Family Center		Exterior	Owned	Parking Facility	Visitors	1-Public Unsupervised	Facility Specifications		Number, accessible	4	Yes					n/a	$ -	
F05882	Children and Family Center		Exterior	Owned	Parking Facility	Visitors	1-Public Unsupervised	Facility Specifications		Number, van spaces	4	Yes					n/a	$ -	
F05883	Children and Family Center		Exterior	Owned	Parking Facility	Visitors	1-Public Unsupervised	Parking Space	#1	Slope, cross	0.1%	Yes					n/a	$ -	
F05884	Children and Family Center		Exterior	Owned	Parking Facility	Visitors	1-Public Unsupervised	Parking Space	#2	Slope, cross	0.7%	Yes					n/a	$ -	
F05885	Children and Family Center		Exterior	Owned	Parking Facility	Visitors	1-Public Unsupervised	Parking Space	#3	Slope, running	1.3%	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05886	Children and Family Center		Exterior	Owned	Parking Facility	Visitors	1-Public Unsupervised	Parking Space	#2	Slope, running	1.5%	Yes					n/a	$ -	
F05887	Children and Family Center		Exterior	Owned	Parking Facility	Visitors	1-Public Unsupervised	Parking Space	#1	Van sign?	N	Yes					n/a	$ -	
F10413	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F10414	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clear opening	40	Yes					n/a	$ -	
F10415	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clear opening	32	Yes					n/a	$ -	
F10416	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	62	Yes					n/a	$ -	
F10417	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	90	Yes					n/a	$ -	
F10418	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	60	Yes					n/a	$ -	
F10419	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, pull parallel	24	Yes					n/a	$ -	
F10420	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, pull parallel	18	Yes					n/a	$ -	
F10421	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F10422	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F10423	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	2.5	Yes					n/a	$ -	
F10424	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4	Yes					n/a	$ -	
F10425	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F10426	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F10427	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F10428	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F10429	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F10430	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F10431	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, wide side	42	Yes					n/a	$ -	
F10432	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, wide side	42	Yes					n/a	$ -	
F10433	Children and Family Center		4th Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, wide side	39	Yes					n/a	$ -	
F10434	Children and Family Center		1st Floor	Owned	Restroom	Men's	3-Employee Common	Water Closet		Dimension, wide side	39	Yes					n/a	$ -	
F10435	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F10436	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F10437	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Height	32	Yes					n/a	$ -	
F10438	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Height	32	Yes					n/a	$ -	
F10439	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Height, bottom	59	Yes					n/a	$ -	
F10440	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F10441	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F10442	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F10443	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F10444	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F10445	Children and Family Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F10446	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F10447	Children and Family Center		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10498	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F10499	Children and Family Center		3rd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F10500	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	91	Yes					n/a	$ -	
F10501	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4	Yes					n/a	$ -	
F10502	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F10503	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F10504	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F10505	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, wide side	42	Yes					n/a	$ -	
F10506	Children and Family Center		3rd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, wide side	42	Yes					n/a	$ -	
F10507	Children and Family Center		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, wide side	39	Yes					n/a	$ -	
F10508	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F10509	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Height	32	Yes					n/a	$ -	
F10510	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Height, flush control	OK	Yes					n/a	$ -	
F10511	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F10512	Children and Family Center		3rd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F10513	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F10514	Children and Family Center		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F15937	Children and Family Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp		Landing?	Y	Yes					n/a	$ -	
F15938	Children and Family Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp		Slope, left flare	3.9%	Yes					n/a	$ -	
F15939	Children and Family Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp		Slope, right flare	7.3%	Yes					n/a	$ -	
F15941	Children and Family Center		Exterior	Owned	Walkway	To employee entrance	3-Employee Common	Door Gate		Slope, cross	0.3%	Yes					n/a	$ -	
F15944	Children and Family Center		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Clear opening	40	Yes					n/a	$ -	
F07383	City View Park		Exterior	Owned	Play Area		1-Public Unsupervised	Transfer		Clearance, parallel	99	Yes					n/a	$ -	
F07384	City View Park		Exterior	Owned	Play Area		1-Public Unsupervised	Transfer		Clearance, perpendicular	99	Yes					n/a	$ -	
F07385	City View Park		Exterior	Owned	Play Area		1-Public Unsupervised	Transfer		Depth, platform/step	14	Yes					n/a	$ -	
F07386	City View Park		Exterior	Owned	Play Area		1-Public Unsupervised	Component Entry	Swings	Height	23	Yes					n/a	$ -	
F07387	City View Park		Exterior	Owned	Play Area		1-Public Unsupervised	Transfer		Height, platform/step	16	Yes					n/a	$ -	
F07388	City View Park		Exterior	Owned	Play Area		1-Public Unsupervised	Transfer		Transfer support?	Y	Yes					n/a	$ -	
F07389	City View Park		Exterior	Owned	Play Area		1-Public Unsupervised	Transfer		Width, platform/step	28	Yes					n/a	$ -	
F15947	City View Park		Exterior	Owned	Walkway	From street parking to play area	1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F15948	City View Park		Exterior	Owned	Walkway	From street parking to play area	1-Public Unsupervised	Walking Surface		Width	72	Yes					n/a	$ -	
F04280	District Attorneys Building		Exterior	Owned	Loading Zone	Street Bus Stop	1-Public Unsupervised	Pullup Space		Clearance, vertical	84	Yes					n/a	$ -	
F04281	District Attorneys Building		Exterior	Owned	Loading Zone	Street Bus Stop	1-Public Unsupervised	Pullup Space		Firm, stable, slip resistant	Y	Yes					n/a	$ -	
F04282	District Attorneys Building		Exterior	Owned	Loading Zone	Street Bus Stop	1-Public Unsupervised	Pullup Space		Length	99	Yes					n/a	$ -	
F04283	District Attorneys Building		Exterior	Owned	Loading Zone	Street Bus Stop	1-Public Unsupervised	Pullup Space		Slope, cross	1.0%	Yes					n/a	$ -	
F04284	District Attorneys Building		Exterior	Owned	Loading Zone	Street Bus Stop	1-Public Unsupervised	Pullup Space		Width	99	Yes					n/a	$ -	
F04318	District Attorneys Building		Exterior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate	Main entrance	Closing speed	5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F04319	District Attorneys Building		Exterior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate	Main entrance	Opening force	Auto	Yes					n/a	$ -	
F04684	District Attorneys Building		Interior	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment	Roll-in	Control location	F	Yes					n/a	$ -	
F04685	District Attorneys Building		Interior	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment	Roll-in	Hand spray unit?	Y	Yes					n/a	$ -	
F04686	District Attorneys Building		Interior	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment	Roll-in	Height, shower control	41.5	Yes					n/a	$ -	
F04687	District Attorneys Building		Interior	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment	Roll-in	Length, hose	72	Yes					n/a	$ -	
F04688	District Attorneys Building		Interior	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment	Roll-in	Seat location	Rear	Yes					n/a	$ -	
F04696	District Attorneys Building		Interior	Owned	Locker Room	Women's	3-Employee Common	Shower Compartment		Control location	F	Yes					n/a	$ -	
F04697	District Attorneys Building		Interior	Owned	Locker Room	Women's	3-Employee Common	Shower Compartment		Height, shower control	42	Yes					n/a	$ -	
F04698	District Attorneys Building		Interior	Owned	Locker Room	Women's	3-Employee Common	Shower Compartment		Seat location	Rear	Yes					n/a	$ -	
F04699	District Attorneys Building		Interior	Owned	Locker Room	Women's	3-Employee Common	Shower Compartment		Seat type	F	Yes					n/a	$ -	
F05889	District Attorneys Building		Exterior	Owned	Parking Facility	East parking lot	3-Employee Common	Facility Specifications		Number, accessible	2	Yes					n/a	$ -	
F05890	District Attorneys Building		Exterior	Owned	Parking Facility	East parking lot	3-Employee Common	Facility Specifications		Number, total spaces	31	Yes					n/a	$ -	
F05891	District Attorneys Building		Exterior	Owned	Parking Facility	East parking lot	3-Employee Common	Facility Specifications		Number, van spaces	2	Yes					n/a	$ -	
F05924	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 3 space #1	Access aisle?	Y	Yes					n/a	$ -	
F05925	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 3 space #2	Access aisle?	Y	Yes					n/a	$ -	
F05926	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 3 space #3	Access aisle?	Y	Yes					n/a	$ -	
F05927	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Access aisle?	Y	Yes					n/a	$ -	
F05928	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Access aisle?	Y	Yes					n/a	$ -	
F05929	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Access aisle?	Y	Yes					n/a	$ -	
F05930	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Access aisle?	Y	Yes					n/a	$ -	
F05931	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 1 space #1	Access aisle?	Y	Yes					n/a	$ -	
F05932	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 1 space #2	Access aisle?	Y	Yes					n/a	$ -	
F05933	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 1 between spaces #1 & #2	Adjacent pathway?	Y	Yes					n/a	$ -	
F05934	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 3 between spaces #1 & #2	Firm, stable, slip resistant	Y	Yes					n/a	$ -	
F05935	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 3 space #1	Firm, stable, slip resistant	Y	Yes					n/a	$ -	
F05936	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 3 space #1	Height, sign	83.5	Yes					n/a	$ -	
F05937	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 3 space #2	Height, sign	81.5	Yes					n/a	$ -	
F05938	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 3 space #3	Height, sign	69.5	Yes					n/a	$ -	
F05939	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Height, sign	74	Yes					n/a	$ -	
F05940	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Height, sign	76	Yes					n/a	$ -	
F05941	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Height, sign	74	Yes					n/a	$ -	
F05942	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Height, sign	74	Yes					n/a	$ -	
F05943	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 1 space #1	Height, sign	73	Yes					n/a	$ -	
F05944	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 1 space #2	Height, sign	83	Yes					n/a	$ -	
F05945	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Facility Specifications		Number, accessible	9	Yes					n/a	$ -	
F05946	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Facility Specifications		Number, van spaces	5	Yes					n/a	$ -	
F05947	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 1 between spaces #1 & #2	Pathway behind cars?	N	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05948	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 3 space #1	Sign?	Y	Yes					n/a	$ -	
F05949	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 3 space #2	Sign?	Y	Yes					n/a	$ -	
F05950	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 3 space #3	Sign?	Y	Yes					n/a	$ -	
F05951	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Sign?	Y	Yes					n/a	$ -	
F05952	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Sign?	Y	Yes					n/a	$ -	
F05953	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Sign?	Y	Yes					n/a	$ -	
F05954	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Sign?	Y	Yes					n/a	$ -	
F05955	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 1 space #1	Sign?	Y	Yes					n/a	$ -	
F05956	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 1 space #2	Sign?	Y	Yes					n/a	$ -	
F05957	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 3 between spaces #1 & #2	Slope, cross	1.0%	Yes					n/a	$ -	
F05958	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 1 between spaces #1 & #2	Slope, cross	1.0%	Yes					n/a	$ -	
F05959	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 3 between spaces #5 & #6	Slope, cross	1.3%	Yes					n/a	$ -	
F05960	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 3 right of space #7	Slope, cross	1.3%	Yes					n/a	$ -	
F05961	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 3 between spaces #3 & #4	Slope, cross	1.6%	Yes					n/a	$ -	
F05962	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 3 space #1	Slope, cross	0.4%	Yes					n/a	$ -	
F05963	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 3 space #2	Slope, cross	0.4%	Yes					n/a	$ -	
F05964	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Slope, cross	0.7%	Yes					n/a	$ -	
F05965	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Slope, cross	0.8%	Yes					n/a	$ -	
F05966	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Slope, cross	1.0%	Yes					n/a	$ -	
F05967	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 1 space #2	Slope, cross	1.0%	Yes					n/a	$ -	
F05968	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 3 space #3	Slope, cross	1.1%	Yes					n/a	$ -	
F05969	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Slope, cross	1.1%	Yes					n/a	$ -	
F05970	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 1 space #1	Slope, cross	1.8%	Yes					n/a	$ -	
F05971	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 3 between spaces #1 & #2	Surface marking?	Y	Yes					n/a	$ -	
F05972	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 3 between spaces #3 & #4	Surface marking?	Y	Yes					n/a	$ -	
F05973	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 3 between spaces #5 & #6	Surface marking?	Y	Yes					n/a	$ -	
F05974	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 3 right of space #7	Surface marking?	Y	Yes					n/a	$ -	
F05975	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 1 between spaces #1 & #2	Surface marking?	Y	Yes					n/a	$ -	
F05976	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 3 space #1	Van sign?	N	Yes					n/a	$ -	
F05977	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 3 space #2	Van sign?	N	Yes					n/a	$ -	
F05978	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 3 space #3	Van sign?	Y	Yes					n/a	$ -	
F05979	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Van sign?	Y	Yes					n/a	$ -	
F05980	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Van sign?	Y	Yes					n/a	$ -	
F05981	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Van sign?	Y	Yes					n/a	$ -	
F05982	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Van sign?	Y	Yes					n/a	$ -	
F05983	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 1 between spaces #1 & #2	Width	62	Yes					n/a	$ -	
F05984	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 3 between spaces #3 & #4	Width	63	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05985	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 3 between spaces #5 & #6	Width	61	Yes					n/a	$ -	
F05986	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 3 right of space #7	Width	62	Yes					n/a	$ -	
F05987	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Access Aisle	Row 3 between spaces #1 & #2	Width	60	Yes					n/a	$ -	
F05988	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 1 space #1	Width	143	Yes					n/a	$ -	
F05989	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 1 space #2	Width	129	Yes					n/a	$ -	
F05990	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 3 space #1	Width	112	Yes					n/a	$ -	
F05991	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 3 space #2	Width	132	Yes					n/a	$ -	
F05992	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space	Row 3 space #3	Width	157	Yes					n/a	$ -	
F05993	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Width	143	Yes					n/a	$ -	
F05994	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Width	145	Yes					n/a	$ -	
F05995	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Width	141	Yes					n/a	$ -	
F05996	District Attorneys Building		Exterior	Owned	Parking Facility	North side of building	1-Public Unsupervised	Parking Space		Width	155	Yes					n/a	$ -	
F15954	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp at roundabout	1-Public Unsupervised	Curb Ramp		Accumulates water?	N	Yes					n/a	$ -	
F15955	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp at roundabout	1-Public Unsupervised	Landing		Clearance, parallel	60	Yes					n/a	$ -	
F15956	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp at roundabout	1-Public Unsupervised	Landing		Clearance, perpendicular	63	Yes					n/a	$ -	
F15957	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp at roundabout	1-Public Unsupervised	Curb Ramp		Firm, stable, slip resistant	Y	Yes					n/a	$ -	
F15958	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp at roundabout	1-Public Unsupervised	Curb Ramp		Landing, parallel dimension	60	Yes					n/a	$ -	
F15959	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp at roundabout	1-Public Unsupervised	Curb Ramp		Landing, perpendicular dimension	63	Yes					n/a	$ -	
F15960	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp at roundabout	1-Public Unsupervised	Curb Ramp		Slope, counter	3.6%	Yes					n/a	$ -	
F15961	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp at roundabout	1-Public Unsupervised	Landing		Slope, cross	0.9%	Yes					n/a	$ -	
F15962	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp at roundabout	1-Public Unsupervised	Curb Ramp		Slope, right flare	7.0%	Yes					n/a	$ -	
F15963	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp at roundabout	1-Public Unsupervised	Curb Ramp		Width	60	Yes					n/a	$ -	
F15966	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from roundabout to building entrance	1-Public Unsupervised	Curb Ramp		Accumulates water?	N	Yes					n/a	$ -	
F15967	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from roundabout to building entrance	1-Public Unsupervised	Curb Ramp		Firm, stable, slip resistant	Y	Yes					n/a	$ -	
F15968	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from roundabout to building entrance	1-Public Unsupervised	Curb Ramp		Landing, parallel dimension	72	Yes					n/a	$ -	
F15969	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from roundabout to building entrance	1-Public Unsupervised	Curb Ramp		Landing, perpendicular dimension	61	Yes					n/a	$ -	
F15970	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from roundabout to building entrance	1-Public Unsupervised	Curb Ramp		Slope, counter	1.0%	Yes					n/a	$ -	
F15971	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from roundabout to building entrance	1-Public Unsupervised	Curb Ramp		Slope, cross	0.7%	Yes					n/a	$ -	
F15972	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from roundabout to building entrance	1-Public Unsupervised	Landing		Slope, cross	0.9%	Yes					n/a	$ -	
F15973	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from roundabout to building entrance	1-Public Unsupervised	Curb Ramp		Slope, left flare	5.2%	Yes					n/a	$ -	
F15974	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from roundabout to building entrance	1-Public Unsupervised	Curb Ramp		Slope, right flare	7.0%	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15975	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from roundabout to building entrance	1-Public Unsupervised	Curb Ramp		Slope, running	8.3%	Yes					n/a	$ -	
F15976	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from roundabout to building entrance	1-Public Unsupervised	Curb Ramp		Width	72	Yes					n/a	$ -	
F15978	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 2 to main entry	1-Public Unsupervised	Curb Ramp		Accumulates water?	N	Yes					n/a	$ -	
F15979	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 2 to main entry	1-Public Unsupervised	Curb Ramp		Firm, stable, slip resistant	Y	Yes					n/a	$ -	
F15980	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 2 to main entry	1-Public Unsupervised	Curb Ramp		Landing, parallel dimension	60	Yes					n/a	$ -	
F15981	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 2 to main entry	1-Public Unsupervised	Curb Ramp		Landing, perpendicular dimension	70	Yes					n/a	$ -	
F15982	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 2 to main entry	1-Public Unsupervised	Curb Ramp		Slope, counter	0.4%	Yes					n/a	$ -	
F15983	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 2 to main entry	1-Public Unsupervised	Curb Ramp		Slope, cross	0.9%	Yes					n/a	$ -	
F15984	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 2 to main entry	1-Public Unsupervised	Landing		Slope, cross	0.3%	Yes					n/a	$ -	
F15985	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 2 to main entry	1-Public Unsupervised	Curb Ramp		Slope, left flare	6.1%	Yes					n/a	$ -	
F15986	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 2 to main entry	1-Public Unsupervised	Curb Ramp		Slope, right flare	9.8%	Yes					n/a	$ -	
F15987	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 2 to main entry	1-Public Unsupervised	Curb Ramp		Slope, running	7.8%	Yes					n/a	$ -	
F15988	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 2 to main entry	1-Public Unsupervised	Curb Ramp		Width	58	Yes					n/a	$ -	
F15991	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 2 to row 1	1-Public Unsupervised	Curb Ramp		Accumulates water?	N	Yes					n/a	$ -	
F15992	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 2 to row 1	1-Public Unsupervised	Curb Ramp		Firm, stable, slip resistant	Y	Yes					n/a	$ -	
F15993	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 2 to row 1	1-Public Unsupervised	Curb Ramp		Landing, parallel dimension	60	Yes					n/a	$ -	
F15994	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 2 to row 1	1-Public Unsupervised	Curb Ramp		Landing, perpendicular dimension	62	Yes					n/a	$ -	
F15995	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 2 to row 1	1-Public Unsupervised	Curb Ramp		Slope, cross	0.4%	Yes					n/a	$ -	
F15996	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 2 to row 1	1-Public Unsupervised	Landing		Slope, cross	0.3%	Yes					n/a	$ -	
F15997	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 2 to row 1	1-Public Unsupervised	Curb Ramp		Slope, left flare	8.4%	Yes					n/a	$ -	
F15998	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 2 to row 1	1-Public Unsupervised	Curb Ramp		Slope, right flare	7.2%	Yes					n/a	$ -	
F15999	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 2 to row 1	1-Public Unsupervised	Curb Ramp		Slope, running	4.9%	Yes					n/a	$ -	
F16000	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 2 to row 1	1-Public Unsupervised	Curb Ramp		Width	60	Yes					n/a	$ -	
F16003	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 3 to row 2	1-Public Unsupervised	Curb Ramp		Accumulates water?	N	Yes					n/a	$ -	
F16004	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 3 to row 2	1-Public Unsupervised	Curb Ramp		Firm, stable, slip resistant	Y	Yes					n/a	$ -	
F16005	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 3 to row 2	1-Public Unsupervised	Curb Ramp		Landing, parallel dimension	60	Yes					n/a	$ -	
F16006	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 3 to row 2	1-Public Unsupervised	Curb Ramp		Landing, perpendicular dimension	67	Yes					n/a	$ -	
F16007	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 3 to row 2	1-Public Unsupervised	Curb Ramp		Slope, counter	0.3%	Yes					n/a	$ -	
F16008	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 3 to row 2	1-Public Unsupervised	Curb Ramp		Slope, cross	1.6%	Yes					n/a	$ -	
F16009	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 3 to row 2	1-Public Unsupervised	Landing		Slope, cross	0.3%	Yes					n/a	$ -	
F16010	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 3 to row 2	1-Public Unsupervised	Curb Ramp		Slope, left flare	9.4%	Yes					n/a	$ -	
F16011	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 3 to row 2	1-Public Unsupervised	Curb Ramp		Slope, right flare	9.1%	Yes					n/a	$ -	
F16012	District Attorneys Building		Exterior	Owned	Walkway	Curb ramp from row 3 to row 2	1-Public Unsupervised	Curb Ramp		Width	60	Yes					n/a	$ -	
F16014	District Attorneys Building		Exterior	Owned	Walkway	From accessible path to East entry	1-Public Unsupervised	Walking Surface		Firm, stable, slip resistant	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16015	District Attorneys Building		Exterior	Owned	Walkway	From accessible path to East entry	1-Public Unsupervised	Walking Surface		Slope, cross	0.3%	Yes					n/a	$ -	
F16016	District Attorneys Building		Exterior	Owned	Walkway	From accessible path to East entry	1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F16017	District Attorneys Building		Exterior	Owned	Walkway	From accessible path to East entry	1-Public Unsupervised	Walking Surface		Width	55	Yes					n/a	$ -	
F16019	District Attorneys Building		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface		Firm, stable, slip resistant	Y	Yes					n/a	$ -	
F16020	District Attorneys Building		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface		Slope, running	2.2%	Yes					n/a	$ -	
F16021	District Attorneys Building		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F16022	District Attorneys Building		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface		Width	72	Yes					n/a	$ -	
F16024	District Attorneys Building		Exterior	Owned	Walkway	From roundabout to Main entrance	1-Public Unsupervised	Walking Surface		Firm, stable, slip resistant	Y	Yes					n/a	$ -	
F16025	District Attorneys Building		Exterior	Owned	Walkway	From roundabout to Main entrance	1-Public Unsupervised	Walking Surface		Slope, running	4.8%	Yes					n/a	$ -	
F16026	District Attorneys Building		Exterior	Owned	Walkway	From roundabout to Main entrance	1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F16027	District Attorneys Building		Exterior	Owned	Walkway	From roundabout to Main entrance	1-Public Unsupervised	Walking Surface		Width	99	Yes					n/a	$ -	
F16029	District Attorneys Building		Exterior	Owned	Walkway	From street sidewalk to roundabout	1-Public Unsupervised	Walking Surface		Firm, stable, slip resistant	Y	Yes					n/a	$ -	
F16030	District Attorneys Building		Exterior	Owned	Walkway	From street sidewalk to roundabout	1-Public Unsupervised	Walking Surface		Slope, cross	1.4%	Yes					n/a	$ -	
F16031	District Attorneys Building		Exterior	Owned	Walkway	From street sidewalk to roundabout	1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F16032	District Attorneys Building		Exterior	Owned	Walkway	From street sidewalk to roundabout	1-Public Unsupervised	Walking Surface		Width	60	Yes					n/a	$ -	
F16036	District Attorneys Building		Exterior	Owned	Walkway		1-Public Unsupervised	Walking Surface	From parking lot to main entrance	Firm, stable, slip resistant	Y	Yes					n/a	$ -	
F16037	District Attorneys Building		Exterior	Owned	Walkway		1-Public Unsupervised	Walking Surface	From parking lot to main entrance	Surface material	Concrete	Yes					n/a	$ -	
F16038	District Attorneys Building		Exterior	Owned	Walkway		1-Public Unsupervised	Walking Surface	From parking lot to main entrance	Width	60	Yes					n/a	$ -	
F03522	Elaine Valente Open Space		Exterior	Owned	Fishing Pier	2nd Pier - Far side	1-Public Unsupervised	Railing		Length, 34 inch max. railing	40 feet	Yes					n/a	$ -	
F03523	Elaine Valente Open Space		Exterior	Owned	Fishing Pier	2nd Pier - Far side	1-Public Unsupervised	Railing		Length, total railing	40 feet	Yes					n/a	$ -	
F03524	Elaine Valente Open Space		Exterior	Owned	Fishing Pier	2nd Pier - Far side	1-Public Unsupervised	Railing		Lowered sections dispersed?	Y	Yes					n/a	$ -	
F03528	Elaine Valente Open Space		Exterior	Owned	Fishing Pier		1-Public Unsupervised	Edge Protection		Dimension, deck extension	OK	Yes					n/a	$ -	
F03529	Elaine Valente Open Space		Exterior	Owned	Fishing Pier		1-Public Unsupervised	Edge Protection		Height, curb	10	Yes					n/a	$ -	
F03530	Elaine Valente Open Space		Exterior	Owned	Fishing Pier		1-Public Unsupervised	Edge Protection		Other attribute	OK	Yes					n/a	$ -	
F06002	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Access aisle?	Y	Yes					n/a	$ -	
F06003	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Adjacent pathway?	Y	Yes					n/a	$ -	
F06004	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Cars obstruct pathway	N	Yes					n/a	$ -	
F06005	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Height, sign	78	Yes					n/a	$ -	
F06006	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Height, sign	75	Yes					n/a	$ -	
F06007	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Length	OK	Yes					n/a	$ -	
F06008	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, accessible	2	Yes					n/a	$ -	
F06009	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Sign?	Y	Yes					n/a	$ -	
F06010	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Sign?	Y	Yes					n/a	$ -	
F06011	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Slope, cross	0.1%	Yes					n/a	$ -	
F06012	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Slope, cross	0.7%	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06013	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Slope, cross	1.5%	Yes					n/a	$ -	
F06014	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Slope, running	2.0%	Yes					n/a	$ -	
F06015	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Slope, running	1.0%	Yes					n/a	$ -	
F06016	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Slope, running	0.8%	Yes					n/a	$ -	
F06017	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Surface marking?	Y	Yes					n/a	$ -	
F06018	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Surface material	Concrete	Yes					n/a	$ -	
F06019	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Surface material	Asphalt	Yes					n/a	$ -	
F06020	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Van sign?	N	Yes					n/a	$ -	
F06021	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Width	62	Yes					n/a	$ -	
F06022	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Width	112	Yes					n/a	$ -	
F06023	Elaine Valente Open Space		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Width	110	Yes					n/a	$ -	
F10558	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Clear opening	33.5	Yes					n/a	$ -	
F10559	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Water Closet		Clearance, parallel	61.5	Yes					n/a	$ -	
F10560	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Water Closet		Clearance, perpendicular	86	Yes					n/a	$ -	
F10561	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F10562	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F10563	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Clearance, push parallel	18	Yes					n/a	$ -	
F10564	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	87	Yes					n/a	$ -	
F10565	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F10566	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F10567	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F10568	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F10569	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Signage		Dimension, characters	1	Yes					n/a	$ -	
F10570	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	2	Yes					n/a	$ -	
F10571	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F10572	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Water Closet		Dimension, wide side	43	Yes					n/a	$ -	
F10573	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F10574	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Coat Hook		Height	42	Yes					n/a	$ -	
F10575	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Dispenser	TP	Height	26	Yes					n/a	$ -	
F10576	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Signage		Height, bottom	49	Yes					n/a	$ -	
F10578	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Grab Bar	Side	Height, top	34	Yes					n/a	$ -	
F10579	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Grab Bar	Rear	Height, top	34	Yes					n/a	$ -	
F10580	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F10581	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Grab Bar	Side	Length	52	Yes					n/a	$ -	
F10582	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Grab Bar	Rear	Length	40	Yes					n/a	$ -	
F10583	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F10584	Elaine Valente Open Space		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Opening force	3	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16040	Elaine Valente Open Space		Exterior	Owned	Walkway	From parking lot to Pier	1-Public Unsupervised	Walking Surface		Slope, cross	0.0%	Yes					n/a	$ -	
F16041	Elaine Valente Open Space		Exterior	Owned	Walkway	From parking lot to Pier	1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F16042	Elaine Valente Open Space		Exterior	Owned	Walkway	From parking lot to Pier	1-Public Unsupervised	Walking Surface		Width	120	Yes					n/a	$ -	
F16043	Elaine Valente Open Space		Exterior	Owned	Walkway	To fishing pier #2	1-Public Unsupervised	Walking Surface		Width	72	Yes					n/a	$ -	
F16044	Elaine Valente Open Space		Exterior	Owned	Walkway		1-Public Unsupervised	Walking Surface	No curb cut from parking lot	Slope, cross	0.8%	Yes					n/a	$ -	
F16045	Elaine Valente Open Space		Exterior	Owned	Walkway		1-Public Unsupervised	Walking Surface	No curb cut from parking lot	Slope, running	3.0%	Yes					n/a	$ -	
F16046	Elaine Valente Open Space		Exterior	Owned	Walkway		1-Public Unsupervised	Walking Surface	No curb cut from parking lot	Width	95	Yes					n/a	$ -	
F16047	Elaine Valente Open Space		Exterior	Owned	Walkway		1-Public Unsupervised	Walking Surface	No curb cut from parking lot	Width, opening	OK	Yes					n/a	$ -	
F03779	Facilities Mgmt's Storage Facility		Interior	Owned	Hallway		2-Public Supervised	Door Gate	To restrooms	Clear opening	34	Yes					n/a	$ -	
F03780	Facilities Mgmt's Storage Facility		Interior	Owned	Hallway		2-Public Supervised	Door Gate	To restrooms	Clearance, pull parallel	99	Yes					n/a	$ -	
F03781	Facilities Mgmt's Storage Facility		Interior	Owned	Hallway		2-Public Supervised	Door Gate	To restrooms	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F03782	Facilities Mgmt's Storage Facility		Interior	Owned	Hallway		2-Public Supervised	Door Gate	To restrooms	Clearance, push parallel	14	Yes					n/a	$ -	
F03783	Facilities Mgmt's Storage Facility		Interior	Owned	Hallway		2-Public Supervised	Door Gate	To restrooms	Clearance, push perpendicular	99	Yes					n/a	$ -	
F03784	Facilities Mgmt's Storage Facility		Interior	Owned	Hallway		2-Public Supervised	Door Gate	To restrooms	Clearance, vertical	83.5	Yes					n/a	$ -	
F04701	Facilities Mgmt's Storage Facility		Interior	Owned	Locker Room		3-Employee Common	Bench		Height	17	Yes					n/a	$ -	
F04702	Facilities Mgmt's Storage Facility		Interior	Owned	Locker Room		3-Employee Common	Bench		Length	34.25	Yes					n/a	$ -	
F10605	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Door Gate		Clear opening	34	Yes					n/a	$ -	
F10606	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Lavatory Sink		Clearance, perpendicular	48	Yes					n/a	$ -	
F10607	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Door Gate		Clearance, push parallel	29.5	Yes					n/a	$ -	
F10608	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F10609	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F10610	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Grab Bar	Side	Diameter	1.25	Yes					n/a	$ -	
F10611	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Dispenser	TP	Dimension from water closet seat	8	Yes					n/a	$ -	
F10612	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	30	Yes					n/a	$ -	
F10613	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F10614	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F10615	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Shower Compartment		Hand spray unit?	Y	Yes					n/a	$ -	
F10616	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F10617	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Dispenser	Soap	Height	46	Yes					n/a	$ -	
F10618	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Water Closet		Height, flush control	17.75	Yes					n/a	$ -	
F10619	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Shower Compartment		Height, shower control	42	Yes					n/a	$ -	
F10620	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Shower Compartment		Threshold beveled?	Y	Yes					n/a	$ -	
F10621	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Grab Bar	Side	Height, top	35.25	Yes					n/a	$ -	
F10622	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F10623	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Shower Compartment		Length, hose	60	Yes					n/a	$ -	
F10624	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Fixture Count		Number, toilet compartments	1	Yes					n/a	$ -	
F10625	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Fixture Count		Number, urinals	1	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10626	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Shower Compartment		Seat location	S	Yes					n/a	$ -	
F10627	Facilities Mgmt's Storage Facility		Interior	Owned	Restroom	Unisex	2-Public Supervised	Shower Compartment		Seat type	F	Yes					n/a	$ -	
F15577	Facilities Mgmt's Storage Facility		Interior	Owned	Shower Room		2-Public Supervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F15578	Facilities Mgmt's Storage Facility		Interior	Owned	Shower Room		2-Public Supervised	Grab Bar		Height, top	35.75	Yes					n/a	$ -	
F15579	Facilities Mgmt's Storage Facility		Interior	Owned	Shower Room		2-Public Supervised	Grab Bar	Side	Height, top	35.75	Yes					n/a	$ -	
F15580	Facilities Mgmt's Storage Facility		Interior	Owned	Shower Room		2-Public Supervised	Grab Bar		Length	32	Yes					n/a	$ -	
F15581	Facilities Mgmt's Storage Facility		Interior	Owned	Shower Room		2-Public Supervised	Grab Bar	Side	Length	17	Yes					n/a	$ -	
F16051	Facilities Mgmt's Storage Facility		Exterior	Owned	Walkway		2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F16052	Facilities Mgmt's Storage Facility		Exterior	Owned	Walkway		2-Public Supervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F16053	Facilities Mgmt's Storage Facility		Exterior	Owned	Walkway		2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F16054	Facilities Mgmt's Storage Facility		Exterior	Owned	Walkway		2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F16055	Facilities Mgmt's Storage Facility		Exterior	Owned	Walkway		2-Public Supervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F16056	Facilities Mgmt's Storage Facility		Exterior	Owned	Walkway		2-Public Supervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F00123	Government Center		Interior	Owned	Assembly Area	Hearing Room	2-Public Supervised	Door Gate	East doors to seating area	Clear opening	33.5	Yes					n/a	$ -	
F00124	Government Center		Interior	Owned	Assembly Area	Hearing Room	2-Public Supervised	Door Gate	East doors to seating area	Closing speed	5	Yes					n/a	$ -	
F00125	Government Center		Interior	Owned	Assembly Area	Hearing Room	2-Public Supervised	Seating Area		Number, wheelchair spaces	12	Yes					n/a	$ -	
F00423	Government Center		Interior	Owned	Break Room	#C2508	3-Employee Common	Counter		Height	34	Yes					n/a	$ -	
F00424	Government Center		Interior	Owned	Break Room	#C2516	3-Employee Common	Counter		Height	34	Yes					n/a	$ -	
F00427	Government Center		Interior	Owned	Break Room	#C5508	3-Employee Common	Counter		Height	34	Yes					n/a	$ -	
F00431	Government Center		Interior	Owned	Break Room	#W1014	3-Employee Common	Door Gate		Closing speed	8	Yes					n/a	$ -	
F00439	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Door Gate		Clear opening	39	Yes					n/a	$ -	
F00440	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Appliance	Dishwasher	Clearance, parallel	99	Yes					n/a	$ -	
F00441	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Appliance	Ice machine	Clearance, parallel	99	Yes					n/a	$ -	
F00442	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Appliance	Viking refrigerator	Clearance, parallel	60	Yes					n/a	$ -	
F00443	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Appliance	Refrigerator	Clearance, parallel	72	Yes					n/a	$ -	
F00444	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Appliance	Microwave	Clearance, parallel	99	Yes					n/a	$ -	
F00445	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F00446	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	99	Yes					n/a	$ -	
F00447	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Operable Part	Faucets	Clearance, parallel	99	Yes					n/a	$ -	
F00448	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Table		Clearance, parallel	48	Yes					n/a	$ -	
F00449	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Appliance	Dishwasher	Clearance, perpendicular	48	Yes					n/a	$ -	
F00450	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Appliance	Ice machine	Clearance, perpendicular	48	Yes					n/a	$ -	
F00451	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Appliance	Refrigerator	Clearance, perpendicular	48	Yes					n/a	$ -	
F00452	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Appliance	Microwave	Clearance, perpendicular	48	Yes					n/a	$ -	
F00453	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Counter		Clearance, perpendicular	48	Yes					n/a	$ -	
F00454	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	48	Yes					n/a	$ -	
F00455	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Operable Part	Faucets	Clearance, perpendicular	48	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00456	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Table		Clearance, perpendicular	48	Yes					n/a	$ -	
F00457	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F00458	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	60	Yes					n/a	$ -	
F00459	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F00460	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F00461	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Door Gate		Clearance, vertical	92	Yes					n/a	$ -	
F00462	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Appliance	Dishwasher	Control force	2	Yes					n/a	$ -	
F00463	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Appliance	Ice machine	Control force	2	Yes					n/a	$ -	
F00464	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Appliance	Viking refrigerator	Control force	5	Yes					n/a	$ -	
F00465	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Appliance	Refrigerator	Control force	5	Yes					n/a	$ -	
F00466	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Appliance	Microwave	Control force	2	Yes					n/a	$ -	
F00467	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Operable Part	Faucets	Control force	2	Yes					n/a	$ -	
F00468	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	In cabinet	Yes					n/a	$ -	
F00469	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Door Gate		Hardware type	OK	Yes					n/a	$ -	
F00470	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F00471	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Appliance	Dishwasher	Height	34	Yes					n/a	$ -	
F00472	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Appliance	Ice machine	Height	32	Yes					n/a	$ -	
F00473	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Appliance	Viking refrigerator	Height	34	Yes					n/a	$ -	
F00474	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Appliance	Refrigerator	Height	36	Yes					n/a	$ -	
F00475	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Appliance	Microwave	Height	36	Yes					n/a	$ -	
F00476	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Counter		Height	34	Yes					n/a	$ -	
F00477	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F00478	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Operable Part	Faucets	Height	36.5	Yes					n/a	$ -	
F00479	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Table		Height	29	Yes					n/a	$ -	
F00480	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Door Gate		Height, hardware	38	Yes					n/a	$ -	
F00481	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Table		Height, knee clearance	27	Yes					n/a	$ -	
F00482	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Counter		Length	72	Yes					n/a	$ -	
F00483	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Door Gate		Opening force	3	Yes					n/a	$ -	
F00484	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Operable Part	Faucets	Other attribute	19.5	Yes					n/a	$ -	
F00485	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F00487	Government Center		Interior	Owned	Break Room	#W8205 - Catering/Pantry	3-Employee Common	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F00488	Government Center		Interior	Owned	Break Room	#W8205 - Catering/Pantry	3-Employee Common	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F00489	Government Center		Interior	Owned	Break Room	#W8205 - Catering/Pantry	3-Employee Common	Door Gate		Closing speed	6	Yes					n/a	$ -	
F00490	Government Center		Interior	Owned	Break Room	#W8205 - Catering/Pantry	3-Employee Common	Counter		Dimension, knee clearance	34.5	Yes					n/a	$ -	
F00491	Government Center		Interior	Owned	Break Room	#W8205 - Catering/Pantry	3-Employee Common	Counter		Length	99	Yes					n/a	$ -	
F00492	Government Center		Interior	Owned	Break Room	#W5521	1-Public Unsupervised	Door Gate		Threshold beveled?	Y	Yes					n/a	$ -	
F00811	Government Center		Interior	Owned	Cafeteria		1-Public Unsupervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00812	Government Center		Interior	Owned	Cafeteria		1-Public Unsupervised	Table		Clearance, parallel	99	Yes					n/a	$ -	
F00813	Government Center		1st Floor	Owned	Cafeteria		1-Public Unsupervised	Vending Machine	Coke	Clearance, parallel	99	Yes					n/a	$ -	
F00814	Government Center		1st Floor	Owned	Cafeteria		1-Public Unsupervised	Vending Machine	Snacks	Clearance, parallel	99	Yes					n/a	$ -	
F00815	Government Center		1st Floor	Owned	Cafeteria		1-Public Unsupervised	Vending Machine	Aquafina	Clearance, parallel	99	Yes					n/a	$ -	
F00816	Government Center		1st Floor	Owned	Cafeteria		1-Public Unsupervised	Vending Machine	Ice cream	Clearance, parallel	99	Yes					n/a	$ -	
F00817	Government Center		1st Floor	Owned	Cafeteria		1-Public Unsupervised	Vending Machine	Newspaper (2)	Clearance, parallel	99	Yes					n/a	$ -	
F00818	Government Center		1st Floor	Owned	Cafeteria		1-Public Unsupervised	Vending Machine	ATM	Clearance, parallel	99	Yes					n/a	$ -	
F00819	Government Center		Interior	Owned	Cafeteria		1-Public Unsupervised	Counter		Clearance, perpendicular	60	Yes					n/a	$ -	
F00820	Government Center		Interior	Owned	Cafeteria		1-Public Unsupervised	Table		Clearance, perpendicular	99	Yes					n/a	$ -	
F00821	Government Center		1st Floor	Owned	Cafeteria		1-Public Unsupervised	Vending Machine	Coke	Clearance, perpendicular	99	Yes					n/a	$ -	
F00822	Government Center		1st Floor	Owned	Cafeteria		1-Public Unsupervised	Vending Machine	Snacks	Clearance, perpendicular	99	Yes					n/a	$ -	
F00823	Government Center		1st Floor	Owned	Cafeteria		1-Public Unsupervised	Vending Machine	Aquafina	Clearance, perpendicular	99	Yes					n/a	$ -	
F00824	Government Center		1st Floor	Owned	Cafeteria		1-Public Unsupervised	Vending Machine	Ice cream	Clearance, perpendicular	99	Yes					n/a	$ -	
F00825	Government Center		1st Floor	Owned	Cafeteria		1-Public Unsupervised	Vending Machine	Newspaper (2)	Clearance, perpendicular	99	Yes					n/a	$ -	
F00826	Government Center		1st Floor	Owned	Cafeteria		1-Public Unsupervised	Vending Machine	ATM	Clearance, perpendicular	99	Yes					n/a	$ -	
F00827	Government Center		1st Floor	Owned	Cafeteria		1-Public Unsupervised	Vending Machine	Coke	Control force	2	Yes					n/a	$ -	
F00828	Government Center		1st Floor	Owned	Cafeteria		1-Public Unsupervised	Vending Machine	Snacks	Control force	2	Yes					n/a	$ -	
F00829	Government Center		1st Floor	Owned	Cafeteria		1-Public Unsupervised	Vending Machine	Aquafina	Control force	2	Yes					n/a	$ -	
F00830	Government Center		1st Floor	Owned	Cafeteria		1-Public Unsupervised	Vending Machine	Ice cream	Control force	2	Yes					n/a	$ -	
F00831	Government Center		1st Floor	Owned	Cafeteria		1-Public Unsupervised	Vending Machine	Newspaper (2)	Control force	2	Yes					n/a	$ -	
F00832	Government Center		1st Floor	Owned	Cafeteria		1-Public Unsupervised	Vending Machine	ATM	Control force	2	Yes					n/a	$ -	
F00833	Government Center		Interior	Owned	Cafeteria		1-Public Unsupervised	Counter		Height	34	Yes					n/a	$ -	
F00834	Government Center		Interior	Owned	Cafeteria		1-Public Unsupervised	Table		Height	29.5	Yes					n/a	$ -	
F00835	Government Center		1st Floor	Owned	Cafeteria		1-Public Unsupervised	Vending Machine	Coke	Height, control	47	Yes					n/a	$ -	
F00836	Government Center		1st Floor	Owned	Cafeteria		1-Public Unsupervised	Vending Machine	Aquafina	Height, control	47	Yes					n/a	$ -	
F00837	Government Center		1st Floor	Owned	Cafeteria		1-Public Unsupervised	Vending Machine	Ice cream	Height, control	31	Yes					n/a	$ -	
F00838	Government Center		1st Floor	Owned	Cafeteria		1-Public Unsupervised	Vending Machine	Newspaper (2)	Height, control	45	Yes					n/a	$ -	
F00839	Government Center		1st Floor	Owned	Cafeteria		1-Public Unsupervised	Vending Machine	ATM	Height, control	48	Yes					n/a	$ -	
F00840	Government Center		Interior	Owned	Cafeteria		1-Public Unsupervised	Table		Height, knee clearance	28	Yes					n/a	$ -	
F00841	Government Center		Interior	Owned	Cafeteria		1-Public Unsupervised	Counter		Length	36	Yes					n/a	$ -	
F00842	Government Center		Interior	Owned	Cafeteria		1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F00936	Government Center		Interior	Owned	Conference Room	#W8101	2-Public Supervised	Door Gate		Closing speed	7	Yes					n/a	$ -	
F00950	Government Center		Interior	Owned	Conference Room	#W8302	2-Public Supervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F00951	Government Center		Interior	Owned	Conference Room	#W8302	2-Public Supervised	Door Gate		Clearance, pull parallel	48	Yes					n/a	$ -	
F00952	Government Center		Interior	Owned	Conference Room	#W8302	2-Public Supervised	Door Gate		Clearance, pull perpendicular	72	Yes					n/a	$ -	
F00953	Government Center		Interior	Owned	Conference Room	#W8302	2-Public Supervised	Door Gate		Clearance, push parallel	48	Yes					n/a	$ -	
F00954	Government Center		Interior	Owned	Conference Room	#W8302	2-Public Supervised	Door Gate		Clearance, push perpendicular	60	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00955	Government Center		Interior	Owned	Conference Room	#W8302	2-Public Supervised	Door Gate		Clearance, vertical	99	Yes					n/a	$ -	
F00956	Government Center		Interior	Owned	Conference Room	#W8302	2-Public Supervised	Door Gate		Closing speed	7	Yes					n/a	$ -	
F00957	Government Center		Interior	Owned	Conference Room	#W8302	2-Public Supervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F00958	Government Center		Interior	Owned	Conference Room	#W8302	2-Public Supervised	Door Gate		Height, hardware	39	Yes					n/a	$ -	
F00959	Government Center		Interior	Owned	Conference Room	#W8302	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	10	Yes					n/a	$ -	
F00960	Government Center		Interior	Owned	Conference Room	#W8302	2-Public Supervised	Seating Area		Number, wheelchair spaces	14	Yes					n/a	$ -	
F00961	Government Center		Interior	Owned	Conference Room	#W8302	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F00963	Government Center		Interior	Owned	Conference Room	#W8305	2-Public Supervised	Door Gate		Closing speed	6	Yes					n/a	$ -	
F00965	Government Center		Interior	Owned	Conference Room	#W8307	2-Public Supervised	Door Gate		Closing speed	7	Yes					n/a	$ -	
F00967	Government Center		Interior	Owned	Conference Room	#W8309	2-Public Supervised	Door Gate		Closing speed	11	Yes					n/a	$ -	
F00969	Government Center		Interior	Owned	Conference Room	#W8311	2-Public Supervised	Door Gate		Closing speed	11	Yes					n/a	$ -	
F00971	Government Center		Interior	Owned	Conference Room	#W8401	2-Public Supervised	Door Gate		Closing speed	10	Yes					n/a	$ -	
F00977	Government Center		Interior	Owned	Conference Room	#W8501	2-Public Supervised	Door Gate		Clearance, pull parallel	28	Yes					n/a	$ -	
F00978	Government Center		Interior	Owned	Conference Room	#W8501	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F00979	Government Center		Interior	Owned	Conference Room	#W8501	2-Public Supervised	Door Gate		Clearance, push parallel	28	Yes					n/a	$ -	
F00980	Government Center		Interior	Owned	Conference Room	#W8501	2-Public Supervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F00981	Government Center		Interior	Owned	Conference Room	#W8501	2-Public Supervised	Door Gate		Closing speed	7	Yes					n/a	$ -	
F00982	Government Center		Interior	Owned	Conference Room	#W8501	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F00986	Government Center		Interior	Owned	Conference Room	#W8503/W8304	2-Public Supervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F00987	Government Center		Interior	Owned	Conference Room	#W8503/W8304	2-Public Supervised	Door Gate		Clearance, pull parallel	42	Yes					n/a	$ -	
F00988	Government Center		Interior	Owned	Conference Room	#W8503/W8304	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F00989	Government Center		Interior	Owned	Conference Room	#W8503/W8304	2-Public Supervised	Door Gate		Clearance, push parallel	42	Yes					n/a	$ -	
F00990	Government Center		Interior	Owned	Conference Room	#W8503/W8304	2-Public Supervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F00991	Government Center		Interior	Owned	Conference Room	#W8503/W8304	2-Public Supervised	Door Gate		Closing speed	6	Yes					n/a	$ -	
F00992	Government Center		Interior	Owned	Conference Room	#W8503/W8304	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F00993	Government Center		Interior	Owned	Conference Room	#W8508	2-Public Supervised	Door Gate		Closing speed	7	Yes					n/a	$ -	
F03034	Government Center		Interior	Owned	Elevator	#1 - #3 elevator	1-Public Unsupervised	Elevator Door		Clear opening	42	Yes					n/a	$ -	
F03035	Government Center		Interior	Owned	Elevator	#1 - #3 elevator	1-Public Unsupervised	Elevator Door		Closing speed	8	Yes					n/a	$ -	
F03036	Government Center		Interior	Owned	Elevator	#1 - #3 elevator	1-Public Unsupervised	Elevator Door		Distance to door	17.75	Yes					n/a	$ -	
F03037	Government Center		Interior	Owned	Elevator	#1 - #3 elevator	1-Public Unsupervised	Elevator Door		Reopen device?	Y	Yes					n/a	$ -	
F03040	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Elevator Car		Audible signal?	Y	Yes					n/a	$ -	
F03041	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Position Indicators		Audible signal?	Y	Yes					n/a	$ -	
F03042	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Car Controls		Braille instructions	Y	Yes					n/a	$ -	
F03043	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Handrail		Clearance to wall	1.75	Yes					n/a	$ -	
F03044	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Call Control		Clearance, parallel	99	Yes					n/a	$ -	
F03045	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Call Control		Clearance, perpendicular	99	Yes					n/a	$ -	
F03046	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Handrail		Continuous?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F03047	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Elevator Car		Dimension, back to front	70.5	Yes					n/a	$ -	
F03048	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Elevator Car		Dimension, gap	1.25	Yes					n/a	$ -	
F03049	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Elevator Car		Dimension, side to side	81	Yes					n/a	$ -	
F03050	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Car Controls		Height, bottom	38.5	Yes					n/a	$ -	
F03051	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Call Control		Height, top	42.5	Yes					n/a	$ -	
F03052	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Car Controls		Height, top	43.5	Yes					n/a	$ -	
F03053	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Handrail		Height, top	32	Yes					n/a	$ -	
F03054	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Car Controls		Lighted?	Y	Yes					n/a	$ -	
F03055	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Position Indicators		Location	Both sides	Yes					n/a	$ -	
F03056	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Handrail		Rotates?	N	Yes					n/a	$ -	
F03057	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Call Control		Size	1	Yes					n/a	$ -	
F03058	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Car Controls		Size	1	Yes					n/a	$ -	
F03059	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Position Indicators		Size	2	Yes					n/a	$ -	
F03060	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Car Controls		Star?	Y	Yes					n/a	$ -	
F03061	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Car Controls		Tactile?	Y	Yes					n/a	$ -	
F03062	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Call Control		Up above down?	Y	Yes					n/a	$ -	
F03063	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Call Control		Visible signal?	Y	Yes					n/a	$ -	
F03064	Government Center		Interior	Owned	Elevator	#3	1-Public Unsupervised	Position Indicators		Visible signal?	Y	Yes					n/a	$ -	
F03065	Government Center		Interior	Owned	Elevator	#4	1-Public Unsupervised	Hoistway Sign		All floors?	Y	Yes					n/a	$ -	
F03066	Government Center		Interior	Owned	Elevator	#4	1-Public Unsupervised	Hall Signal		Audible signal?	Y	Yes					n/a	$ -	
F03067	Government Center		Interior	Owned	Elevator	#4	1-Public Unsupervised	Hoistway Sign		Both jambs?	Y	Yes					n/a	$ -	
F03068	Government Center		Interior	Owned	Elevator	#4	1-Public Unsupervised	Hoistway Sign		Braille?	Y	Yes					n/a	$ -	
F03069	Government Center		Interior	Owned	Elevator	#4	1-Public Unsupervised	Call Control		Clearance, parallel	99	Yes					n/a	$ -	
F03070	Government Center		Interior	Owned	Elevator	#4	1-Public Unsupervised	Call Control		Clearance, perpendicular	99	Yes					n/a	$ -	
F03071	Government Center		Interior	Owned	Elevator	#4	1-Public Unsupervised	Hall Signal		Height, center	99	Yes					n/a	$ -	
F03072	Government Center		Interior	Owned	Elevator	#4	1-Public Unsupervised	Call Control		Height, top	42.5	Yes					n/a	$ -	
F03073	Government Center		Interior	Owned	Elevator	#4	1-Public Unsupervised	Call Control		Size	1	Yes					n/a	$ -	
F03074	Government Center		Interior	Owned	Elevator	#4	1-Public Unsupervised	Hall Signal		Size	2	Yes					n/a	$ -	
F03075	Government Center		Interior	Owned	Elevator	#4	1-Public Unsupervised	Hoistway Sign		Tactile letters?	Y	Yes					n/a	$ -	
F03076	Government Center		Interior	Owned	Elevator	#4	1-Public Unsupervised	Call Control		Up above down?	Y	Yes					n/a	$ -	
F03077	Government Center		Interior	Owned	Elevator	#4	1-Public Unsupervised	Call Control		Visible signal?	Y	Yes					n/a	$ -	
F03081	Government Center		Interior	Owned	Elevator	#4 - Freight elevator	1-Public Unsupervised	Elevator Car		Audible signal?	Y	Yes					n/a	$ -	
F03082	Government Center		Interior	Owned	Elevator	#4 - Freight elevator	1-Public Unsupervised	Position Indicators		Audible signal?	Y	Yes					n/a	$ -	
F03083	Government Center		Interior	Owned	Elevator	#4 - Freight elevator	1-Public Unsupervised	Elevator Door		Clear opening	54	Yes					n/a	$ -	
F03084	Government Center		Interior	Owned	Elevator	#4 - Freight elevator	1-Public Unsupervised	Handrail		Clearance to wall	1.75	Yes					n/a	$ -	
F03085	Government Center		Interior	Owned	Elevator	#4 - Freight elevator	1-Public Unsupervised	Handrail		Continuous?	Y	Yes					n/a	$ -	
F03086	Government Center		Interior	Owned	Elevator	#4 - Freight elevator	1-Public Unsupervised	Elevator Car		Dimension, back to front	112	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F03087	Government Center		Interior	Owned	Elevator	#4 - Freight elevator	1-Public Unsupervised	Elevator Car		Dimension, gap	1.25	Yes					n/a	$ -	
F03088	Government Center		Interior	Owned	Elevator	#4 - Freight elevator	1-Public Unsupervised	Elevator Car		Dimension, side to side	69	Yes					n/a	$ -	
F03089	Government Center		Interior	Owned	Elevator	#4 - Freight elevator	1-Public Unsupervised	Emergency Communications		Height, bottom	31	Yes					n/a	$ -	
F03090	Government Center		Interior	Owned	Elevator	#4 - Freight elevator	1-Public Unsupervised	Emergency Communications		Height, top	32.5	Yes					n/a	$ -	
F03091	Government Center		Interior	Owned	Elevator	#4 - Freight elevator	1-Public Unsupervised	Handrail		Height, top	32	Yes					n/a	$ -	
F03092	Government Center		Interior	Owned	Elevator	#4 - Freight elevator	1-Public Unsupervised	Position Indicators		Location	Both sides	Yes					n/a	$ -	
F03093	Government Center		Interior	Owned	Elevator	#4 - Freight elevator	1-Public Unsupervised	Emergency Communications		Provided?	Y	Yes					n/a	$ -	
F03094	Government Center		Interior	Owned	Elevator	#4 - Freight elevator	1-Public Unsupervised	Elevator Door		Reopen device?	Y	Yes					n/a	$ -	
F03095	Government Center		Interior	Owned	Elevator	#4 - Freight elevator	1-Public Unsupervised	Position Indicators		Size	2	Yes					n/a	$ -	
F03096	Government Center		Interior	Owned	Elevator	#4 - Freight elevator	1-Public Unsupervised	Emergency Communications		Tactile?	Y	Yes					n/a	$ -	
F03097	Government Center		Interior	Owned	Elevator	#4 - Freight elevator	1-Public Unsupervised	Position Indicators		Visible signal?	Y	Yes					n/a	$ -	
F03098	Government Center		1st Floor	Owned	Elevator	Lobby	1-Public Unsupervised	Hall Signal	#1	Audible signal?	Y	Yes					n/a	$ -	
F03099	Government Center		1st Floor	Owned	Elevator	Lobby	1-Public Unsupervised	Call Control	#1	Clearance, parallel	99	Yes					n/a	$ -	
F03100	Government Center		1st Floor	Owned	Elevator	Lobby	1-Public Unsupervised	Call Control	#1	Clearance, perpendicular	99	Yes					n/a	$ -	
F03101	Government Center		1st Floor	Owned	Elevator	Lobby	1-Public Unsupervised	Hall Signal	#1	Height, center	Above door	Yes					n/a	$ -	
F03102	Government Center		1st Floor	Owned	Elevator	Lobby	1-Public Unsupervised	Call Control	#1	Height, top	42.5	Yes					n/a	$ -	
F03103	Government Center		1st Floor	Owned	Elevator	Lobby	1-Public Unsupervised	Call Control	#1	Size	1	Yes					n/a	$ -	
F03104	Government Center		1st Floor	Owned	Elevator	Lobby	1-Public Unsupervised	Hall Signal	#1	Size	1.5	Yes					n/a	$ -	
F03105	Government Center		1st Floor	Owned	Elevator	Lobby	1-Public Unsupervised	Call Control	#1	Up above down?	Y	Yes					n/a	$ -	
F03106	Government Center		1st Floor	Owned	Elevator	Lobby	1-Public Unsupervised	Call Control	#1	Visible signal?	Y	Yes					n/a	$ -	
F03786	Government Center		Interior	Owned	Hallway		3-Employee Common	Door Gate		Closing speed	8	Yes					n/a	$ -	
F03791	Government Center		Interior	Owned	Hallway	West entrance	1-Public Unsupervised	Signage	Exit Sign	Dimension, characters	6	Yes					n/a	$ -	
F03792	Government Center		Interior	Owned	Hallway	West entrance	1-Public Unsupervised	Signage	Exit Sign	Location	At exit doorway	Yes					n/a	$ -	
F03796	Government Center		Interior	Owned	Hallway	West hallway	2-Public Supervised	Drinking Fountain	Near #W5007	Clearance, parallel	99	Yes					n/a	$ -	
F03797	Government Center		Interior	Owned	Hallway	West hallway	2-Public Supervised	Drinking Fountain	Near #W5007	Clearance, perpendicular	98	Yes					n/a	$ -	
F03798	Government Center		Interior	Owned	Hallway	West hallway	2-Public Supervised	Drinking Fountain	Near #W5007	Control force	Auto	Yes					n/a	$ -	
F03799	Government Center		Interior	Owned	Hallway	West hallway	2-Public Supervised	Drinking Fountain	Near #W5007	Height	35.5	Yes					n/a	$ -	
F03800	Government Center		Interior	Owned	Hallway	West hallway	2-Public Supervised	Drinking Fountain	Near #W5007	Height, water flow	39	Yes					n/a	$ -	
F03801	Government Center		Interior	Owned	Hallway	West hallway	2-Public Supervised	Drinking Fountain	Near #W5007	Spout location	3	Yes					n/a	$ -	
F04320	Government Center	Assessor's Office	Interior	Owned	Lobby Reception	#C2100	2-Public Supervised	Counter		Height	31	Yes					n/a	$ -	
F04321	Government Center		Interior	Owned	Lobby Reception	#C2436	1-Public Unsupervised	Counter	Treasurer's Office	Height	29	Yes					n/a	$ -	
F04322	Government Center		Interior	Owned	Lobby Reception	#C2436	1-Public Unsupervised	Counter	Treasurer's Office	Length	54	Yes					n/a	$ -	
F04323	Government Center		Interior	Owned	Lobby Reception	#C3000	1-Public Unsupervised	Counter		Height	34	Yes					n/a	$ -	
F04324	Government Center		Interior	Owned	Lobby Reception	#C4000	1-Public Unsupervised	Counter		Height	34	Yes					n/a	$ -	
F04325	Government Center		Interior	Owned	Lobby Reception	#C4000	1-Public Unsupervised	Counter		Length	59	Yes					n/a	$ -	
F04326	Government Center		Interior	Owned	Lobby Reception	#C5000	1-Public Unsupervised	Counter		Height	34	Yes					n/a	$ -	
F04327	Government Center		Interior	Owned	Lobby Reception	#C5000	1-Public Unsupervised	Counter		Length	59	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F04328	Government Center		Interior	Owned	Lobby Reception	Recording Office	1-Public Unsupervised	Counter	Check-in	Height	36	Yes					n/a	$ -	
F04945	Government Center		Interior	Owned	Other Room	#C1700 - Facility Ops	3-Employee Common	Signage		Braille?	Y	Yes					n/a	$ -	
F04946	Government Center		Interior	Owned	Other Room	#C1700 - Facility Ops	3-Employee Common	Door Gate		Closing speed	6	Yes					n/a	$ -	
F04947	Government Center		Interior	Owned	Other Room	#C1700 - Facility Ops	3-Employee Common	Signage		Location	L	Yes					n/a	$ -	
F04948	Government Center		Interior	Owned	Other Room	#C1700 - Facility Ops	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F04951	Government Center		Interior	Owned	Other Room	#W1000 - Public Trustee	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F04952	Government Center		Interior	Owned	Other Room	#W1000 - Public Trustee	1-Public Unsupervised	Door Gate		Closing speed	7	Yes					n/a	$ -	
F04956	Government Center		Interior	Owned	Other Room	#W5000 - Workforce Business Center	1-Public Unsupervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F04957	Government Center		Interior	Owned	Other Room	#W5000 - Workforce Business Center	1-Public Unsupervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F04958	Government Center		Interior	Owned	Other Room	#W5000 - Workforce Business Center	1-Public Unsupervised	Counter		Clearance, perpendicular	48	Yes					n/a	$ -	
F04959	Government Center		Interior	Owned	Other Room	#W5000 - Workforce Business Center	1-Public Unsupervised	Counter		Dimension, knee clearance	0	Yes					n/a	$ -	
F04960	Government Center		Interior	Owned	Other Room	#W5000 - Workforce Business Center	1-Public Unsupervised	Counter		Height	30	Yes					n/a	$ -	
F04961	Government Center		Interior	Owned	Other Room	#W5000 - Workforce Business Center	1-Public Unsupervised	Counter		Length	36	Yes					n/a	$ -	
F04962	Government Center		Interior	Owned	Other Room	#W5000 - Workforce Business Center	1-Public Unsupervised	Door Gate		Opening force	Open during business hours	Yes					n/a	$ -	
F04963	Government Center		Interior	Owned	Other Room	#W5000 - Workforce Business Center	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F04965	Government Center		Interior	Owned	Other Room	#W8301 - Team Room	1-Public Unsupervised	Door Gate		Closing speed	8	Yes					n/a	$ -	
F04967	Government Center		Interior	Owned	Other Room	#W8303 - Team Room	1-Public Unsupervised	Door Gate		Closing speed	9	Yes					n/a	$ -	
F04970	Government Center		Interior	Owned	Other Room	#W8506 - Video Conference Room	2-Public Supervised	Door Gate		Closing speed	7	Yes					n/a	$ -	
F04972	Government Center		Interior	Owned	Other Room	Planning & Development Public Works Reception Area	1-Public Unsupervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F04973	Government Center		Interior	Owned	Other Room	Planning & Development Public Works Reception Area	1-Public Unsupervised	Counter		Clearance, perpendicular	71	Yes					n/a	$ -	
F04974	Government Center		Interior	Owned	Other Room	Planning & Development Public Works Reception Area	1-Public Unsupervised	Counter		Dimension, knee clearance	27	Yes					n/a	$ -	
F04975	Government Center		Interior	Owned	Other Room	Planning & Development Public Works Reception Area	1-Public Unsupervised	Counter		Length	71	Yes					n/a	$ -	
F04976	Government Center		Interior	Owned	Other Room	Planning & Development Public Works Reception Area	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F06030	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#1	Access aisle?	Y	Yes					n/a	$ -	
F06031	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#2	Access aisle?	Y	Yes					n/a	$ -	
F06032	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#3	Access aisle?	Y	Yes					n/a	$ -	
F06033	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#4	Access aisle?	Y	Yes					n/a	$ -	
F06034	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	Between parking spaces #1 & #2	Adjacent pathway?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06035	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	Between parking spaces #3 & #4	Adjacent pathway?	Y	Yes					n/a	$ -	
F06036	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Facility Specifications		Cars obstruct pathway	N	Yes					n/a	$ -	
F06037	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#1	Height, sign	72	Yes					n/a	$ -	
F06038	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#2	Height, sign	75	Yes					n/a	$ -	
F06039	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#3	Height, sign	79	Yes					n/a	$ -	
F06040	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#4	Height, sign	83	Yes					n/a	$ -	
F06041	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	Between parking spaces #1 & #2	Length	192	Yes					n/a	$ -	
F06042	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	Between parking spaces #3 & #4	Length	192	Yes					n/a	$ -	
F06043	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Facility Specifications		Number, accessible	4	Yes					n/a	$ -	
F06044	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Facility Specifications		Number, van spaces	2	Yes					n/a	$ -	
F06045	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	Between parking spaces #1 & #2	Pathway behind cars?	N	Yes					n/a	$ -	
F06046	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	Between parking spaces #3 & #4	Pathway behind cars?	N	Yes					n/a	$ -	
F06047	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#1	Sign?	Y	Yes					n/a	$ -	
F06048	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#2	Sign?	Y	Yes					n/a	$ -	
F06049	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#3	Sign?	Y	Yes					n/a	$ -	
F06050	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#4	Sign?	Y	Yes					n/a	$ -	
F06051	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	Between parking spaces #1 & #2	Slope, cross	0.3%	Yes					n/a	$ -	
F06052	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	Between parking spaces #3 & #4	Slope, cross	0.9%	Yes					n/a	$ -	
F06053	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#3	Slope, cross	0.1%	Yes					n/a	$ -	
F06054	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#2	Slope, cross	0.7%	Yes					n/a	$ -	
F06055	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#4	Slope, cross	0.8%	Yes					n/a	$ -	
F06056	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#1	Slope, cross	1.4%	Yes					n/a	$ -	
F06057	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	Between parking spaces #1 & #2	Slope, running	1.3%	Yes					n/a	$ -	
F06058	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	Between parking spaces #3 & #4	Slope, running	1.8%	Yes					n/a	$ -	
F06059	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#1	Slope, running	0.9%	Yes					n/a	$ -	
F06060	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#4	Slope, running	1.4%	Yes					n/a	$ -	
F06061	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#2	Slope, running	1.7%	Yes					n/a	$ -	
F06062	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#3	Slope, running	1.7%	Yes					n/a	$ -	
F06063	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	Between parking spaces #1 & #2	Surface marking?	Y	Yes					n/a	$ -	
F06064	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	Between parking spaces #3 & #4	Surface marking?	Y	Yes					n/a	$ -	
F06065	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#1	Van sign?	Y	Yes					n/a	$ -	
F06066	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#2	Van sign?	Y	Yes					n/a	$ -	
F06067	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	Between parking spaces #1 & #2	Width	124	Yes					n/a	$ -	
F06068	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Access Aisle	Between parking spaces #3 & #4	Width	96	Yes					n/a	$ -	
F06069	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#1	Width	135	Yes					n/a	$ -	
F06070	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#2	Width	100	Yes					n/a	$ -	
F06071	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#3	Width	96	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06072	Government Center		Exterior	Owned	Parking Facility	East Parking Lot	1-Public Unsupervised	Parking Space	#4	Width	106	Yes					n/a	$ -	
F06082	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#1	Access aisle?	Y	Yes					n/a	$ -	
F06083	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#2	Access aisle?	Y	Yes					n/a	$ -	
F06084	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#3	Access aisle?	Y	Yes					n/a	$ -	
F06085	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#4	Access aisle?	Y	Yes					n/a	$ -	
F06086	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#5	Access aisle?	Y	Yes					n/a	$ -	
F06087	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#6	Access aisle?	Y	Yes					n/a	$ -	
F06088	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#1	Access aisle?	Y	Yes					n/a	$ -	
F06089	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	Between parking spaces #1 & #2	Adjacent pathway?	Y	Yes					n/a	$ -	
F06090	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	Between parking spaces #3 & #4	Adjacent pathway?	Y	Yes					n/a	$ -	
F06091	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	Between parking spaces #5 & #6	Adjacent pathway?	Y	Yes					n/a	$ -	
F06092	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Facility Specifications		Cars obstruct pathway	N	Yes					n/a	$ -	
F06093	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#1	Height, sign	78	Yes					n/a	$ -	
F06094	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#2	Height, sign	78	Yes					n/a	$ -	
F06095	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#3	Height, sign	79	Yes					n/a	$ -	
F06096	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#4	Height, sign	78	Yes					n/a	$ -	
F06097	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#5	Height, sign	77	Yes					n/a	$ -	
F06098	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#6	Height, sign	79	Yes					n/a	$ -	
F06099	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#1	Height, sign	79	Yes					n/a	$ -	
F06100	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	Between parking spaces #1 & #2	Length	192	Yes					n/a	$ -	
F06101	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	Between parking spaces #3 & #4	Length	192	Yes					n/a	$ -	
F06102	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	Between parking spaces #5 & #6	Length	192	Yes					n/a	$ -	
F06103	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Facility Specifications		Number, accessible	6	Yes					n/a	$ -	
F06104	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Facility Specifications		Number, van spaces	2	Yes					n/a	$ -	
F06105	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	Between parking spaces #1 & #2	Pathway behind cars?	N	Yes					n/a	$ -	
F06106	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	Between parking spaces #3 & #4	Pathway behind cars?	N	Yes					n/a	$ -	
F06107	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	Between parking spaces #5 & #6	Pathway behind cars?	N	Yes					n/a	$ -	
F06108	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#1	Sign?	Y	Yes					n/a	$ -	
F06109	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#2	Sign?	Y	Yes					n/a	$ -	
F06110	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#3	Sign?	Y	Yes					n/a	$ -	
F06111	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#4	Sign?	Y	Yes					n/a	$ -	
F06112	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#5	Sign?	Y	Yes					n/a	$ -	
F06113	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#6	Sign?	Y	Yes					n/a	$ -	
F06114	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#1	Sign?	Y	Yes					n/a	$ -	
F06115	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	Between parking spaces #3 & #4	Slope, cross	0.0%	Yes					n/a	$ -	
F06116	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	Between parking spaces #5 & #6	Slope, cross	0.4%	Yes					n/a	$ -	
F06117	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	Between parking spaces #1 & #2	Slope, cross	0.6%	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06118	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#2	Slope, cross	0.3%	Yes					n/a	$ -	
F06119	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#4	Slope, cross	0.3%	Yes					n/a	$ -	
F06120	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#1	Slope, cross	0.4%	Yes					n/a	$ -	
F06121	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#1	Slope, cross	0.4%	Yes					n/a	$ -	
F06122	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#5	Slope, cross	0.6%	Yes					n/a	$ -	
F06123	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#3	Slope, cross	0.8%	Yes					n/a	$ -	
F06124	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#6	Slope, cross	0.8%	Yes					n/a	$ -	
F06125	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	Between parking spaces #5 & #6	Slope, running	0.9%	Yes					n/a	$ -	
F06126	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	Between parking spaces #3 & #4	Slope, running	1.4%	Yes					n/a	$ -	
F06127	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	Between parking spaces #1 & #2	Slope, running	1.5%	Yes					n/a	$ -	
F06128	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#1	Slope, running	0.3%	Yes					n/a	$ -	
F06129	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#2	Slope, running	1.0%	Yes					n/a	$ -	
F06130	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#5	Slope, running	1.0%	Yes					n/a	$ -	
F06131	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#4	Slope, running	1.2%	Yes					n/a	$ -	
F06132	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#1	Slope, running	1.6%	Yes					n/a	$ -	
F06133	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#3	Slope, running	1.6%	Yes					n/a	$ -	
F06134	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#6	Slope, running	1.6%	Yes					n/a	$ -	
F06135	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	Between parking spaces #1 & #2	Surface marking?	Y	Yes					n/a	$ -	
F06136	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	Between parking spaces #3 & #4	Surface marking?	Y	Yes					n/a	$ -	
F06137	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	Between parking spaces #5 & #6	Surface marking?	Y	Yes					n/a	$ -	
F06138	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	Between parking spaces #1 & #2	Width	60	Yes					n/a	$ -	
F06139	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	Between parking spaces #3 & #4	Width	60	Yes					n/a	$ -	
F06140	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Access Aisle	Between parking spaces #5 & #6	Width	96	Yes					n/a	$ -	
F06141	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#1	Width	107	Yes					n/a	$ -	
F06142	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#1	Width	107	Yes					n/a	$ -	
F06143	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#2	Width	108	Yes					n/a	$ -	
F06144	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#3	Width	108	Yes					n/a	$ -	
F06145	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#4	Width	107	Yes					n/a	$ -	
F06146	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#5	Width	108	Yes					n/a	$ -	
F06147	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot	3-Employee Common	Parking Space	#6	Width	96	Yes					n/a	$ -	
F06153	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#2	Access aisle?	Y	Yes					n/a	$ -	
F06154	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#3	Access aisle?	Y	Yes					n/a	$ -	
F06155	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#4	Access aisle?	Y	Yes					n/a	$ -	
F06156	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#5	Access aisle?	Y	Yes					n/a	$ -	
F06157	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Access Aisle	#1	Adjacent pathway?	Y	Yes					n/a	$ -	
F06158	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Adjacent pathway?	Y	Yes					n/a	$ -	
F06159	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Adjacent pathway?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06160	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#2	Height, sign	78	Yes					n/a	$ -	
F06161	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#3	Height, sign	77	Yes					n/a	$ -	
F06162	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#4	Height, sign	77	Yes					n/a	$ -	
F06163	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#5	Height, sign	78	Yes					n/a	$ -	
F06164	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Access Aisle	#1	Length	192	Yes					n/a	$ -	
F06165	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Length	192	Yes					n/a	$ -	
F06166	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Length	192	Yes					n/a	$ -	
F06167	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Access Aisle	#1	Pathway behind cars?	N	Yes					n/a	$ -	
F06168	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Pathway behind cars?	N	Yes					n/a	$ -	
F06169	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Pathway behind cars?	N	Yes					n/a	$ -	
F06170	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#2	Sign?	Y	Yes					n/a	$ -	
F06171	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#3	Sign?	Y	Yes					n/a	$ -	
F06172	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#4	Sign?	Y	Yes					n/a	$ -	
F06173	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#5	Sign?	Y	Yes					n/a	$ -	
F06174	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Slope, cross	0.0%	Yes					n/a	$ -	
F06175	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Slope, cross	0.3%	Yes					n/a	$ -	
F06176	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Access Aisle	#1	Slope, cross	0.5%	Yes					n/a	$ -	
F06177	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#2	Slope, cross	0.3%	Yes					n/a	$ -	
F06178	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#5	Slope, cross	0.7%	Yes					n/a	$ -	
F06179	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#4	Slope, cross	0.3%	Yes					n/a	$ -	
F06180	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#3	Slope, cross	0.9%	Yes					n/a	$ -	
F06181	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Slope, running	0.2%	Yes					n/a	$ -	
F06182	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Slope, running	1.6%	Yes					n/a	$ -	
F06183	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Access Aisle	#1	Slope, running	1.7%	Yes					n/a	$ -	
F06184	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#4	Slope, running	0.4%	Yes					n/a	$ -	
F06185	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#3	Slope, running	1.1%	Yes					n/a	$ -	
F06186	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#5	Slope, running	1.1%	Yes					n/a	$ -	
F06187	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#2	Slope, running	1.7%	Yes					n/a	$ -	
F06188	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Access Aisle	#1	Surface marking?	Y	Yes					n/a	$ -	
F06189	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Surface marking?	Y	Yes					n/a	$ -	
F06190	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Surface marking?	Y	Yes					n/a	$ -	
F06191	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Access Aisle	#1	Width	69	Yes					n/a	$ -	
F06192	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Width	60	Yes					n/a	$ -	
F06193	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#2	Width	107	Yes					n/a	$ -	
F06194	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#3	Width	107	Yes					n/a	$ -	
F06195	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#4	Width	107	Yes					n/a	$ -	
F06196	Government Center		Exterior	Owned	Parking Facility	Employee Parking Lot - NW	1-Public Unsupervised	Parking Space	#5	Width	107	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06205	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#1	Access aisle?	Y	Yes					n/a	$ -	
F06206	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#2	Access aisle?	Y	Yes					n/a	$ -	
F06207	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#3	Access aisle?	Y	Yes					n/a	$ -	
F06208	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#4	Access aisle?	Y	Yes					n/a	$ -	
F06209	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#5	Access aisle?	Y	Yes					n/a	$ -	
F06210	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Access Aisle	#1	Adjacent pathway?	Y	Yes					n/a	$ -	
F06211	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Access Aisle	#2	Adjacent pathway?	Y	Yes					n/a	$ -	
F06212	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Adjacent pathway?	Y	Yes					n/a	$ -	
F06213	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Facility Specifications		Cars obstruct pathway	N	Yes					n/a	$ -	
F06214	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#1	Height, sign	78	Yes					n/a	$ -	
F06215	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#2	Height, sign	78	Yes					n/a	$ -	
F06216	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#3	Height, sign	77	Yes					n/a	$ -	
F06217	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#4	Height, sign	77	Yes					n/a	$ -	
F06218	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#5	Height, sign	77	Yes					n/a	$ -	
F06219	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Access Aisle	#1	Length	192	Yes					n/a	$ -	
F06220	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Access Aisle	#2	Length	192	Yes					n/a	$ -	
F06221	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Length	192	Yes					n/a	$ -	
F06222	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Facility Specifications		Number, accessible	5	Yes					n/a	$ -	
F06223	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Facility Specifications		Number, van spaces	2	Yes					n/a	$ -	
F06224	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Access Aisle	#1	Pathway behind cars?	N	Yes					n/a	$ -	
F06225	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Access Aisle	#2	Pathway behind cars?	N	Yes					n/a	$ -	
F06226	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Pathway behind cars?	N	Yes					n/a	$ -	
F06227	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#1	Sign?	Y	Yes					n/a	$ -	
F06228	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#2	Sign?	Y	Yes					n/a	$ -	
F06229	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#3	Sign?	Y	Yes					n/a	$ -	
F06230	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#4	Sign?	Y	Yes					n/a	$ -	
F06231	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#5	Sign?	Y	Yes					n/a	$ -	
F06232	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Access Aisle	#1	Slope, cross	0.4%	Yes					n/a	$ -	
F06233	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Access Aisle	#2	Slope, cross	0.8%	Yes					n/a	$ -	
F06234	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Slope, cross	1.3%	Yes					n/a	$ -	
F06235	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#2	Slope, cross	0.0%	Yes					n/a	$ -	
F06236	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#1	Slope, cross	0.4%	Yes					n/a	$ -	
F06237	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#5	Slope, cross	0.9%	Yes					n/a	$ -	
F06238	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#4	Slope, cross	1.0%	Yes					n/a	$ -	
F06239	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#3	Slope, cross	1.5%	Yes					n/a	$ -	
F06240	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Access Aisle	#1	Slope, running	0.7%	Yes					n/a	$ -	
F06241	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Slope, running	1.7%	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06242	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Access Aisle	#2	Slope, running	2.0%	Yes					n/a	$ -	
F06243	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#1	Slope, running	0.7%	Yes					n/a	$ -	
F06244	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#5	Slope, running	1.4%	Yes					n/a	$ -	
F06245	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#2	Slope, running	1.5%	Yes					n/a	$ -	
F06246	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#3	Slope, running	1.7%	Yes					n/a	$ -	
F06247	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Access Aisle	#1	Surface marking?	Y	Yes					n/a	$ -	
F06248	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Access Aisle	#2	Surface marking?	Y	Yes					n/a	$ -	
F06249	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Surface marking?	Y	Yes					n/a	$ -	
F06250	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Access Aisle	#1	Width	60	Yes					n/a	$ -	
F06251	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Access Aisle	#2	Width	62	Yes					n/a	$ -	
F06252	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Width	97	Yes					n/a	$ -	
F06253	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#1	Width	111	Yes					n/a	$ -	
F06254	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#2	Width	111	Yes					n/a	$ -	
F06255	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#3	Width	112	Yes					n/a	$ -	
F06256	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#4	Width	111	Yes					n/a	$ -	
F06257	Government Center		Exterior	Owned	Parking Facility	Main entrance	1-Public Unsupervised	Parking Space	#5	Width	107	Yes					n/a	$ -	
F06264	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#1	Access aisle?	Y	Yes					n/a	$ -	
F06265	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#2	Access aisle?	Y	Yes					n/a	$ -	
F06266	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#3	Access aisle?	Y	Yes					n/a	$ -	
F06267	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#4	Access aisle?	Y	Yes					n/a	$ -	
F06268	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	Between parking spaces #3 & #4	Adjacent pathway?	Y	Yes					n/a	$ -	
F06269	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#1	Height, sign	72	Yes					n/a	$ -	
F06270	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#2	Height, sign	72	Yes					n/a	$ -	
F06271	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#3	Height, sign	79	Yes					n/a	$ -	
F06272	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#4	Height, sign	80	Yes					n/a	$ -	
F06273	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#1	Length	192	Yes					n/a	$ -	
F06274	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	Between parking spaces #3 & #4	Length	192	Yes					n/a	$ -	
F06275	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Facility Specifications		Number, accessible	8	Yes					n/a	$ -	
F06276	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Facility Specifications		Number, van spaces	4	Yes					n/a	$ -	
F06277	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#1	Pathway behind cars?	N	Yes					n/a	$ -	
F06278	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	Between parking spaces #3 & #4	Pathway behind cars?	N	Yes					n/a	$ -	
F06279	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#1	Sign?	Y	Yes					n/a	$ -	
F06280	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#2	Sign?	Y	Yes					n/a	$ -	
F06281	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#3	Sign?	Y	Yes					n/a	$ -	
F06282	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#4	Sign?	Y	Yes					n/a	$ -	
F06283	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	Between parking spaces #3 & #4	Slope, cross	1.1%	Yes					n/a	$ -	
F06284	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#4	Slope, cross	0.4%	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06285	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#3	Slope, cross	1.0%	Yes					n/a	$ -	
F06286	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#1	Slope, cross	1.5%	Yes					n/a	$ -	
F06287	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#2	Slope, cross	1.8%	Yes					n/a	$ -	
F06288	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	Between parking spaces #3 & #4	Slope, running	1.1%	Yes					n/a	$ -	
F06289	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#1	Slope, running	1.8%	Yes					n/a	$ -	
F06290	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#4	Slope, running	0.2%	Yes					n/a	$ -	
F06291	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#2	Slope, running	0.7%	Yes					n/a	$ -	
F06292	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#3	Slope, running	0.9%	Yes					n/a	$ -	
F06293	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#1	Surface marking?	Y	Yes					n/a	$ -	
F06294	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	Between parking spaces #3 & #4	Surface marking?	Y	Yes					n/a	$ -	
F06295	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#1	Van sign?	Y	Yes					n/a	$ -	
F06296	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#2	Van sign?	Y	Yes					n/a	$ -	
F06297	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#1	Width	98	Yes					n/a	$ -	
F06298	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#1	Width	103	Yes					n/a	$ -	
F06299	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#2	Width	112	Yes					n/a	$ -	
F06300	Government Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#3	Width	111	Yes					n/a	$ -	
F06301	Government Center		Exterior	Owned	Parking Facility	West Parking Lot NW side	1-Public Unsupervised	Access Aisle	#1	Adjacent pathway?	Y	Yes					n/a	$ -	
F06302	Government Center		Exterior	Owned	Parking Facility	West Parking Lot NW side	1-Public Unsupervised	Facility Specifications		Cars obstruct pathway	OK	Yes					n/a	$ -	
F06303	Government Center		Exterior	Owned	Parking Facility	West Parking Lot NW side	1-Public Unsupervised	Access Aisle	Between parking spaces #3 & #4	Width	60	Yes					n/a	$ -	
F06304	Government Center		Exterior	Owned	Parking Facility	West Parking Lot NW side	1-Public Unsupervised	Parking Space	#4	Width	113	Yes					n/a	$ -	
F06315	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#5	Access aisle?	Y	Yes					n/a	$ -	
F06316	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#7	Access aisle?	Y	Yes					n/a	$ -	
F06317	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Access Aisle	Between parking spaces #5 & #6	Adjacent pathway?	Y	Yes					n/a	$ -	
F06318	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Access Aisle	Between parking spaces #7 & #8	Adjacent pathway?	Y	Yes					n/a	$ -	
F06319	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#5	Height, sign	79	Yes					n/a	$ -	
F06320	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#6	Height, sign	79	Yes					n/a	$ -	
F06321	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#7	Height, sign	72	Yes					n/a	$ -	
F06322	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#8	Height, sign	73	Yes					n/a	$ -	
F06323	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Access Aisle	Between parking spaces #5 & #6	Length	192	Yes					n/a	$ -	
F06324	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Access Aisle	Between parking spaces #7 & #8	Length	192	Yes					n/a	$ -	
F06325	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Access Aisle	Between parking spaces #5 & #6	Pathway behind cars?	N	Yes					n/a	$ -	
F06326	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Access Aisle	Between parking spaces #7 & #8	Pathway behind cars?	N	Yes					n/a	$ -	
F06327	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#5	Sign?	Y	Yes					n/a	$ -	
F06328	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#6	Sign?	Y	Yes					n/a	$ -	
F06329	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#7	Sign?	Y	Yes					n/a	$ -	
F06330	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#8	Sign?	Y	Yes					n/a	$ -	
F06331	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Access Aisle	Between parking spaces #7 & #8	Slope, cross	1.7%	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06332	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#6	Slope, cross	1.7%	Yes					n/a	$ -	
F06333	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#7	Slope, cross	1.9%	Yes					n/a	$ -	
F06334	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#5	Slope, cross	2.0%	Yes					n/a	$ -	
F06335	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Access Aisle	Between parking spaces #5 & #6	Surface marking?	Y	Yes					n/a	$ -	
F06336	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Access Aisle	Between parking spaces #7 & #8	Surface marking?	Y	Yes					n/a	$ -	
F06337	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#7	Van sign?	Y	Yes					n/a	$ -	
F06338	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#8	Van sign?	Y	Yes					n/a	$ -	
F06339	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Access Aisle	Between parking spaces #5 & #6	Width	60	Yes					n/a	$ -	
F06340	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Access Aisle	Between parking spaces #7 & #8	Width	101	Yes					n/a	$ -	
F06341	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#5	Width	111	Yes					n/a	$ -	
F06342	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#6	Width	111	Yes					n/a	$ -	
F06343	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#7	Width	114	Yes					n/a	$ -	
F06344	Government Center		Exterior	Owned	Parking Facility	West Parking Lot SW side	1-Public Unsupervised	Parking Space	#8	Width	108	Yes					n/a	$ -	
F07398	Government Center		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Transfer		Depth, platform/step	15	Yes					n/a	$ -	
F07399	Government Center		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Component Entry	Alligator	Height	12	Yes					n/a	$ -	
F07400	Government Center		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Transfer		Height, platform/step	18	Yes					n/a	$ -	
F07401	Government Center		Exterior	Owned	Play Area	Ages 2 - 5	1-Public Unsupervised	Transfer		Width, platform/step	41	Yes					n/a	$ -	
F07405	Government Center		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Transfer		Depth, platform/step	16	Yes					n/a	$ -	
F07406	Government Center		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Component Entry	Fixed bench/counter	Height	16	Yes					n/a	$ -	
F07407	Government Center		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Transfer		Height, platform/step	15	Yes					n/a	$ -	
F07408	Government Center		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Area Specifications		Number, ground components	3	Yes					n/a	$ -	
F07409	Government Center		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Area Specifications		Number, ground types	3	Yes					n/a	$ -	
F07410	Government Center		Exterior	Owned	Play Area	Ages 5 - 12	1-Public Unsupervised	Transfer		Width, platform/step	42	Yes					n/a	$ -	
F10637	Government Center		Interior	Owned	Restroom	Men's - Near C1205	1-Public Unsupervised	Dispenser	TP	Height	19	Yes					n/a	$ -	
F10638	Government Center		Interior	Owned	Restroom	Men's - Near C1205	1-Public Unsupervised	Dispenser	TP	Height	19	Yes					n/a	$ -	
F10639	Government Center		Interior	Owned	Restroom	Men's - Near C1205	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F10640	Government Center		Interior	Owned	Restroom	Men's - Near C1205	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F10641	Government Center		Interior	Owned	Restroom	Men's - Near C1205	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F10642	Government Center		Interior	Owned	Restroom	Men's - Near C1205	1-Public Unsupervised	Fixture Count		Number, toilet compartments	2	Yes					n/a	$ -	
F10643	Government Center		Interior	Owned	Restroom	Men's - Near C1205	1-Public Unsupervised	Fixture Count		Number, toilet compartments	2	Yes					n/a	$ -	
F10644	Government Center		Interior	Owned	Restroom	Men's - Near C1205	1-Public Unsupervised	Fixture Count		Number, urinals	2	Yes					n/a	$ -	
F10645	Government Center		Interior	Owned	Restroom	Men's - Near C1205	1-Public Unsupervised	Fixture Count		Number, urinals	2	Yes					n/a	$ -	
F10650	Government Center		Interior	Owned	Restroom	Men's - Near C1304	3-Employee Common	Door Gate		Closing speed	9	Yes					n/a	$ -	
F10651	Government Center		Interior	Owned	Restroom	Men's - Near C1304	3-Employee Common	Dispenser		Height	19	Yes					n/a	$ -	
F10652	Government Center		Interior	Owned	Restroom	Men's - Near C1304	3-Employee Common	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10653	Government Center		Interior	Owned	Restroom	Men's - Near C1304	3-Employee Common	Fixture Count		Number, toilet compartments	1	Yes					n/a	$ -	
F10654	Government Center		Interior	Owned	Restroom	Men's - Near C1304	3-Employee Common	Fixture Count		Number, urinals	1	Yes					n/a	$ -	
F10675	Government Center		Interior	Owned	Restroom	Men's - Near W2606	3-Employee Common	Door Gate		Closing speed	6	Yes					n/a	$ -	
F10676	Government Center		Interior	Owned	Restroom	Men's - Near W2606	3-Employee Common	Dispenser	TP	Height	19	Yes					n/a	$ -	
F10677	Government Center		Interior	Owned	Restroom	Men's - Near W2606	3-Employee Common	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F10678	Government Center		Interior	Owned	Restroom	Men's - Near W2606	3-Employee Common	Fixture Count		Number, toilet compartments	1	Yes					n/a	$ -	
F10679	Government Center		Interior	Owned	Restroom	Men's - Near W2606	3-Employee Common	Fixture Count		Number, urinals	1	Yes					n/a	$ -	
F10682	Government Center		Interior	Owned	Restroom	Men's - Near W5007	1-Public Unsupervised	Turning Space		T-space provided?	OK	Yes					n/a	$ -	
F10683	Government Center		Interior	Owned	Restroom	Men's - Near W5007	1-Public Unsupervised	Urinal		Clearance, parallel	32	Yes					n/a	$ -	
F10684	Government Center		Interior	Owned	Restroom	Men's - Near W5007	1-Public Unsupervised	Urinal		Clearance, perpendicular	99	Yes					n/a	$ -	
F10685	Government Center		Interior	Owned	Restroom	Men's - Near W5007	1-Public Unsupervised	Door Gate		Clearance, pull parallel	24	Yes					n/a	$ -	
F10686	Government Center		Interior	Owned	Restroom	Men's - Near W5007	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	24	Yes					n/a	$ -	
F10687	Government Center		Interior	Owned	Restroom	Men's - Near W5007	1-Public Unsupervised	Door Gate		Clearance, push parallel	72	Yes					n/a	$ -	
F10688	Government Center		Interior	Owned	Restroom	Men's - Near W5007	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F10689	Government Center		Interior	Owned	Restroom	Men's - Near W5007	1-Public Unsupervised	Urinal		Control force	Auto	Yes					n/a	$ -	
F10690	Government Center		Interior	Owned	Restroom	Men's - Near W5007	1-Public Unsupervised	Urinal		Depth	15	Yes					n/a	$ -	
F10691	Government Center		Interior	Owned	Restroom	Men's - Near W5007	1-Public Unsupervised	Urinal		Height, flush control	Auto	Yes					n/a	$ -	
F10692	Government Center		Interior	Owned	Restroom	Men's - Near W5007	1-Public Unsupervised	Urinal		Height, rim	17	Yes					n/a	$ -	
F10693	Government Center		Interior	Owned	Restroom	Men's - Near W5007	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F10694	Government Center		Interior	Owned	Restroom	Men's - Near W5007	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F10695	Government Center		Interior	Owned	Restroom	Men's - Near W5007	1-Public Unsupervised	Fixture Count		Number, toilet compartments	2	Yes					n/a	$ -	
F10696	Government Center		Interior	Owned	Restroom	Men's - Near W5007	1-Public Unsupervised	Fixture Count		Number, urinals	1	Yes					n/a	$ -	
F10697	Government Center		Interior	Owned	Restroom	Men's - Near W5007	1-Public Unsupervised	Coat Hook		Other attribute	60	Yes					n/a	$ -	
F10698	Government Center		Interior	Owned	Restroom	Men's - Near W5007	1-Public Unsupervised	Counter		Other attribute	OK	Yes					n/a	$ -	
F10699	Government Center		Interior	Owned	Restroom	Men's - Near W5007	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F10703	Government Center		Interior	Owned	Restroom	Men's - Near W5522	1-Public Unsupervised	Turning Space		T-space provided?	OK	Yes					n/a	$ -	
F10704	Government Center		Interior	Owned	Restroom	Men's - Near W5522	1-Public Unsupervised	Door Gate		Clearance, push parallel	24	Yes					n/a	$ -	
F10705	Government Center		Interior	Owned	Restroom	Men's - Near W5522	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	72	Yes					n/a	$ -	
F10706	Government Center		Interior	Owned	Restroom	Men's - Near W5522	1-Public Unsupervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F10707	Government Center		Interior	Owned	Restroom	Men's - Near W5522	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F10708	Government Center		Interior	Owned	Restroom	Men's - Near W5522	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F10709	Government Center		Interior	Owned	Restroom	Men's - Near W5522	1-Public Unsupervised	Fixture Count		Number, toilet compartments	1	Yes					n/a	$ -	
F10710	Government Center		Interior	Owned	Restroom	Men's - Near W5522	1-Public Unsupervised	Fixture Count		Number, urinals	1	Yes					n/a	$ -	
F10711	Government Center		Interior	Owned	Restroom	Men's - Near W5522	1-Public Unsupervised	Coat Hook		Other attribute	60	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10712	Government Center		Interior	Owned	Restroom	Men's - Near W5522	1-Public Unsupervised	Counter		Other attribute	OK	Yes					n/a	$ -	
F10713	Government Center		Interior	Owned	Restroom	Men's - Near W5522	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F10718	Government Center		Interior	Owned	Restroom	Men's - Near W6504	3-Employee Common	Door Gate		Closing speed	6	Yes					n/a	$ -	
F10719	Government Center		Interior	Owned	Restroom	Men's - Near W6504	3-Employee Common	Dispenser	TP	Height	19	Yes					n/a	$ -	
F10720	Government Center		Interior	Owned	Restroom	Men's - Near W6504	3-Employee Common	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F10721	Government Center		Interior	Owned	Restroom	Men's - Near W6504	3-Employee Common	Fixture Count		Number, toilet compartments	2	Yes					n/a	$ -	
F10722	Government Center		Interior	Owned	Restroom	Men's - Near W6504	3-Employee Common	Fixture Count		Number, urinals	1	Yes					n/a	$ -	
F10734	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F10735	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Urinal	Standard	Clearance, parallel	34	Yes					n/a	$ -	
F10736	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Urinal	Accessible	Clearance, parallel	35	Yes					n/a	$ -	
F10737	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Urinal	Standard	Clearance, perpendicular	99	Yes					n/a	$ -	
F10738	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Urinal	Accessible	Clearance, perpendicular	99	Yes					n/a	$ -	
F10739	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Door Gate		Clearance, pull parallel	21	Yes					n/a	$ -	
F10740	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	78	Yes					n/a	$ -	
F10741	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Door Gate		Clearance, push parallel	21	Yes					n/a	$ -	
F10742	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	70	Yes					n/a	$ -	
F10743	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Door Gate		Clearance, vertical	92	Yes					n/a	$ -	
F10744	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F10745	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Urinal	Standard	Control force	Auto	Yes					n/a	$ -	
F10746	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Urinal	Accessible	Control force	Auto	Yes					n/a	$ -	
F10747	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Urinal		Depth	15	Yes					n/a	$ -	
F10748	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Urinal		Depth	15	Yes					n/a	$ -	
F10749	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Door Gate		Hardware type	OK	Yes					n/a	$ -	
F10750	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Urinal	Standard	Height, flush control	Auto	Yes					n/a	$ -	
F10751	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Urinal	Accessible	Height, flush control	Auto	Yes					n/a	$ -	
F10752	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Door Gate		Height, hardware	38	Yes					n/a	$ -	
F10753	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Urinal		Height, rim	15.5	Yes					n/a	$ -	
F10754	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	12	Yes					n/a	$ -	
F10755	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F10756	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F10757	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Fixture Count		Number, toilet compartments	3	Yes					n/a	$ -	
F10758	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Fixture Count		Number, urinals	2	Yes					n/a	$ -	
F10759	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Coat Hook		Other attribute	60	Yes					n/a	$ -	
F10760	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Counter		Other attribute	OK	Yes					n/a	$ -	
F10761	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Turning Space		T-space provided?	OK	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10762	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F10767	Government Center		Interior	Owned	Restroom	Men's - Near W8404	2-Public Supervised	Door Gate		Closing speed	7	Yes					n/a	$ -	
F10768	Government Center		Interior	Owned	Restroom	Men's - Near W8404	2-Public Supervised	Dispenser	TP	Dimension from water closet seat	7	Yes					n/a	$ -	
F10769	Government Center		Interior	Owned	Restroom	Men's - Near W8404	2-Public Supervised	Dispenser	TP	Height	19	Yes					n/a	$ -	
F10770	Government Center		Interior	Owned	Restroom	Men's - Near W8404	2-Public Supervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F10771	Government Center		Interior	Owned	Restroom	Men's - Near W8404	2-Public Supervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F10772	Government Center		Interior	Owned	Restroom	Men's - Near W8404	2-Public Supervised	Fixture Count		Number, toilet compartments	3	Yes					n/a	$ -	
F10773	Government Center		Interior	Owned	Restroom	Men's - Near W8404	2-Public Supervised	Fixture Count		Number, urinals	2	Yes					n/a	$ -	
F10784	Government Center		Interior	Owned	Restroom	Women's - Near C1205	1-Public Unsupervised	Door Gate		Closing speed	8	Yes					n/a	$ -	
F10785	Government Center		Interior	Owned	Restroom	Women's - Near C1205	1-Public Unsupervised	Dispenser	TP	Height	19	Yes					n/a	$ -	
F10786	Government Center		Interior	Owned	Restroom	Women's - Near C1205	1-Public Unsupervised	Dispenser	TP	Height	19	Yes					n/a	$ -	
F10787	Government Center		Interior	Owned	Restroom	Women's - Near C1205	1-Public Unsupervised	Protrusion	Feminine product dispenser	Height	48	Yes					n/a	$ -	
F10788	Government Center		Interior	Owned	Restroom	Women's - Near C1205	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F10789	Government Center		Interior	Owned	Restroom	Women's - Near C1205	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F10790	Government Center		Interior	Owned	Restroom	Women's - Near C1205	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F10791	Government Center		Interior	Owned	Restroom	Women's - Near C1205	1-Public Unsupervised	Fixture Count		Number, toilet compartments	4	Yes					n/a	$ -	
F10792	Government Center		Interior	Owned	Restroom	Women's - Near C1205	1-Public Unsupervised	Fixture Count		Number, toilet compartments	4	Yes					n/a	$ -	
F10793	Government Center		Interior	Owned	Restroom	Women's - Near C1205	1-Public Unsupervised	Fixture Count		Number, urinals	0	Yes					n/a	$ -	
F10798	Government Center		Interior	Owned	Restroom	Women's - Near C1304	3-Employee Common	Door Gate		Closing speed	6	Yes					n/a	$ -	
F10799	Government Center		Interior	Owned	Restroom	Women's - Near C1304	3-Employee Common	Dispenser	TP	Height	18.5	Yes					n/a	$ -	
F10800	Government Center		Interior	Owned	Restroom	Women's - Near C1304	3-Employee Common	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F10801	Government Center		Interior	Owned	Restroom	Women's - Near C1304	3-Employee Common	Fixture Count		Number, toilet compartments	2	Yes					n/a	$ -	
F10828	Government Center		Interior	Owned	Restroom	Women's - Near W2606	3-Employee Common	Door Gate		Closing speed	5	Yes					n/a	$ -	
F10829	Government Center		Interior	Owned	Restroom	Women's - Near W2606	3-Employee Common	Dispenser	TP	Height	19	Yes					n/a	$ -	
F10830	Government Center		Interior	Owned	Restroom	Women's - Near W2606	3-Employee Common	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F10831	Government Center		Interior	Owned	Restroom	Women's - Near W2606	3-Employee Common	Fixture Count		Number, toilet compartments	2	Yes					n/a	$ -	
F10834	Government Center		Interior	Owned	Restroom	Women's - Near W5007	1-Public Unsupervised	Turning Space		T-space provided?	OK	Yes					n/a	$ -	
F10835	Government Center		Interior	Owned	Restroom	Women's - Near W5007	1-Public Unsupervised	Door Gate		Clearance, pull parallel	24	Yes					n/a	$ -	
F10836	Government Center		Interior	Owned	Restroom	Women's - Near W5007	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	74	Yes					n/a	$ -	
F10837	Government Center		Interior	Owned	Restroom	Women's - Near W5007	1-Public Unsupervised	Door Gate		Clearance, push parallel	24	Yes					n/a	$ -	
F10838	Government Center		Interior	Owned	Restroom	Women's - Near W5007	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	60	Yes					n/a	$ -	
F10839	Government Center		Interior	Owned	Restroom	Women's - Near W5007	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10840	Government Center		Interior	Owned	Restroom	Women's - Near W5007	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F10841	Government Center		Interior	Owned	Restroom	Women's - Near W5007	1-Public Unsupervised	Fixture Count		Number, toilet compartments	3	Yes					n/a	$ -	
F10842	Government Center		Interior	Owned	Restroom	Women's - Near W5007	1-Public Unsupervised	Counter		Other attribute	OK	Yes					n/a	$ -	
F10843	Government Center		Interior	Owned	Restroom	Women's - Near W5007	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F10847	Government Center		Interior	Owned	Restroom	Women's - Near W5522	1-Public Unsupervised	Turning Space		T-space provided?	OK	Yes					n/a	$ -	
F10848	Government Center		Interior	Owned	Restroom	Women's - Near W5522	1-Public Unsupervised	Door Gate		Clearance, pull parallel	24	Yes					n/a	$ -	
F10849	Government Center		Interior	Owned	Restroom	Women's - Near W5522	1-Public Unsupervised	Door Gate		Clearance, push parallel	24	Yes					n/a	$ -	
F10850	Government Center		Interior	Owned	Restroom	Women's - Near W5522	1-Public Unsupervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F10851	Government Center		Interior	Owned	Restroom	Women's - Near W5522	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F10852	Government Center		Interior	Owned	Restroom	Women's - Near W5522	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F10853	Government Center		Interior	Owned	Restroom	Women's - Near W5522	1-Public Unsupervised	Fixture Count		Number, toilet compartments	2	Yes					n/a	$ -	
F10854	Government Center		Interior	Owned	Restroom	Women's - Near W5522	1-Public Unsupervised	Fixture Count		Number, urinals	0	Yes					n/a	$ -	
F10855	Government Center		Interior	Owned	Restroom	Women's - Near W5522	1-Public Unsupervised	Coat Hook		Other attribute	60	Yes					n/a	$ -	
F10856	Government Center		Interior	Owned	Restroom	Women's - Near W5522	1-Public Unsupervised	Counter		Other attribute	OK	Yes					n/a	$ -	
F10857	Government Center		Interior	Owned	Restroom	Women's - Near W5522	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F10862	Government Center		Interior	Owned	Restroom	Women's - Near W6504	3-Employee Common	Door Gate		Closing speed	7	Yes					n/a	$ -	
F10863	Government Center		Interior	Owned	Restroom	Women's - Near W6504	3-Employee Common	Dispenser	TP	Height	18.5	Yes					n/a	$ -	
F10864	Government Center		Interior	Owned	Restroom	Women's - Near W6504	3-Employee Common	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F10865	Government Center		Interior	Owned	Restroom	Women's - Near W6504	3-Employee Common	Fixture Count		Number, toilet compartments	3	Yes					n/a	$ -	
F10906	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F10907	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F10908	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Clear opening	34	Yes					n/a	$ -	
F10909	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F10910	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Coat Hook		Clearance, parallel	99	Yes					n/a	$ -	
F10911	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Dispenser	Soap	Clearance, parallel	74	Yes					n/a	$ -	
F10912	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Dispenser	TP	Clearance, parallel	99	Yes					n/a	$ -	
F10913	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Dispenser	Toilet seat covers	Clearance, parallel	99	Yes					n/a	$ -	
F10914	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Dispenser	PT	Clearance, parallel	60	Yes					n/a	$ -	
F10915	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	84	Yes					n/a	$ -	
F10916	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Operable Part	Faucets	Clearance, parallel	72	Yes					n/a	$ -	
F10917	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Changing Station		Clearance, parallel	60	Yes					n/a	$ -	
F10918	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Water Closet		Clearance, parallel	60	Yes					n/a	$ -	
F10919	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Coat Hook		Clearance, perpendicular	60	Yes					n/a	$ -	
F10920	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Dispenser	Soap	Clearance, perpendicular	60	Yes					n/a	$ -	
F10921	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Dispenser	TP	Clearance, perpendicular	60	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10922	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Dispenser	Toilet seat covers	Clearance, perpendicular	60	Yes					n/a	$ -	
F10923	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Dispenser	PT	Clearance, perpendicular	72	Yes					n/a	$ -	
F10924	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	66	Yes					n/a	$ -	
F10925	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Operable Part	Faucets	Clearance, perpendicular	60	Yes					n/a	$ -	
F10926	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Changing Station		Clearance, perpendicular	84	Yes					n/a	$ -	
F10927	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	99	Yes					n/a	$ -	
F10928	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Water Closet		Clearance, perpendicular	83	Yes					n/a	$ -	
F10929	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Clearance, pull parallel	20	Yes					n/a	$ -	
F10930	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Clearance, pull parallel	65	Yes					n/a	$ -	
F10931	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	74	Yes					n/a	$ -	
F10932	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	60	Yes					n/a	$ -	
F10933	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Clearance, push parallel	24	Yes					n/a	$ -	
F10934	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Clearance, push parallel	47	Yes					n/a	$ -	
F10935	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	74	Yes					n/a	$ -	
F10936	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F10937	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F10938	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F10939	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Clearance, vertical	92	Yes					n/a	$ -	
F10940	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F10941	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Operable Part	Faucets	Control force	Auto	Yes					n/a	$ -	
F10942	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Water Closet		Control force	Auto	Yes					n/a	$ -	
F10943	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Grab Bar	Side	Cross section dimension, maximum	1.5	Yes					n/a	$ -	
F10944	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Grab Bar	Rear	Cross section dimension, maximum	1.5	Yes					n/a	$ -	
F10945	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F10946	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F10947	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Turning Space		Diameter	72	Yes					n/a	$ -	
F10948	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Signage		Dimension, characters	4	Yes					n/a	$ -	
F10949	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F10950	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F10951	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	28	Yes					n/a	$ -	
F10952	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F10953	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F10954	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Turning Space		Door swing?	OK	Yes					n/a	$ -	
F10955	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F10956	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	Y	Yes					n/a	$ -	
F10957	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10958	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Hardware type	OK	Yes					n/a	$ -	
F10959	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Lavatory Sink		Hardware type	Auto	Yes					n/a	$ -	
F10960	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Toilet Compartment		Hardware type	OK	Yes					n/a	$ -	
F10961	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Alarm System		Height	Ceiling mount	Yes					n/a	$ -	
F10962	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Coat Hook		Height	48	Yes					n/a	$ -	
F10963	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Dispenser	Soap	Height	35	Yes					n/a	$ -	
F10964	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Dispenser	TP	Height	21	Yes					n/a	$ -	
F10965	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Dispenser	Toilet seat covers	Height	41	Yes					n/a	$ -	
F10966	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Dispenser	PT	Height	42	Yes					n/a	$ -	
F10967	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F10968	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Operable Part	Faucets	Height	35	Yes					n/a	$ -	
F10969	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Mirror		Height, bottom	40	Yes					n/a	$ -	
F10970	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Mirror	Full length	Height, bottom	12	Yes					n/a	$ -	
F10971	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Signage		Height, bottom	57.5	Yes					n/a	$ -	
F10972	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Water Closet		Height, flush control	Auto	Yes					n/a	$ -	
F10973	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Height, hardware	37	Yes					n/a	$ -	
F10974	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Height, hardware	37	Yes					n/a	$ -	
F10975	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Water Closet		Height, seat	17	Yes					n/a	$ -	
F10976	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	11	Yes					n/a	$ -	
F10977	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Grab Bar	Side	Height, top	34	Yes					n/a	$ -	
F10978	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Grab Bar	Side	Height, top	35.5	Yes					n/a	$ -	
F10979	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Grab Bar	Rear	Height, top	34	Yes					n/a	$ -	
F10980	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Grab Bar	Rear	Height, top	35.5	Yes					n/a	$ -	
F10981	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F10982	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Kick plate?	OK	Yes					n/a	$ -	
F10983	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F10984	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F10985	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F10986	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Water Closet		Location, flush control	Auto	Yes					n/a	$ -	
F10987	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F10988	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F10989	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Fixture Count		Number, toilet compartments	5	Yes					n/a	$ -	
F10990	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Fixture Count		Number, urinals	0	Yes					n/a	$ -	
F10991	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Opening force	5	Yes					n/a	$ -	
F10992	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Grab Bar	Rear	Perimeter	1.5	Yes					n/a	$ -	
F10993	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F10994	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Turning Space		T-space provided?	Y	Yes					n/a	$ -	
F10995	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F11001	Government Center		Interior	Owned	Restroom	Women's - Near W8404	2-Public Supervised	Door Gate		Closing speed	7	Yes					n/a	$ -	
F11002	Government Center		Interior	Owned	Restroom	Women's - Near W8404	2-Public Supervised	Dispenser	TP	Height	19	Yes					n/a	$ -	
F11003	Government Center		Interior	Owned	Restroom	Women's - Near W8404	2-Public Supervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F11004	Government Center		Interior	Owned	Restroom	Women's - Near W8404	2-Public Supervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F11005	Government Center		Interior	Owned	Restroom	Women's - Near W8404	2-Public Supervised	Fixture Count		Number, toilet compartments	5	Yes					n/a	$ -	
F11006	Government Center		Interior	Owned	Restroom	Women's - Near W8404	2-Public Supervised	Fixture Count		Number, urinals	0	Yes					n/a	$ -	
F11007	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Door Gate		Height, threshold	0.5	Yes					n/a	$ -	
F11008	Government Center		Interior	Owned	Restroom	Men's - Near W8105	1-Public Unsupervised	Door Gate		Threshold beveled?	Y	Yes					n/a	$ -	
F11009	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Height, threshold	0.5	Yes					n/a	$ -	
F11010	Government Center		Interior	Owned	Restroom	Women's - Near W8105	1-Public Unsupervised	Door Gate		Threshold beveled?	Y	Yes					n/a	$ -	
F15637	Government Center		Exterior	Owned	Stairway	West Parking Lot	1-Public Unsupervised	Tread		Accumulates water?	N	Yes					n/a	$ -	
F15638	Government Center		Exterior	Owned	Stairway	West Parking Lot	1-Public Unsupervised	Handrail		Clearance to wall	OK	Yes					n/a	$ -	
F15639	Government Center		Exterior	Owned	Stairway	West Parking Lot	1-Public Unsupervised	Landing		Clearance, parallel	99	Yes					n/a	$ -	
F15640	Government Center		Exterior	Owned	Stairway	West Parking Lot	1-Public Unsupervised	Landing		Clearance, perpendicular	99	Yes					n/a	$ -	
F15641	Government Center		Exterior	Owned	Stairway	West Parking Lot	1-Public Unsupervised	Handrail		Continuous?	Y	Yes					n/a	$ -	
F15642	Government Center		Exterior	Owned	Stairway	West Parking Lot	1-Public Unsupervised	Handrail		Cross section dimension, maximum	1.5	Yes					n/a	$ -	
F15643	Government Center		Exterior	Owned	Stairway	West Parking Lot	1-Public Unsupervised	Tread		Depth	13	Yes					n/a	$ -	
F15644	Government Center		Exterior	Owned	Stairway	West Parking Lot	1-Public Unsupervised	Handrail		Diameter	1.5	Yes					n/a	$ -	
F15645	Government Center		Exterior	Owned	Stairway	West Parking Lot	1-Public Unsupervised	Handrail		Dimension between handrails	54	Yes					n/a	$ -	
F15646	Government Center		Exterior	Owned	Stairway	West Parking Lot	1-Public Unsupervised	Landing		Edge protection?	Y	Yes					n/a	$ -	
F15647	Government Center		Exterior	Owned	Stairway	West Parking Lot	1-Public Unsupervised	Handrail		Extension	16	Yes					n/a	$ -	
F15648	Government Center		Exterior	Owned	Stairway	West Parking Lot	1-Public Unsupervised	Tread		Firm, stable, slip resistant	Concrete	Yes					n/a	$ -	
F15649	Government Center		Exterior	Owned	Stairway	West Parking Lot	1-Public Unsupervised	Riser	To West entrance	Height	6	Yes					n/a	$ -	
F15650	Government Center		Exterior	Owned	Stairway	West Parking Lot	1-Public Unsupervised	Handrail		Height, top	37	Yes					n/a	$ -	
F15651	Government Center		Exterior	Owned	Stairway	West Parking Lot	1-Public Unsupervised	Tread		Nosing	N	Yes					n/a	$ -	
F15652	Government Center		Exterior	Owned	Stairway	West Parking Lot	1-Public Unsupervised	Riser	To West entrance	Open?	N	Yes					n/a	$ -	
F15653	Government Center		Exterior	Owned	Stairway	West Parking Lot	1-Public Unsupervised	Handrail		Perimeter	1.5	Yes					n/a	$ -	
F15654	Government Center		Exterior	Owned	Stairway	West Parking Lot	1-Public Unsupervised	Handrail		Rotates?	N	Yes					n/a	$ -	
F15655	Government Center		Exterior	Owned	Stairway	West Parking Lot	1-Public Unsupervised	Landing		Slope, cross	1.5%	Yes					n/a	$ -	
F15656	Government Center		Exterior	Owned	Stairway	West Parking Lot	1-Public Unsupervised	Tread		Slope, cross	0.0%	Yes					n/a	$ -	
F15657	Government Center		Exterior	Owned	Stairway	West Parking Lot	1-Public Unsupervised	Landing		Slope, running	1.5%	Yes					n/a	$ -	
F15658	Government Center		Exterior	Owned	Stairway	West Parking Lot	1-Public Unsupervised	Tread		Slope, running	0.0%	Yes					n/a	$ -	
F15659	Government Center		Exterior	Owned	Stairway	West Parking Lot	1-Public Unsupervised	Riser	To West entrance	Uniform risers?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15660	Government Center		Exterior	Owned	Stairway	West Parking Lot	1-Public Unsupervised	Tread		Uniform treads?	Y	Yes					n/a	$ -	
F16059	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate	1st set in series	Height, threshold	0.5	Yes					n/a	$ -	
F16060	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate	1st set in series	Threshold beveled?	Y	Yes					n/a	$ -	
F16063	Government Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface		Slope, cross	0.9%	Yes					n/a	$ -	
F16064	Government Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface		Slope, running	1.8%	Yes					n/a	$ -	
F16065	Government Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface		Slope, running	2.4%	Yes					n/a	$ -	
F16066	Government Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F16067	Government Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F16068	Government Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface		Width	99	Yes					n/a	$ -	
F16069	Government Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Walking Surface		Width	99	Yes					n/a	$ -	
F16076	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	1st set in series	Height, threshold	0.5	Yes					n/a	$ -	
F16085	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	1st set in series	Threshold beveled?	Y	Yes					n/a	$ -	
F16088	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate	1st set in series	Clear opening	32	Yes					n/a	$ -	
F16089	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F16090	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate	1st set in series	Clearance, pull parallel	99	Yes					n/a	$ -	
F16091	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F16092	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate	1st set in series	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F16093	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate	1st set in series	Clearance, push parallel	48	Yes					n/a	$ -	
F16094	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F16095	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate	1st set in series	Clearance, push perpendicular	99	Yes					n/a	$ -	
F16096	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F16097	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate	1st set in series	Clearance, series doors	99	Yes					n/a	$ -	
F16098	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate		Clearance, series doors	99	Yes					n/a	$ -	
F16099	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate	1st set in series	Clearance, vertical	92	Yes					n/a	$ -	
F16100	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate		Clearance, vertical	92	Yes					n/a	$ -	
F16101	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate	1st set in series	Closing speed	6	Yes					n/a	$ -	
F16102	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate		Closing speed	6	Yes					n/a	$ -	
F16103	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate	1st set in series	Hardware type	OK	Yes					n/a	$ -	
F16104	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate		Hardware type	OK	Yes					n/a	$ -	
F16105	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate	1st set in series	Height, hardware	42	Yes					n/a	$ -	
F16106	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate		Height, hardware	42	Yes					n/a	$ -	
F16107	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate	1st set in series	Height, smooth surface (kick plate)	12	Yes					n/a	$ -	
F16108	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	12	Yes					n/a	$ -	
F16109	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate	1st set in series	Opening force	Auto	Yes					n/a	$ -	
F16110	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Door Gate		Opening force	Auto	Yes					n/a	$ -	
F16111	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Walking Surface		Slope, cross	1.9%	Yes					n/a	$ -	
F16112	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16113	Government Center		Exterior	Owned	Walkway	From East parking lot to East entrance	1-Public Unsupervised	Walking Surface		Width	52	Yes					n/a	$ -	
F16115	Government Center		Exterior	Owned	Walkway	From Employee parking lot to Employee entrance	3-Employee Common	Walking Surface		Slope, cross	1.0%	Yes					n/a	$ -	
F16116	Government Center		Exterior	Owned	Walkway	From Employee parking lot to Employee entrance	3-Employee Common	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F16117	Government Center		Exterior	Owned	Walkway	From Employee parking lot to Employee entrance	3-Employee Common	Walking Surface		Width	99	Yes					n/a	$ -	
F16118	Government Center		Exterior	Owned	Walkway	From Employee parking lot to Employee entrance	3-Employee Common	Walking Surface		Width, opening	53	Yes					n/a	$ -	
F16131	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	1st set in series	Height, threshold	0.5	Yes					n/a	$ -	
F16132	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	1st set in series	Threshold beveled?	Y	Yes					n/a	$ -	
F16134	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	1st set in series	Clear opening	32	Yes					n/a	$ -	
F16135	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	2nd set in series	Clear opening	32	Yes					n/a	$ -	
F16136	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	1st set in series	Clearance, pull parallel	99	Yes					n/a	$ -	
F16137	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	2nd set in series	Clearance, pull parallel	99	Yes					n/a	$ -	
F16138	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	1st set in series	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F16139	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	2nd set in series	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F16140	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	1st set in series	Clearance, push parallel	99	Yes					n/a	$ -	
F16141	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	2nd set in series	Clearance, push parallel	99	Yes					n/a	$ -	
F16142	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	1st set in series	Clearance, push perpendicular	99	Yes					n/a	$ -	
F16143	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	2nd set in series	Clearance, push perpendicular	99	Yes					n/a	$ -	
F16144	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	1st set in series	Clearance, series doors	99	Yes					n/a	$ -	
F16145	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	2nd set in series	Clearance, series doors	99	Yes					n/a	$ -	
F16146	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	1st set in series	Clearance, vertical	92	Yes					n/a	$ -	
F16147	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	2nd set in series	Clearance, vertical	92	Yes					n/a	$ -	
F16148	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	1st set in series	Closing speed	6	Yes					n/a	$ -	
F16149	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	2nd set in series	Closing speed	6	Yes					n/a	$ -	
F16150	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Walking Surface		Firm, stable, slip resistant	Concrete	Yes					n/a	$ -	
F16151	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	1st set in series	Hardware type	OK	Yes					n/a	$ -	
F16152	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	2nd set in series	Hardware type	OK	Yes					n/a	$ -	
F16153	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	1st set in series	Height, hardware	41	Yes					n/a	$ -	
F16154	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	2nd set in series	Height, hardware	41	Yes					n/a	$ -	
F16155	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	1st set in series	Height, smooth surface (kick plate)	12	Yes					n/a	$ -	
F16156	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	2nd set in series	Height, smooth surface (kick plate)	12	Yes					n/a	$ -	
F16157	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	1st set in series	Opening force	Auto	Yes					n/a	$ -	
F16158	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate	2nd set in series	Opening force	Auto	Yes					n/a	$ -	
F16159	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Walking Surface		Slope, cross	0.6%	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16160	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Walking Surface		Slope, running	3.9%	Yes					n/a	$ -	
F16161	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F16162	Government Center		Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Walking Surface		Width	60	Yes					n/a	$ -	
F16163	Government Center		Exterior	Owned	Walkway	From parking lot to playground	1-Public Unsupervised	Walking Surface		Slope, cross	0.6%	Yes					n/a	$ -	
F16164	Government Center		Exterior	Owned	Walkway	From parking lot to playground	1-Public Unsupervised	Walking Surface		Slope, running	2.7%	Yes					n/a	$ -	
F16165	Government Center		Exterior	Owned	Walkway	From parking lot to playground	1-Public Unsupervised	Walking Surface		Width	59	Yes					n/a	$ -	
F16172	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	1st set in series	Height, threshold	0.5	Yes					n/a	$ -	
F16179	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	1st set in series	Clear opening	32	Yes					n/a	$ -	
F16180	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	2nd set in series	Clear opening	32	Yes					n/a	$ -	
F16181	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	1st set in series	Clearance, pull parallel	99	Yes					n/a	$ -	
F16182	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	2nd set in series	Clearance, pull parallel	99	Yes					n/a	$ -	
F16183	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	1st set in series	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F16184	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	2nd set in series	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F16185	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	1st set in series	Clearance, push parallel	99	Yes					n/a	$ -	
F16186	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	2nd set in series	Clearance, push parallel	99	Yes					n/a	$ -	
F16187	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	1st set in series	Clearance, push perpendicular	99	Yes					n/a	$ -	
F16188	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	2nd set in series	Clearance, push perpendicular	99	Yes					n/a	$ -	
F16189	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	1st set in series	Clearance, series doors	99	Yes					n/a	$ -	
F16190	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	2nd set in series	Clearance, series doors	99	Yes					n/a	$ -	
F16191	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	1st set in series	Clearance, vertical	92	Yes					n/a	$ -	
F16192	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	2nd set in series	Clearance, vertical	92	Yes					n/a	$ -	
F16193	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	1st set in series	Closing speed	6	Yes					n/a	$ -	
F16194	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	2nd set in series	Closing speed	6	Yes					n/a	$ -	
F16195	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	1st set in series	Hardware type	OK	Yes					n/a	$ -	
F16196	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	2nd set in series	Hardware type	OK	Yes					n/a	$ -	
F16197	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	1st set in series	Height, hardware	43	Yes					n/a	$ -	
F16198	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	2nd set in series	Height, hardware	44	Yes					n/a	$ -	
F16199	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	1st set in series	Height, smooth surface (kick plate)	12	Yes					n/a	$ -	
F16200	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	2nd set in series	Height, smooth surface (kick plate)	12	Yes					n/a	$ -	
F16201	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	1st set in series	Threshold beveled?	Y	Yes					n/a	$ -	
F16202	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	1st set in series	Opening force	Auto	Yes					n/a	$ -	
F16203	Government Center		Exterior	Owned	Walkway	To Employee entrance	3-Employee Common	Door Gate	2nd set in series	Opening force	Auto	Yes					n/a	$ -	
F16216	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	1st set in series	Clear opening	32	Yes					n/a	$ -	
F16217	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	2nd set in series	Clear opening	32	Yes					n/a	$ -	
F16218	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	1st set in series	Clearance, pull parallel	99	Yes					n/a	$ -	
F16219	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	2nd set in series	Clearance, pull parallel	54	Yes					n/a	$ -	
F16220	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	1st set in series	Clearance, pull perpendicular	99	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16221	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	2nd set in series	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F16222	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	1st set in series	Clearance, push parallel	99	Yes					n/a	$ -	
F16223	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	2nd set in series	Clearance, push parallel	99	Yes					n/a	$ -	
F16224	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	1st set in series	Clearance, push perpendicular	99	Yes					n/a	$ -	
F16225	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	2nd set in series	Clearance, push perpendicular	99	Yes					n/a	$ -	
F16226	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	1st set in series	Clearance, series doors	Y	Yes					n/a	$ -	
F16227	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	2nd set in series	Clearance, series doors	99	Yes					n/a	$ -	
F16228	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	1st set in series	Clearance, vertical	94	Yes					n/a	$ -	
F16229	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	2nd set in series	Clearance, vertical	99	Yes					n/a	$ -	
F16230	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	1st set in series	Closing speed	6	Yes					n/a	$ -	
F16231	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	2nd set in series	Closing speed	6	Yes					n/a	$ -	
F16232	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	1st set in series	Hardware type	OK	Yes					n/a	$ -	
F16233	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	2nd set in series	Hardware type	Auto	Yes					n/a	$ -	
F16234	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	1st set in series	Height, hardware	45	Yes					n/a	$ -	
F16235	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	2nd set in series	Height, hardware	40	Yes					n/a	$ -	
F16236	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	1st set in series	Height, smooth surface (kick plate)	12	Yes					n/a	$ -	
F16237	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	2nd set in series	Height, smooth surface (kick plate)	12	Yes					n/a	$ -	
F16238	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	1st set in series	Opening force	Auto	Yes					n/a	$ -	
F16239	Government Center		Exterior	Owned	Walkway	West entrance	1-Public Unsupervised	Door Gate	2nd set in series	Opening force	Auto	Yes					n/a	$ -	
F16243	Government Center		Exterior	Owned	Walkway	West Parking Lot NW side	1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F16244	Government Center		Exterior	Owned	Walkway	West Parking Lot NW side	1-Public Unsupervised	Walking Surface		Width	60	Yes					n/a	$ -	
F16245	Government Center		Exterior	Owned	Walkway	West Parking Lot NW side	1-Public Unsupervised	Walking Surface		Width, opening	99	Yes					n/a	$ -	
F16248	Government Center		Exterior	Owned	Walkway	West Parking Lot SW side	1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F16249	Government Center		Exterior	Owned	Walkway	West Parking Lot SW side	1-Public Unsupervised	Walking Surface		Width	60	Yes					n/a	$ -	
F16250	Government Center		Exterior	Owned	Walkway	West Parking Lot SW side	1-Public Unsupervised	Walking Surface		Width, opening	99	Yes					n/a	$ -	
F00498	Honnen Building	Food Pantry	Interior	Owned	Break Room	Warehouse area	1-Public Unsupervised	Lavatory Sink	Large utility sink	Clearance, parallel	OK	Yes					n/a	$ -	
F00499	Honnen Building	Food Pantry	Interior	Owned	Break Room	Warehouse area	1-Public Unsupervised	Lavatory Sink	Large utility sink	Clearance, perpendicular	OK	Yes					n/a	$ -	
F00500	Honnen Building	Food Pantry	Interior	Owned	Break Room	Warehouse area	1-Public Unsupervised	Lavatory Sink	Wall mount	Dimension, knee clearance	28	Yes					n/a	$ -	
F00501	Honnen Building	Food Pantry	Interior	Owned	Break Room	Warehouse area	1-Public Unsupervised	Lavatory Sink	Large utility sink	Dimension, knee clearance	22	Yes					n/a	$ -	
F00502	Honnen Building	Food Pantry	Interior	Owned	Break Room	Warehouse area	1-Public Unsupervised	Lavatory Sink	Wall mount	Hardware type	OK	Yes					n/a	$ -	
F00503	Honnen Building	Food Pantry	Interior	Owned	Break Room	Warehouse area	1-Public Unsupervised	Lavatory Sink	Large utility sink	Hardware type	L	Yes					n/a	$ -	
F00504	Honnen Building	Food Pantry	Interior	Owned	Break Room	Warehouse area	1-Public Unsupervised	Dispenser	Soap	Height	48	Yes					n/a	$ -	
F00505	Honnen Building	Food Pantry	Interior	Owned	Break Room	Warehouse area	1-Public Unsupervised	Lavatory Sink	Wall mount	Height	33	Yes					n/a	$ -	
F00513	Honnen Building		2nd Floor	Owned	Break Room		3-Employee Common	Counter		Clearance, parallel	32	Yes					n/a	$ -	
F00514	Honnen Building		2nd Floor	Owned	Break Room		3-Employee Common	Counter		Clearance, perpendicular	60	Yes					n/a	$ -	
F00515	Honnen Building		2nd Floor	Owned	Break Room		3-Employee Common	Dispenser	Soap	Height	45	Yes					n/a	$ -	
F03809	Honnen Building	Food Pantry	Interior	Owned	Hallway	To secured office & classrooms	2-Public Supervised	Door Gate	Security keypad	Clear opening	33	Yes					n/a	$ -	
F03810	Honnen Building	Food Pantry	Interior	Owned	Hallway	To secured office & classrooms	2-Public Supervised	Door Gate	Security keypad	Clearance, pull parallel	OK	Yes					n/a	$ -	
F03811	Honnen Building	Food Pantry	Interior	Owned	Hallway	To secured office & classrooms	2-Public Supervised	Door Gate	Security keypad	Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F03812	Honnen Building	Food Pantry	Interior	Owned	Hallway	To secured office & classrooms	2-Public Supervised	Door Gate	Security keypad	Clearance, push perpendicular	99	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F03813	Honnen Building	Food Pantry	Interior	Owned	Hallway	To secured office & classrooms	2-Public Supervised	Door Gate	Security keypad	Closing speed	5	Yes					n/a	$ -	
F03814	Honnen Building	Food Pantry	Interior	Owned	Hallway	To secured office & classrooms	2-Public Supervised	Door Gate	Security keypad	Hardware type	L	Yes					n/a	$ -	
F04344	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F04345	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate	Into open office	Clear opening	33.5	Yes					n/a	$ -	
F04346	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Clearance, parallel	64	Yes					n/a	$ -	
F04347	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F04348	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F04349	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate	Into open office	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F04350	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate	Into open office	Clearance, push parallel	OK	Yes					n/a	$ -	
F04351	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F04352	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate	Into open office	Clearance, push perpendicular	64	Yes					n/a	$ -	
F04353	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Clearance, vertical	82	Yes					n/a	$ -	
F04354	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate	Into open office	Clearance, vertical	80	Yes					n/a	$ -	
F04355	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Closing speed	14	Yes					n/a	$ -	
F04356	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Dimension, knee clearance	1.5	Yes					n/a	$ -	
F04357	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Length	99	Yes					n/a	$ -	
F04358	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate	Into open office	Other attribute	OK	Yes					n/a	$ -	
F04359	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Slope, cross	0.6%	Yes					n/a	$ -	
F04360	Honnen Building	Food Pantry	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Threshold beveled?	Y	Yes					n/a	$ -	
F04376	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Door Gate	Entry to Head Start #2	Clear opening	32.5	Yes					n/a	$ -	
F04377	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Door Gate	Entry to Head Start #1	Clear opening	33	Yes					n/a	$ -	
F04378	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Door Gate	Entry to Head Start #2	Clearance, pull parallel	OK	Yes					n/a	$ -	
F04379	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Door Gate	Entry to Head Start #1	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F04380	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Door Gate	Entry to Head Start #2	Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F04381	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Door Gate	Entry to Head Start #1	Clearance, push perpendicular	99	Yes					n/a	$ -	
F04382	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Door Gate	Entry to Head Start #2	Clearance, push perpendicular	OK	Yes					n/a	$ -	
F04383	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Door Gate	Entry to Head Start #1	Clearance, vertical	82	Yes					n/a	$ -	
F04384	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Door Gate	Entry to Head Start #2	Clearance, vertical	80.5	Yes					n/a	$ -	
F04385	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Counter		Dimension, knee clearance	38	Yes					n/a	$ -	
F04386	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Door Gate	Entry to Head Start #2	Kick plate?	N	Yes					n/a	$ -	
F04387	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Counter		Length	96	Yes					n/a	$ -	
F04388	Honnen Building	Head Start	Interior	Owned	Lobby Reception		2-Public Supervised	Door Gate	Entry to Head Start #1	Threshold beveled?	Y	Yes					n/a	$ -	
F04986	Honnen Building	Food Pantry	Interior	Owned	Other Room	Pantry office to warehouse	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F04987	Honnen Building	Food Pantry	Interior	Owned	Other Room	Pantry office to warehouse	3-Employee Common	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F04988	Honnen Building	Food Pantry	Interior	Owned	Other Room	Pantry office to warehouse	3-Employee Common	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F04989	Honnen Building	Food Pantry	Interior	Owned	Other Room	Pantry office to warehouse	3-Employee Common	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F04997	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Signage		Braille?	Y	Yes					n/a	$ -	
F04998	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Door Gate		Clear opening	33.5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F04999	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Door Gate	To children's restroom	Clear opening	33.5	Yes					n/a	$ -	
F05000	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Lavatory Sink	Children's	Clearance, parallel	OK	Yes					n/a	$ -	
F05001	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Lavatory Sink	Children's	Clearance, perpendicular	OK	Yes					n/a	$ -	
F05002	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F05003	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Door Gate	To children's restroom	Clearance, pull parallel	OK	Yes					n/a	$ -	
F05004	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F05005	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Door Gate	To children's restroom	Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F05006	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Door Gate	To children's restroom	Clearance, push parallel	5	Yes					n/a	$ -	
F05007	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F05008	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Door Gate	To children's restroom	Clearance, push perpendicular	99	Yes					n/a	$ -	
F05009	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Door Gate		Clearance, vertical	80	Yes					n/a	$ -	
F05010	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Door Gate	To children's restroom	Clearance, vertical	80	Yes					n/a	$ -	
F05011	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Lavatory Sink	Children's	Dimension, knee clearance	21.5	Yes					n/a	$ -	
F05012	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F05013	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Door Gate	To children's restroom	Hardware type	L	Yes					n/a	$ -	
F05014	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Lavatory Sink	Children's	Hardware type	L	Yes					n/a	$ -	
F05015	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Dispenser	Soap	Height	36	Yes					n/a	$ -	
F05016	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Dispenser	PT	Height	41.5	Yes					n/a	$ -	
F05017	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Lavatory Sink	Children's	Height	25	Yes					n/a	$ -	
F05018	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Mirror		Height	29.5	Yes					n/a	$ -	
F05019	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Signage		Height, bottom	57	Yes					n/a	$ -	
F05020	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	
F05021	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Door Gate	To children's restroom	Other attribute	OK	Yes					n/a	$ -	
F05022	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom A	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F05027	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom B	2-Public Supervised	Signage		Braille?	Y	Yes					n/a	$ -	
F05028	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom B	2-Public Supervised	Door Gate		Clear opening	33.5	Yes					n/a	$ -	
F05029	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom B	2-Public Supervised	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F05030	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom B	2-Public Supervised	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F05031	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom B	2-Public Supervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F05032	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom B	2-Public Supervised	Door Gate		Clearance, vertical	81	Yes					n/a	$ -	
F05033	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom B	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F05034	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom B	2-Public Supervised	Signage		Height, bottom	57.5	Yes					n/a	$ -	
F05035	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom B	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	
F05036	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom B	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F05041	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom C	2-Public Supervised	Signage		Braille?	Y	Yes					n/a	$ -	
F05042	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom C	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F05043	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom C	2-Public Supervised	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F05044	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom C	2-Public Supervised	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F05045	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom C	2-Public Supervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F05046	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom C	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F05047	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom C	2-Public Supervised	Signage		Height, bottom	57	Yes					n/a	$ -	
F05048	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom C	2-Public Supervised	Signage		Height, bottom	57	Yes					n/a	$ -	
F05049	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom C	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F05050	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom C	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F05055	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom D	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F05056	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom D	2-Public Supervised	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F05057	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom D	2-Public Supervised	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F05058	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom D	2-Public Supervised	Door Gate		Clearance, vertical	80	Yes					n/a	$ -	
F05059	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom D	2-Public Supervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F05060	Honnen Building	Head Start	Interior	Owned	Other Room	Classroom D	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06359	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Access aisle?	Y	Yes					n/a	$ -	
F06360	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Access aisle?	Y	Yes					n/a	$ -	
F06361	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Access aisle?	Y	Yes					n/a	$ -	
F06362	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#6	Access aisle?	Y	Yes					n/a	$ -	
F06363	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Cars obstruct pathway	N	Yes					n/a	$ -	
F06364	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Height, sign	69.5	Yes					n/a	$ -	
F06365	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Height, sign	OK	Yes					n/a	$ -	
F06366	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, accessible	6	Yes					n/a	$ -	
F06367	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Sign?	Y	Yes					n/a	$ -	
F06368	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Sign?	Y	Yes					n/a	$ -	
F06369	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Sign?	Y	Yes					n/a	$ -	
F06370	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#2	Slope, cross	0.5%	Yes					n/a	$ -	
F06371	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#3	Slope, cross	1.2%	Yes					n/a	$ -	
F06372	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Slope, cross	0.2%	Yes					n/a	$ -	
F06373	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#6	Slope, cross	0.7%	Yes					n/a	$ -	
F06374	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Slope, cross	1.1%	Yes					n/a	$ -	
F06375	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Slope, cross	1.4%	Yes					n/a	$ -	
F06376	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#2	Slope, running	0.3%	Yes					n/a	$ -	
F06377	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#3	Slope, running	1.5%	Yes					n/a	$ -	
F06378	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Slope, running	1.4%	Yes					n/a	$ -	
F06379	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#2	Surface marking?	Y	Yes					n/a	$ -	
F06380	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#3	Surface marking?	Y	Yes					n/a	$ -	
F06381	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Van sign?	N	Yes					n/a	$ -	
F06382	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Van sign?	N	Yes					n/a	$ -	
F06383	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Van sign?	N	Yes					n/a	$ -	
F06384	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Van sign?	N	Yes					n/a	$ -	
F06385	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#6	Van sign?	N	Yes					n/a	$ -	
F06386	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#3	Width	60	Yes					n/a	$ -	
F06387	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Width	153	Yes					n/a	$ -	
F06388	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Width	134	Yes					n/a	$ -	
F06389	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Width	134	Yes					n/a	$ -	
F06390	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Width	125	Yes					n/a	$ -	
F06391	Honnen Building	Food Pantry	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#6	Width	135	Yes					n/a	$ -	
F06394	Honnen Building	Head Start	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	Single at Head Start entrance	Access aisle?	Y	Yes					n/a	$ -	
F06395	Honnen Building	Head Start	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Adjacent pathway?	Y	Yes					n/a	$ -	
F06396	Honnen Building	Head Start	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	Single at Head Start entrance	Height, sign	79	Yes					n/a	$ -	
F06397	Honnen Building	Head Start	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Pathway behind cars?	N	Yes					n/a	$ -	
F06398	Honnen Building	Head Start	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	Single at Head Start entrance	Sign?	Y	Yes					n/a	$ -	
F06399	Honnen Building	Head Start	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Slope, cross	0.1%	Yes					n/a	$ -	
F06400	Honnen Building	Head Start	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	Single at Head Start entrance	Slope, cross	1.7%	Yes					n/a	$ -	
F06401	Honnen Building	Head Start	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	Single at Head Start entrance	Slope, running	0.3%	Yes					n/a	$ -	
F06402	Honnen Building	Head Start	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	Single at Head Start entrance	Van sign?	N	Yes					n/a	$ -	
F06403	Honnen Building	Head Start	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	Single at Head Start entrance	Width	136	Yes					n/a	$ -	
F07416	Honnen Building		Exterior	Owned	Play Area		2-Public Supervised	Transfer		Depth, platform/step	16	Yes					n/a	$ -	
F07417	Honnen Building		Exterior	Owned	Play Area		2-Public Supervised	Transfer		Depth, platform/step	14	Yes					n/a	$ -	
F07418	Honnen Building		Exterior	Owned	Play Area		2-Public Supervised	Component Entry	Spring rocker	Height	24	Yes					n/a	$ -	
F07419	Honnen Building		Exterior	Owned	Play Area		2-Public Supervised	Transfer		Height, platform/step	17	Yes					n/a	$ -	
F07420	Honnen Building		Exterior	Owned	Play Area		2-Public Supervised	Transfer		Height, platform/step	8	Yes					n/a	$ -	
F07421	Honnen Building		Exterior	Owned	Play Area		2-Public Supervised	Area Specifications		Number, elevated components on accessible route	5	Yes					n/a	$ -	
F07422	Honnen Building		Exterior	Owned	Play Area		2-Public Supervised	Area Specifications		Number, ground components	6	Yes					n/a	$ -	
F07423	Honnen Building		Exterior	Owned	Play Area		2-Public Supervised	Transfer		Transfer support?	Y	Yes					n/a	$ -	
F07424	Honnen Building		Exterior	Owned	Play Area		2-Public Supervised	Transfer		Width, platform/step	28	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07425	Honnen Building		Exterior	Owned	Play Area		2-Public Supervised	Transfer		Width, platform/step	35	Yes					n/a	$ -	
F11023	Honnen Building	Food distribution	1st Floor	Owned	Restroom	Unisex	3-Employee Common	Signage		Braille?	Y	Yes					n/a	$ -	
F11024	Honnen Building	Food distribution	1st Floor	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F11025	Honnen Building	Food distribution	2nd Floor	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Clearance, parallel	64	Yes					n/a	$ -	
F11026	Honnen Building	Food distribution	2nd Floor	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Clearance, perpendicular	63	Yes					n/a	$ -	
F11027	Honnen Building	Food distribution	2nd Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F11028	Honnen Building	Food distribution	1st Floor	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Clearance, vertical	80	Yes					n/a	$ -	
F11029	Honnen Building	Food distribution	2nd Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F11030	Honnen Building	Food distribution	2nd Floor	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F11031	Honnen Building	Food distribution	2nd Floor	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Height	32	Yes					n/a	$ -	
F11032	Honnen Building	Food distribution	1st Floor	Owned	Restroom	Unisex	3-Employee Common	Signage		Height, bottom	52	Yes					n/a	$ -	
F11033	Honnen Building	Food distribution	2nd Floor	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Height, seat	18	Yes					n/a	$ -	
F11034	Honnen Building	Food distribution	2nd Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Rear	Height, top	36	Yes					n/a	$ -	
F11035	Honnen Building	Food distribution	1st Floor	Owned	Restroom	Unisex	3-Employee Common	Signage		ISA?	Y	Yes					n/a	$ -	
F11036	Honnen Building	Food distribution	2nd Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F11037	Honnen Building	Food distribution	2nd Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F11038	Honnen Building	Food distribution	2nd Floor	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F11039	Honnen Building	Food distribution	1st Floor	Owned	Restroom	Unisex	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F11057	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F11058	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Door Gate		Clear opening	33.5	Yes					n/a	$ -	
F11059	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	36	Yes					n/a	$ -	
F11060	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Water Closet		Clearance, parallel	65	Yes					n/a	$ -	
F11061	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	48	Yes					n/a	$ -	
F11062	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Water Closet		Clearance, perpendicular	65	Yes					n/a	$ -	
F11063	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F11064	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F11065	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Door Gate		Clearance, push parallel	4	Yes					n/a	$ -	
F11066	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	48	Yes					n/a	$ -	
F11067	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F11068	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F11069	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Door Gate		Clearance, vertical	80.5	Yes					n/a	$ -	
F11070	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F11071	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F11072	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F11073	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Dispenser	TP	Height	41	Yes					n/a	$ -	
F11074	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Lavatory Sink		Height	31.5	Yes					n/a	$ -	
F11075	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Signage		Height, bottom	52	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11076	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Water Closet		Height, seat	18.25	Yes					n/a	$ -	
F11077	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Grab Bar	Rear	Height, top	36	Yes					n/a	$ -	
F11078	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Grab Bar	Side	Height, top	36	Yes					n/a	$ -	
F11079	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F11080	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F11081	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F11082	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F11083	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Access from Pantry Office	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F11099	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Signage		Braille?	Y	Yes					n/a	$ -	
F11100	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Lavatory Sink		Clearance, parallel	OK	Yes					n/a	$ -	
F11101	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	26	Yes					n/a	$ -	
F11102	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Water Closet	Children's	Dimension, sidewall	16.5	Yes					n/a	$ -	
F11103	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F11104	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Dispenser	Soap	Height	36	Yes					n/a	$ -	
F11105	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Dispenser	PT	Height	42	Yes					n/a	$ -	
F11106	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Lavatory Sink		Height	29	Yes					n/a	$ -	
F11107	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Water Closet	Children's	Height, seat	11.5	Yes					n/a	$ -	
F11108	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Signage		Height, top	53	Yes					n/a	$ -	
F11109	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F11110	Honnen Building	Food Pantry	Interior	Owned	Restroom	Unisex - Near Classroom A	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F11127	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Signage		Braille?	Y	Yes					n/a	$ -	
F11128	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Lavatory Sink		Clearance, parallel	37	Yes					n/a	$ -	
F11129	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F11130	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F11131	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Door Gate		Clearance, push parallel	OK	Yes					n/a	$ -	
F11132	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Door Gate		Clearance, push perpendicular	OK	Yes					n/a	$ -	
F11133	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	26	Yes					n/a	$ -	
F11134	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Water Closet		Dimension, sidewall	13.5	Yes					n/a	$ -	
F11135	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F11136	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F11137	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Dispenser	PT	Height	42	Yes					n/a	$ -	
F11138	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Dispenser	Soap	Height	30	Yes					n/a	$ -	
F11139	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Dispenser	TP	Height	24	Yes					n/a	$ -	
F11140	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Lavatory Sink		Height	32	Yes					n/a	$ -	
F11141	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Signage		Height, bottom	52.5	Yes					n/a	$ -	
F11142	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11143	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Door Gate		Other attribute	OK	Yes					n/a	$ -	
F11144	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom C	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F11162	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Signage		Braille?	Y	Yes					n/a	$ -	
F11163	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Lavatory Sink		Clearance, parallel	OK	Yes					n/a	$ -	
F11164	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Water Closet		Clearance, perpendicular	56	Yes					n/a	$ -	
F11165	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F11166	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F11167	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Door Gate		Clearance, push parallel	OK	Yes					n/a	$ -	
F11168	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Door Gate		Clearance, push perpendicular	OK	Yes					n/a	$ -	
F11169	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	26	Yes					n/a	$ -	
F11170	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Water Closet		Dimension, sidewall	15	Yes					n/a	$ -	
F11171	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F11172	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F11173	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Dispenser	TP	Height	27.5	Yes					n/a	$ -	
F11174	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Dispenser	Soap	Height	35	Yes					n/a	$ -	
F11175	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Dispenser	PT	Height	40	Yes					n/a	$ -	
F11176	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Lavatory Sink		Height	32	Yes					n/a	$ -	
F11177	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Signage		Height, bottom	52.5	Yes					n/a	$ -	
F11178	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Water Closet		Location, flush control	OK	Yes					n/a	$ -	
F11179	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Door Gate		Other attribute	OK	Yes					n/a	$ -	
F11180	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Classroom D	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F11196	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Signage		Braille?	Y	Yes					n/a	$ -	
F11197	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Water Closet		Clearance, parallel	60	Yes					n/a	$ -	
F11198	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Door Gate		Clearance, pull parallel	29	Yes					n/a	$ -	
F11199	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Door Gate		Clearance, push parallel	OK	Yes					n/a	$ -	
F11200	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Door Gate		Clearance, push perpendicular	OK	Yes					n/a	$ -	
F11201	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Dispenser	TP	Dimension from water closet seat	9	Yes					n/a	$ -	
F11202	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	26	Yes					n/a	$ -	
F11203	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Water Closet		Dimension, sidewall	13	Yes					n/a	$ -	
F11204	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F11205	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Dispenser	Soap	Height	36	Yes					n/a	$ -	
F11206	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Dispenser	TP	Height	27.5	Yes					n/a	$ -	
F11207	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Lavatory Sink		Height	32	Yes					n/a	$ -	
F11208	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Signage		Height, bottom	53.5	Yes					n/a	$ -	
F11209	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Water Closet		Height, seat	18.5	Yes					n/a	$ -	
F11210	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	
F11211	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Water Closet		Location, flush control	On wall	Yes					n/a	$ -	
F11212	Honnen Building	Head Start	Interior	Owned	Restroom	Unisex - Lobby	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F11230	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Signage		Braille?	Y	Yes					n/a	$ -	
F11231	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F11232	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Water Closet		Clearance, parallel	60	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11233	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Water Closet		Clearance, perpendicular	99	Yes					n/a	$ -	
F11234	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Door Gate		Clearance, push perpendicular	44	Yes					n/a	$ -	
F11235	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F11236	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F11237	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Lavatory Sink		Dimension, knee clearance	28	Yes					n/a	$ -	
F11238	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F11239	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Lavatory Sink		Height	32	Yes					n/a	$ -	
F11240	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Signage		Height, bottom	52	Yes					n/a	$ -	
F11241	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Grab Bar	Rear	Height, top	36	Yes					n/a	$ -	
F11242	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Signage		ISA?	Y	Yes					n/a	$ -	
F11243	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Signage		Location	L	Yes					n/a	$ -	
F11244	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F11245	Honnen Building		Interior	Owned	Restroom	Unisex - Near Classroom C	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F11257	Honnen Building		2nd Floor	Owned	Restroom	Unisex - North	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F11258	Honnen Building		2nd Floor	Owned	Restroom	Unisex - North	3-Employee Common	Fixture Count		Number, toilet compartments	1	Yes					n/a	$ -	
F11272	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Northeast	3-Employee Common	Fixture Count		Number, toilet compartments	1	Yes					n/a	$ -	
F11274	Honnen Building		2nd Floor	Owned	Restroom	Unisex - South	3-Employee Common	Fixture Count		Number, toilet compartments	1	Yes					n/a	$ -	
F11285	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Southeast	3-Employee Common	Water Closet		Clearance, parallel	60	Yes					n/a	$ -	
F11286	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Southeast	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F11287	Honnen Building		2nd Floor	Owned	Restroom	Unisex - Southeast	3-Employee Common	Fixture Count		Number, toilet compartments	1	Yes					n/a	$ -	
F11289	Honnen Building		2nd Floor	Owned	Restroom	Women's	3-Employee Common	Fixture Count		Number, toilet compartments	1	Yes					n/a	$ -	
F16256	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From East parking lot to entrance	1-Public Unsupervised	Curb Ramp		Slope, counter	4.2%	Yes					n/a	$ -	
F16257	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From East parking lot to entrance	1-Public Unsupervised	Curb Ramp		Slope, cross	0.1%	Yes					n/a	$ -	
F16258	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From East parking lot to entrance	1-Public Unsupervised	Curb Ramp		Slope, running	8.3%	Yes					n/a	$ -	
F16259	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From East parking lot to entrance	1-Public Unsupervised	Curb Ramp		Surface material	Concrete	Yes					n/a	$ -	
F16260	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From East parking lot to entrance	1-Public Unsupervised	Curb Ramp		Width	96	Yes					n/a	$ -	
F16268	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From North side to parking lot	1-Public Unsupervised	Curb Ramp		Accumulates water?	N	Yes					n/a	$ -	
F16269	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From North side to parking lot	1-Public Unsupervised	Curb Ramp	West side of lot entry	Accumulates water?	N	Yes					n/a	$ -	
F16270	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From North side to parking lot	1-Public Unsupervised	Curb Ramp		Landing, parallel dimension	54	Yes					n/a	$ -	
F16271	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From North side to parking lot	1-Public Unsupervised	Curb Ramp		Landing, perpendicular dimension	99	Yes					n/a	$ -	
F16272	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From North side to parking lot	1-Public Unsupervised	Curb Ramp		Landing?	Y	Yes					n/a	$ -	
F16273	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From North side to parking lot	1-Public Unsupervised	Curb Ramp	West side of lot entry	Slope, counter	0.9%	Yes					n/a	$ -	
F16274	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From North side to parking lot	1-Public Unsupervised	Curb Ramp		Slope, counter	1.4%	Yes					n/a	$ -	
F16275	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From North side to parking lot	1-Public Unsupervised	Curb Ramp		Slope, cross	0.2%	Yes					n/a	$ -	
F16276	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From North side to parking lot	1-Public Unsupervised	Curb Ramp		Slope, left flare	0.0%	Yes					n/a	$ -	
F16277	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From North side to parking lot	1-Public Unsupervised	Curb Ramp	West side of lot entry	Slope, running	6.3%	Yes					n/a	$ -	
F16278	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From North side to parking lot	1-Public Unsupervised	Curb Ramp		Slope, running	7.7%	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16279	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From North side to parking lot	1-Public Unsupervised	Curb Ramp		Surface material	Concrete	Yes					n/a	$ -	
F16280	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From North side to parking lot	1-Public Unsupervised	Curb Ramp		Width	48	Yes					n/a	$ -	
F16281	Honnen Building	Food Pantry	Exterior	Owned	Walkway	From North side to parking lot	1-Public Unsupervised	Curb Ramp	West side of lot entry	Width	55	Yes					n/a	$ -	
F00152	Human Service Building		Interior	Owned	Assembly Area	Basement	2-Public Supervised	Alarm System		Height	82.5	Yes					n/a	$ -	
F00153	Human Service Building		Interior	Owned	Assembly Area	Basement	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F00164	Human Service Building		Interior	Owned	Assembly Area	Basement - Conf Rm. #2	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F00165	Human Service Building		Interior	Owned	Assembly Area	Basement - Conf Rm. #2	2-Public Supervised	Door Gate		Clearance, push parallel	14	Yes					n/a	$ -	
F00166	Human Service Building		Interior	Owned	Assembly Area	Basement - Conf Rm. #2	2-Public Supervised	Alarm System		Height	83	Yes					n/a	$ -	
F00167	Human Service Building		Interior	Owned	Assembly Area	Basement - Conf Rm. #2	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F00173	Human Service Building		5th Floor	Owned	Assembly Area	Meeting room	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F00517	Human Service Building	Investigations	3rd Floor	Owned	Break Room		3-Employee Common	Appliance	Refrigerator	Clearance, parallel	37.5	Yes					n/a	$ -	
F00518	Human Service Building	Investigations	3rd Floor	Owned	Break Room		3-Employee Common	Appliance	Refrigerator	Clearance, perpendicular	99	Yes					n/a	$ -	
F00519	Human Service Building	Investigations	3rd Floor	Owned	Break Room		3-Employee Common	Appliance	Refrigerator	Height	47	Yes					n/a	$ -	
F00520	Human Service Building	Investigations	3rd Floor	Owned	Break Room		3-Employee Common	Turning Space	Refrigerator	T-space provided?	Y	Yes					n/a	$ -	
F00521	Human Service Building	Investigations	3rd Floor	Owned	Break Room		3-Employee Common	Turning Space	Refrigerator	T-space provided?	Y	Yes					n/a	$ -	
F00529	Human Service Building		Interior	Owned	Break Room	Basement	1-Public Unsupervised	Door Gate		Clear opening	35	Yes					n/a	$ -	
F00530	Human Service Building		Interior	Owned	Break Room	Basement	1-Public Unsupervised	Alarm System		Height	83	Yes					n/a	$ -	
F00531	Human Service Building		Interior	Owned	Break Room	Basement	1-Public Unsupervised	Door Gate		Opening force	5	Yes					n/a	$ -	
F00532	Human Service Building		Interior	Owned	Break Room	Basement	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F00536	Human Service Building		5th Floor	Owned	Break Room	Child Support Services	2-Public Supervised	Counter		Dimension, knee clearance	27	Yes					n/a	$ -	
F00537	Human Service Building		5th Floor	Owned	Break Room	Child Support Services	2-Public Supervised	Counter		Height	33.25	Yes					n/a	$ -	
F00538	Human Service Building		5th Floor	Owned	Break Room	Child Support Services	2-Public Supervised	Lavatory Sink		Height	33.75	Yes					n/a	$ -	
F00541	Human Service Building		6th Floor	Owned	Break Room	Family Transition	2-Public Supervised	Counter		Dimension, knee clearance	29.5	Yes					n/a	$ -	
F00542	Human Service Building		6th Floor	Owned	Break Room	Family Transition	2-Public Supervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F00543	Human Service Building		6th Floor	Owned	Break Room	Family Transition	2-Public Supervised	Appliance	Refrigerator	Height	46.5	Yes					n/a	$ -	
F00544	Human Service Building		6th Floor	Owned	Break Room	Family Transition	2-Public Supervised	Counter		Height	34	Yes					n/a	$ -	
F00550	Human Service Building		6th Floor	Owned	Break Room	Housing Authority	3-Employee Common	Counter		Dimension, knee clearance	30	Yes					n/a	$ -	
F00551	Human Service Building		6th Floor	Owned	Break Room	Housing Authority	3-Employee Common	Lavatory Sink		Dimension, knee clearance	30	Yes					n/a	$ -	
F00553	Human Service Building		4th Floor	Owned	Break Room	North	3-Employee Common	Appliance	Refrigerator	Height	47	Yes					n/a	$ -	
F00554	Human Service Building		3rd Floor	Owned	Break Room	North	3-Employee Common	Appliance	Refrigerator	Height	47	Yes					n/a	$ -	
F00564	Human Service Building		4th Floor	Owned	Break Room	South	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F00565	Human Service Building		4th Floor	Owned	Break Room	South	3-Employee Common	Lavatory Sink		Dimension, knee clearance	0	Yes					n/a	$ -	
F00566	Human Service Building		4th Floor	Owned	Break Room	South	3-Employee Common	Lavatory Sink		Drain wrapped?	In cabinet	Yes					n/a	$ -	
F00567	Human Service Building		4th Floor	Owned	Break Room	South	3-Employee Common	Appliance	Refrigerator	Height	47	Yes					n/a	$ -	
F03110	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Hoistway Sign		All floors?	Y	Yes					n/a	$ -	
F03111	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Elevator Car		Audible signal?	Y	Yes					n/a	$ -	
F03112	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Hall Signal		Audible signal?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F03113	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Position Indicators		Audible signal?	Y	Yes					n/a	$ -	
F03114	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Hoistway Sign		Both jambs?	Y	Yes					n/a	$ -	
F03115	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Car Controls		Braille instructions	Y	Yes					n/a	$ -	
F03116	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Hoistway Sign		Braille?	Y	Yes					n/a	$ -	
F03117	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Elevator Door		Clear opening	42	Yes					n/a	$ -	
F03118	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Elevator Door		Closing speed	7	Yes					n/a	$ -	
F03119	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Elevator Car		Dimension, back to front	56	Yes					n/a	$ -	
F03120	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Elevator Car		Dimension, gap	1.25	Yes					n/a	$ -	
F03121	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Elevator Car		Dimension, side to side	71	Yes					n/a	$ -	
F03122	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Elevator Door		Distance to door	9.5	Yes					n/a	$ -	
F03123	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Car Controls		Height, bottom	34	Yes					n/a	$ -	
F03124	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Emergency Communications		Height, bottom	24	Yes					n/a	$ -	
F03125	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Hall Signal		Height, center	72	Yes					n/a	$ -	
F03126	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Call Control		Height, top	44	Yes					n/a	$ -	
F03127	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Car Controls		Height, top	46	Yes					n/a	$ -	
F03128	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Emergency Communications		Height, top	25	Yes					n/a	$ -	
F03129	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Car Controls		Lighted?	Y	Yes					n/a	$ -	
F03130	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Position Indicators		Location	Above door	Yes					n/a	$ -	
F03131	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Emergency Communications		Provided?	Y	Yes					n/a	$ -	
F03132	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Elevator Door		Reopen device?	Y	Yes					n/a	$ -	
F03133	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Call Control		Size	1	Yes					n/a	$ -	
F03134	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Car Controls		Size	1	Yes					n/a	$ -	
F03135	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Hall Signal		Size	OK	Yes					n/a	$ -	
F03136	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Position Indicators		Size	1.25	Yes					n/a	$ -	
F03137	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Car Controls		Star?	Y	Yes					n/a	$ -	
F03138	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Hoistway Sign		Tactile letters?	Y	Yes					n/a	$ -	
F03139	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Car Controls		Tactile?	Y	Yes					n/a	$ -	
F03140	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Emergency Communications		Tactile?	Y	Yes					n/a	$ -	
F03141	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Call Control		Up above down?	Y	Yes					n/a	$ -	
F03142	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Call Control		Visible signal?	Y	Yes					n/a	$ -	
F03143	Human Service Building		Interior	Owned	Elevator	#1 - West	1-Public Unsupervised	Position Indicators		Visible signal?	Y	Yes					n/a	$ -	
F03148	Human Service Building		Interior	Owned	Elevator	#2 - South/East car	1-Public Unsupervised	Emergency Communications		Other attribute	TYP	Yes					n/a	$ -	
F03149	Human Service Building		Interior	Owned	Elevator	#2 - South/East car	1-Public Unsupervised	Elevator Car		Audible signal?	Y	Yes					n/a	$ -	
F03150	Human Service Building		Interior	Owned	Elevator	#2 - South/East car	1-Public Unsupervised	Elevator Door		Clear opening	42	Yes					n/a	$ -	
F03151	Human Service Building		Interior	Owned	Elevator	#2 - South/East car	1-Public Unsupervised	Elevator Door		Closing speed	7	Yes					n/a	$ -	
F03152	Human Service Building		Interior	Owned	Elevator	#2 - South/East car	1-Public Unsupervised	Elevator Car		Dimension, gap	1.26	Yes					n/a	$ -	
F03153	Human Service Building		Interior	Owned	Elevator	#2 - South/East car	1-Public Unsupervised	Elevator Car		Dimension, side to side	79	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F03154	Human Service Building		Interior	Owned	Elevator	#2 - South/East car	1-Public Unsupervised	Elevator Door		Distance to door	6	Yes					n/a	$ -	
F03155	Human Service Building		Interior	Owned	Elevator	#2 - South/East car	1-Public Unsupervised	Elevator Door		Reopen device?	Y	Yes					n/a	$ -	
F03159	Human Service Building		Interior	Owned	Elevator	#3 - North/East car	1-Public Unsupervised	Elevator Car		Audible signal?	Y	Yes					n/a	$ -	
F03160	Human Service Building		Interior	Owned	Elevator	#3 - North/East car	1-Public Unsupervised	Elevator Door		Clear opening	42	Yes					n/a	$ -	
F03161	Human Service Building		Interior	Owned	Elevator	#3 - North/East car	1-Public Unsupervised	Elevator Door		Closing speed	7	Yes					n/a	$ -	
F03162	Human Service Building		Interior	Owned	Elevator	#3 - North/East car	1-Public Unsupervised	Elevator Car		Dimension, gap	1.25	Yes					n/a	$ -	
F03163	Human Service Building		Interior	Owned	Elevator	#3 - North/East car	1-Public Unsupervised	Elevator Car		Dimension, side to side	79.5	Yes					n/a	$ -	
F03164	Human Service Building		Interior	Owned	Elevator	#3 - North/East car	1-Public Unsupervised	Elevator Door		Distance to door	6	Yes					n/a	$ -	
F03165	Human Service Building		Interior	Owned	Elevator	#3 - North/East car	1-Public Unsupervised	Elevator Door		Reopen device?	Y	Yes					n/a	$ -	
F03818	Human Service Building		Basement	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near restrooms	Spout location	2.5	Yes					n/a	$ -	
F04391	Human Service Building	Child Support Services	5th Floor	Owned	Lobby Reception		2-Public Supervised	Door Gate	Interview rooms #1 thru #6	Clear opening	33	Yes					n/a	$ -	
F04396	Human Service Building		5th Floor	Owned	Lobby Reception	Child Support Services	2-Public Supervised	Counter	Check-in	Dimension, knee clearance	3.75	Yes					n/a	$ -	
F04397	Human Service Building		5th Floor	Owned	Lobby Reception	Child Support Services	2-Public Supervised	Counter	Check-in	Length	99	Yes					n/a	$ -	
F04399	Human Service Building		6th Floor	Owned	Lobby Reception	Housing Authority	1-Public Unsupervised	Counter	Check-in	Dimension, knee clearance	41	Yes					n/a	$ -	
F04400	Human Service Building		6th Floor	Owned	Lobby Reception	Housing Authority	1-Public Unsupervised	Counter	Check-in	Length	136	Yes					n/a	$ -	
F05067	Human Service Building		4th Floor	Owned	Other Room	Adult Services	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F05068	Human Service Building		4th Floor	Owned	Other Room	Adult Services	3-Employee Common	Door Gate		Closing speed	5	Yes					n/a	$ -	
F05075	Human Service Building		6th Floor	Owned	Other Room	Family Transition	2-Public Supervised	Door Gate		Clear opening	33.5	Yes					n/a	$ -	
F05076	Human Service Building		6th Floor	Owned	Other Room	Family Transition	2-Public Supervised	Door Gate		Closing speed	8	Yes					n/a	$ -	
F05077	Human Service Building		6th Floor	Owned	Other Room	Family Transition	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F05083	Human Service Building		6th Floor	Owned	Other Room	Housing Authority	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F05084	Human Service Building		6th Floor	Owned	Other Room	Housing Authority	3-Employee Common	Signage		Dimension, characters	1	Yes					n/a	$ -	
F05085	Human Service Building		6th Floor	Owned	Other Room	Housing Authority	3-Employee Common	Signage		Height, bottom	49	Yes					n/a	$ -	
F05086	Human Service Building		6th Floor	Owned	Other Room	Housing Authority	3-Employee Common	Signage		Height, top	50	Yes					n/a	$ -	
F05087	Human Service Building		6th Floor	Owned	Other Room	Housing Authority	3-Employee Common	Signage		Location	L	Yes					n/a	$ -	
F05092	Human Service Building		Interior	Owned	Other Room	Interview Room #1	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F06438	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#10	Access aisle?	Y	Yes					n/a	$ -	
F06439	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#11	Access aisle?	Y	Yes					n/a	$ -	
F06440	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#12	Access aisle?	Y	Yes					n/a	$ -	
F06441	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#13	Access aisle?	Y	Yes					n/a	$ -	
F06442	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#14	Access aisle?	Y	Yes					n/a	$ -	
F06443	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#15	Access aisle?	Y	Yes					n/a	$ -	
F06444	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#16	Access aisle?	Y	Yes					n/a	$ -	
F06445	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#17	Access aisle?	Y	Yes					n/a	$ -	
F06446	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#18	Access aisle?	Y	Yes					n/a	$ -	
F06447	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space		Access aisle?	Y	Yes					n/a	$ -	
F06448	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #15 & #16	Pathway behind cars?	N	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06449	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#10	Sign?	Y	Yes					n/a	$ -	
F06450	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#11	Sign?	Y	Yes					n/a	$ -	
F06451	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#12	Sign?	Y	Yes					n/a	$ -	
F06452	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#13	Sign?	Y	Yes					n/a	$ -	
F06453	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#14	Sign?	Y	Yes					n/a	$ -	
F06454	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#15	Sign?	Y	Yes					n/a	$ -	
F06455	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#16	Sign?	Y	Yes					n/a	$ -	
F06456	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#17	Sign?	Y	Yes					n/a	$ -	
F06457	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#18	Sign?	Y	Yes					n/a	$ -	
F06458	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space		Sign?	Y	Yes					n/a	$ -	
F06459	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #16 & #17	Slope, cross	0.2%	Yes					n/a	$ -	
F06460	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #10 & #11	Slope, cross	0.3%	Yes					n/a	$ -	
F06461	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	#19	Slope, cross	0.5%	Yes					n/a	$ -	
F06462	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #18 & #19	Slope, cross	0.6%	Yes					n/a	$ -	
F06463	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #17 & #18	Slope, cross	1.4%	Yes					n/a	$ -	
F06464	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #15 & #16	Slope, cross	1.5%	Yes					n/a	$ -	
F06465	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #11 & #12	Slope, cross	1.9%	Yes					n/a	$ -	
F06466	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#17	Slope, cross	0.2%	Yes					n/a	$ -	
F06467	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#18	Slope, cross	0.3%	Yes					n/a	$ -	
F06468	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#11	Slope, cross	0.5%	Yes					n/a	$ -	
F06469	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#10	Slope, cross	0.7%	Yes					n/a	$ -	
F06470	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#12	Slope, cross	1.4%	Yes					n/a	$ -	
F06471	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#13	Slope, cross	1.7%	Yes					n/a	$ -	
F06472	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space		Slope, cross	0.3%	Yes					n/a	$ -	
F06473	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	#19	Slope, running	1.6%	Yes					n/a	$ -	
F06474	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#14	Slope, running	1.0%	Yes					n/a	$ -	
F06475	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#11	Slope, running	2.0%	Yes					n/a	$ -	
F06476	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #15 & #16	Surface marking?	Y	Yes					n/a	$ -	
F06477	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #16 & #17	Surface marking?	Y	Yes					n/a	$ -	
F06478	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #18 & #19	Surface marking?	Y	Yes					n/a	$ -	
F06479	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	#19	Surface marking?	Y	Yes					n/a	$ -	
F06480	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#10	Van sign?	N	Yes					n/a	$ -	
F06481	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#11	Van sign?	N	Yes					n/a	$ -	
F06482	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#12	Van sign?	N	Yes					n/a	$ -	
F06483	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#13	Van sign?	N	Yes					n/a	$ -	
F06484	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#14	Van sign?	N	Yes					n/a	$ -	
F06485	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#15	Van sign?	N	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06486	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#16	Van sign?	N	Yes					n/a	$ -	
F06487	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#17	Van sign?	N	Yes					n/a	$ -	
F06488	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#18	Van sign?	N	Yes					n/a	$ -	
F06489	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space		Van sign?	N	Yes					n/a	$ -	
F06490	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	#19	Width	60	Yes					n/a	$ -	
F06491	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #10 & #11	Width	60	Yes					n/a	$ -	
F06492	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #11 & #12	Width	60	Yes					n/a	$ -	
F06493	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #12 & #13	Width	60	Yes					n/a	$ -	
F06494	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #13 & #14	Width	60	Yes					n/a	$ -	
F06495	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #15 & #16	Width	60	Yes					n/a	$ -	
F06496	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #16 & #17	Width	60	Yes					n/a	$ -	
F06497	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #17 & #18	Width	60	Yes					n/a	$ -	
F06498	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #18 & #19	Width	60	Yes					n/a	$ -	
F06499	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#10	Width	132	Yes					n/a	$ -	
F06500	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#11	Width	132	Yes					n/a	$ -	
F06501	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#12	Width	132	Yes					n/a	$ -	
F06502	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#13	Width	132	Yes					n/a	$ -	
F06503	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#14	Width	135	Yes					n/a	$ -	
F06504	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#15	Width	135	Yes					n/a	$ -	
F06505	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#16	Width	132	Yes					n/a	$ -	
F06506	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#17	Width	130	Yes					n/a	$ -	
F06507	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space	#18	Width	133	Yes					n/a	$ -	
F06508	Human Service Building		Exterior	Owned	Parking Facility	South parking lot	1-Public Unsupervised	Parking Space		Width	132	Yes					n/a	$ -	
F06522	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#1 North	Access aisle?	Y	Yes					n/a	$ -	
F06523	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#2	Access aisle?	Y	Yes					n/a	$ -	
F06524	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#3	Access aisle?	Y	Yes					n/a	$ -	
F06525	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#4	Access aisle?	Y	Yes					n/a	$ -	
F06526	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#5	Access aisle?	Y	Yes					n/a	$ -	
F06527	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#6	Access aisle?	Y	Yes					n/a	$ -	
F06528	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#7	Access aisle?	Y	Yes					n/a	$ -	
F06529	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#9	Access aisle?	Y	Yes					n/a	$ -	
F06530	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle		Pathway behind cars?	N	Yes					n/a	$ -	
F06531	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#1 North	Sign?	Y	Yes					n/a	$ -	
F06532	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#2	Sign?	Y	Yes					n/a	$ -	
F06533	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#3	Sign?	Y	Yes					n/a	$ -	
F06534	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#4	Sign?	Y	Yes					n/a	$ -	
F06535	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#5	Sign?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06536	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#6	Sign?	Y	Yes					n/a	$ -	
F06537	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#7	Sign?	Y	Yes					n/a	$ -	
F06538	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#8	Sign?	Y	Yes					n/a	$ -	
F06539	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#9	Sign?	Y	Yes					n/a	$ -	
F06540	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	#1	Slope, cross	0.1%	Yes					n/a	$ -	
F06541	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle		Slope, cross	0.5%	Yes					n/a	$ -	
F06542	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #6 & #7	Slope, cross	0.9%	Yes					n/a	$ -	
F06543	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #7 & #8	Slope, cross	1.1%	Yes					n/a	$ -	
F06544	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #8 & #9	Slope, cross	1.3%	Yes					n/a	$ -	
F06545	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#1 North	Slope, cross	0.3%	Yes					n/a	$ -	
F06546	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#5	Slope, cross	0.3%	Yes					n/a	$ -	
F06547	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#6	Slope, cross	0.4%	Yes					n/a	$ -	
F06548	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#2	Slope, cross	0.5%	Yes					n/a	$ -	
F06549	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#7	Slope, cross	0.6%	Yes					n/a	$ -	
F06550	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#8	Slope, cross	0.7%	Yes					n/a	$ -	
F06551	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#9	Slope, cross	1.1%	Yes					n/a	$ -	
F06552	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#4	Slope, cross	0.2%	Yes					n/a	$ -	
F06553	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #8 & #9	Slope, running	0.7%	Yes					n/a	$ -	
F06554	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	#1	Slope, running	0.8%	Yes					n/a	$ -	
F06555	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #6 & #7	Slope, running	1.2%	Yes					n/a	$ -	
F06556	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #7 & #8	Slope, running	1.4%	Yes					n/a	$ -	
F06557	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle		Slope, running	1.7%	Yes					n/a	$ -	
F06558	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#1 North	Slope, running	0.1%	Yes					n/a	$ -	
F06559	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#6	Slope, running	0.3%	Yes					n/a	$ -	
F06560	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#4	Slope, running	0.8%	Yes					n/a	$ -	
F06561	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#7	Slope, running	1.7%	Yes					n/a	$ -	
F06562	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #8 & #9	Surface marking?	Y	Yes					n/a	$ -	
F06563	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#4	Van sign?	N	Yes					n/a	$ -	
F06564	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#3	Van sign?	N	Yes					n/a	$ -	
F06565	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#5	Van sign?	N	Yes					n/a	$ -	
F06566	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#6	Van sign?	N	Yes					n/a	$ -	
F06567	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#7	Van sign?	N	Yes					n/a	$ -	
F06568	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#8	Van sign?	N	Yes					n/a	$ -	
F06569	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#9	Van sign?	N	Yes					n/a	$ -	
F06570	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#1 North	Van sign?	N	Yes					n/a	$ -	
F06571	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#2	Van sign?	N	Yes					n/a	$ -	
F06572	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	#1	Width	60	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06573	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #6 & #7	Width	60	Yes					n/a	$ -	
F06574	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #7 & #8	Width	61	Yes					n/a	$ -	
F06575	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	Between parking spaces #8 & #9	Width	60	Yes					n/a	$ -	
F06576	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle		Width	150	Yes					n/a	$ -	
F06577	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	#3	Width	60	Yes					n/a	$ -	
F06578	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#4	Width	132	Yes					n/a	$ -	
F06579	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#3	Width	132	Yes					n/a	$ -	
F06580	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#5	Width	132	Yes					n/a	$ -	
F06581	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#6	Width	132	Yes					n/a	$ -	
F06582	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#7	Width	132	Yes					n/a	$ -	
F06583	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#8	Width	132	Yes					n/a	$ -	
F06584	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#9	Width	123	Yes					n/a	$ -	
F06585	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#1 North	Width	169	Yes					n/a	$ -	
F06586	Human Service Building		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#2	Width	132	Yes					n/a	$ -	
F06590	Human Service Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Cars obstruct pathway	N	Yes					n/a	$ -	
F06591	Human Service Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, accessible	19	Yes					n/a	$ -	
F06592	Human Service Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Pathway behind cars?	N	Yes					n/a	$ -	
F06593	Human Service Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Slope, cross	1.6%	Yes					n/a	$ -	
F06594	Human Service Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Slope, running	1.9%	Yes					n/a	$ -	
F06595	Human Service Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Surface marking?	Y	Yes					n/a	$ -	
F06596	Human Service Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Surface material	Asphalt	Yes					n/a	$ -	
F11344	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F11345	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Ambulatory Compartment		Clear opening	32	Yes					n/a	$ -	
F11346	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F11347	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F11348	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clear opening	32.25	Yes					n/a	$ -	
F11349	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	Soap	Clearance, parallel	OK	Yes					n/a	$ -	
F11350	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Ambulatory Compartment		Clearance, perpendicular	94	Yes					n/a	$ -	
F11351	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	Soap	Clearance, perpendicular	OK	Yes					n/a	$ -	
F11352	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	92	Yes					n/a	$ -	
F11353	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Clearance, perpendicular	92	Yes					n/a	$ -	
F11354	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Ambulatory	Clearance, to wall	1.5	Yes					n/a	$ -	
F11355	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F11356	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Amb - Side #1	Diameter	1.5	Yes					n/a	$ -	
F11357	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Amb - Side #2	Diameter	1.5	Yes					n/a	$ -	
F11358	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Ambulatory	Diameter	1.25	Yes					n/a	$ -	
F11359	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.25	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11360	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	9	Yes					n/a	$ -	
F11361	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Ambulatory	Dimension, end to wall	12	Yes					n/a	$ -	
F11362	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F11363	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29.25	Yes					n/a	$ -	
F11364	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	28.5	Yes					n/a	$ -	
F11365	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F11366	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, wide side	42	Yes					n/a	$ -	
F11367	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Ambulatory Compartment		Door swing direction	In	Yes					n/a	$ -	
F11368	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F11369	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Ambulatory Compartment		Hardware both sides?	Y	Yes					n/a	$ -	
F11370	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	Y	Yes					n/a	$ -	
F11371	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Ambulatory Compartment		Hardware type	PP	Yes					n/a	$ -	
F11372	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Hardware type	PP	Yes					n/a	$ -	
F11373	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Alarm System		Height	84	Yes					n/a	$ -	
F11374	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Height	20	Yes					n/a	$ -	
F11375	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Mirror		Height, bottom	39.5	Yes					n/a	$ -	
F11376	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Mirror		Height, bottom	38.75	Yes					n/a	$ -	
F11377	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Height, bottom	51	Yes					n/a	$ -	
F11378	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet	Ambulatory	Height, flush control	Auto	Yes					n/a	$ -	
F11379	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet	Ambulatory	Height, seat	19	Yes					n/a	$ -	
F11380	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Height, seat	19	Yes					n/a	$ -	
F11381	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Ambulatory Compartment		Height, toe clearance	12.5	Yes					n/a	$ -	
F11382	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12.5	Yes					n/a	$ -	
F11383	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Amb - Side #1	Height, top	34	Yes					n/a	$ -	
F11384	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Amb - Side #2	Height, top	34	Yes					n/a	$ -	
F11385	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Amb - Side #1	Length	42.5	Yes					n/a	$ -	
F11386	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Amb - Side #2	Length	42.5	Yes					n/a	$ -	
F11387	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Ambulatory	Length	54	Yes					n/a	$ -	
F11388	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Length	42	Yes					n/a	$ -	
F11389	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F11390	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet	Ambulatory	Location, flush control	Auto	Yes					n/a	$ -	
F11391	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Location, flush control	Auto	Yes					n/a	$ -	
F11392	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Ambulatory Compartment		Self-closing?	Y	Yes					n/a	$ -	
F11393	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Self-closing?	Y	Yes					n/a	$ -	
F11394	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F11395	Human Service Building		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F11396	Human Service Building		Basement	Owned	Restroom	Men's	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11439	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F11440	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F11441	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Ambulatory Compartment		Clear opening	32	Yes					n/a	$ -	
F11442	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F11443	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clear opening	32	Yes					n/a	$ -	
F11444	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F11445	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Ambulatory Compartment		Clearance, perpendicular	94	Yes					n/a	$ -	
F11446	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	92	Yes					n/a	$ -	
F11447	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F11448	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F11449	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Amb - Side #1	Diameter	1.5	Yes					n/a	$ -	
F11450	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Amb - Side #2	Diameter	1.5	Yes					n/a	$ -	
F11451	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Diameter	1.25	Yes					n/a	$ -	
F11452	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.25	Yes					n/a	$ -	
F11453	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Dimension, between	12	Yes					n/a	$ -	
F11454	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F11455	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Counter		Dimension, knee clearance	38.5	Yes					n/a	$ -	
F11456	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F11457	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, wide side	41.5	Yes					n/a	$ -	
F11458	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Ambulatory Compartment		Door swing direction	In	Yes					n/a	$ -	
F11459	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F11460	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Ambulatory Compartment		Hardware both sides?	Y	Yes					n/a	$ -	
F11461	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	Y	Yes					n/a	$ -	
F11462	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Alarm System		Height	83	Yes					n/a	$ -	
F11463	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Counter		Height	33.5	Yes					n/a	$ -	
F11464	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Feminine products	Height	41	Yes					n/a	$ -	
F11465	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Height	43.5	Yes					n/a	$ -	
F11466	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Protrusion	Hand dryer	Height	48	Yes					n/a	$ -	
F11467	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Mirror		Height, bottom	39	Yes					n/a	$ -	
F11468	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Height, bottom	60	Yes					n/a	$ -	
F11469	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Height, bottom	51	Yes					n/a	$ -	
F11470	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Height, bottom	51	Yes					n/a	$ -	
F11471	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Height, seat	18.5	Yes					n/a	$ -	
F11472	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Amb - Side #1	Height, top	34	Yes					n/a	$ -	
F11473	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Amb - Side #2	Height, top	34	Yes					n/a	$ -	
F11474	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Amb - Side #1	Length	42	Yes					n/a	$ -	
F11475	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Length	54	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11476	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Length	42	Yes					n/a	$ -	
F11477	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Amb - Side #2	Length	42	Yes					n/a	$ -	
F11478	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F11479	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Location, flush control	Auto	Yes					n/a	$ -	
F11480	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	1	Yes					n/a	$ -	
F11481	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, toilet compartments	3	Yes					n/a	$ -	
F11482	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Opening force	5	Yes					n/a	$ -	
F11483	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Ambulatory Compartment		Self-closing?	Y	Yes					n/a	$ -	
F11484	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Self-closing?	Y	Yes					n/a	$ -	
F11485	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F11486	Human Service Building		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F11487	Human Service Building		Basement	Owned	Restroom	Women's	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F16284	Human Service Building		Exterior	Owned	Walkway	From Bus Stop on 72nd Street	1-Public Unsupervised	Walking Surface		Slope, cross	0.5%	Yes					n/a	$ -	
F16285	Human Service Building		Exterior	Owned	Walkway	From Bus Stop on 72nd Street	1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F16286	Human Service Building		Exterior	Owned	Walkway	From Bus Stop on 72nd Street	1-Public Unsupervised	Walking Surface		Width	63	Yes					n/a	$ -	
F16288	Human Service Building		Exterior	Owned	Walkway	West parking lot	1-Public Unsupervised	Walking Surface		Slope, cross	1.0%	Yes					n/a	$ -	
F16295	Human Service Building		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	At corner crosswalk - North side	Accumulates water?	N	Yes					n/a	$ -	
F16296	Human Service Building		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	At corner crosswalk - North side	Slope, counter	4.4%	Yes					n/a	$ -	
F16297	Human Service Building		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	At corner crosswalk - North side	Width	48	Yes					n/a	$ -	
F03533	Jim Baker Reservoir		Exterior	Owned	Fishing Pier		1-Public Unsupervised	Edge Protection		Height, curb	9	Yes					n/a	$ -	
F03534	Jim Baker Reservoir		Exterior	Owned	Fishing Pier		1-Public Unsupervised	Railing		Length, total railing	180 Feet	Yes					n/a	$ -	
F03535	Jim Baker Reservoir		Exterior	Owned	Fishing Pier		1-Public Unsupervised	Railing		Length, total railing	48	Yes					n/a	$ -	
F03536	Jim Baker Reservoir		Exterior	Owned	Fishing Pier		1-Public Unsupervised	Edge Protection		Railings exist?	Y	Yes					n/a	$ -	
F06600	Jim Baker Reservoir		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, total spaces	20	Yes					n/a	$ -	
F11494	Jim Baker Reservoir		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F11495	Jim Baker Reservoir		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Water Closet		Clearance, parallel	76	Yes					n/a	$ -	
F11496	Jim Baker Reservoir		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Water Closet		Clearance, perpendicular	68	Yes					n/a	$ -	
F11497	Jim Baker Reservoir		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Closing speed	OK	Yes					n/a	$ -	
F11498	Jim Baker Reservoir		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Signage		Dimension, characters	6	Yes					n/a	$ -	
F11499	Jim Baker Reservoir		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Water Closet		Dimension, sidewall	17	Yes					n/a	$ -	
F11500	Jim Baker Reservoir		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Water Closet		Dimension, wide side	62.25	Yes					n/a	$ -	
F11501	Jim Baker Reservoir		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Dispenser	TP	Height	24	Yes					n/a	$ -	
F11502	Jim Baker Reservoir		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Signage		Height, bottom	51	Yes					n/a	$ -	
F11503	Jim Baker Reservoir		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Water Closet		Height, flush control	N	Yes					n/a	$ -	
F11504	Jim Baker Reservoir		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Water Closet		Height, seat	18.5	Yes					n/a	$ -	
F11505	Jim Baker Reservoir		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11506	Jim Baker Reservoir		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Grab Bar	Continuous	Length	OK	Yes					n/a	$ -	
F11507	Jim Baker Reservoir		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F11508	Jim Baker Reservoir		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Water Closet		Location, flush control	OK	Yes					n/a	$ -	
F11509	Jim Baker Reservoir		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Opening force	4	Yes					n/a	$ -	
F11510	Jim Baker Reservoir		Exterior	Owned	Restroom	Unisex	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F00180	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S431	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F00181	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S431	2-Public Supervised	Door Gate		Clearance, pull parallel	26	Yes					n/a	$ -	
F00182	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S431	2-Public Supervised	Door Gate		Clearance, pull perpendicular	80	Yes					n/a	$ -	
F00183	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S431	2-Public Supervised	Door Gate		Clearance, push parallel	36	Yes					n/a	$ -	
F00184	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S431	2-Public Supervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F00185	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S431	2-Public Supervised	Door Gate		Clearance, vertical	94	Yes					n/a	$ -	
F00186	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S431	2-Public Supervised	Door Gate		Closing speed	6	Yes					n/a	$ -	
F00187	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S431	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F00188	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S431	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F00194	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S432	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F00195	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S432	2-Public Supervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F00196	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S432	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F00197	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S432	2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F00198	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S432	2-Public Supervised	Door Gate		Clearance, push perpendicular	72	Yes					n/a	$ -	
F00199	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S432	2-Public Supervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F00200	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S432	2-Public Supervised	Door Gate		Closing speed	6	Yes					n/a	$ -	
F00201	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S432	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F00202	Justice Center	ADR/Mediation Room	4th Floor	Owned	Assembly Area	#S432	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F00215	Justice Center	Self Help Resource Center	Interior	Owned	Assembly Area	Training Room	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F00216	Justice Center	Self Help Resource Center	Interior	Owned	Assembly Area	Training Room	1-Public Unsupervised	Door Gate		Clearance, pull parallel	64	Yes					n/a	$ -	
F00217	Justice Center	Self Help Resource Center	Interior	Owned	Assembly Area	Training Room	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F00218	Justice Center	Self Help Resource Center	Interior	Owned	Assembly Area	Training Room	1-Public Unsupervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F00219	Justice Center	Self Help Resource Center	Interior	Owned	Assembly Area	Training Room	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F00220	Justice Center	Self Help Resource Center	Interior	Owned	Assembly Area	Training Room	1-Public Unsupervised	Door Gate		Clearance, vertical	85	Yes					n/a	$ -	
F00221	Justice Center	Self Help Resource Center	Interior	Owned	Assembly Area	Training Room	1-Public Unsupervised	Counter	With sink	Hardware type	L	Yes					n/a	$ -	
F00222	Justice Center	Self Help Resource Center	Interior	Owned	Assembly Area	Training Room	1-Public Unsupervised	Door Gate		Hardware type	Panic bar	Yes					n/a	$ -	
F00223	Justice Center	Self Help Resource Center	Interior	Owned	Assembly Area	Training Room	1-Public Unsupervised	Dispenser	Soap	Height	42	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00224	Justice Center	Self Help Resource Center	Interior	Owned	Assembly Area	Training Room	1-Public Unsupervised	Dispenser	PT	Height	48	Yes					n/a	$ -	
F00225	Justice Center	Self Help Resource Center	Interior	Owned	Assembly Area	Training Room	1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F00226	Justice Center	Self Help Resource Center	Interior	Owned	Assembly Area	Training Room	1-Public Unsupervised	Seating Area		Seating dispersed?	Y	Yes					n/a	$ -	
F00227	Justice Center	Self Help Resource Center	Interior	Owned	Assembly Area	Training Room	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F00237	Justice Center		Interior	Owned	Assembly Area	Jury Assembly Area	1-Public Unsupervised	Counter		Clearance, parallel	30	Yes					n/a	$ -	
F00238	Justice Center		Interior	Owned	Assembly Area	Jury Assembly Area	1-Public Unsupervised	Vending Machine	Coke	Clearance, parallel	OK	Yes					n/a	$ -	
F00239	Justice Center		Interior	Owned	Assembly Area	Jury Assembly Area	1-Public Unsupervised	Counter		Clearance, perpendicular	60	Yes					n/a	$ -	
F00240	Justice Center		Interior	Owned	Assembly Area	Jury Assembly Area	1-Public Unsupervised	Vending Machine	Coke	Clearance, perpendicular	OK	Yes					n/a	$ -	
F00241	Justice Center		Interior	Owned	Assembly Area	Jury Assembly Area	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	In cabinet	Yes					n/a	$ -	
F00242	Justice Center		Interior	Owned	Assembly Area	Jury Assembly Area	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F00243	Justice Center		Interior	Owned	Assembly Area	Jury Assembly Area	1-Public Unsupervised	Vending Machine	Change machine	Height, control	46	Yes					n/a	$ -	
F00244	Justice Center		Interior	Owned	Assembly Area	Jury Assembly Area	1-Public Unsupervised	Counter		Length	69	Yes					n/a	$ -	
F00245	Justice Center		Interior	Owned	Assembly Area	Jury Assembly Area	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F00262	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Seating Area		Assistive listening systems?	Y	Yes					n/a	$ -	
F00263	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Clear opening	34	Yes					n/a	$ -	
F00264	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F00265	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F00266	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F00267	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Clearance, push parallel	9	Yes					n/a	$ -	
F00268	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Clearance, vertical	92	Yes					n/a	$ -	
F00269	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Closing speed	9	Yes					n/a	$ -	
F00270	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F00271	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	13	Yes					n/a	$ -	
F00272	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Signage		ISA?	N	Yes					n/a	$ -	
F00273	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Seating Area		Number, aisle seats	OK	Yes					n/a	$ -	
F00274	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Seating Area		Number, ALS receivers	8	Yes					n/a	$ -	
F00275	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Seating Area		Number, marked aisle seats	OK	Yes					n/a	$ -	
F00276	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Seating Area		Number, wheelchair spaces	OK	Yes					n/a	$ -	
F00277	Justice Center		Interior	Owned	Assembly Area		1-Public Unsupervised	Seating Area		Seating dispersed?	Y	Yes					n/a	$ -	
F00576	Justice Center		Interior	Owned	Break Room	#105 - South wall	3-Employee Common	Lavatory Sink		Clearance, parallel	99	Yes					n/a	$ -	
F00577	Justice Center		Interior	Owned	Break Room	#105 - South wall	3-Employee Common	Lavatory Sink		Clearance, perpendicular	55	Yes					n/a	$ -	
F00578	Justice Center		Interior	Owned	Break Room	#105 - South wall	3-Employee Common	Lavatory Sink		Drain wrapped?	In cabinet	Yes					n/a	$ -	
F00579	Justice Center		Interior	Owned	Break Room	#105 - South wall	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F00580	Justice Center		Interior	Owned	Break Room	#105 - South wall	3-Employee Common	Dispenser	Soap	Height	44.5	Yes					n/a	$ -	
F00581	Justice Center		Interior	Owned	Break Room	#105 - South wall	3-Employee Common	Counter		Length	45.5	Yes					n/a	$ -	
F00591	Justice Center		Interior	Owned	Break Room	#105 - Work Area	3-Employee Common	Counter		Clearance, parallel	60	Yes					n/a	$ -	
F00592	Justice Center		Interior	Owned	Break Room	#105 - Work Area	3-Employee Common	Lavatory Sink		Clearance, parallel	72	Yes					n/a	$ -	
F00593	Justice Center		Interior	Owned	Break Room	#105 - Work Area	3-Employee Common	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F00594	Justice Center		Interior	Owned	Break Room	#105 - Work Area	3-Employee Common	Lavatory Sink		Clearance, perpendicular	99	Yes					n/a	$ -	
F00595	Justice Center		Interior	Owned	Break Room	#105 - Work Area	3-Employee Common	Lavatory Sink		Drain wrapped?	In cabinet	Yes					n/a	$ -	
F00596	Justice Center		Interior	Owned	Break Room	#105 - Work Area	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F00597	Justice Center		Interior	Owned	Break Room	#105 - Work Area	3-Employee Common	Appliance	Refrigerator	Height	46.5	Yes					n/a	$ -	
F00598	Justice Center		Interior	Owned	Break Room	#105 - Work Area	3-Employee Common	Dispenser	Soap	Height	44.5	Yes					n/a	$ -	
F00599	Justice Center		Interior	Owned	Break Room	#105 - Work Area	3-Employee Common	Counter		Length	72	Yes					n/a	$ -	
F00605	Justice Center		4th Floor	Owned	Break Room	#405 - Staff Area	3-Employee Common	Counter		Clearance, parallel	45	Yes					n/a	$ -	
F00606	Justice Center		4th Floor	Owned	Break Room	#405 - Staff Area	3-Employee Common	Dispenser	Soap	Clearance, parallel	45	Yes					n/a	$ -	
F00607	Justice Center		4th Floor	Owned	Break Room	#405 - Staff Area	3-Employee Common	Lavatory Sink		Clearance, parallel	45	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00608	Justice Center		4th Floor	Owned	Break Room	#405 - Staff Area	3-Employee Common	Counter		Clearance, perpendicular	72	Yes					n/a	$ -	
F00609	Justice Center		4th Floor	Owned	Break Room	#405 - Staff Area	3-Employee Common	Dispenser	Soap	Clearance, perpendicular	72	Yes					n/a	$ -	
F00610	Justice Center		4th Floor	Owned	Break Room	#405 - Staff Area	3-Employee Common	Lavatory Sink		Clearance, perpendicular	72	Yes					n/a	$ -	
F00611	Justice Center		4th Floor	Owned	Break Room	#405 - Staff Area	3-Employee Common	Counter		Dimension, knee clearance	0	Yes					n/a	$ -	
F00612	Justice Center		4th Floor	Owned	Break Room	#405 - Staff Area	3-Employee Common	Lavatory Sink		Dimension, knee clearance	0	Yes					n/a	$ -	
F00613	Justice Center		4th Floor	Owned	Break Room	#405 - Staff Area	3-Employee Common	Lavatory Sink		Drain wrapped?	In cabinet	Yes					n/a	$ -	
F00614	Justice Center		4th Floor	Owned	Break Room	#405 - Staff Area	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F00615	Justice Center		4th Floor	Owned	Break Room	#405 - Staff Area	3-Employee Common	Appliance	Refrig/Freezer	Height	44	Yes					n/a	$ -	
F00616	Justice Center		4th Floor	Owned	Break Room	#405 - Staff Area	3-Employee Common	Dispenser	PT	Height	46	Yes					n/a	$ -	
F00617	Justice Center		4th Floor	Owned	Break Room	#405 - Staff Area	3-Employee Common	Dispenser	Soap	Height	43.5	Yes					n/a	$ -	
F00618	Justice Center		4th Floor	Owned	Break Room	#405 - Staff Area	3-Employee Common	Counter		Length	45	Yes					n/a	$ -	
F00623	Justice Center		6th Floor	Owned	Break Room	#605 - Staff Area	3-Employee Common	Appliance	Microwave	Height	44	Yes					n/a	$ -	
F00624	Justice Center		6th Floor	Owned	Break Room	#605 - Staff Area	3-Employee Common	Dispenser	Soap	Height	43	Yes					n/a	$ -	
F00625	Justice Center		6th Floor	Owned	Break Room	#605 - Staff Area	3-Employee Common	Dispenser	PT	Height	48	Yes					n/a	$ -	
F00626	Justice Center		6th Floor	Owned	Break Room	#605 - Staff Area	3-Employee Common	Lavatory Sink		Other attribute	In Cabinet	Yes					n/a	$ -	
F00634	Justice Center		4th Floor	Owned	Break Room	#S437	3-Employee Common	Counter		Clearance, parallel	OK	Yes					n/a	$ -	
F00635	Justice Center		4th Floor	Owned	Break Room	#S437	3-Employee Common	Counter		Clearance, perpendicular	OK	Yes					n/a	$ -	
F00636	Justice Center		4th Floor	Owned	Break Room	#S437	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F00637	Justice Center		4th Floor	Owned	Break Room	#S437	3-Employee Common	Appliance	Refrig/Freezer	Height	44	Yes					n/a	$ -	
F00638	Justice Center		4th Floor	Owned	Break Room	#S437	3-Employee Common	Counter		Length	64	Yes					n/a	$ -	
F00641	Justice Center		6th Floor	Owned	Break Room	Near #S640 AV Closet	3-Employee Common	Appliance	Refrigerator	Height	45	Yes					n/a	$ -	
F00642	Justice Center		6th Floor	Owned	Break Room	Near #S640 AV Closet	3-Employee Common	Lavatory Sink		Other attribute	In Cabinet	Yes					n/a	$ -	
F00648	Justice Center		5th Floor	Owned	Break Room	South	3-Employee Common	Appliance	Refrigerator	Clearance, parallel	OK	Yes					n/a	$ -	
F00649	Justice Center		5th Floor	Owned	Break Room	South	3-Employee Common	Counter		Clearance, parallel	64	Yes					n/a	$ -	
F00650	Justice Center		5th Floor	Owned	Break Room	South	3-Employee Common	Lavatory Sink		Clearance, parallel	OK	Yes					n/a	$ -	
F00651	Justice Center		5th Floor	Owned	Break Room	South	3-Employee Common	Appliance	Refrigerator	Clearance, perpendicular	OK	Yes					n/a	$ -	
F00652	Justice Center		5th Floor	Owned	Break Room	South	3-Employee Common	Counter		Clearance, perpendicular	68	Yes					n/a	$ -	
F00653	Justice Center		5th Floor	Owned	Break Room	South	3-Employee Common	Lavatory Sink		Clearance, perpendicular	OK	Yes					n/a	$ -	
F00654	Justice Center		5th Floor	Owned	Break Room	South	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F00655	Justice Center		5th Floor	Owned	Break Room	South	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F00656	Justice Center		5th Floor	Owned	Break Room	South	3-Employee Common	Appliance	Refrigerator	Height	44.5	Yes					n/a	$ -	
F00657	Justice Center		5th Floor	Owned	Break Room	South	3-Employee Common	Counter		Length	63	Yes					n/a	$ -	
F00669	Justice Center		Interior	Owned	Break Room		3-Employee Common	Door Gate		Clear opening	35.5	Yes					n/a	$ -	
F00670	Justice Center		5th Floor	Owned	Break Room		3-Employee Common	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F00671	Justice Center		Interior	Owned	Break Room		3-Employee Common	Counter		Clearance, parallel	90	Yes					n/a	$ -	
F00672	Justice Center		5th Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Clearance, parallel	99	Yes					n/a	$ -	
F00673	Justice Center		5th Floor	Owned	Break Room		3-Employee Common	Counter		Clearance, perpendicular	64	Yes					n/a	$ -	
F00674	Justice Center		Interior	Owned	Break Room		3-Employee Common	Counter		Clearance, perpendicular	66	Yes					n/a	$ -	
F00675	Justice Center		5th Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Clearance, perpendicular	64	Yes					n/a	$ -	
F00676	Justice Center		Interior	Owned	Break Room		3-Employee Common	Door Gate		Clearance, vertical	82	Yes					n/a	$ -	
F00677	Justice Center		Interior	Owned	Break Room		3-Employee Common	Operable Part	Garbage disposal switch	Depth, obstruction	24.75	Yes					n/a	$ -	
F00678	Justice Center		5th Floor	Owned	Break Room		3-Employee Common	Counter		Dimension, knee clearance	0	Yes					n/a	$ -	
F00679	Justice Center		5th Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Dimension, knee clearance	0	Yes					n/a	$ -	
F00680	Justice Center		Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Dimension, knee clearance	OK	Yes					n/a	$ -	
F00681	Justice Center		5th Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F00682	Justice Center		Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Drain wrapped?	OK	Yes					n/a	$ -	
F00683	Justice Center		5th Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F00684	Justice Center		Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F00685	Justice Center		Interior	Owned	Break Room		3-Employee Common	Appliance	Refrigerator	Height	46	Yes					n/a	$ -	
F00686	Justice Center		5th Floor	Owned	Break Room		3-Employee Common	Dispenser	Soap	Height	43.5	Yes					n/a	$ -	
F00687	Justice Center		5th Floor	Owned	Break Room		3-Employee Common	Dispenser	PT	Height	46.5	Yes					n/a	$ -	
F00688	Justice Center		Interior	Owned	Break Room		3-Employee Common	Dispenser	Soap	Height	44	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00689	Justice Center		Interior	Owned	Break Room		3-Employee Common	Operable Part	Garbage disposal switch	Height	42	Yes					n/a	$ -	
F00690	Justice Center		Interior	Owned	Break Room		3-Employee Common	Operable Part	Garbage disposal switch	height, obstruction	36.25	Yes					n/a	$ -	
F00691	Justice Center		5th Floor	Owned	Break Room		3-Employee Common	Counter		Length	45	Yes					n/a	$ -	
F00692	Justice Center		Interior	Owned	Break Room		3-Employee Common	Counter		Length	90	Yes					n/a	$ -	
F00871	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate	To exterior Courtyard	Clear opening	32.5	Yes					n/a	$ -	
F00872	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F00873	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Counter	Tray slide	Clearance, parallel	99	Yes					n/a	$ -	
F00874	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Counter	At cash register	Clearance, parallel	99	Yes					n/a	$ -	
F00875	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Counter	Condiment countertop	Clearance, parallel	43	Yes					n/a	$ -	
F00876	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Vending Machine	Pepsi	Clearance, parallel	OK	Yes					n/a	$ -	
F00877	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Vending Machine	Snacks	Clearance, parallel	OK	Yes					n/a	$ -	
F00878	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Vending Machine	Soft drink counter dispenser	Clearance, parallel	60	Yes					n/a	$ -	
F00879	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Counter	Tray slide	Clearance, perpendicular	66	Yes					n/a	$ -	
F00880	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Counter	At cash register	Clearance, perpendicular	66	Yes					n/a	$ -	
F00881	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Counter	Condiment countertop	Clearance, perpendicular	99	Yes					n/a	$ -	
F00882	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Vending Machine	Pepsi	Clearance, perpendicular	OK	Yes					n/a	$ -	
F00883	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Vending Machine	Snacks	Clearance, perpendicular	OK	Yes					n/a	$ -	
F00884	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Vending Machine	Soft drink counter dispenser	Clearance, perpendicular	76	Yes					n/a	$ -	
F00885	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate		Clearance, pull parallel	38	Yes					n/a	$ -	
F00886	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate	To exterior Courtyard	Clearance, pull parallel	99	Yes					n/a	$ -	
F00887	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F00888	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate	To exterior Courtyard	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F00889	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate		Clearance, push parallel	80	Yes					n/a	$ -	
F00890	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F00891	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate	To exterior Courtyard	Clearance, push perpendicular	99	Yes					n/a	$ -	
F00892	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate		Clearance, vertical	92	Yes					n/a	$ -	
F00893	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate	To exterior Courtyard	Clearance, vertical	91	Yes					n/a	$ -	
F00894	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate		Closing speed	10	Yes					n/a	$ -	
F00895	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate	To exterior Courtyard	Closing speed	6	Yes					n/a	$ -	
F00896	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Counter	Tray slide	Dimension, knee clearance	33	Yes					n/a	$ -	
F00897	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Counter	Condiment countertop	Dimension, knee clearance	34.75	Yes					n/a	$ -	
F00898	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate		Hardware type	Panic bar	Yes					n/a	$ -	
F00899	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate	To exterior Courtyard	Hardware type	Panic bar	Yes					n/a	$ -	
F00900	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Alarm System		Height	89.75	Yes					n/a	$ -	
F00901	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Counter	Tray slide	Height	34	Yes					n/a	$ -	
F00902	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F00903	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Door Gate	To exterior Courtyard	Height, smooth surface (kick plate)	11.5	Yes					n/a	$ -	
F00904	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Counter	Tray slide	Length	99	Yes					n/a	$ -	
F00905	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Counter	At cash register	Length	99	Yes					n/a	$ -	
F00906	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Counter	Condiment countertop	Length	54	Yes					n/a	$ -	
F00907	Justice Center		1st Floor	Owned	Cafeteria	#176 - Kitchen	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F01008	Justice Center		2nd Floor	Owned	Conference Room	#258	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F01009	Justice Center		2nd Floor	Owned	Conference Room	#258	2-Public Supervised	Door Gate		Clearance, pull parallel	42	Yes					n/a	$ -	
F01010	Justice Center		2nd Floor	Owned	Conference Room	#258	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F01011	Justice Center		2nd Floor	Owned	Conference Room	#258	2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F01012	Justice Center		2nd Floor	Owned	Conference Room	#258	2-Public Supervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F01013	Justice Center		2nd Floor	Owned	Conference Room	#258	2-Public Supervised	Door Gate		Clearance, vertical	93	Yes					n/a	$ -	
F01014	Justice Center		2nd Floor	Owned	Conference Room	#258	2-Public Supervised	Signage		Dimension, characters	0.75	Yes					n/a	$ -	
F01015	Justice Center		2nd Floor	Owned	Conference Room	#258	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F01016	Justice Center		2nd Floor	Owned	Conference Room	#258	2-Public Supervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F01017	Justice Center		2nd Floor	Owned	Conference Room	#258	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F01018	Justice Center		2nd Floor	Owned	Conference Room	#258	2-Public Supervised	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F01019	Justice Center		2nd Floor	Owned	Conference Room	#258	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	
F01020	Justice Center		2nd Floor	Owned	Conference Room	#258	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F01022	Justice Center		5th Floor	Owned	Conference Room	#511	2-Public Supervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F01023	Justice Center		5th Floor	Owned	Conference Room	#511	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F01024	Justice Center		5th Floor	Owned	Conference Room	#511	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	
F01025	Justice Center		5th Floor	Owned	Conference Room	#511	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F01032	Justice Center		5th Floor	Owned	Conference Room	#512	2-Public Supervised	Door Gate		Clearance, pull parallel	47	Yes					n/a	$ -	
F01033	Justice Center		5th Floor	Owned	Conference Room	#512	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F01034	Justice Center		5th Floor	Owned	Conference Room	#512	2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F01035	Justice Center		5th Floor	Owned	Conference Room	#512	2-Public Supervised	Door Gate		Clearance, push perpendicular	82	Yes					n/a	$ -	
F01036	Justice Center		5th Floor	Owned	Conference Room	#512	2-Public Supervised	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F01037	Justice Center		5th Floor	Owned	Conference Room	#512	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F01038	Justice Center		5th Floor	Owned	Conference Room	#512	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F01039	Justice Center		5th Floor	Owned	Conference Room	#512	2-Public Supervised	Door Gate		Opening force	1	Yes					n/a	$ -	
F01047	Justice Center		5th Floor	Owned	Conference Room	#512 - Family Court	2-Public Supervised	Signage		Braille?	Y	Yes					n/a	$ -	
F01048	Justice Center		5th Floor	Owned	Conference Room	#512 - Family Court	2-Public Supervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F01049	Justice Center		5th Floor	Owned	Conference Room	#512 - Family Court	2-Public Supervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F01050	Justice Center		5th Floor	Owned	Conference Room	#512 - Family Court	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F01051	Justice Center		5th Floor	Owned	Conference Room	#512 - Family Court	2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F01052	Justice Center		5th Floor	Owned	Conference Room	#512 - Family Court	2-Public Supervised	Door Gate		Clearance, push perpendicular	83	Yes					n/a	$ -	
F01053	Justice Center		5th Floor	Owned	Conference Room	#512 - Family Court	2-Public Supervised	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F01054	Justice Center		5th Floor	Owned	Conference Room	#512 - Family Court	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F01055	Justice Center		5th Floor	Owned	Conference Room	#512 - Family Court	2-Public Supervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F01056	Justice Center		5th Floor	Owned	Conference Room	#512 - Family Court	2-Public Supervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F01057	Justice Center		5th Floor	Owned	Conference Room	#512 - Family Court	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F01058	Justice Center		5th Floor	Owned	Conference Room	#512 - Family Court	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F01059	Justice Center		5th Floor	Owned	Conference Room	#512 - Family Court	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F01060	Justice Center		5th Floor	Owned	Conference Room	#512 - Family Court	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	
F01061	Justice Center		5th Floor	Owned	Conference Room	#512 - Family Court	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	
F01062	Justice Center		5th Floor	Owned	Conference Room	#512 - Family Court	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F01063	Justice Center		5th Floor	Owned	Conference Room	#512 - Family Court	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F01069	Justice Center		5th Floor	Owned	Conference Room	#512 - Family Court	2-Public Supervised	Door Gate		Height, threshold	0	Yes					n/a	$ -	
F01070	Justice Center		5th Floor	Owned	Conference Room	#552	2-Public Supervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F01071	Justice Center		5th Floor	Owned	Conference Room	#552	2-Public Supervised	Door Gate		Clearance, pull parallel	46	Yes					n/a	$ -	
F01072	Justice Center		5th Floor	Owned	Conference Room	#552	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F01073	Justice Center		5th Floor	Owned	Conference Room	#552	2-Public Supervised	Door Gate		Clearance, push parallel	46	Yes					n/a	$ -	
F01074	Justice Center		5th Floor	Owned	Conference Room	#552	2-Public Supervised	Door Gate		Clearance, push perpendicular	82	Yes					n/a	$ -	
F01075	Justice Center		5th Floor	Owned	Conference Room	#552	2-Public Supervised	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F01076	Justice Center		5th Floor	Owned	Conference Room	#552	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F01077	Justice Center		5th Floor	Owned	Conference Room	#552	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F01078	Justice Center		5th Floor	Owned	Conference Room	#552	2-Public Supervised	Door Gate		Opening force	2	Yes					n/a	$ -	
F01088	Justice Center		4th Floor	Owned	Conference Room	#S410	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F01089	Justice Center		4th Floor	Owned	Conference Room	#S410	2-Public Supervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F01090	Justice Center		4th Floor	Owned	Conference Room	#S410	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F01091	Justice Center		4th Floor	Owned	Conference Room	#S410	2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F01092	Justice Center		4th Floor	Owned	Conference Room	#S410	2-Public Supervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F01093	Justice Center		4th Floor	Owned	Conference Room	#S410	2-Public Supervised	Door Gate		Clearance, vertical	94	Yes					n/a	$ -	
F01094	Justice Center		4th Floor	Owned	Conference Room	#S410	2-Public Supervised	Signage		Dimension, characters	.75	Yes					n/a	$ -	
F01095	Justice Center		4th Floor	Owned	Conference Room	#S410	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F01096	Justice Center		4th Floor	Owned	Conference Room	#S410	2-Public Supervised	Signage		Height, bottom	58.25	Yes					n/a	$ -	
F01097	Justice Center		4th Floor	Owned	Conference Room	#S410	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F01098	Justice Center		4th Floor	Owned	Conference Room	#S410	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F01105	Justice Center		5th Floor	Owned	Conference Room	#552	2-Public Supervised	Door Gate		Height, threshold	0	Yes					n/a	$ -	
F01106	Justice Center		5th Floor	Owned	Conference Room	#S510	2-Public Supervised	Door Gate		Approach type, push	Y	Yes					n/a	$ -	
F01107	Justice Center		5th Floor	Owned	Conference Room	#S510	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F01108	Justice Center		5th Floor	Owned	Conference Room	#S510	2-Public Supervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F01109	Justice Center		5th Floor	Owned	Conference Room	#S510	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F01110	Justice Center		5th Floor	Owned	Conference Room	#S510	2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F01111	Justice Center		5th Floor	Owned	Conference Room	#S510	2-Public Supervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F01112	Justice Center		5th Floor	Owned	Conference Room	#S510	2-Public Supervised	Door Gate		Clearance, vertical	94	Yes					n/a	$ -	
F01113	Justice Center		5th Floor	Owned	Conference Room	#S510	2-Public Supervised	Door Gate		Closing speed	6	Yes					n/a	$ -	
F01114	Justice Center		5th Floor	Owned	Conference Room	#S510	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F01115	Justice Center		5th Floor	Owned	Conference Room	#S510	2-Public Supervised	Signage		Height, bottom	57.75	Yes					n/a	$ -	
F01116	Justice Center		5th Floor	Owned	Conference Room	#S510	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F01117	Justice Center		5th Floor	Owned	Conference Room	#S510	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F01118	Justice Center		5th Floor	Owned	Conference Room	#S510	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F01128	Justice Center		2nd Floor	Owned	Conference Room	Court 201 - Inside double door area	2-Public Supervised	Door Gate	Room 1	Clear opening	33	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F01129	Justice Center		2nd Floor	Owned	Conference Room	Court 201 - Inside double door area	2-Public Supervised	Door Gate	Room 2 - #228	Clear opening	33	Yes					n/a	$ -	
F01130	Justice Center		2nd Floor	Owned	Conference Room	Court 201 - Inside double door area	2-Public Supervised	Door Gate	Room 1	Clearance, pull parallel	46	Yes					n/a	$ -	
F01131	Justice Center		2nd Floor	Owned	Conference Room	Court 201 - Inside double door area	2-Public Supervised	Door Gate	Room 2 - #228	Clearance, pull parallel	46	Yes					n/a	$ -	
F01132	Justice Center		2nd Floor	Owned	Conference Room	Court 201 - Inside double door area	2-Public Supervised	Door Gate	Room 1	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F01133	Justice Center		2nd Floor	Owned	Conference Room	Court 201 - Inside double door area	2-Public Supervised	Door Gate	Room 2 - #228	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F01134	Justice Center		2nd Floor	Owned	Conference Room	Court 201 - Inside double door area	2-Public Supervised	Door Gate	Room 1	Clearance, push parallel	46	Yes					n/a	$ -	
F01135	Justice Center		2nd Floor	Owned	Conference Room	Court 201 - Inside double door area	2-Public Supervised	Door Gate	Room 2 - #228	Clearance, push parallel	46	Yes					n/a	$ -	
F01136	Justice Center		2nd Floor	Owned	Conference Room	Court 201 - Inside double door area	2-Public Supervised	Door Gate	Room 1	Clearance, push perpendicular	82	Yes					n/a	$ -	
F01137	Justice Center		2nd Floor	Owned	Conference Room	Court 201 - Inside double door area	2-Public Supervised	Door Gate	Room 2 - #228	Clearance, push perpendicular	82	Yes					n/a	$ -	
F01138	Justice Center		2nd Floor	Owned	Conference Room	Court 201 - Inside double door area	2-Public Supervised	Door Gate	Room 1	Clearance, vertical	83	Yes					n/a	$ -	
F01139	Justice Center		2nd Floor	Owned	Conference Room	Court 201 - Inside double door area	2-Public Supervised	Door Gate	Room 2 - #228	Clearance, vertical	83	Yes					n/a	$ -	
F01140	Justice Center		2nd Floor	Owned	Conference Room	Court 201 - Inside double door area	2-Public Supervised	Door Gate	Room 1	Hardware type	L	Yes					n/a	$ -	
F01141	Justice Center		2nd Floor	Owned	Conference Room	Court 201 - Inside double door area	2-Public Supervised	Door Gate	Room 2 - #228	Hardware type	L	Yes					n/a	$ -	
F01142	Justice Center		2nd Floor	Owned	Conference Room	Court 201 - Inside double door area	2-Public Supervised	Door Gate	Room 1	Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F01143	Justice Center		2nd Floor	Owned	Conference Room	Court 201 - Inside double door area	2-Public Supervised	Door Gate	Room 2 - #228	Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F01159	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F01160	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Counter		Clearance, parallel	48	Yes					n/a	$ -	
F01161	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Lavatory Sink		Clearance, parallel	48	Yes					n/a	$ -	
F01162	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F01163	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Lavatory Sink		Clearance, perpendicular	99	Yes					n/a	$ -	
F01164	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Door Gate		Clearance, pull parallel	46	Yes					n/a	$ -	
F01165	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Door Gate		Clearance, push parallel	76	Yes					n/a	$ -	
F01166	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F01167	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F01168	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Lavatory Sink		Drain wrapped?	In cabinet	Yes					n/a	$ -	
F01169	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F01170	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F01171	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Dispenser	Soap	Height	44	Yes					n/a	$ -	
F01172	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Dispenser	PT	Height	48	Yes					n/a	$ -	
F01173	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F01174	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 235	2-Public Supervised	Counter		Length	47	Yes					n/a	$ -	
F01180	Justice Center		2nd Floor	Owned	Conference Room	Jury Room 239	2-Public Supervised	Dispenser		Other attribute	48	Yes					n/a	$ -	
F01195	Justice Center		3rd Floor	Owned	Conference Room	Jury Room 329	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F01222	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F01223	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Lavatory Sink		Clearance, parallel	48	Yes					n/a	$ -	
F01224	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Lavatory Sink		Clearance, perpendicular	99	Yes					n/a	$ -	
F01225	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Door Gate		Clearance, pull parallel	48	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F01226	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F01227	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Door Gate		Clearance, push perpendicular	64	Yes					n/a	$ -	
F01228	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F01229	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Signage		Dimension, characters	.75	Yes					n/a	$ -	
F01230	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Counter		Dimension, knee clearance	0	Yes					n/a	$ -	
F01231	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	0	Yes					n/a	$ -	
F01232	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F01233	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F01234	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Dispenser	PT	Height	47.75	Yes					n/a	$ -	
F01235	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Dispenser	Soap	Height	43.25	Yes					n/a	$ -	
F01236	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F01237	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F01238	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Counter		Length	47	Yes					n/a	$ -	
F01239	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	
F01240	Justice Center		4th Floor	Owned	Conference Room	Jury Room 421	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F01257	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F01258	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Counter		Clearance, parallel	48	Yes					n/a	$ -	
F01259	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Lavatory Sink		Clearance, parallel	48	Yes					n/a	$ -	
F01260	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F01261	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Lavatory Sink		Clearance, perpendicular	99	Yes					n/a	$ -	
F01262	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Door Gate		Clearance, pull parallel	48	Yes					n/a	$ -	
F01263	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Door Gate		Clearance, pull parallel	72	Yes					n/a	$ -	
F01264	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F01265	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F01266	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Door Gate		Clearance, push parallel	12	Yes					n/a	$ -	
F01267	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Door Gate		Clearance, push perpendicular	64	Yes					n/a	$ -	
F01268	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Door Gate		Clearance, push perpendicular	86	Yes					n/a	$ -	
F01269	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F01270	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F01271	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F01272	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Signage		Dimension, characters	.75	Yes					n/a	$ -	
F01273	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Counter		Dimension, knee clearance	0	Yes					n/a	$ -	
F01274	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	0	Yes					n/a	$ -	
F01275	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F01276	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F01277	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F01278	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Dispenser	Soap	Height	43	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F01279	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Dispenser	PT	Height	48	Yes					n/a	$ -	
F01280	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F01281	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F01282	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F01283	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Counter		Length	47	Yes					n/a	$ -	
F01284	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	
F01285	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F01286	Justice Center		4th Floor	Owned	Conference Room	Jury Room 425	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F01300	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F01301	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Counter		Clearance, parallel	48	Yes					n/a	$ -	
F01302	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Lavatory Sink		Clearance, parallel	48	Yes					n/a	$ -	
F01303	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F01304	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Lavatory Sink		Clearance, perpendicular	99	Yes					n/a	$ -	
F01305	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Door Gate		Clearance, pull parallel	48	Yes					n/a	$ -	
F01306	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F01307	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Door Gate		Clearance, push perpendicular	58	Yes					n/a	$ -	
F01308	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F01309	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Door Gate		Closing speed	7	Yes					n/a	$ -	
F01310	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Counter		Dimension, knee clearance	0	Yes					n/a	$ -	
F01311	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	0	Yes					n/a	$ -	
F01312	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F01313	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Dispenser	PT	Height	46.5	Yes					n/a	$ -	
F01314	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Dispenser	Soap	Height	43	Yes					n/a	$ -	
F01315	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Door Gate		Height, hardware	OK	Yes					n/a	$ -	
F01316	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F01317	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Counter		Length	48	Yes					n/a	$ -	
F01318	Justice Center		4th Floor	Owned	Conference Room	Jury Room 465	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F01333	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F01334	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Counter		Clearance, parallel	48	Yes					n/a	$ -	
F01335	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Lavatory Sink		Clearance, parallel	48	Yes					n/a	$ -	
F01336	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F01337	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Lavatory Sink		Clearance, perpendicular	99	Yes					n/a	$ -	
F01338	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F01339	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F01340	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Door Gate		Clearance, push perpendicular	58	Yes					n/a	$ -	
F01341	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F01342	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Door Gate		Closing speed	5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F01343	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Counter		Dimension, knee clearance	0	Yes					n/a	$ -	
F01344	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	0	Yes					n/a	$ -	
F01345	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F01346	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F01347	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Alarm System		Height	Ceiling mount	Yes					n/a	$ -	
F01348	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Dispenser	Soap	Height	42.25	Yes					n/a	$ -	
F01349	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Dispenser	PT	Height	46	Yes					n/a	$ -	
F01350	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F01351	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F01352	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Counter		Length	47.5	Yes					n/a	$ -	
F01353	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F01354	Justice Center		4th Floor	Owned	Conference Room	Jury Room 470	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F01368	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F01369	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Counter		Clearance, parallel	48	Yes					n/a	$ -	
F01370	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Lavatory Sink		Clearance, parallel	48	Yes					n/a	$ -	
F01371	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F01372	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Lavatory Sink		Clearance, perpendicular	99	Yes					n/a	$ -	
F01373	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Door Gate		Clearance, pull parallel	48	Yes					n/a	$ -	
F01374	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F01375	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Door Gate		Clearance, push perpendicular	77	Yes					n/a	$ -	
F01376	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F01377	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Counter		Dimension, knee clearance	0	Yes					n/a	$ -	
F01378	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	0	Yes					n/a	$ -	
F01379	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Lavatory Sink		Drain wrapped?	In cabinet	Yes					n/a	$ -	
F01380	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F01381	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F01382	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Dispenser	Soap	Height	44	Yes					n/a	$ -	
F01383	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Dispenser	PT	Height	44	Yes					n/a	$ -	
F01384	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F01385	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F01386	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F01387	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Counter		Length	47	Yes					n/a	$ -	
F01388	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	
F01389	Justice Center		5th Floor	Owned	Conference Room	Jury Room 524	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F01403	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F01404	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F01405	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Lavatory Sink		Clearance, parallel	99	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F01406	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F01407	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Lavatory Sink		Clearance, perpendicular	99	Yes					n/a	$ -	
F01408	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Door Gate		Clearance, pull parallel	56	Yes					n/a	$ -	
F01409	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F01410	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Door Gate		Clearance, push perpendicular	60	Yes					n/a	$ -	
F01411	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F01412	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Counter		Dimension, knee clearance	0	Yes					n/a	$ -	
F01413	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	0	Yes					n/a	$ -	
F01414	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F01415	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F01416	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F01417	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Alarm System		Height	Ceiling mount	Yes					n/a	$ -	
F01418	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Counter		Height	36	Yes					n/a	$ -	
F01419	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Dispenser	Soap	Height	44	Yes					n/a	$ -	
F01420	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Dispenser	PT	Height	46	Yes					n/a	$ -	
F01421	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F01422	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F01423	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F01424	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Counter		Length	46.5	Yes					n/a	$ -	
F01425	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	
F01426	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F01427	Justice Center		5th Floor	Owned	Conference Room	Jury Room 568	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F01436	Justice Center		6th Floor	Owned	Conference Room	Jury Room 631	2-Public Supervised	Counter		Height	36	Yes					n/a	$ -	
F01437	Justice Center		6th Floor	Owned	Conference Room	Jury Room 631	2-Public Supervised	Dispenser	Soap	Height	46	Yes					n/a	$ -	
F01438	Justice Center		6th Floor	Owned	Conference Room	Jury Room 631	2-Public Supervised	Lavatory Sink		Other attribute	In Cabinet	Yes					n/a	$ -	
F01455	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F01456	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Clear opening	33.5	Yes					n/a	$ -	
F01457	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Counter		Clearance, parallel	60	Yes					n/a	$ -	
F01458	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Lavatory Sink		Clearance, parallel	60	Yes					n/a	$ -	
F01459	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F01460	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Lavatory Sink		Clearance, perpendicular	99	Yes					n/a	$ -	
F01461	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Clearance, pull parallel	52.5	Yes					n/a	$ -	
F01462	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F01463	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F01464	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F01465	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Clearance, push parallel	15	Yes					n/a	$ -	
F01466	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Clearance, push perpendicular	61	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F01467	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F01468	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F01469	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F01470	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F01471	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Counter		Dimension, knee clearance	0	Yes					n/a	$ -	
F01472	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	0	Yes					n/a	$ -	
F01473	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Lavatory Sink		Drain wrapped?	In cabinet	Yes					n/a	$ -	
F01474	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F01475	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F01476	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Other Element	Wall mounted phone	Height	48	Yes					n/a	$ -	
F01477	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Height, hardware	OK	Yes					n/a	$ -	
F01478	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F01479	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F01480	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Counter		Length	45	Yes					n/a	$ -	
F01481	Justice Center		4th Floor	Owned	Conference Room	Jury Room S422	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F01503	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F01504	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F01505	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F01506	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F01507	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Dispenser	PT	Clearance, parallel	99	Yes					n/a	$ -	
F01508	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F01509	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F01510	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Dispenser	PT	Clearance, perpendicular	99	Yes					n/a	$ -	
F01511	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Clearance, pull parallel	52.5	Yes					n/a	$ -	
F01512	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Clearance, pull parallel	52	Yes					n/a	$ -	
F01513	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Clearance, pull perpendicular	60	Yes					n/a	$ -	
F01514	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F01515	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F01516	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Clearance, push perpendicular	69	Yes					n/a	$ -	
F01517	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Clearance, push perpendicular	62	Yes					n/a	$ -	
F01518	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F01519	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F01520	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Counter		Dimension, knee clearance	0	Yes					n/a	$ -	
F01521	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F01522	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F01523	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F01524	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Alarm System		Height	Ceiling mount	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F01525	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Counter		Height	36	Yes					n/a	$ -	
F01526	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Signage		Height, bottom	57.75	Yes					n/a	$ -	
F01527	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F01528	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F01529	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F01530	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F01531	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F01532	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Counter		Length	46.75	Yes					n/a	$ -	
F01533	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Counter		Length	46	Yes					n/a	$ -	
F01534	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	
F01535	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	
F01536	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F01537	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F01538	Justice Center		5th Floor	Owned	Conference Room	Jury Room S522	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F01546	Justice Center		6th Floor	Owned	Conference Room	Jury Room S622	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F01547	Justice Center		6th Floor	Owned	Conference Room	Jury Room S622	2-Public Supervised	Door Gate		Clearance, pull parallel	48	Yes					n/a	$ -	
F01548	Justice Center		6th Floor	Owned	Conference Room	Jury Room S622	2-Public Supervised	Door Gate		Clearance, pull perpendicular	48	Yes					n/a	$ -	
F01549	Justice Center		6th Floor	Owned	Conference Room	Jury Room S622	2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F01550	Justice Center		6th Floor	Owned	Conference Room	Jury Room S622	2-Public Supervised	Door Gate		Clearance, push perpendicular	61	Yes					n/a	$ -	
F01551	Justice Center		6th Floor	Owned	Conference Room	Jury Room S622	2-Public Supervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F01552	Justice Center		6th Floor	Owned	Conference Room	Jury Room S622	2-Public Supervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F01553	Justice Center		6th Floor	Owned	Conference Room	Jury Room S622	2-Public Supervised	Counter		Height	36	Yes					n/a	$ -	
F01554	Justice Center		6th Floor	Owned	Conference Room	Jury Room S622	2-Public Supervised	Lavatory Sink		Other attribute	In Cabinet	Yes					n/a	$ -	
F01555	Justice Center		5th Floor	Owned	Conference Room	#S510	2-Public Supervised	Door Gate		Threshold beveled?	Y	Yes					n/a	$ -	
F01586	Justice Center	Traffic Court	2nd Floor	Owned	Courtroom	#251	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F01587	Justice Center	Traffic Court	2nd Floor	Owned	Courtroom	#251	2-Public Supervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F01588	Justice Center	Traffic Court	2nd Floor	Owned	Courtroom	#251	2-Public Supervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F01589	Justice Center	Traffic Court	2nd Floor	Owned	Courtroom	#251	2-Public Supervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F01590	Justice Center	Traffic Court	2nd Floor	Owned	Courtroom	#251	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F01591	Justice Center	Traffic Court	2nd Floor	Owned	Courtroom	#251	2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F01592	Justice Center	Traffic Court	2nd Floor	Owned	Courtroom	#251	2-Public Supervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F01593	Justice Center	Traffic Court	2nd Floor	Owned	Courtroom	#251	2-Public Supervised	Door Gate		Clearance, vertical	93	Yes					n/a	$ -	
F01594	Justice Center	Traffic Court	2nd Floor	Owned	Courtroom	#251	2-Public Supervised	Counter		Dimension, knee clearance	41	Yes					n/a	$ -	
F01595	Justice Center	Traffic Court	2nd Floor	Owned	Courtroom	#251	2-Public Supervised	Door Gate		Hardware type	Panic bar	Yes					n/a	$ -	
F01596	Justice Center	Traffic Court	2nd Floor	Owned	Courtroom	#251	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F01597	Justice Center	Traffic Court	2nd Floor	Owned	Courtroom	#251	2-Public Supervised	Counter		Length	99	Yes					n/a	$ -	
F01633	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Wheelchair Space	Spectator	Adjacent wheelchair space?	Y	Yes					n/a	$ -	
F01634	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Court staff entrance	Clear opening	33	Yes					n/a	$ -	
F01635	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Jury entrance	Clear opening	33	Yes					n/a	$ -	
F01636	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Counter	Clerk	Clearance, parallel	99	Yes					n/a	$ -	
F01637	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Courtroom Station		Clearance, parallel	85	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F01638	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Judge Bench		Clearance, parallel	72	Yes					n/a	$ -	
F01639	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Jury Box		Clearance, parallel	38	Yes					n/a	$ -	
F01640	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Witness Stand		Clearance, parallel	48	Yes					n/a	$ -	
F01641	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Counter	Clerk	Clearance, perpendicular	99	Yes					n/a	$ -	
F01642	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Courtroom Station		Clearance, perpendicular	76	Yes					n/a	$ -	
F01643	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Judge Bench		Clearance, perpendicular	76	Yes					n/a	$ -	
F01644	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Jury Box		Clearance, perpendicular	48	Yes					n/a	$ -	
F01645	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Witness Stand		Clearance, perpendicular	76	Yes					n/a	$ -	
F01646	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Court staff entrance	Clearance, pull parallel	20	Yes					n/a	$ -	
F01647	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Jury entrance	Clearance, pull parallel	76	Yes					n/a	$ -	
F01648	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Court staff entrance	Clearance, pull perpendicular	77	Yes					n/a	$ -	
F01649	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Jury entrance	Clearance, pull perpendicular	76	Yes					n/a	$ -	
F01650	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Jury entrance	Clearance, push parallel	99	Yes					n/a	$ -	
F01651	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Court staff entrance	Clearance, push perpendicular	99	Yes					n/a	$ -	
F01652	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Jury entrance	Clearance, push perpendicular	99	Yes					n/a	$ -	
F01653	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Court staff entrance	Clearance, vertical	93	Yes					n/a	$ -	
F01654	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Jury entrance	Clearance, vertical	93	Yes					n/a	$ -	
F01655	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Wheelchair Space	Spectator	Companion seat?	Y	Yes					n/a	$ -	
F01656	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Wheelchair Space	Spectator	Depth	48	Yes					n/a	$ -	
F01657	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Counter	Clerk	Dimension, knee clearance	0	Yes					n/a	$ -	
F01658	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Court staff entrance	Hardware type	L	Yes					n/a	$ -	
F01659	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Jury entrance	Hardware type	L	Yes					n/a	$ -	
F01660	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Jury entrance	Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F01661	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Door Gate	Court staff entrance	Kick plate?	SD	Yes					n/a	$ -	
F01662	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Counter	Clerk	Length	96	Yes					n/a	$ -	
F01663	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Seating Area		Number, wheelchair spaces	2	Yes					n/a	$ -	
F01664	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Wheelchair Space	Spectator	On access route?	Y	Yes					n/a	$ -	
F01665	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Seating Area		Seating dispersed?	Y	Yes					n/a	$ -	
F01666	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F01667	Justice Center		2nd Floor	Owned	Courtroom	#201	2-Public Supervised	Wheelchair Space	Spectator	Width	42	Yes					n/a	$ -	
F01674	Justice Center		2nd Floor	Owned	Courtroom	#201 - Room 226	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F01675	Justice Center		2nd Floor	Owned	Courtroom	#201 - Room 226	2-Public Supervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F01676	Justice Center		2nd Floor	Owned	Courtroom	#201 - Room 226	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F01677	Justice Center		2nd Floor	Owned	Courtroom	#201 - Room 226	2-Public Supervised	Door Gate		Clearance, push parallel	43	Yes					n/a	$ -	
F01678	Justice Center		2nd Floor	Owned	Courtroom	#201 - Room 226	2-Public Supervised	Door Gate		Clearance, push perpendicular	92	Yes					n/a	$ -	
F01679	Justice Center		2nd Floor	Owned	Courtroom	#201 - Room 226	2-Public Supervised	Door Gate		Closer?	93	Yes					n/a	$ -	
F01680	Justice Center		2nd Floor	Owned	Courtroom	#201 - Room 226	2-Public Supervised	Signage		Dimension, characters	0.75	Yes					n/a	$ -	
F01681	Justice Center		2nd Floor	Owned	Courtroom	#201 - Room 226	2-Public Supervised	Door Gate		Hardware type	Panic bar	Yes					n/a	$ -	
F01682	Justice Center		2nd Floor	Owned	Courtroom	#201 - Room 226	2-Public Supervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F01683	Justice Center		2nd Floor	Owned	Courtroom	#201 - Room 226	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F01684	Justice Center		2nd Floor	Owned	Courtroom	#201 - Room 226	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F01685	Justice Center		2nd Floor	Owned	Courtroom	#201 - Room 226	2-Public Supervised	Signage		Location	H	Yes					n/a	$ -	
F01686	Justice Center		2nd Floor	Owned	Courtroom	#201 - Room 226	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F01693	Justice Center		2nd Floor	Owned	Courtroom	#202 - Room 220	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F01701	Justice Center		2nd Floor	Owned	Courtroom	#203 - Room 256	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F01711	Justice Center		3rd Floor	Owned	Courtroom	#303 - Room 350	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F01722	Justice Center		3rd Floor	Owned	Courtroom	#304 - Room 356	2-Public Supervised	Wheelchair Space	#1	Adjacent wheelchair space?	Y	Yes					n/a	$ -	
F01723	Justice Center		3rd Floor	Owned	Courtroom	#304 - Room 356	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F01751	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Door Gate		Clear opening	33.5	Yes					n/a	$ -	
F01752	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Counter	Clerk	Clearance, parallel	99	Yes					n/a	$ -	
F01753	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Judge Bench		Clearance, parallel	50	Yes					n/a	$ -	
F01754	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Jury Box		Clearance, parallel	38	Yes					n/a	$ -	
F01755	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Witness Stand		Clearance, parallel	50	Yes					n/a	$ -	
F01756	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Counter	Clerk	Clearance, perpendicular	99	Yes					n/a	$ -	
F01757	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Judge Bench		Clearance, perpendicular	68	Yes					n/a	$ -	
F01758	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Jury Box		Clearance, perpendicular	48	Yes					n/a	$ -	
F01759	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Witness Stand		Clearance, perpendicular	76	Yes					n/a	$ -	
F01760	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Door Gate		Clearance, pull parallel	72	Yes					n/a	$ -	
F01761	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F01762	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Door Gate		Clearance, push parallel	72	Yes					n/a	$ -	
F01763	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Door Gate		Clearance, push perpendicular	98	Yes					n/a	$ -	
F01764	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Door Gate		Clearance, series doors	98	Yes					n/a	$ -	
F01765	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Door Gate		Clearance, vertical	91.5	Yes					n/a	$ -	
F01766	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Door Gate		Closing speed	8	Yes					n/a	$ -	
F01767	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Counter	Clerk	Dimension, knee clearance	0	Yes					n/a	$ -	
F01768	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Door Gate		Hardware type	Panic bar	Yes					n/a	$ -	
F01769	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F01770	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Counter	Clerk	Length	96	Yes					n/a	$ -	
F01771	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Seating Area		Number, wheelchair spaces	2	Yes					n/a	$ -	
F01772	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F01773	Justice Center		4th Floor	Owned	Courtroom	#401 - Room 412	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F01799	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Door Gate		Clear opening	33.5	Yes					n/a	$ -	
F01800	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Counter	Clerk	Clearance, parallel	99	Yes					n/a	$ -	
F01801	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Judge Bench		Clearance, parallel	77	Yes					n/a	$ -	
F01802	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Jury Box		Clearance, parallel	38	Yes					n/a	$ -	
F01803	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Witness Stand		Clearance, parallel	50	Yes					n/a	$ -	
F01804	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Counter	Clerk	Clearance, perpendicular	99	Yes					n/a	$ -	
F01805	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Judge Bench		Clearance, perpendicular	62	Yes					n/a	$ -	
F01806	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Jury Box		Clearance, perpendicular	48	Yes					n/a	$ -	
F01807	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Witness Stand		Clearance, perpendicular	76	Yes					n/a	$ -	
F01808	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Door Gate		Clearance, pull parallel	72	Yes					n/a	$ -	
F01809	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F01810	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Door Gate		Clearance, push parallel	72	Yes					n/a	$ -	
F01811	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Door Gate		Clearance, push perpendicular	98	Yes					n/a	$ -	
F01812	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Door Gate		Clearance, series doors	Y	Yes					n/a	$ -	
F01813	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Door Gate		Clearance, vertical	91.5	Yes					n/a	$ -	
F01814	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Door Gate		Closing speed	6	Yes					n/a	$ -	
F01815	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Signage		Dimension, characters	1	Yes					n/a	$ -	
F01816	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Counter	Clerk	Dimension, knee clearance	0	Yes					n/a	$ -	
F01817	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Door Gate		Hardware type	Panic bar	Yes					n/a	$ -	
F01818	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Signage		Height, bottom	58.25	Yes					n/a	$ -	
F01819	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F01820	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F01821	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Counter	Clerk	Length	94	Yes					n/a	$ -	
F01822	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Signage		Location	H	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F01823	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Seating Area	Spectator	Number, wheelchair spaces	2	Yes					n/a	$ -	
F01824	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Seating Area	Spectator	Seating dispersed?	Y	Yes					n/a	$ -	
F01825	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F01826	Justice Center		4th Floor	Owned	Courtroom	#402 - Room 406	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F01856	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Door Gate	Double door entrance	Clear opening	33.5	Yes					n/a	$ -	
F01857	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Counter		Clearance, parallel	50	Yes					n/a	$ -	
F01858	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Counter	Clerk	Clearance, parallel	99	Yes					n/a	$ -	
F01859	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Judge Bench		Clearance, parallel	72	Yes					n/a	$ -	
F01860	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Jury Box		Clearance, parallel	38	Yes					n/a	$ -	
F01861	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Witness Stand		Clearance, parallel	50	Yes					n/a	$ -	
F01862	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Counter		Clearance, perpendicular	78	Yes					n/a	$ -	
F01863	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Counter	Clerk	Clearance, perpendicular	99	Yes					n/a	$ -	
F01864	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Judge Bench		Clearance, perpendicular	64	Yes					n/a	$ -	
F01865	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Jury Box		Clearance, perpendicular	48	Yes					n/a	$ -	
F01866	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Witness Stand		Clearance, perpendicular	78	Yes					n/a	$ -	
F01867	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Door Gate	Double door entrance	Clearance, pull parallel	72	Yes					n/a	$ -	
F01868	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Door Gate	Double door entrance	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F01869	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Door Gate	Double door entrance	Clearance, push parallel	72	Yes					n/a	$ -	
F01870	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Door Gate	Double door entrance	Clearance, push perpendicular	99	Yes					n/a	$ -	
F01871	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Door Gate	Double door entrance	Clearance, vertical	91	Yes					n/a	$ -	
F01872	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Door Gate	Double door entrance	Closing speed	5	Yes					n/a	$ -	
F01873	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Counter		Dimension, knee clearance	28.5	Yes					n/a	$ -	
F01874	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Counter	Clerk	Dimension, knee clearance	0	Yes					n/a	$ -	
F01875	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Door Gate	Double door entrance	Hardware type	Panic bar	Yes					n/a	$ -	
F01876	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Alarm System		Height	Ceiling mount	Yes					n/a	$ -	
F01877	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Counter		Height	30	Yes					n/a	$ -	
F01878	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Door Gate	Double door entrance	Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F01879	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Counter		Length	50	Yes					n/a	$ -	
F01880	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Counter	Clerk	Length	84	Yes					n/a	$ -	
F01881	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Seating Area	Spectator	Number, wheelchair spaces	2	Yes					n/a	$ -	
F01882	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Seating Area	Spectator	Seating dispersed?	Y	Yes					n/a	$ -	
F01883	Justice Center		4th Floor	Owned	Courtroom	#403 - Room 450	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F01907	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Wheelchair Space	#1	Adjacent wheelchair space?	Y	Yes					n/a	$ -	
F01908	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Seating Area	Spectator	Assistive listening systems?	Y	Yes					n/a	$ -	
F01909	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Door Gate		Clear opening	33.5	Yes					n/a	$ -	
F01910	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Counter	Clerk	Clearance, parallel	99	Yes					n/a	$ -	
F01911	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Judge Bench		Clearance, parallel	60	Yes					n/a	$ -	
F01912	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Jury Box		Clearance, parallel	38	Yes					n/a	$ -	
F01913	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Jury Box		Clearance, parallel	38	Yes					n/a	$ -	
F01914	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Counter	Clerk	Clearance, perpendicular	99	Yes					n/a	$ -	
F01915	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Judge Bench		Clearance, perpendicular	78	Yes					n/a	$ -	
F01916	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Jury Box		Clearance, perpendicular	48	Yes					n/a	$ -	
F01917	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Jury Box		Clearance, perpendicular	48	Yes					n/a	$ -	
F01918	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Door Gate		Clearance, pull parallel	72	Yes					n/a	$ -	
F01919	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F01920	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Door Gate		Clearance, push parallel	72	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F01921	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Door Gate		Clearance, push perpendicular	96	Yes					n/a	$ -	
F01922	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Door Gate		Clearance, series doors	Y	Yes					n/a	$ -	
F01923	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Door Gate		Clearance, vertical	91.5	Yes					n/a	$ -	
F01924	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F01925	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Counter	Clerk	Dimension, knee clearance	0	Yes					n/a	$ -	
F01926	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Door Gate		Hardware type	Panic bar	Yes					n/a	$ -	
F01927	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F01928	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Counter	Clerk	Length	84	Yes					n/a	$ -	
F01929	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Seating Area	Spectator	Number, wheelchair spaces	2	Yes					n/a	$ -	
F01930	Justice Center		4th Floor	Owned	Courtroom	#404 - Room 456	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F01963	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Wheelchair Space		Adjacent wheelchair space?	Y	Yes					n/a	$ -	
F01964	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Seating Area	Spectator	Assistive listening systems?	Y	Yes					n/a	$ -	
F01965	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate	Jury entrance	Clear opening	33	Yes					n/a	$ -	
F01966	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate		Clear opening	33.5	Yes					n/a	$ -	
F01967	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Counter	Clerk	Clearance, parallel	99	Yes					n/a	$ -	
F01968	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Judge Bench		Clearance, parallel	65	Yes					n/a	$ -	
F01969	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Jury Box		Clearance, parallel	38	Yes					n/a	$ -	
F01970	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Witness Stand		Clearance, parallel	65	Yes					n/a	$ -	
F01971	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Counter	Clerk	Clearance, perpendicular	99	Yes					n/a	$ -	
F01972	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Judge Bench		Clearance, perpendicular	82	Yes					n/a	$ -	
F01973	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Jury Box		Clearance, perpendicular	48	Yes					n/a	$ -	
F01974	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Witness Stand		Clearance, perpendicular	82	Yes					n/a	$ -	
F01975	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate		Clearance, pull parallel	72	Yes					n/a	$ -	
F01976	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate	Jury entrance	Clearance, pull parallel	99	Yes					n/a	$ -	
F01977	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate		Clearance, pull perpendicular	72	Yes					n/a	$ -	
F01978	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate	Jury entrance	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F01979	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate		Clearance, push parallel	72	Yes					n/a	$ -	
F01980	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate	Jury entrance	Clearance, push parallel	99	Yes					n/a	$ -	
F01981	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F01982	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate	Jury entrance	Clearance, push perpendicular	61	Yes					n/a	$ -	
F01983	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate		Clearance, series doors	99	Yes					n/a	$ -	
F01984	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate		Clearance, vertical	91.5	Yes					n/a	$ -	
F01985	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate	Jury entrance	Clearance, vertical	91	Yes					n/a	$ -	
F01986	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate	Jury entrance	Closing speed	6	Yes					n/a	$ -	
F01987	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Wheelchair Space		Companion seat?	N	Yes					n/a	$ -	
F01988	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Wheelchair Space		Depth	48	Yes					n/a	$ -	
F01989	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Counter	Clerk	Dimension, knee clearance	0	Yes					n/a	$ -	
F01990	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate		Hardware type	Panic bar	Yes					n/a	$ -	
F01991	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate	Jury entrance	Hardware type	Panic bar	Yes					n/a	$ -	
F01992	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate	Jury entrance	Hardware type	L	Yes					n/a	$ -	
F01993	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Alarm System		Height	Ceiling mount	Yes					n/a	$ -	
F01994	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate	Jury entrance	Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F01995	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F01996	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Counter	Clerk	Length	84	Yes					n/a	$ -	
F01997	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Seating Area	Spectator	Number, wheelchair spaces	2	Yes					n/a	$ -	
F01998	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Door Gate		Opening force	5	Yes					n/a	$ -	
F01999	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Witness Stand		Ramp?	Y	Yes					n/a	$ -	
F02000	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F02001	Justice Center		4th Floor	Owned	Courtroom	#405 - Room S408	2-Public Supervised	Wheelchair Space		Width	38	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F02027	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Seating Area	Spectator	Assistive listening systems?	Y	Yes					n/a	$ -	
F02028	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F02029	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Clear opening	33.5	Yes					n/a	$ -	
F02030	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Counter	Clerk	Clearance, parallel	99	Yes					n/a	$ -	
F02031	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Judge Bench		Clearance, parallel	65	Yes					n/a	$ -	
F02032	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Jury Box		Clearance, parallel	38	Yes					n/a	$ -	
F02033	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Counter	Clerk	Clearance, perpendicular	99	Yes					n/a	$ -	
F02034	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Judge Bench		Clearance, perpendicular	82	Yes					n/a	$ -	
F02035	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Jury Box		Clearance, perpendicular	48	Yes					n/a	$ -	
F02036	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F02037	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Clearance, pull parallel	46	Yes					n/a	$ -	
F02038	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F02039	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F02040	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Clearance, push parallel	72	Yes					n/a	$ -	
F02041	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Clearance, push parallel	46	Yes					n/a	$ -	
F02042	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F02043	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Clearance, push perpendicular	90	Yes					n/a	$ -	
F02044	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Clearance, series doors	99	Yes					n/a	$ -	
F02045	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Clearance, vertical	91.5	Yes					n/a	$ -	
F02046	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F02047	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Signage		Dimension, characters	.75	Yes					n/a	$ -	
F02048	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Counter	Clerk	Dimension, knee clearance	0	Yes					n/a	$ -	
F02049	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Hardware type	Panic bar	Yes					n/a	$ -	
F02050	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F02051	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Signage		Height, bottom	58.25	Yes					n/a	$ -	
F02052	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F02053	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F02054	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F02055	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Counter	Clerk	Length	84	Yes					n/a	$ -	
F02056	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Signage		Location	H	Yes					n/a	$ -	
F02057	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Seating Area		Number, wheelchair spaces	2	Yes					n/a	$ -	
F02058	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Wheelchair Space		On access route?	Y	Yes					n/a	$ -	
F02059	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Door Gate		Opening force	3	Yes					n/a	$ -	
F02060	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F02061	Justice Center		4th Floor	Owned	Courtroom	#406 - Room S412	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F02113	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Wheelchair Space	Spectator	Adjacent wheelchair space?	Y	Yes					n/a	$ -	
F02114	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Seating Area	Spectator	Assistive listening systems?	Y	Yes					n/a	$ -	
F02115	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F02116	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	2nd set in series	Clear opening	33	Yes					n/a	$ -	
F02117	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Court staff entrance	Clear opening	33	Yes					n/a	$ -	
F02118	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Jury entrance	Clear opening	33	Yes					n/a	$ -	
F02119	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Courtroom Station		Clearance, parallel	84	Yes					n/a	$ -	
F02120	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Judge Bench		Clearance, parallel	51	Yes					n/a	$ -	
F02121	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Jury Box		Clearance, parallel	38	Yes					n/a	$ -	
F02122	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Witness Stand		Clearance, parallel	49	Yes					n/a	$ -	
F02123	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Courtroom Station		Clearance, perpendicular	74	Yes					n/a	$ -	
F02124	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Judge Bench		Clearance, perpendicular	74	Yes					n/a	$ -	
F02125	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Jury Box		Clearance, perpendicular	48	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F02126	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Witness Stand		Clearance, perpendicular	78	Yes					n/a	$ -	
F02127	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F02128	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	2nd set in series	Clearance, pull parallel	42	Yes					n/a	$ -	
F02129	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Court staff entrance	Clearance, pull parallel	20	Yes					n/a	$ -	
F02130	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Jury entrance	Clearance, pull parallel	72	Yes					n/a	$ -	
F02131	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate		Clearance, pull perpendicular	93	Yes					n/a	$ -	
F02132	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	2nd set in series	Clearance, pull perpendicular	96	Yes					n/a	$ -	
F02133	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Court staff entrance	Clearance, pull perpendicular	77	Yes					n/a	$ -	
F02134	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Jury entrance	Clearance, pull perpendicular	78	Yes					n/a	$ -	
F02135	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate		Clearance, push parallel	40	Yes					n/a	$ -	
F02136	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	2nd set in series	Clearance, push parallel	41	Yes					n/a	$ -	
F02137	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Jury entrance	Clearance, push parallel	99	Yes					n/a	$ -	
F02138	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate		Clearance, push perpendicular	96	Yes					n/a	$ -	
F02139	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	2nd set in series	Clearance, push perpendicular	99	Yes					n/a	$ -	
F02140	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Court staff entrance	Clearance, push perpendicular	99	Yes					n/a	$ -	
F02141	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Jury entrance	Clearance, push perpendicular	99	Yes					n/a	$ -	
F02142	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate		Clearance, series doors	59	Yes					n/a	$ -	
F02143	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	2nd set in series	Clearance, series doors	59	Yes					n/a	$ -	
F02144	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate		Clearance, vertical	93	Yes					n/a	$ -	
F02145	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	2nd set in series	Clearance, vertical	93	Yes					n/a	$ -	
F02146	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Court staff entrance	Clearance, vertical	93	Yes					n/a	$ -	
F02147	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Jury entrance	Clearance, vertical	93	Yes					n/a	$ -	
F02148	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Wheelchair Space	Spectator	Companion seat?	Y	Yes					n/a	$ -	
F02149	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Wheelchair Space	Spectator	Depth	48	Yes					n/a	$ -	
F02150	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate		Hardware type	Lever - Panic	Yes					n/a	$ -	
F02151	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	2nd set in series	Hardware type	PP	Yes					n/a	$ -	
F02152	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Jury entrance	Hardware type	Panic bar	Yes					n/a	$ -	
F02153	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Signage		Height, bottom	57.5	Yes					n/a	$ -	
F02154	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F02155	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	2nd set in series	Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F02156	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Court staff entrance	Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F02157	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	Jury entrance	Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F02158	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F02159	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Counter	Clerk	Length	96	Yes					n/a	$ -	
F02160	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Signage		Location	H	Yes					n/a	$ -	
F02161	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Seating Area		Number, wheelchair spaces	2	Yes					n/a	$ -	
F02162	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Wheelchair Space	Spectator	On access route?	Y	Yes					n/a	$ -	
F02163	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Seating Area		Seating dispersed?	Y	Yes					n/a	$ -	
F02164	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F02165	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F02166	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Wheelchair Space	Spectator	Width	44	Yes					n/a	$ -	
F02213	Justice Center		5th Floor	Owned	Courtroom	#501 - Room 515	2-Public Supervised	Door Gate	2nd set in series	Height, threshold	0	Yes					n/a	$ -	
F02214	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Height, threshold	0	Yes					n/a	$ -	
F02223	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Wheelchair Space		Adjacent wheelchair space?	Y	Yes					n/a	$ -	
F02224	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Seating Area	Spectator	Assistive listening systems?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F02225	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Circulation Path		Both sides of court?	Y	Yes					n/a	$ -	
F02226	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F02227	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	Court staff entrance	Clear opening	32	Yes					n/a	$ -	
F02228	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F02229	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	2nd set in series	Clear opening	33	Yes					n/a	$ -	
F02230	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F02231	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Courtroom Station		Clearance, parallel	58	Yes					n/a	$ -	
F02232	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Judge Bench		Clearance, parallel	72	Yes					n/a	$ -	
F02233	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Witness Stand		Clearance, parallel	56	Yes					n/a	$ -	
F02234	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F02235	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Courtroom Station		Clearance, perpendicular	66	Yes					n/a	$ -	
F02236	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Judge Bench		Clearance, perpendicular	58	Yes					n/a	$ -	
F02237	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Witness Stand		Clearance, perpendicular	64	Yes					n/a	$ -	
F02238	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F02239	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	2nd set in series	Clearance, pull parallel	44	Yes					n/a	$ -	
F02240	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F02241	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	Court staff entrance	Clearance, pull parallel	99	Yes					n/a	$ -	
F02242	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F02243	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	2nd set in series	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F02244	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Clearance, pull perpendicular	77	Yes					n/a	$ -	
F02245	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	Court staff entrance	Clearance, pull perpendicular	77	Yes					n/a	$ -	
F02246	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Clearance, push parallel	44	Yes					n/a	$ -	
F02247	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	2nd set in series	Clearance, push parallel	38	Yes					n/a	$ -	
F02248	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Clearance, push parallel	40	Yes					n/a	$ -	
F02249	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	Court staff entrance	Clearance, push parallel	30	Yes					n/a	$ -	
F02250	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F02251	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	2nd set in series	Clearance, push perpendicular	99	Yes					n/a	$ -	
F02252	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F02253	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	Court staff entrance	Clearance, push perpendicular	99	Yes					n/a	$ -	
F02254	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Clearance, series doors	99	Yes					n/a	$ -	
F02255	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	2nd set in series	Clearance, series doors	99	Yes					n/a	$ -	
F02256	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Clearance, vertical	93	Yes					n/a	$ -	
F02257	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	2nd set in series	Clearance, vertical	93	Yes					n/a	$ -	
F02258	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Clearance, vertical	93	Yes					n/a	$ -	
F02259	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	Court staff entrance	Clearance, vertical	93	Yes					n/a	$ -	
F02260	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	2nd set in series	Closing speed	6	Yes					n/a	$ -	
F02261	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Wheelchair Space		Companion seat?	Y	Yes					n/a	$ -	
F02262	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Circulation Path		Connects to all elements?	Y	Yes					n/a	$ -	
F02263	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Counter		Dimension, knee clearance	0	Yes					n/a	$ -	
F02264	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	Jury entrance	Hardware type	Lever - Panic	Yes					n/a	$ -	
F02265	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	2nd set in series	Hardware type	PP	Yes					n/a	$ -	
F02266	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	Double door entrance	Hardware type	Lever - Panic	Yes					n/a	$ -	
F02267	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	Court staff entrance	Hardware type	L	Yes					n/a	$ -	
F02268	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Alarm System		Height	Ceiling mount	Yes					n/a	$ -	
F02269	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Signage		Height, bottom	57.5	Yes					n/a	$ -	
F02270	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F02271	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Signage	Court staff entrance	Height, bottom	58	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F02272	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F02273	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	2nd set in series	Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F02274	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F02275	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate	Court staff entrance	Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F02276	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F02277	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F02278	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Signage	Court staff entrance	ISA?	N	Yes					n/a	$ -	
F02279	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Counter		Length	72	Yes					n/a	$ -	
F02280	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Wheelchair Space		Line of sight?	Y	Yes					n/a	$ -	
F02281	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Signage		Location	H	Yes					n/a	$ -	
F02282	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	
F02283	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Signage	Court staff entrance	Location	L	Yes					n/a	$ -	
F02284	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Seating Area		Number, wheelchair spaces	2	Yes					n/a	$ -	
F02285	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Wheelchair Space		On access route?	Y	Yes					n/a	$ -	
F02286	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Seating Area		Seating dispersed?	Y	Yes					n/a	$ -	
F02287	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Circulation Path		Surface material	Carpet	Yes					n/a	$ -	
F02288	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Wheelchair Space		Surface material	Carpet	Yes					n/a	$ -	
F02289	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F02290	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F02291	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Signage	Court staff entrance	Tactile letters?	Y	Yes					n/a	$ -	
F02292	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F02293	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Wheelchair Space		Width	40	Yes					n/a	$ -	
F02300	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 511	2-Public Supervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F02301	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 511	2-Public Supervised	Door Gate		Clearance, pull parallel	48	Yes					n/a	$ -	
F02302	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 511	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F02303	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 511	2-Public Supervised	Door Gate		Clearance, push parallel	48	Yes					n/a	$ -	
F02304	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 511	2-Public Supervised	Door Gate		Clearance, push perpendicular	81	Yes					n/a	$ -	
F02305	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 511	2-Public Supervised	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F02306	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 511	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F02307	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 511	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F02308	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 511	2-Public Supervised	Door Gate		Opening force	1	Yes					n/a	$ -	
F02345	Justice Center		5th Floor	Owned	Courtroom	#502 - Room 508	2-Public Supervised	Door Gate		Height, threshold	0	Yes					n/a	$ -	
F02346	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate		Height, threshold	0	Yes					n/a	$ -	
F02347	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	2nd set in series	Height, threshold	0	Yes					n/a	$ -	
F02355	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Wheelchair Space		Adjacent wheelchair space?	Y	Yes					n/a	$ -	
F02356	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Seating Area	Spectator	Assistive listening systems?	Y	Yes					n/a	$ -	
F02357	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Circulation Path		Both sides of court?	Y	Yes					n/a	$ -	
F02358	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	Court staff entrance	Clear opening	32	Yes					n/a	$ -	
F02359	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F02360	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	2nd set in series	Clear opening	33	Yes					n/a	$ -	
F02361	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F02362	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Courtroom Station		Clearance, parallel	45	Yes					n/a	$ -	
F02363	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Judge Bench		Clearance, parallel	99	Yes					n/a	$ -	
F02364	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Witness Stand		Clearance, parallel	99	Yes					n/a	$ -	
F02365	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F02366	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Courtroom Station		Clearance, perpendicular	69	Yes					n/a	$ -	
F02367	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Judge Bench		Clearance, perpendicular	62	Yes					n/a	$ -	
F02368	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Witness Stand		Clearance, perpendicular	56	Yes					n/a	$ -	
F02369	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F02370	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	2nd set in series	Clearance, pull parallel	43	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F02371	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	Court staff entrance	Clearance, pull parallel	99	Yes					n/a	$ -	
F02372	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F02373	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	2nd set in series	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F02374	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	Court staff entrance	Clearance, pull perpendicular	90	Yes					n/a	$ -	
F02375	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate		Clearance, push parallel	43	Yes					n/a	$ -	
F02376	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	2nd set in series	Clearance, push parallel	34	Yes					n/a	$ -	
F02377	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F02378	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	2nd set in series	Clearance, push perpendicular	99	Yes					n/a	$ -	
F02379	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	Court staff entrance	Clearance, push perpendicular	99	Yes					n/a	$ -	
F02380	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate		Clearance, series doors	87	Yes					n/a	$ -	
F02381	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	2nd set in series	Clearance, series doors	84	Yes					n/a	$ -	
F02382	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate		Clearance, vertical	93	Yes					n/a	$ -	
F02383	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	2nd set in series	Clearance, vertical	93	Yes					n/a	$ -	
F02384	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	Court staff entrance	Clearance, vertical	93	Yes					n/a	$ -	
F02385	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F02386	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	2nd set in series	Closing speed	7	Yes					n/a	$ -	
F02387	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Wheelchair Space		Companion seat?	Y	Yes					n/a	$ -	
F02388	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Circulation Path		Connects to all elements?	Y	Yes					n/a	$ -	
F02389	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Counter		Dimension, knee clearance	0	Yes					n/a	$ -	
F02390	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate		Hardware type	Lever - Panic	Yes					n/a	$ -	
F02391	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	2nd set in series	Hardware type	PP	Yes					n/a	$ -	
F02392	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	Court staff entrance	Hardware type	L	Yes					n/a	$ -	
F02393	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Alarm System		Height	Ceiling mount	Yes					n/a	$ -	
F02394	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F02395	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	2nd set in series	Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F02396	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	Court staff entrance	Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F02397	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Counter		Length	66	Yes					n/a	$ -	
F02398	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Wheelchair Space		Line of sight?	Y	Yes					n/a	$ -	
F02399	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Seating Area		Number, wheelchair spaces	2	Yes					n/a	$ -	
F02400	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Wheelchair Space		On access route?	Y	Yes					n/a	$ -	
F02401	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Seating Area		Seating dispersed?	Y	Yes					n/a	$ -	
F02402	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Wheelchair Space		Surface material	Carpet	Yes					n/a	$ -	
F02403	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F02404	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Wheelchair Space		Width	37	Yes					n/a	$ -	
F02406	Justice Center		5th Floor	Owned	Courtroom	#503 - Room 506	2-Public Supervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F02407	Justice Center		5th Floor	Owned	Courtroom	#503 - Room 506	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F02408	Justice Center		5th Floor	Owned	Courtroom	#503 - Room 506	2-Public Supervised	Signage		Location	H	Yes					n/a	$ -	
F02409	Justice Center		5th Floor	Owned	Courtroom	#503 - Room 506	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F02417	Justice Center		5th Floor	Owned	Courtroom	#503	2-Public Supervised	Door Gate	Court staff entrance	Height, threshold	0	Yes					n/a	$ -	
F02418	Justice Center		5th Floor	Owned	Courtroom	#503 - Room 507	2-Public Supervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F02419	Justice Center		5th Floor	Owned	Courtroom	#503 - Room 507	2-Public Supervised	Door Gate		Clearance, pull parallel	49	Yes					n/a	$ -	
F02420	Justice Center		5th Floor	Owned	Courtroom	#503 - Room 507	2-Public Supervised	Door Gate		Clearance, pull perpendicular	84	Yes					n/a	$ -	
F02421	Justice Center		5th Floor	Owned	Courtroom	#503 - Room 507	2-Public Supervised	Door Gate		Clearance, push parallel	72	Yes					n/a	$ -	
F02422	Justice Center		5th Floor	Owned	Courtroom	#503 - Room 507	2-Public Supervised	Door Gate		Clearance, push perpendicular	82	Yes					n/a	$ -	
F02423	Justice Center		5th Floor	Owned	Courtroom	#503 - Room 507	2-Public Supervised	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F02424	Justice Center		5th Floor	Owned	Courtroom	#503 - Room 507	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F02425	Justice Center		5th Floor	Owned	Courtroom	#503 - Room 507	2-Public Supervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F02426	Justice Center		5th Floor	Owned	Courtroom	#503 - Room 507	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F02427	Justice Center		5th Floor	Owned	Courtroom	#503 - Room 507	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F02428	Justice Center		5th Floor	Owned	Courtroom	#503 - Room 507	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	
F02429	Justice Center		5th Floor	Owned	Courtroom	#503 - Room 507	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F02478	Justice Center		5th Floor	Owned	Courtroom	#503 - Room 507	2-Public Supervised	Door Gate		Height, threshold	0	Yes					n/a	$ -	
F02479	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Court staff entrance	Height, threshold	0	Yes					n/a	$ -	
F02480	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Jury entrance	Height, threshold	0	Yes					n/a	$ -	
F02481	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	2nd set in series	Height, threshold	0	Yes					n/a	$ -	
F02491	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Wheelchair Space		Adjacent wheelchair space?	Y	Yes					n/a	$ -	
F02492	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Circulation Path		Both sides of court?	Y	Yes					n/a	$ -	
F02493	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Court staff entrance	Clear opening	32	Yes					n/a	$ -	
F02494	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Jury entrance	Clear opening	32	Yes					n/a	$ -	
F02495	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	2nd set in series	Clear opening	33	Yes					n/a	$ -	
F02496	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Double door entrance	Clear opening	33	Yes					n/a	$ -	
F02497	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F02498	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Courtroom Station		Clearance, parallel	83	Yes					n/a	$ -	
F02499	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Judge Bench		Clearance, parallel	72	Yes					n/a	$ -	
F02500	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Jury Box		Clearance, parallel	60	Yes					n/a	$ -	
F02501	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Witness Stand		Clearance, parallel	79	Yes					n/a	$ -	
F02502	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F02503	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Courtroom Station		Clearance, perpendicular	63.5	Yes					n/a	$ -	
F02504	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Judge Bench		Clearance, perpendicular	63	Yes					n/a	$ -	
F02505	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Jury Box		Clearance, perpendicular	99	Yes					n/a	$ -	
F02506	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Witness Stand		Clearance, perpendicular	68	Yes					n/a	$ -	
F02507	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Court staff entrance	Clearance, pull parallel	23	Yes					n/a	$ -	
F02508	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Jury entrance	Clearance, pull parallel	99	Yes					n/a	$ -	
F02509	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	2nd set in series	Clearance, pull parallel	43	Yes					n/a	$ -	
F02510	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Double door entrance	Clearance, pull parallel	99	Yes					n/a	$ -	
F02511	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Court staff entrance	Clearance, pull perpendicular	72	Yes					n/a	$ -	
F02512	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Jury entrance	Clearance, pull perpendicular	77	Yes					n/a	$ -	
F02513	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	2nd set in series	Clearance, pull perpendicular	60	Yes					n/a	$ -	
F02514	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Double door entrance	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F02515	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Jury entrance	Clearance, push parallel	74.5	Yes					n/a	$ -	
F02516	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	2nd set in series	Clearance, push parallel	41	Yes					n/a	$ -	
F02517	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Double door entrance	Clearance, push parallel	43	Yes					n/a	$ -	
F02518	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Court staff entrance	Clearance, push perpendicular	99	Yes					n/a	$ -	
F02519	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Jury entrance	Clearance, push perpendicular	99	Yes					n/a	$ -	
F02520	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	2nd set in series	Clearance, push perpendicular	99	Yes					n/a	$ -	
F02521	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Double door entrance	Clearance, push perpendicular	60	Yes					n/a	$ -	
F02522	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	2nd set in series	Clearance, series doors	60	Yes					n/a	$ -	
F02523	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Double door entrance	Clearance, series doors	60	Yes					n/a	$ -	
F02524	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Court staff entrance	Clearance, vertical	93	Yes					n/a	$ -	
F02525	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Jury entrance	Clearance, vertical	93	Yes					n/a	$ -	
F02526	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	2nd set in series	Clearance, vertical	93	Yes					n/a	$ -	
F02527	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Double door entrance	Clearance, vertical	93	Yes					n/a	$ -	
F02528	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Court staff entrance	Closing speed	5	Yes					n/a	$ -	
F02529	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	2nd set in series	Closing speed	5	Yes					n/a	$ -	
F02530	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Wheelchair Space		Companion seat?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F02531	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Circulation Path		Connects to all elements?	Y	Yes					n/a	$ -	
F02532	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Wheelchair Space		Depth	63	Yes					n/a	$ -	
F02533	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Counter		Dimension, knee clearance	0	Yes					n/a	$ -	
F02534	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Court staff entrance	Hardware type	L	Yes					n/a	$ -	
F02535	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Jury entrance	Hardware type	Lever - Panic	Yes					n/a	$ -	
F02536	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	2nd set in series	Hardware type	PP	Yes					n/a	$ -	
F02537	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Double door entrance	Hardware type	Lever - Panic	Yes					n/a	$ -	
F02538	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Alarm System		Height	Ceiling mount	Yes					n/a	$ -	
F02539	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Signage	Court staff entrance	Height, bottom	58	Yes					n/a	$ -	
F02540	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F02541	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Court staff entrance	Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F02542	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Jury entrance	Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F02543	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	2nd set in series	Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F02544	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Double door entrance	Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F02545	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Signage	Court staff entrance	ISA?	N	Yes					n/a	$ -	
F02546	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F02547	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Counter		Length	96	Yes					n/a	$ -	
F02548	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Wheelchair Space		Line of sight?	Y	Yes					n/a	$ -	
F02549	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Signage	Court staff entrance	Location	L	Yes					n/a	$ -	
F02550	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Signage		Location	H	Yes					n/a	$ -	
F02551	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Seating Area		Number, wheelchair spaces	2	Yes					n/a	$ -	
F02552	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Wheelchair Space		On access route?	Y	Yes					n/a	$ -	
F02553	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Seating Area		Seating dispersed?	Y	Yes					n/a	$ -	
F02554	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Circulation Path		Surface material	Carpet	Yes					n/a	$ -	
F02555	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Wheelchair Space		Surface material	Carpet	Yes					n/a	$ -	
F02556	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Signage	Court staff entrance	Tactile letters?	Y	Yes					n/a	$ -	
F02557	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F02558	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F02559	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Wheelchair Space		Width	40	Yes					n/a	$ -	
F02564	Justice Center		5th Floor	Owned	Courtroom	#504	2-Public Supervised	Door Gate	Double door entrance	Height, threshold	0	Yes					n/a	$ -	
F02565	Justice Center		5th Floor	Owned	Courtroom	#504 - Room 551	2-Public Supervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F02566	Justice Center		5th Floor	Owned	Courtroom	#504 - Room 551	2-Public Supervised	Door Gate		Clearance, pull parallel	46	Yes					n/a	$ -	
F02567	Justice Center		5th Floor	Owned	Courtroom	#504 - Room 551	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F02568	Justice Center		5th Floor	Owned	Courtroom	#504 - Room 551	2-Public Supervised	Door Gate		Clearance, push parallel	46	Yes					n/a	$ -	
F02569	Justice Center		5th Floor	Owned	Courtroom	#504 - Room 551	2-Public Supervised	Door Gate		Clearance, push perpendicular	82	Yes					n/a	$ -	
F02570	Justice Center		5th Floor	Owned	Courtroom	#504 - Room 551	2-Public Supervised	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F02571	Justice Center		5th Floor	Owned	Courtroom	#504 - Room 551	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F02572	Justice Center		5th Floor	Owned	Courtroom	#504 - Room 551	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F02573	Justice Center		5th Floor	Owned	Courtroom	#504 - Room 551	2-Public Supervised	Door Gate		Opening force	2	Yes					n/a	$ -	
F02580	Justice Center		5th Floor	Owned	Courtroom	#504 - Room 551	2-Public Supervised	Door Gate		Height, threshold	0	Yes					n/a	$ -	
F02582	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S505	2-Public Supervised	Signage		Braille?	Y	Yes					n/a	$ -	
F02583	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S505	2-Public Supervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F02584	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S505	2-Public Supervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F02585	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S505	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F02586	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S505	2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F02587	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S505	2-Public Supervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F02588	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S505	2-Public Supervised	Door Gate		Clearance, vertical	93	Yes					n/a	$ -	
F02589	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S505	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F02590	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S505	2-Public Supervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F02591	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S505	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F02592	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S505	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F02593	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S505	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F02594	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S505	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F02602	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S507	2-Public Supervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F02603	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S507	2-Public Supervised	Door Gate		Clearance, pull parallel	48	Yes					n/a	$ -	
F02604	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S507	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F02605	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S507	2-Public Supervised	Door Gate		Clearance, push parallel	48	Yes					n/a	$ -	
F02606	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S507	2-Public Supervised	Door Gate		Clearance, push perpendicular	82	Yes					n/a	$ -	
F02607	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S507	2-Public Supervised	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F02608	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S507	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F02609	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S507	2-Public Supervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F02610	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S507	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F02611	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S507	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F02612	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S507	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	
F02613	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S507	2-Public Supervised	Door Gate		Opening force	1	Yes					n/a	$ -	
F02614	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S507	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F02657	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S505	2-Public Supervised	Door Gate		Height, threshold	0	Yes					n/a	$ -	
F02658	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	2nd set in series	Height, threshold	0	Yes					n/a	$ -	
F02659	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Double door entrance	Height, threshold	0	Yes					n/a	$ -	
F02666	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Wheelchair Space		Adjacent wheelchair space?	Y	Yes					n/a	$ -	
F02667	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Seating Area	Spectator	Assistive listening systems?	Y	Yes					n/a	$ -	
F02668	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Circulation Path		Both sides of court?	Y	Yes					n/a	$ -	
F02669	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F02670	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Jury entrance	Clear opening	32	Yes					n/a	$ -	
F02671	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	2nd set in series	Clear opening	33	Yes					n/a	$ -	
F02672	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Double door entrance	Clear opening	33	Yes					n/a	$ -	
F02673	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F02674	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Courtroom Station		Clearance, parallel	80	Yes					n/a	$ -	
F02675	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Judge Bench		Clearance, parallel	66	Yes					n/a	$ -	
F02676	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Jury Box		Clearance, parallel	40	Yes					n/a	$ -	
F02677	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Witness Stand		Clearance, parallel	60	Yes					n/a	$ -	
F02678	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F02679	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Courtroom Station		Clearance, perpendicular	48	Yes					n/a	$ -	
F02680	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Judge Bench		Clearance, perpendicular	62	Yes					n/a	$ -	
F02681	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Jury Box		Clearance, perpendicular	48	Yes					n/a	$ -	
F02682	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Witness Stand		Clearance, perpendicular	69	Yes					n/a	$ -	
F02683	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	2nd set in series	Clearance, pull parallel	43	Yes					n/a	$ -	
F02684	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Double door entrance	Clearance, pull parallel	99	Yes					n/a	$ -	
F02685	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate		Clearance, pull parallel	60	Yes					n/a	$ -	
F02686	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Jury entrance	Clearance, pull parallel	18	Yes					n/a	$ -	
F02687	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	2nd set in series	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F02688	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Double door entrance	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F02689	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate		Clearance, pull perpendicular	62	Yes					n/a	$ -	
F02690	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Jury entrance	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F02691	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	2nd set in series	Clearance, push parallel	48	Yes					n/a	$ -	
F02692	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Double door entrance	Clearance, push parallel	44	Yes					n/a	$ -	
F02693	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate		Clearance, push parallel	24	Yes					n/a	$ -	
F02694	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Jury entrance	Clearance, push parallel	99	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F02695	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	2nd set in series	Clearance, push perpendicular	99	Yes					n/a	$ -	
F02696	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Double door entrance	Clearance, push perpendicular	99	Yes					n/a	$ -	
F02697	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F02698	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Jury entrance	Clearance, push perpendicular	70	Yes					n/a	$ -	
F02699	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	2nd set in series	Clearance, series doors	72	Yes					n/a	$ -	
F02700	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Double door entrance	Clearance, series doors	72	Yes					n/a	$ -	
F02701	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	2nd set in series	Clearance, vertical	93	Yes					n/a	$ -	
F02702	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Double door entrance	Clearance, vertical	93	Yes					n/a	$ -	
F02703	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate		Clearance, vertical	93	Yes					n/a	$ -	
F02704	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Jury entrance	Clearance, vertical	93	Yes					n/a	$ -	
F02705	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	2nd set in series	Closing speed	5	Yes					n/a	$ -	
F02706	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Wheelchair Space		Companion seat?	Y	Yes					n/a	$ -	
F02707	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Circulation Path		Connects to all elements?	Y	Yes					n/a	$ -	
F02708	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Wheelchair Space		Depth	60	Yes					n/a	$ -	
F02709	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Counter		Dimension, knee clearance	0	Yes					n/a	$ -	
F02710	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Aisle Seat		Folding/removable armrest?	Y	Yes					n/a	$ -	
F02711	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	2nd set in series	Hardware type	PP	Yes					n/a	$ -	
F02712	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Double door entrance	Hardware type	Lever - Panic	Yes					n/a	$ -	
F02713	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Jury entrance	Hardware type	Lever - Panic	Yes					n/a	$ -	
F02714	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Jury entrance	Hardware type	L	Yes					n/a	$ -	
F02715	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Alarm System		Height	Ceiling mount	Yes					n/a	$ -	
F02716	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Signage	Court staff entrance	Height, bottom	58	Yes					n/a	$ -	
F02717	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Signage	Jury entrance	Height, bottom	58	Yes					n/a	$ -	
F02718	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	2nd set in series	Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F02719	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Double door entrance	Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F02720	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F02721	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Jury entrance	Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F02722	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Aisle Seat		ISA?	Y	Yes					n/a	$ -	
F02723	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Signage	Court staff entrance	ISA?	N	Yes					n/a	$ -	
F02724	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Signage	Jury entrance	ISA?	N	Yes					n/a	$ -	
F02725	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate		Kick plate?	N	Yes					n/a	$ -	
F02726	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate	Jury entrance	Kick plate?	SD	Yes					n/a	$ -	
F02727	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Counter		Length	90	Yes					n/a	$ -	
F02728	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Wheelchair Space		Line of sight?	Y	Yes					n/a	$ -	
F02729	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Signage	Court staff entrance	Location	L	Yes					n/a	$ -	
F02730	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Signage	Jury entrance	Location	L	Yes					n/a	$ -	
F02731	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Seating Area		Number, ALS receivers	4	Yes					n/a	$ -	
F02732	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Seating Area		Number, wheelchair spaces	2	Yes					n/a	$ -	
F02733	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Wheelchair Space		On access route?	Y	Yes					n/a	$ -	
F02734	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Courtroom Station		Ramp?	Y	Yes					n/a	$ -	
F02735	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Witness Stand		Ramp?	Y	Yes					n/a	$ -	
F02736	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Seating Area		Seating dispersed?	Y	Yes					n/a	$ -	
F02737	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Circulation Path		Surface material	Carpet	Yes					n/a	$ -	
F02738	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Wheelchair Space		Surface material	Carpet	Yes					n/a	$ -	
F02739	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Signage	Court staff entrance	Tactile letters?	Y	Yes					n/a	$ -	
F02740	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Signage	Jury entrance	Tactile letters?	Y	Yes					n/a	$ -	
F02741	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F02742	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Circulation Path		Width	OK	Yes					n/a	$ -	
F02743	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Wheelchair Space		Width	36	Yes					n/a	$ -	
F02767	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Circulation Path		Adjacent pathway?	Y	Yes					n/a	$ -	
F02768	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Wheelchair Space		Adjacent wheelchair space?	Y	Yes					n/a	$ -	
F02769	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Seating Area	Spectator	Assistive listening systems?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F02770	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Circulation Path		Both sides of court?	Y	Yes					n/a	$ -	
F02771	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Courtroom Station		Clearance, parallel	92	Yes					n/a	$ -	
F02772	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Judge Bench		Clearance, parallel	70	Yes					n/a	$ -	
F02773	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Jury Box		Clearance, parallel	99	Yes					n/a	$ -	
F02774	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Witness Stand		Clearance, parallel	66	Yes					n/a	$ -	
F02775	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Judge Bench		Clearance, perpendicular	68.25	Yes					n/a	$ -	
F02776	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Jury Box		Clearance, perpendicular	48	Yes					n/a	$ -	
F02777	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Witness Stand		Clearance, perpendicular	73.25	Yes					n/a	$ -	
F02778	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Wheelchair Space		Companion seat?	Y	Yes					n/a	$ -	
F02779	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Counter		Length	93	Yes					n/a	$ -	
F02780	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Wheelchair Space		Line of sight?	OK	Yes					n/a	$ -	
F02781	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Seating Area		Number, ALS receivers	4	Yes					n/a	$ -	
F02782	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Seating Area		Number, wheelchair spaces	2	Yes					n/a	$ -	
F02783	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Wheelchair Space		On access route?	Y	Yes					n/a	$ -	
F02784	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Witness Stand		Ramp?	Y	Yes					n/a	$ -	
F02785	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Seating Area		Seating dispersed?	Y	Yes					n/a	$ -	
F02786	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Circulation Path		Surface material	OK	Yes					n/a	$ -	
F02787	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Wheelchair Space		Surface material	OK	Yes					n/a	$ -	
F02788	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F02789	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Circulation Path		Width	OK	Yes					n/a	$ -	
F02790	Justice Center		5th Floor	Owned	Courtroom	#507	2-Public Supervised	Wheelchair Space		Width	36	Yes					n/a	$ -	
F02798	Justice Center		5th Floor	Owned	Courtroom	#507 - Employee Entrance	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F02799	Justice Center		5th Floor	Owned	Courtroom	#507 - Employee Entrance	2-Public Supervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F02800	Justice Center		5th Floor	Owned	Courtroom	#507 - Employee Entrance	2-Public Supervised	Door Gate		Clearance, pull perpendicular	61.75	Yes					n/a	$ -	
F02801	Justice Center		5th Floor	Owned	Courtroom	#507 - Employee Entrance	2-Public Supervised	Door Gate		Clearance, push parallel	77	Yes					n/a	$ -	
F02802	Justice Center		5th Floor	Owned	Courtroom	#507 - Employee Entrance	2-Public Supervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F02803	Justice Center		5th Floor	Owned	Courtroom	#507 - Employee Entrance	2-Public Supervised	Door Gate		Clearance, vertical	92	Yes					n/a	$ -	
F02804	Justice Center		5th Floor	Owned	Courtroom	#507 - Employee Entrance	2-Public Supervised	Signage		Height, bottom	58.75	Yes					n/a	$ -	
F02805	Justice Center		5th Floor	Owned	Courtroom	#507 - Employee Entrance	2-Public Supervised	Door Gate		Height, hardware	OK	Yes					n/a	$ -	
F02806	Justice Center		5th Floor	Owned	Courtroom	#507 - Employee Entrance	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F02807	Justice Center		5th Floor	Owned	Courtroom	#507 - Employee Entrance	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F02812	Justice Center		5th Floor	Owned	Courtroom	#507 - Juror Entrance	2-Public Supervised	Door Gate		Approach type, push	Y	Yes					n/a	$ -	
F02813	Justice Center		5th Floor	Owned	Courtroom	#507 - Juror Entrance	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F02814	Justice Center		5th Floor	Owned	Courtroom	#507 - Juror Entrance	2-Public Supervised	Door Gate		Clearance, pull parallel	18	Yes					n/a	$ -	
F02815	Justice Center		5th Floor	Owned	Courtroom	#507 - Juror Entrance	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F02816	Justice Center		5th Floor	Owned	Courtroom	#507 - Juror Entrance	2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F02817	Justice Center		5th Floor	Owned	Courtroom	#507 - Juror Entrance	2-Public Supervised	Door Gate		Clearance, push perpendicular	77	Yes					n/a	$ -	
F02818	Justice Center		5th Floor	Owned	Courtroom	#507 - Juror Entrance	2-Public Supervised	Door Gate		Clearance, vertical	92	Yes					n/a	$ -	
F02819	Justice Center		5th Floor	Owned	Courtroom	#507 - Juror Entrance	2-Public Supervised	Door Gate		Closing speed	6	Yes					n/a	$ -	
F02820	Justice Center		5th Floor	Owned	Courtroom	#507 - Juror Entrance	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F02821	Justice Center		5th Floor	Owned	Courtroom	#507 - Juror Entrance	2-Public Supervised	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F02825	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S511	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F02826	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S511	2-Public Supervised	Door Gate		Clearance, pull parallel	47	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F02827	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S511	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F02828	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S511	2-Public Supervised	Door Gate		Clearance, push parallel	46.75	Yes					n/a	$ -	
F02829	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S511	2-Public Supervised	Door Gate		Clearance, push perpendicular	90	Yes					n/a	$ -	
F02830	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S511	2-Public Supervised	Door Gate		Clearance, vertical	83.5	Yes					n/a	$ -	
F02831	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S511	2-Public Supervised	Signage		Height, bottom	57.75	Yes					n/a	$ -	
F02832	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S511	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F02833	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S511	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	
F02834	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S511	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F02845	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate		Clear opening	33.25	Yes					n/a	$ -	
F02846	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate	2nd set in series	Clear opening	33.5	Yes					n/a	$ -	
F02847	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F02848	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate	2nd set in series	Clearance, pull parallel	41.5	Yes					n/a	$ -	
F02849	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F02850	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate	2nd set in series	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F02851	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate		Clearance, push parallel	41	Yes					n/a	$ -	
F02852	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate	2nd set in series	Clearance, push parallel	50	Yes					n/a	$ -	
F02853	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F02854	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate	2nd set in series	Clearance, push perpendicular	99	Yes					n/a	$ -	
F02855	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate		Clearance, series doors	71	Yes					n/a	$ -	
F02856	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate		Clearance, vertical	92	Yes					n/a	$ -	
F02857	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate	2nd set in series	Clearance, vertical	91	Yes					n/a	$ -	
F02858	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate	2nd set in series	Closing speed	5	Yes					n/a	$ -	
F02859	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate		Firm, stable, slip resistant	OK	Yes					n/a	$ -	
F02860	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate		Hardware type	Panic bar	Yes					n/a	$ -	
F02861	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F02862	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate		Height, hardware	OK	Yes					n/a	$ -	
F02863	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate	2nd set in series	Height, hardware	OK	Yes					n/a	$ -	
F02864	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F02865	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F02866	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Door Gate	2nd set in series	Kick plate?	SD	Yes					n/a	$ -	
F02867	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	
F02868	Justice Center		5th Floor	Owned	Courtroom	#507 - Room S512	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F02872	Justice Center		6th Floor	Owned	Courtroom	#601	2-Public Supervised	Seating Area		Number, ALS receivers	4	Yes					n/a	$ -	
F02873	Justice Center		6th Floor	Owned	Courtroom	#601	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F02888	Justice Center		6th Floor	Owned	Courtroom	#602	2-Public Supervised	Seating Area		Number, wheelchair spaces	2	Yes					n/a	$ -	
F02889	Justice Center		6th Floor	Owned	Courtroom	#602	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F02894	Justice Center		6th Floor	Owned	Courtroom	#603	2-Public Supervised	Seating Area		Number, ALS receivers	4	Yes					n/a	$ -	
F02909	Justice Center		6th Floor	Owned	Courtroom	#604	2-Public Supervised	Seating Area		Number, wheelchair spaces	2	Yes					n/a	$ -	
F02910	Justice Center		6th Floor	Owned	Courtroom	#604	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F02942	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Seating Area	Spectator	Assistive listening systems?	Y	Yes					n/a	$ -	
F02943	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Door Gate	Court staff entrance	Clear opening	33.5	Yes					n/a	$ -	
F02944	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Counter	Check-in	Clearance, parallel	99	Yes					n/a	$ -	
F02945	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Jury Box		Clearance, parallel	99	Yes					n/a	$ -	
F02946	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Witness Stand		Clearance, parallel	99	Yes					n/a	$ -	
F02947	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Counter	Check-in	Clearance, perpendicular	99	Yes					n/a	$ -	
F02948	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Jury Box		Clearance, perpendicular	48	Yes					n/a	$ -	
F02949	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Witness Stand		Clearance, perpendicular	99	Yes					n/a	$ -	
F02950	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Door Gate	Court staff entrance	Clearance, pull parallel	99	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F02951	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Door Gate	Court staff entrance	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F02952	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Door Gate	Court staff entrance	Clearance, push parallel	99	Yes					n/a	$ -	
F02953	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Door Gate	Court staff entrance	Clearance, push perpendicular	99	Yes					n/a	$ -	
F02954	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Door Gate	Court staff entrance	Closing speed	5	Yes					n/a	$ -	
F02955	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Door Gate	Court staff entrance	Hardware type	L	Yes					n/a	$ -	
F02956	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Witness Stand		Ramp?	Y	Yes					n/a	$ -	
F02957	Justice Center		6th Floor	Owned	Courtroom	#S612	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F02958	Justice Center		5th Floor	Owned	Courtroom	#506 - Room S508	2-Public Supervised	Door Gate		Height, threshold	0	Yes					n/a	$ -	
F03173	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Hoistway Sign		All floors?	Y	Yes					n/a	$ -	
F03174	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Elevator Car		Audible signal?	Y	Yes					n/a	$ -	
F03175	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Hall Signal		Audible signal?	Y	Yes					n/a	$ -	
F03176	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Position Indicators		Audible signal?	Y	Yes					n/a	$ -	
F03177	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Hoistway Sign		Both jambs?	Y	Yes					n/a	$ -	
F03178	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Car Controls		Braille instructions	Y	Yes					n/a	$ -	
F03179	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Hoistway Sign		Braille?	Y	Yes					n/a	$ -	
F03180	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Elevator Door		Clear opening	42	Yes					n/a	$ -	
F03181	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Handrail		Clearance to wall	2.25	Yes					n/a	$ -	
F03182	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Car Controls		Clearance, parallel	99	Yes					n/a	$ -	
F03183	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Car Controls		Clearance, perpendicular	99	Yes					n/a	$ -	
F03184	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Elevator Door		Closing speed	5	Yes					n/a	$ -	
F03185	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Handrail		Cross section dimension, maximum	1.25	Yes					n/a	$ -	
F03186	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Handrail		Diameter	1.25	Yes					n/a	$ -	
F03187	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Handrail		Dimension between handrails	5	Yes					n/a	$ -	
F03188	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Elevator Car		Dimension, back to front	63.5	Yes					n/a	$ -	
F03189	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Elevator Car		Dimension, side to side	78	Yes					n/a	$ -	
F03190	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Elevator Door		Distance to door	19	Yes					n/a	$ -	
F03191	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Elevator Car		Firm, stable, slip resistant	Y	Yes					n/a	$ -	
F03192	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Car Controls		Height, bottom	34.5	Yes					n/a	$ -	
F03193	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Emergency Communications		Height, bottom	21	Yes					n/a	$ -	
F03194	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Hall Signal		Height, center	104	Yes					n/a	$ -	
F03195	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Elevator Car		Height, level change	OK	Yes					n/a	$ -	
F03196	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Car Controls		Height, top	42.5	Yes					n/a	$ -	
F03197	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Car Controls		Height, top	41.5	Yes					n/a	$ -	
F03198	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Emergency Communications		Height, top	21	Yes					n/a	$ -	
F03199	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Handrail		Height, top	32.25	Yes					n/a	$ -	
F03200	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Car Controls		Lighted?	Y	Yes					n/a	$ -	
F03201	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Emergency Communications		Provided?	Y	Yes					n/a	$ -	
F03202	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Elevator Door		Reopen device?	Y	Yes					n/a	$ -	
F03203	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Handrail		Rotates?	N	Yes					n/a	$ -	
F03204	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Car Controls		Size	1	Yes					n/a	$ -	
F03205	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Car Controls		Size	1	Yes					n/a	$ -	
F03206	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Hall Signal		Size	3	Yes					n/a	$ -	
F03207	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Position Indicators		Size	1.5	Yes					n/a	$ -	
F03208	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Car Controls		Star?	Y	Yes					n/a	$ -	
F03209	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Hoistway Sign		Tactile letters?	Y	Yes					n/a	$ -	
F03210	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Car Controls		Tactile?	Y	Yes					n/a	$ -	
F03211	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Emergency Communications		Tactile?	Y	Yes					n/a	$ -	
F03212	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Car Controls		Up above down?	Y	Yes					n/a	$ -	
F03213	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Car Controls		Visible signal?	Y	Yes					n/a	$ -	
F03214	Justice Center		Interior	Owned	Elevator	#1 - Off main lobby	1-Public Unsupervised	Position Indicators		Visible signal?	Y	Yes					n/a	$ -	
F03221	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Hoistway Sign		All floors?	Y	Yes					n/a	$ -	
F03222	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Hall Signal		Audible signal?	Y	Yes					n/a	$ -	
F03223	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Position Indicators		Audible signal?	Y	Yes					n/a	$ -	
F03224	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Hoistway Sign		Both jambs?	Y	Yes					n/a	$ -	
F03225	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Car Controls		Braille instructions	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F03226	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Hoistway Sign		Braille?	Y	Yes					n/a	$ -	
F03227	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Elevator Door		Clear opening	42	Yes					n/a	$ -	
F03228	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Car Controls		Clearance, parallel	72	Yes					n/a	$ -	
F03229	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Car Controls		Clearance, perpendicular	99	Yes					n/a	$ -	
F03230	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Elevator Car		Dimension, back to front	83.5	Yes					n/a	$ -	
F03231	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Elevator Car		Dimension, gap	1.25	Yes					n/a	$ -	
F03232	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Elevator Car		Dimension, side to side	77.5	Yes					n/a	$ -	
F03233	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Elevator Door		Distance to door	19	Yes					n/a	$ -	
F03234	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Car Controls		Height, bottom	34.5	Yes					n/a	$ -	
F03235	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Emergency Communications		Height, bottom	17.5	Yes					n/a	$ -	
F03236	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Hall Signal		Height, center	104	Yes					n/a	$ -	
F03237	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Car Controls		Height, emergency control	35	Yes					n/a	$ -	
F03238	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Elevator Car		Height, level change	OK	Yes					n/a	$ -	
F03239	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Car Controls		Height, top	42.5	Yes					n/a	$ -	
F03240	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Car Controls		Height, top	41.5	Yes					n/a	$ -	
F03241	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Emergency Communications		Height, top	29.25	Yes					n/a	$ -	
F03242	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Car Controls		Lighted?	Y	Yes					n/a	$ -	
F03243	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Position Indicators		Location	Above call controls	Yes					n/a	$ -	
F03244	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Emergency Communications		Provided?	Y	Yes					n/a	$ -	
F03245	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Elevator Door		Reopen device?	Y	Yes					n/a	$ -	
F03246	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Car Controls		Size	1	Yes					n/a	$ -	
F03247	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Car Controls		Size	1	Yes					n/a	$ -	
F03248	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Hall Signal		Size	3.5	Yes					n/a	$ -	
F03249	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Position Indicators		Size	1.25	Yes					n/a	$ -	
F03250	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Car Controls		Star?	Y	Yes					n/a	$ -	
F03251	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Hoistway Sign		Tactile letters?	Y	Yes					n/a	$ -	
F03252	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Car Controls		Tactile?	Y	Yes					n/a	$ -	
F03253	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Emergency Communications		Tactile?	Y	Yes					n/a	$ -	
F03254	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Car Controls		Up above down?	Y	Yes					n/a	$ -	
F03255	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Car Controls		Visible signal?	Y	Yes					n/a	$ -	
F03256	Justice Center		Interior	Owned	Elevator	#3 - Off main lobby	1-Public Unsupervised	Position Indicators		Visible signal?	Y	Yes					n/a	$ -	
F03262	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Hoistway Sign		All floors?	Y	Yes					n/a	$ -	
F03263	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Elevator Car		Audible signal?	Y	Yes					n/a	$ -	
F03264	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Hall Signal		Audible signal?	Y	Yes					n/a	$ -	
F03265	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Hoistway Sign		Both jambs?	Y	Yes					n/a	$ -	
F03266	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Car Controls		Braille instructions	Y	Yes					n/a	$ -	
F03267	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Hoistway Sign		Braille?	Y	Yes					n/a	$ -	
F03268	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Elevator Door		Clear opening	48	Yes					n/a	$ -	
F03269	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Handrail		Clearance to wall	1.5	Yes					n/a	$ -	
F03270	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Elevator Door		Closing speed	5	Yes					n/a	$ -	
F03271	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Handrail		Diameter	1.5	Yes					n/a	$ -	
F03272	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Elevator Car		Dimension, back to front	103	Yes					n/a	$ -	
F03273	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Elevator Car		Dimension, gap	1	Yes					n/a	$ -	
F03274	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Car Controls		Height, bottom	32	Yes					n/a	$ -	
F03275	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Emergency Communications		Height, bottom	32.5	Yes					n/a	$ -	
F03276	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Hall Signal		Height, center	77	Yes					n/a	$ -	
F03277	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Car Controls		Height, emergency control	35	Yes					n/a	$ -	
F03278	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Car Controls		Height, top	42	Yes					n/a	$ -	
F03279	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Car Controls		Height, top	45	Yes					n/a	$ -	
F03280	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Handrail		Height, top	32	Yes					n/a	$ -	
F03281	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Car Controls		Lighted?	Y	Yes					n/a	$ -	
F03282	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Position Indicators		Location	79	Yes					n/a	$ -	
F03283	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Emergency Communications		Provided?	Y	Yes					n/a	$ -	
F03284	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Elevator Door		Reopen device?	Y	Yes					n/a	$ -	
F03285	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Handrail		Rotates?	N	Yes					n/a	$ -	
F03286	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Car Controls		Size	1	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F03287	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Car Controls		Size	1	Yes					n/a	$ -	
F03288	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Hall Signal		Size	3	Yes					n/a	$ -	
F03289	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Position Indicators		Size	2	Yes					n/a	$ -	
F03290	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Car Controls		Star?	Y	Yes					n/a	$ -	
F03291	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Hoistway Sign		Tactile letters?	Y	Yes					n/a	$ -	
F03292	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Car Controls		Tactile?	Y	Yes					n/a	$ -	
F03293	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Emergency Communications		Tactile?	Y	Yes					n/a	$ -	
F03294	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Car Controls		Up above down?	Y	Yes					n/a	$ -	
F03295	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Car Controls		Visible signal?	Y	Yes					n/a	$ -	
F03296	Justice Center		Interior	Owned	Elevator	#8 - South	1-Public Unsupervised	Position Indicators		Visible signal?	Y	Yes					n/a	$ -	
F03298	Justice Center		Interior	Owned	Elevator	North	2-Public Supervised	Elevator Car		Audible signal?	Y	Yes					n/a	$ -	
F03299	Justice Center		Interior	Owned	Elevator	North	2-Public Supervised	Elevator Car		Dimension, back to front	73	Yes					n/a	$ -	
F03300	Justice Center		Interior	Owned	Elevator	North	2-Public Supervised	Elevator Car		Dimension, gap	1.25	Yes					n/a	$ -	
F03301	Justice Center		Interior	Owned	Elevator	North	2-Public Supervised	Elevator Car		Dimension, side to side	81	Yes					n/a	$ -	
F03305	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Position Indicators		Audible signal?	Y	Yes					n/a	$ -	
F03306	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Car Controls		Braille instructions	Y	Yes					n/a	$ -	
F03307	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Elevator Door		Clear opening	42	Yes					n/a	$ -	
F03308	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Car Controls		Clearance, parallel	60	Yes					n/a	$ -	
F03309	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Car Controls		Clearance, perpendicular	60	Yes					n/a	$ -	
F03310	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Elevator Door		Closing speed	5	Yes					n/a	$ -	
F03311	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Elevator Door		Distance to door	72	Yes					n/a	$ -	
F03312	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Car Controls		Height, bottom	35	Yes					n/a	$ -	
F03313	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Emergency Communications		Height, bottom	18	Yes					n/a	$ -	
F03314	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Car Controls		Height, emergency control	35	Yes					n/a	$ -	
F03315	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Car Controls		Height, top	41.5	Yes					n/a	$ -	
F03316	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Car Controls		Height, top	41	Yes					n/a	$ -	
F03317	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Emergency Communications		Height, top	29	Yes					n/a	$ -	
F03318	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Car Controls		Lighted?	Y	Yes					n/a	$ -	
F03319	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Position Indicators		Location	Above call controls	Yes					n/a	$ -	
F03320	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Emergency Communications		Provided?	Y	Yes					n/a	$ -	
F03321	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Elevator Door		Reopen device?	Y	Yes					n/a	$ -	
F03322	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Car Controls		Size	1	Yes					n/a	$ -	
F03323	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Car Controls		Size	1	Yes					n/a	$ -	
F03324	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Position Indicators		Size	2	Yes					n/a	$ -	
F03325	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Car Controls		Star?	Y	Yes					n/a	$ -	
F03326	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Car Controls		Tactile?	Y	Yes					n/a	$ -	
F03327	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Emergency Communications		Tactile?	Y	Yes					n/a	$ -	
F03328	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Car Controls		Up above down?	Y	Yes					n/a	$ -	
F03329	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Car Controls		Visible signal?	Y	Yes					n/a	$ -	
F03330	Justice Center		Interior	Owned	Elevator	North - Basement level	2-Public Supervised	Position Indicators		Visible signal?	Y	Yes					n/a	$ -	
F03333	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Hoistway Sign		All floors?	Y	Yes					n/a	$ -	
F03334	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Elevator Car		Audible signal?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F03335	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Hall Signal		Audible signal?	Y	Yes					n/a	$ -	
F03336	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Position Indicators		Audible signal?	Y	Yes					n/a	$ -	
F03337	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Hoistway Sign		Both jambs?	Y	Yes					n/a	$ -	
F03338	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Car Controls		Braille instructions	Y	Yes					n/a	$ -	
F03339	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Hoistway Sign		Braille?	Y	Yes					n/a	$ -	
F03340	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Elevator Door		Clear opening	48	Yes					n/a	$ -	
F03341	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Car Controls		Clearance, parallel	72	Yes					n/a	$ -	
F03342	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Car Controls		Clearance, perpendicular	99	Yes					n/a	$ -	
F03343	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Elevator Door		Closing speed	5	Yes					n/a	$ -	
F03344	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Elevator Car		Dimension, back to front	104	Yes					n/a	$ -	
F03345	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Elevator Car		Dimension, gap	1	Yes					n/a	$ -	
F03346	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Elevator Car		Dimension, side to side	69	Yes					n/a	$ -	
F03347	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Car Controls		Height, bottom	32	Yes					n/a	$ -	
F03348	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Emergency Communications		Height, bottom	32.5	Yes					n/a	$ -	
F03349	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Car Controls		Height, emergency control	35	Yes					n/a	$ -	
F03350	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Car Controls		Height, top	42	Yes					n/a	$ -	
F03351	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Car Controls		Height, top	48	Yes					n/a	$ -	
F03352	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Car Controls		Lighted?	Y	Yes					n/a	$ -	
F03353	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Position Indicators		Location	Above call controls	Yes					n/a	$ -	
F03354	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Emergency Communications		Provided?	Y	Yes					n/a	$ -	
F03355	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Elevator Door		Reopen device?	Y	Yes					n/a	$ -	
F03356	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Car Controls		Size	1	Yes					n/a	$ -	
F03357	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Car Controls		Size	1	Yes					n/a	$ -	
F03358	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Hall Signal		Size	3	Yes					n/a	$ -	
F03359	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Position Indicators		Size	2	Yes					n/a	$ -	
F03360	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Car Controls		Star?	Y	Yes					n/a	$ -	
F03361	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Hoistway Sign		Tactile letters?	Y	Yes					n/a	$ -	
F03362	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Car Controls		Tactile?	Y	Yes					n/a	$ -	
F03363	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Emergency Communications		Tactile?	Y	Yes					n/a	$ -	
F03364	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Car Controls		Up above down?	Y	Yes					n/a	$ -	
F03365	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Car Controls		Visible signal?	Y	Yes					n/a	$ -	
F03366	Justice Center		Interior	Owned	Elevator	South - Basement level	2-Public Supervised	Position Indicators		Visible signal?	Y	Yes					n/a	$ -	
F03370	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Hoistway Sign		All floors?	Y	Yes					n/a	$ -	
F03371	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Elevator Car		Audible signal?	Y	Yes					n/a	$ -	
F03372	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Hall Signal		Audible signal?	Y	Yes					n/a	$ -	
F03373	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Hoistway Sign		Both jambs?	Y	Yes					n/a	$ -	
F03374	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Car Controls		Braille instructions	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F03375	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Hoistway Sign		Braille?	Y	Yes					n/a	$ -	
F03376	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Elevator Door		Clear opening	42	Yes					n/a	$ -	
F03377	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Handrail		Clearance to wall	1.5	Yes					n/a	$ -	
F03378	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Car Controls		Clearance, parallel	OK	Yes					n/a	$ -	
F03379	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Car Controls		Clearance, perpendicular	OK	Yes					n/a	$ -	
F03380	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Elevator Door		Closing speed	10	Yes					n/a	$ -	
F03381	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Handrail		Diameter	1.5	Yes					n/a	$ -	
F03382	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Elevator Car		Dimension, back to front	65.5	Yes					n/a	$ -	
F03383	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Elevator Car		Dimension, gap	1	Yes					n/a	$ -	
F03384	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Elevator Car		Dimension, side to side	80	Yes					n/a	$ -	
F03385	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Elevator Door		Distance to door	9.75	Yes					n/a	$ -	
F03386	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Elevator Car		Firm, stable, slip resistant	OK	Yes					n/a	$ -	
F03387	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Car Controls		Height, bottom	32	Yes					n/a	$ -	
F03388	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Emergency Communications		Height, bottom	32.5	Yes					n/a	$ -	
F03389	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Hall Signal		Height, center	77.5	Yes					n/a	$ -	
F03390	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Elevator Car		Height, level change	OK	Yes					n/a	$ -	
F03391	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Car Controls		Height, top	44	Yes					n/a	$ -	
F03392	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Car Controls		Height, top	45.25	Yes					n/a	$ -	
F03393	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Emergency Communications		Height, top	32.5	Yes					n/a	$ -	
F03394	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Handrail		Height, top	32	Yes					n/a	$ -	
F03395	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Car Controls		Lighted?	Y	Yes					n/a	$ -	
F03396	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Emergency Communications		Provided?	Y	Yes					n/a	$ -	
F03397	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Elevator Door		Reopen device?	Y	Yes					n/a	$ -	
F03398	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Car Controls		Size	1	Yes					n/a	$ -	
F03399	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Car Controls		Size	1	Yes					n/a	$ -	
F03400	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Hall Signal		Size	3	Yes					n/a	$ -	
F03401	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Car Controls		Star?	Y	Yes					n/a	$ -	
F03402	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Hoistway Sign		Tactile letters?	Y	Yes					n/a	$ -	
F03403	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Car Controls		Tactile?	Y	Yes					n/a	$ -	
F03404	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Emergency Communications		Tactile?	Y	Yes					n/a	$ -	
F03405	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Car Controls		Up above down?	Y	Yes					n/a	$ -	
F03406	Justice Center		Interior	Owned	Elevator	South end within staff area	3-Employee Common	Car Controls		Visible signal?	Y	Yes					n/a	$ -	
F03407	Justice Center		Interior	Owned	Elevator	West - Basement level	2-Public Supervised	Position Indicators		Location	Above call controls	Yes					n/a	$ -	
F03833	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room A	Clear opening	33	Yes					n/a	$ -	
F03834	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room B	Clear opening	33	Yes					n/a	$ -	
F03835	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room A	Clearance, pull parallel	99	Yes					n/a	$ -	
F03836	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room B	Clearance, pull parallel	99	Yes					n/a	$ -	
F03837	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room A	Clearance, pull perpendicular	99	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F03838	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room B	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F03839	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room A	Clearance, push parallel	99	Yes					n/a	$ -	
F03840	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room A	Clearance, push perpendicular	64	Yes					n/a	$ -	
F03841	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room B	Clearance, push perpendicular	99	Yes					n/a	$ -	
F03842	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room A	Clearance, vertical	84	Yes					n/a	$ -	
F03843	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room B	Clearance, vertical	84	Yes					n/a	$ -	
F03844	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room A	Closing speed	5	Yes					n/a	$ -	
F03845	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room B	Closing speed	7	Yes					n/a	$ -	
F03846	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room A	Hardware type	L	Yes					n/a	$ -	
F03847	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room B	Hardware type	L	Yes					n/a	$ -	
F03848	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Signage	Conf Room A	Height, bottom	58.25	Yes					n/a	$ -	
F03849	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Signage	Conf Room B	Height, bottom	58.25	Yes					n/a	$ -	
F03850	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room A	Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F03851	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Door Gate	Conf Room B	Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F03852	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Signage	Conf Room A	ISA?	N	Yes					n/a	$ -	
F03853	Justice Center	CASA	Interior	Owned	Hallway	#151 - Office	1-Public Unsupervised	Signage	Conf Room B	ISA?	N	Yes					n/a	$ -	
F03862	Justice Center	CASA	Interior	Owned	Hallway	#152 - Office	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F03863	Justice Center	CASA	Interior	Owned	Hallway	#152 - Office	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F03864	Justice Center	CASA	Interior	Owned	Hallway	#152 - Office	1-Public Unsupervised	Door Gate		Clearance, push parallel	19	Yes					n/a	$ -	
F03865	Justice Center	CASA	Interior	Owned	Hallway	#152 - Office	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F03866	Justice Center	CASA	Interior	Owned	Hallway	#152 - Office	1-Public Unsupervised	Door Gate		Clearance, vertical	93	Yes					n/a	$ -	
F03867	Justice Center	CASA	Interior	Owned	Hallway	#152 - Office	1-Public Unsupervised	Door Gate		Closing speed	7	Yes					n/a	$ -	
F03868	Justice Center	CASA	Interior	Owned	Hallway	#152 - Office	1-Public Unsupervised	Door Gate		Hardware type	Panic bar	Yes					n/a	$ -	
F03869	Justice Center	CASA	Interior	Owned	Hallway	#152 - Office	1-Public Unsupervised	Signage	At entrance to hall	Height, bottom	58.25	Yes					n/a	$ -	
F03870	Justice Center	CASA	Interior	Owned	Hallway	#152 - Office	1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F03871	Justice Center	CASA	Interior	Owned	Hallway	#152 - Office	1-Public Unsupervised	Signage	At entrance to hall	ISA?	N	Yes					n/a	$ -	
F03872	Justice Center	CASA	Interior	Owned	Hallway	#152 - Office	1-Public Unsupervised	Signage	At entrance to hall	Location	L	Yes					n/a	$ -	
F03877	Justice Center	Self Help Resource Center	1st Floor	Owned	Hallway	Training Room	1-Public Unsupervised	Drinking Fountain	Between men's & women's restrooms	Clearance, parallel	71.5	Yes					n/a	$ -	
F03878	Justice Center	Self Help Resource Center	1st Floor	Owned	Hallway	Training Room	1-Public Unsupervised	Drinking Fountain	Between men's & women's restrooms	Clearance, perpendicular	99	Yes					n/a	$ -	
F03879	Justice Center	Self Help Resource Center	1st Floor	Owned	Hallway	Training Room	1-Public Unsupervised	Drinking Fountain	Between men's & women's restrooms	Control force	2	Yes					n/a	$ -	
F03880	Justice Center	Self Help Resource Center	1st Floor	Owned	Hallway	Training Room	1-Public Unsupervised	Drinking Fountain	Between men's & women's restrooms	Dimension, knee clearance	27	Yes					n/a	$ -	
F03881	Justice Center	Self Help Resource Center	1st Floor	Owned	Hallway	Training Room	1-Public Unsupervised	Alarm System		Height	89.5	Yes					n/a	$ -	
F03882	Justice Center	Self Help Resource Center	1st Floor	Owned	Hallway	Training Room	1-Public Unsupervised	Drinking Fountain	Between men's & women's restrooms	Height	34.5	Yes					n/a	$ -	
F03883	Justice Center	Self Help Resource Center	1st Floor	Owned	Hallway	Training Room	1-Public Unsupervised	Drinking Fountain	Between men's & women's restrooms	Height, water flow	39	Yes					n/a	$ -	
F03884	Justice Center	Self Help Resource Center	1st Floor	Owned	Hallway	Training Room	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F03885	Justice Center	Self Help Resource Center	1st Floor	Owned	Hallway	Training Room	1-Public Unsupervised	Drinking Fountain	Between men's & women's restrooms	Spout location	2.75	Yes					n/a	$ -	
F03898	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F03899	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F03900	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Clearance, pull parallel	39	Yes					n/a	$ -	
F03901	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Clearance, pull parallel	37	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F03902	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Clearance, pull perpendicular	86	Yes					n/a	$ -	
F03903	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F03904	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Clearance, push parallel	39	Yes					n/a	$ -	
F03905	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Clearance, push parallel	21	Yes					n/a	$ -	
F03906	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F03907	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F03908	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Clearance, vertical	93	Yes					n/a	$ -	
F03909	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F03910	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F03911	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Hardware type	Panic bar	Yes					n/a	$ -	
F03912	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F03913	Justice Center		4th Floor	Owned	Hallway	#405 - Back hall entrance	3-Employee Common	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F03920	Justice Center		4th Floor	Owned	Hallway	#S412 - Back hall entrance	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F03921	Justice Center		4th Floor	Owned	Hallway	#S412 - Back hall entrance	3-Employee Common	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F03922	Justice Center		4th Floor	Owned	Hallway	#S412 - Back hall entrance	3-Employee Common	Door Gate		Clearance, pull perpendicular	61	Yes					n/a	$ -	
F03923	Justice Center		4th Floor	Owned	Hallway	#S412 - Back hall entrance	3-Employee Common	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F03924	Justice Center		4th Floor	Owned	Hallway	#S412 - Back hall entrance	3-Employee Common	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F03925	Justice Center		4th Floor	Owned	Hallway	#S412 - Back hall entrance	3-Employee Common	Door Gate		Clearance, vertical	82	Yes					n/a	$ -	
F03926	Justice Center		4th Floor	Owned	Hallway	#S412 - Back hall entrance	3-Employee Common	Door Gate		Closing speed	6	Yes					n/a	$ -	
F03927	Justice Center		4th Floor	Owned	Hallway	#S412 - Back hall entrance	3-Employee Common	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F03934	Justice Center		4th Floor	Owned	Hallway	#S418 - Back hall entrance	2-Public Supervised	Door Gate		Clear opening	33.5	Yes					n/a	$ -	
F03935	Justice Center		4th Floor	Owned	Hallway	#S418 - Back hall entrance	2-Public Supervised	Door Gate		Clearance, pull parallel	19	Yes					n/a	$ -	
F03936	Justice Center		4th Floor	Owned	Hallway	#S418 - Back hall entrance	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F03937	Justice Center		4th Floor	Owned	Hallway	#S418 - Back hall entrance	2-Public Supervised	Door Gate		Clearance, push parallel	19	Yes					n/a	$ -	
F03938	Justice Center		4th Floor	Owned	Hallway	#S418 - Back hall entrance	2-Public Supervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F03939	Justice Center		4th Floor	Owned	Hallway	#S418 - Back hall entrance	2-Public Supervised	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F03940	Justice Center		4th Floor	Owned	Hallway	#S418 - Back hall entrance	2-Public Supervised	Door Gate		Closing speed	6	Yes					n/a	$ -	
F03941	Justice Center		4th Floor	Owned	Hallway	#S418 - Back hall entrance	2-Public Supervised	Door Gate		Hardware type	Secure access	Yes					n/a	$ -	
F03942	Justice Center		4th Floor	Owned	Hallway	#S418 - Back hall entrance	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F03949	Justice Center		4th Floor	Owned	Hallway	#S437 - Back hall entrance	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F03950	Justice Center		4th Floor	Owned	Hallway	#S437 - Back hall entrance	2-Public Supervised	Door Gate		Clearance, pull parallel	19	Yes					n/a	$ -	
F03951	Justice Center		4th Floor	Owned	Hallway	#S437 - Back hall entrance	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F03952	Justice Center		4th Floor	Owned	Hallway	#S437 - Back hall entrance	2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F03953	Justice Center		4th Floor	Owned	Hallway	#S437 - Back hall entrance	2-Public Supervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F03954	Justice Center		4th Floor	Owned	Hallway	#S437 - Back hall entrance	2-Public Supervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F03955	Justice Center		4th Floor	Owned	Hallway	#S437 - Back hall entrance	2-Public Supervised	Door Gate		Closing speed	7	Yes					n/a	$ -	
F03956	Justice Center		4th Floor	Owned	Hallway	#S437 - Back hall entrance	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F03957	Justice Center		4th Floor	Owned	Hallway	#S437 - Back hall entrance	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F03962	Justice Center		6th Floor	Owned	Hallway	Between restrooms	1-Public Unsupervised	Drinking Fountain		Height	34	Yes					n/a	$ -	
F03963	Justice Center		6th Floor	Owned	Hallway	Between restrooms	1-Public Unsupervised	Drinking Fountain		Height	41	Yes					n/a	$ -	
F03964	Justice Center		6th Floor	Owned	Hallway	Between restrooms	1-Public Unsupervised	Drinking Fountain		Height, water flow	6	Yes					n/a	$ -	
F03965	Justice Center		6th Floor	Owned	Hallway	Between restrooms	1-Public Unsupervised	Drinking Fountain		Spout location	3	Yes					n/a	$ -	
F03967	Justice Center		1st Floor	Owned	Hallway	Between rooms #108 & #109	1-Public Unsupervised	Drinking Fountain		Clearance, parallel	76	Yes					n/a	$ -	
F03968	Justice Center		1st Floor	Owned	Hallway	Between rooms #108 & #109	1-Public Unsupervised	Drinking Fountain		Clearance, perpendicular	99	Yes					n/a	$ -	
F03969	Justice Center		1st Floor	Owned	Hallway	Between rooms #108 & #109	1-Public Unsupervised	Drinking Fountain		Control force	5	Yes					n/a	$ -	
F03970	Justice Center		1st Floor	Owned	Hallway	Between rooms #108 & #109	1-Public Unsupervised	Drinking Fountain		Dimension, knee clearance	27.25	Yes					n/a	$ -	
F03971	Justice Center		1st Floor	Owned	Hallway	Between rooms #108 & #109	1-Public Unsupervised	Drinking Fountain		Height	34	Yes					n/a	$ -	
F03972	Justice Center		1st Floor	Owned	Hallway	Between rooms #108 & #109	1-Public Unsupervised	Drinking Fountain		Height, water flow	38	Yes					n/a	$ -	
F03973	Justice Center		1st Floor	Owned	Hallway	Between rooms #108 & #109	1-Public Unsupervised	Drinking Fountain		Spout location	2.5	Yes					n/a	$ -	
F03975	Justice Center		3rd Floor	Owned	Hallway	Between rooms #354 & #355	1-Public Unsupervised	Drinking Fountain		Clearance, parallel	99	Yes					n/a	$ -	
F03976	Justice Center		3rd Floor	Owned	Hallway	Between rooms #354 & #355	1-Public Unsupervised	Drinking Fountain		Clearance, perpendicular	99	Yes					n/a	$ -	
F03977	Justice Center		3rd Floor	Owned	Hallway	Between rooms #354 & #355	1-Public Unsupervised	Drinking Fountain		Dimension, knee clearance	27	Yes					n/a	$ -	
F03978	Justice Center		3rd Floor	Owned	Hallway	Between rooms #354 & #355	1-Public Unsupervised	Drinking Fountain		Height	34	Yes					n/a	$ -	
F03979	Justice Center		3rd Floor	Owned	Hallway	Between rooms #354 & #355	1-Public Unsupervised	Drinking Fountain		Height, water flow	36	Yes					n/a	$ -	
F03980	Justice Center		3rd Floor	Owned	Hallway	Between rooms #354 & #355	1-Public Unsupervised	Drinking Fountain		Spout location	4	Yes					n/a	$ -	
F03984	Justice Center		4th Floor	Owned	Hallway	Between rooms #410 & #411	1-Public Unsupervised	Drinking Fountain		Clearance, parallel	99	Yes					n/a	$ -	
F03985	Justice Center		4th Floor	Owned	Hallway	Between rooms #410 & #411	1-Public Unsupervised	Drinking Fountain		Clearance, perpendicular	99	Yes					n/a	$ -	
F03986	Justice Center		4th Floor	Owned	Hallway	Between rooms #410 & #411	1-Public Unsupervised	Drinking Fountain		Control force	5	Yes					n/a	$ -	
F03987	Justice Center		4th Floor	Owned	Hallway	Between rooms #410 & #411	1-Public Unsupervised	Drinking Fountain		Dimension, knee clearance	28	Yes					n/a	$ -	
F03988	Justice Center		4th Floor	Owned	Hallway	Between rooms #410 & #411	1-Public Unsupervised	Drinking Fountain		Height	35.5	Yes					n/a	$ -	
F03989	Justice Center		4th Floor	Owned	Hallway	Between rooms #410 & #411	1-Public Unsupervised	Drinking Fountain		Height, water flow	39.5	Yes					n/a	$ -	
F03990	Justice Center		4th Floor	Owned	Hallway	Between rooms #410 & #411	1-Public Unsupervised	Drinking Fountain		Spout location	4	Yes					n/a	$ -	
F03994	Justice Center		4th Floor	Owned	Hallway	Between rooms #454 & #455	1-Public Unsupervised	Drinking Fountain		Clearance, parallel	99	Yes					n/a	$ -	
F03995	Justice Center		4th Floor	Owned	Hallway	Between rooms #454 & #455	1-Public Unsupervised	Drinking Fountain		Clearance, perpendicular	99	Yes					n/a	$ -	
F03996	Justice Center		4th Floor	Owned	Hallway	Between rooms #454 & #455	1-Public Unsupervised	Drinking Fountain		Dimension, knee clearance	27.75	Yes					n/a	$ -	
F03997	Justice Center		4th Floor	Owned	Hallway	Between rooms #454 & #455	1-Public Unsupervised	Drinking Fountain		Height	35	Yes					n/a	$ -	
F03998	Justice Center		4th Floor	Owned	Hallway	Between rooms #454 & #455	1-Public Unsupervised	Drinking Fountain		Height, water flow	37	Yes					n/a	$ -	
F03999	Justice Center		4th Floor	Owned	Hallway	Between rooms #454 & #455	1-Public Unsupervised	Drinking Fountain		Spout location	4	Yes					n/a	$ -	
F04001	Justice Center		5th Floor	Owned	Hallway	Between rooms #504 & #505	1-Public Unsupervised	Drinking Fountain		Clearance, parallel	99	Yes					n/a	$ -	
F04002	Justice Center		5th Floor	Owned	Hallway	Between rooms #504 & #505	1-Public Unsupervised	Drinking Fountain		Clearance, perpendicular	99	Yes					n/a	$ -	
F04003	Justice Center		5th Floor	Owned	Hallway	Between rooms #504 & #505	1-Public Unsupervised	Drinking Fountain		Control force	5	Yes					n/a	$ -	
F04004	Justice Center		5th Floor	Owned	Hallway	Between rooms #504 & #505	1-Public Unsupervised	Drinking Fountain		Dimension, knee clearance	28	Yes					n/a	$ -	
F04005	Justice Center		5th Floor	Owned	Hallway	Between rooms #504 & #505	1-Public Unsupervised	Drinking Fountain		Height	35	Yes					n/a	$ -	
F04006	Justice Center		5th Floor	Owned	Hallway	Between rooms #504 & #505	1-Public Unsupervised	Drinking Fountain		Height, water flow	39	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F04007	Justice Center		5th Floor	Owned	Hallway	Between rooms #504 & #505	1-Public Unsupervised	Drinking Fountain		Spout location	4	Yes					n/a	$ -	
F04011	Justice Center		6th Floor	Owned	Hallway	Between rooms #616 & #617	1-Public Unsupervised	Drinking Fountain		Control force	2	Yes					n/a	$ -	
F04012	Justice Center		6th Floor	Owned	Hallway	Between rooms #616 & #617	1-Public Unsupervised	Drinking Fountain		Dimension, knee clearance	27.5	Yes					n/a	$ -	
F04013	Justice Center		6th Floor	Owned	Hallway	Between rooms #616 & #617	1-Public Unsupervised	Drinking Fountain		Height	35.5	Yes					n/a	$ -	
F04014	Justice Center		6th Floor	Owned	Hallway	Between rooms #616 & #617	1-Public Unsupervised	Drinking Fountain		Height	41.5	Yes					n/a	$ -	
F04015	Justice Center		6th Floor	Owned	Hallway	Between rooms #616 & #617	1-Public Unsupervised	Drinking Fountain		Spout location	4.25	Yes					n/a	$ -	
F04018	Justice Center		6th Floor	Owned	Hallway	Between rooms #654 & #655	1-Public Unsupervised	Drinking Fountain		Control force	5	Yes					n/a	$ -	
F04019	Justice Center		6th Floor	Owned	Hallway	Between rooms #654 & #655	1-Public Unsupervised	Drinking Fountain		Dimension, knee clearance	28	Yes					n/a	$ -	
F04020	Justice Center		6th Floor	Owned	Hallway	Between rooms #654 & #655	1-Public Unsupervised	Drinking Fountain		Height	36	Yes					n/a	$ -	
F04021	Justice Center		6th Floor	Owned	Hallway	Between rooms #654 & #655	1-Public Unsupervised	Drinking Fountain		Height	41	Yes					n/a	$ -	
F04022	Justice Center		6th Floor	Owned	Hallway	Between rooms #654 & #655	1-Public Unsupervised	Drinking Fountain		Spout location	4	Yes					n/a	$ -	
F04024	Justice Center		4th Floor	Owned	Hallway	Between rooms #S403 & #S404	1-Public Unsupervised	Drinking Fountain		Clearance, parallel	99	Yes					n/a	$ -	
F04025	Justice Center		4th Floor	Owned	Hallway	Between rooms #S403 & #S404	1-Public Unsupervised	Drinking Fountain		Clearance, perpendicular	99	Yes					n/a	$ -	
F04026	Justice Center		4th Floor	Owned	Hallway	Between rooms #S403 & #S404	1-Public Unsupervised	Drinking Fountain		Control force	3	Yes					n/a	$ -	
F04027	Justice Center		4th Floor	Owned	Hallway	Between rooms #S403 & #S404	1-Public Unsupervised	Drinking Fountain		Dimension, knee clearance	27	Yes					n/a	$ -	
F04028	Justice Center		4th Floor	Owned	Hallway	Between rooms #S403 & #S404	1-Public Unsupervised	Drinking Fountain		Height	35	Yes					n/a	$ -	
F04029	Justice Center		4th Floor	Owned	Hallway	Between rooms #S403 & #S404	1-Public Unsupervised	Drinking Fountain		Height, water flow	39	Yes					n/a	$ -	
F04030	Justice Center		4th Floor	Owned	Hallway	Between rooms #S403 & #S404	1-Public Unsupervised	Drinking Fountain		Spout location	2	Yes					n/a	$ -	
F04038	Justice Center		5th Floor	Owned	Hallway	Employee entrance	3-Employee Common	Door Gate		Clear opening	32	Yes					n/a	$ -	
F04039	Justice Center		5th Floor	Owned	Hallway	Employee entrance	3-Employee Common	Door Gate		Clearance, pull parallel	21	Yes					n/a	$ -	
F04040	Justice Center		5th Floor	Owned	Hallway	Employee entrance	3-Employee Common	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F04041	Justice Center		5th Floor	Owned	Hallway	Employee entrance	3-Employee Common	Door Gate		Clearance, push parallel	21	Yes					n/a	$ -	
F04042	Justice Center		5th Floor	Owned	Hallway	Employee entrance	3-Employee Common	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F04043	Justice Center		5th Floor	Owned	Hallway	Employee entrance	3-Employee Common	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F04044	Justice Center		5th Floor	Owned	Hallway	Employee entrance	3-Employee Common	Door Gate		Hardware type	Lever - Panic	Yes					n/a	$ -	
F04045	Justice Center		5th Floor	Owned	Hallway	Employee entrance	3-Employee Common	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F04050	Justice Center		Interior	Owned	Hallway		3-Employee Common	Drinking Fountain	Between rooms #111 & #112	Clearance, parallel	OK	Yes					n/a	$ -	
F04051	Justice Center		5th Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain		Clearance, parallel	99	Yes					n/a	$ -	
F04052	Justice Center		Interior	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Between rooms #224 & #225	Clearance, parallel	99	Yes					n/a	$ -	
F04053	Justice Center		Interior	Owned	Hallway		3-Employee Common	Drinking Fountain	Between rooms #111 & #112	Clearance, perpendicular	OK	Yes					n/a	$ -	
F04054	Justice Center		5th Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain		Clearance, perpendicular	99	Yes					n/a	$ -	
F04055	Justice Center		Interior	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Between rooms #224 & #225	Clearance, perpendicular	98	Yes					n/a	$ -	
F04056	Justice Center		5th Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain		Control force	3	Yes					n/a	$ -	
F04057	Justice Center		Interior	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Between rooms #224 & #225	Control force	3	Yes					n/a	$ -	
F04058	Justice Center		5th Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain		Dimension, knee clearance	27	Yes					n/a	$ -	
F04059	Justice Center		Interior	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Between rooms #224 & #225	Dimension, knee clearance	28	Yes					n/a	$ -	
F04060	Justice Center		5th Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain		Flow direction	OK	Yes					n/a	$ -	
F04061	Justice Center		Interior	Owned	Hallway		3-Employee Common	Drinking Fountain	Between rooms #111 & #112	Height	34	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F04062	Justice Center		5th Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain		Height	35	Yes					n/a	$ -	
F04063	Justice Center		Interior	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Between rooms #224 & #225	Height	36	Yes					n/a	$ -	
F04064	Justice Center		Interior	Owned	Hallway		3-Employee Common	Protrusion	Drinking Fountain near restroom	Height	26.75	Yes					n/a	$ -	
F04065	Justice Center		Interior	Owned	Hallway		3-Employee Common	Drinking Fountain	Between rooms #111 & #112	Height, water flow	36.5	Yes					n/a	$ -	
F04066	Justice Center		5th Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain		Height, water flow	37.5	Yes					n/a	$ -	
F04067	Justice Center		Interior	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Between rooms #224 & #225	Height, water flow	38	Yes					n/a	$ -	
F04068	Justice Center		Interior	Owned	Hallway		3-Employee Common	Drinking Fountain	Between rooms #111 & #112	Spout location	2.75	Yes					n/a	$ -	
F04069	Justice Center		5th Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain		Spout location	3	Yes					n/a	$ -	
F04070	Justice Center		Interior	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Between rooms #224 & #225	Spout location	4	Yes					n/a	$ -	
F04071	Justice Center		5th Floor	Owned	Hallway	Employee entrance	3-Employee Common	Door Gate		Height, threshold	0	Yes					n/a	$ -	
F04125	Justice Center		Interior	Owned	Holding Cell	Adult Female #4	2-Public Supervised	Bench		Back support?	Y	Yes					n/a	$ -	
F04126	Justice Center		Interior	Owned	Holding Cell	Adult Female #4	2-Public Supervised	Bench		Clearance, parallel	60	Yes					n/a	$ -	
F04127	Justice Center		Interior	Owned	Holding Cell	Adult Female #4	2-Public Supervised	Bench		Clearance, perpendicular	99	Yes					n/a	$ -	
F04128	Justice Center		Interior	Owned	Holding Cell	Adult Female #4	2-Public Supervised	Water Closet	Combination lav/toilet	Clearance, perpendicular	99	Yes					n/a	$ -	
F04129	Justice Center		Interior	Owned	Holding Cell	Adult Female #4	2-Public Supervised	Bench		Depth	20	Yes					n/a	$ -	
F04130	Justice Center		Interior	Owned	Holding Cell	Adult Female #4	2-Public Supervised	Lavatory Sink	Combination lav/toilet	Drain wrapped?	Y	Yes					n/a	$ -	
F04131	Justice Center		Interior	Owned	Holding Cell	Adult Female #4	2-Public Supervised	Lavatory Sink	Combination lav/toilet	Hardware type	Push button	Yes					n/a	$ -	
F04132	Justice Center		Interior	Owned	Holding Cell	Adult Female #4	2-Public Supervised	Bench		Height	18.5	Yes					n/a	$ -	
F04133	Justice Center		Interior	Owned	Holding Cell	Adult Female #4	2-Public Supervised	Lavatory Sink	Combination lav/toilet	Height	32.5	Yes					n/a	$ -	
F04134	Justice Center		Interior	Owned	Holding Cell	Adult Female #4	2-Public Supervised	Water Closet	Combination lav/toilet	Height, flush control	35	Yes					n/a	$ -	
F04135	Justice Center		Interior	Owned	Holding Cell	Adult Female #4	2-Public Supervised	Bench		Length	99	Yes					n/a	$ -	
F04136	Justice Center		Interior	Owned	Holding Cell	Adult Female #4	2-Public Supervised	Water Closet	Combination lav/toilet	Location, flush control	W	Yes					n/a	$ -	
F04141	Justice Center		Interior	Owned	Holding Cell	Adult Male #1	2-Public Supervised	Bench		Back support?	Y	Yes					n/a	$ -	
F04142	Justice Center		Interior	Owned	Holding Cell	Adult Male #1	2-Public Supervised	Bench		Clearance, parallel	80	Yes					n/a	$ -	
F04143	Justice Center		Interior	Owned	Holding Cell	Adult Male #1	2-Public Supervised	Lavatory Sink		Clearance, parallel	35	Yes					n/a	$ -	
F04144	Justice Center		Interior	Owned	Holding Cell	Adult Male #1	2-Public Supervised	Bench		Clearance, perpendicular	93.5	Yes					n/a	$ -	
F04145	Justice Center		Interior	Owned	Holding Cell	Adult Male #1	2-Public Supervised	Lavatory Sink		Clearance, perpendicular	85	Yes					n/a	$ -	
F04146	Justice Center		Interior	Owned	Holding Cell	Adult Male #1	2-Public Supervised	Water Closet		Clearance, perpendicular	85	Yes					n/a	$ -	
F04147	Justice Center		Interior	Owned	Holding Cell	Adult Male #1	2-Public Supervised	Bench		Depth	20	Yes					n/a	$ -	
F04148	Justice Center		Interior	Owned	Holding Cell	Adult Male #1	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	28	Yes					n/a	$ -	
F04149	Justice Center		Interior	Owned	Holding Cell	Adult Male #1	2-Public Supervised	Water Closet		Dimension, sidewall	17.75	Yes					n/a	$ -	
F04150	Justice Center		Interior	Owned	Holding Cell	Adult Male #1	2-Public Supervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F04151	Justice Center		Interior	Owned	Holding Cell	Adult Male #1	2-Public Supervised	Lavatory Sink		Hardware type	Push button	Yes					n/a	$ -	
F04152	Justice Center		Interior	Owned	Holding Cell	Adult Male #1	2-Public Supervised	Bench		Height	18.25	Yes					n/a	$ -	
F04153	Justice Center		Interior	Owned	Holding Cell	Adult Male #1	2-Public Supervised	Lavatory Sink		Height	33	Yes					n/a	$ -	
F04154	Justice Center		Interior	Owned	Holding Cell	Adult Male #1	2-Public Supervised	Water Closet		Height, flush control	43	Yes					n/a	$ -	
F04155	Justice Center		Interior	Owned	Holding Cell	Adult Male #1	2-Public Supervised	Water Closet		Height, seat	17.5	Yes					n/a	$ -	
F04156	Justice Center		Interior	Owned	Holding Cell	Adult Male #1	2-Public Supervised	Bench		Length	93.5	Yes					n/a	$ -	
F04168	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Bench		Back support?	Y	Yes					n/a	$ -	
F04169	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Bench		Back support?	Y	Yes					n/a	$ -	
F04170	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Bench		Clearance, parallel	92	Yes					n/a	$ -	
F04171	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Bench		Clearance, parallel	96	Yes					n/a	$ -	
F04172	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Lavatory Sink		Clearance, parallel	34	Yes					n/a	$ -	
F04173	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Lavatory Sink		Clearance, parallel	35	Yes					n/a	$ -	
F04174	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Water Closet		Clearance, parallel	61	Yes					n/a	$ -	
F04175	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Bench		Clearance, perpendicular	95	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F04176	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Bench		Clearance, perpendicular	92	Yes					n/a	$ -	
F04177	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Lavatory Sink		Clearance, perpendicular	95	Yes					n/a	$ -	
F04178	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Lavatory Sink		Clearance, perpendicular	95	Yes					n/a	$ -	
F04179	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Water Closet		Clearance, perpendicular	95	Yes					n/a	$ -	
F04180	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Water Closet		Clearance, perpendicular	95	Yes					n/a	$ -	
F04181	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Bench		Depth	20	Yes					n/a	$ -	
F04182	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Bench		Depth	20	Yes					n/a	$ -	
F04183	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	28.5	Yes					n/a	$ -	
F04184	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	27.5	Yes					n/a	$ -	
F04185	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F04186	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F04187	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Lavatory Sink		Hardware type	PP	Yes					n/a	$ -	
F04188	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Lavatory Sink		Hardware type	PP	Yes					n/a	$ -	
F04189	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Bench		Height	18	Yes					n/a	$ -	
F04190	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Bench		Height	18	Yes					n/a	$ -	
F04191	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Lavatory Sink		Height	33.5	Yes					n/a	$ -	
F04192	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Lavatory Sink		Height	32.5	Yes					n/a	$ -	
F04193	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Water Closet		Height, flush control	42	Yes					n/a	$ -	
F04194	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Water Closet		Height, flush control	43	Yes					n/a	$ -	
F04195	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Water Closet		Height, seat	17.5	Yes					n/a	$ -	
F04196	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F04197	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Bench		Length	95	Yes					n/a	$ -	
F04198	Justice Center		Interior	Owned	Holding Cell	Unisex - Juvenile Holding cell #2	2-Public Supervised	Bench		Length	96	Yes					n/a	$ -	
F04264	Justice Center	Self Help Resource Center	1st Floor	Owned	Kitchen	#159 - Training Room	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F04265	Justice Center	Self Help Resource Center	1st Floor	Owned	Kitchen	#159 - Training Room	1-Public Unsupervised	Counter		Clearance, parallel	95	Yes					n/a	$ -	
F04266	Justice Center	Self Help Resource Center	1st Floor	Owned	Kitchen	#159 - Training Room	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	95	Yes					n/a	$ -	
F04267	Justice Center	Self Help Resource Center	1st Floor	Owned	Kitchen	#159 - Training Room	1-Public Unsupervised	Counter		Clearance, perpendicular	72	Yes					n/a	$ -	
F04268	Justice Center	Self Help Resource Center	1st Floor	Owned	Kitchen	#159 - Training Room	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	72	Yes					n/a	$ -	
F04269	Justice Center	Self Help Resource Center	1st Floor	Owned	Kitchen	#159 - Training Room	1-Public Unsupervised	Door Gate		Clearance, pull parallel	56	Yes					n/a	$ -	
F04270	Justice Center	Self Help Resource Center	1st Floor	Owned	Kitchen	#159 - Training Room	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	72	Yes					n/a	$ -	
F04271	Justice Center	Self Help Resource Center	1st Floor	Owned	Kitchen	#159 - Training Room	1-Public Unsupervised	Door Gate		Clearance, push parallel	56	Yes					n/a	$ -	
F04272	Justice Center	Self Help Resource Center	1st Floor	Owned	Kitchen	#159 - Training Room	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	72	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F04273	Justice Center	Self Help Resource Center	1st Floor	Owned	Kitchen	#159 - Training Room	1-Public Unsupervised	Door Gate		Clearance, vertical	83.5	Yes					n/a	$ -	
F04274	Justice Center	Self Help Resource Center	1st Floor	Owned	Kitchen	#159 - Training Room	1-Public Unsupervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F04275	Justice Center	Self Help Resource Center	1st Floor	Owned	Kitchen	#159 - Training Room	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F04276	Justice Center	Self Help Resource Center	1st Floor	Owned	Kitchen	#159 - Training Room	1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F04277	Justice Center	Self Help Resource Center	1st Floor	Owned	Kitchen	#159 - Training Room	1-Public Unsupervised	Counter		Length	94.5	Yes					n/a	$ -	
F04278	Justice Center	Self Help Resource Center	1st Floor	Owned	Kitchen	Training Room	1-Public Unsupervised	Operable Part	Soap dispenser	Height	45	Yes					n/a	$ -	
F04408	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception	Training Room	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F04409	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception	Training Room	1-Public Unsupervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F04410	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception	Training Room	1-Public Unsupervised	Counter		Clearance, perpendicular	76	Yes					n/a	$ -	
F04411	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception	Training Room	1-Public Unsupervised	Door Gate		Clearance, pull parallel	64	Yes					n/a	$ -	
F04412	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception	Training Room	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F04413	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception	Training Room	1-Public Unsupervised	Door Gate		Clearance, push parallel	63	Yes					n/a	$ -	
F04414	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception	Training Room	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F04415	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception	Training Room	1-Public Unsupervised	Door Gate		Clearance, vertical	93	Yes					n/a	$ -	
F04416	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception	Training Room	1-Public Unsupervised	Door Gate		Closing speed	6	Yes					n/a	$ -	
F04417	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception	Training Room	1-Public Unsupervised	Counter		Dimension, knee clearance	31.75	Yes					n/a	$ -	
F04418	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception	Training Room	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F04419	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception	Training Room	1-Public Unsupervised	Counter		Height	34	Yes					n/a	$ -	
F04420	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception	Training Room	1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F04421	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception	Training Room	1-Public Unsupervised	Counter		Length	56.5	Yes					n/a	$ -	
F04424	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F04425	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F04426	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Dimension, knee clearance	40	Yes					n/a	$ -	
F04427	Justice Center	Self Help Resource Center	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Length	99	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F04430	Justice Center		Interior	Owned	Lobby Reception	#605 - Juvenile Clerks Office	1-Public Unsupervised	Counter		Length	65.5	Yes					n/a	$ -	
F04431	Justice Center		6th Floor	Owned	Lobby Reception	#S637	1-Public Unsupervised	Counter		Height	34	Yes					n/a	$ -	
F04433	Justice Center		Interior	Owned	Lobby Reception	Court Clerk	2-Public Supervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F04434	Justice Center		Interior	Owned	Lobby Reception	Court Clerk	2-Public Supervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F04435	Justice Center		Interior	Owned	Lobby Reception	Court Clerk	2-Public Supervised	Counter		Dimension, knee clearance	31.25	Yes					n/a	$ -	
F04436	Justice Center		Interior	Owned	Lobby Reception	Court Clerk	2-Public Supervised	Counter		Height	33.25	Yes					n/a	$ -	
F04437	Justice Center		Interior	Owned	Lobby Reception	Court Clerk	2-Public Supervised	Counter		Length	69.5	Yes					n/a	$ -	
F04439	Justice Center		Interior	Owned	Lobby Reception	Court Clerk 6	2-Public Supervised	Counter		Clearance, parallel	76	Yes					n/a	$ -	
F04440	Justice Center		Interior	Owned	Lobby Reception	Court Clerk 6	2-Public Supervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F04441	Justice Center		Interior	Owned	Lobby Reception	Court Clerk 6	2-Public Supervised	Counter		Dimension, knee clearance	32	Yes					n/a	$ -	
F04442	Justice Center		Interior	Owned	Lobby Reception	Court Clerk 6	2-Public Supervised	Counter		Height	34	Yes					n/a	$ -	
F04443	Justice Center		Interior	Owned	Lobby Reception	Court Clerk 6	2-Public Supervised	Counter		Length	76	Yes					n/a	$ -	
F04445	Justice Center		5th Floor	Owned	Lobby Reception	Family Court Facilitator	1-Public Unsupervised	Counter	Check-in	Clearance, parallel	99	Yes					n/a	$ -	
F04446	Justice Center		5th Floor	Owned	Lobby Reception	Family Court Facilitator	1-Public Unsupervised	Counter	Check-in	Clearance, perpendicular	99	Yes					n/a	$ -	
F04447	Justice Center		5th Floor	Owned	Lobby Reception	Family Court Facilitator	1-Public Unsupervised	Counter	Check-in	Dimension, knee clearance	31.5	Yes					n/a	$ -	
F04448	Justice Center		5th Floor	Owned	Lobby Reception	Family Court Facilitator	1-Public Unsupervised	Counter	Check-in	Height	33.5	Yes					n/a	$ -	
F04449	Justice Center		5th Floor	Owned	Lobby Reception	Family Court Facilitator	1-Public Unsupervised	Counter	Check-in	Length	49.75	Yes					n/a	$ -	
F04456	Justice Center		Interior	Owned	Lobby Reception	Interior Series Door	1-Public Unsupervised	Door Gate		Clear opening	32.5	Yes					n/a	$ -	
F04457	Justice Center		Interior	Owned	Lobby Reception	Interior Series Door	1-Public Unsupervised	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F04458	Justice Center		Interior	Owned	Lobby Reception	Interior Series Door	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F04459	Justice Center		Interior	Owned	Lobby Reception	Interior Series Door	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	OK	Yes					n/a	$ -	
F04460	Justice Center		Interior	Owned	Lobby Reception	Interior Series Door	1-Public Unsupervised	Door Gate		Clearance, series doors	80	Yes					n/a	$ -	
F04461	Justice Center		Interior	Owned	Lobby Reception	Interior Series Door	1-Public Unsupervised	Door Gate		Clearance, vertical	99	Yes					n/a	$ -	
F04462	Justice Center		Interior	Owned	Lobby Reception	Interior Series Door	1-Public Unsupervised	Door Gate		Closing speed	12	Yes					n/a	$ -	
F04463	Justice Center		Interior	Owned	Lobby Reception	Interior Series Door	1-Public Unsupervised	Door Gate		Hardware type	Auto	Yes					n/a	$ -	
F04464	Justice Center		Interior	Owned	Lobby Reception	Interior Series Door	1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	11	Yes					n/a	$ -	
F04465	Justice Center		Interior	Owned	Lobby Reception	Interior Series Door	1-Public Unsupervised	Door Gate		Opening force	Auto	Yes					n/a	$ -	
F04467	Justice Center		Interior	Owned	Lobby Reception	Jury check-in	1-Public Unsupervised	Counter		Clearance, parallel	48	Yes					n/a	$ -	
F04468	Justice Center		Interior	Owned	Lobby Reception	Jury check-in	1-Public Unsupervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F04469	Justice Center		Interior	Owned	Lobby Reception	Jury check-in	1-Public Unsupervised	Counter		Dimension, knee clearance	32.5	Yes					n/a	$ -	
F04470	Justice Center		Interior	Owned	Lobby Reception	Jury check-in	1-Public Unsupervised	Counter		Height	34	Yes					n/a	$ -	
F04471	Justice Center		Interior	Owned	Lobby Reception	Jury check-in	1-Public Unsupervised	Counter		Length	46	Yes					n/a	$ -	
F04473	Justice Center		Interior	Owned	Lobby Reception	Self Pay Center	1-Public Unsupervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F04474	Justice Center		Interior	Owned	Lobby Reception	Self Pay Center	1-Public Unsupervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F04475	Justice Center		Interior	Owned	Lobby Reception	Self Pay Center	1-Public Unsupervised	Counter		Dimension, knee clearance	32	Yes					n/a	$ -	
F04476	Justice Center		Interior	Owned	Lobby Reception	Self Pay Center	1-Public Unsupervised	Counter		Height	34.5	Yes					n/a	$ -	
F04477	Justice Center		Interior	Owned	Lobby Reception	Self Pay Center	1-Public Unsupervised	Counter		Length	54	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F04478	Justice Center		Interior	Owned	Lobby Reception		1-Public Unsupervised	Vending Machine	ATM	Clearance, parallel	72	Yes					n/a	$ -	
F04479	Justice Center		Interior	Owned	Lobby Reception		1-Public Unsupervised	Vending Machine	ATM	Clearance, perpendicular	99	Yes					n/a	$ -	
F04480	Justice Center		Interior	Owned	Lobby Reception		1-Public Unsupervised	Vending Machine	ATM	Height, control	45	Yes					n/a	$ -	
F04481	Justice Center		Interior	Owned	Lobby Reception	Interior Series Door	1-Public Unsupervised	Door Gate		Threshold beveled?	Y	Yes					n/a	$ -	
F04716	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F04717	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Bench		Clearance, parallel	36	Yes					n/a	$ -	
F04718	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Coat Hook		Clearance, parallel	99	Yes					n/a	$ -	
F04719	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Bench		Clearance, perpendicular	99	Yes					n/a	$ -	
F04720	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Coat Hook		Clearance, perpendicular	99	Yes					n/a	$ -	
F04721	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Door Gate		Clearance, pull parallel	60	Yes					n/a	$ -	
F04722	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Door Gate		Clearance, pull perpendicular	60	Yes					n/a	$ -	
F04723	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F04724	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Door Gate		Clearance, push perpendicular	54.5	Yes					n/a	$ -	
F04725	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Door Gate		Clearance, vertical	82	Yes					n/a	$ -	
F04726	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F04727	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Bench		Height	18	Yes					n/a	$ -	
F04728	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Signage		Height, bottom	58	Yes					n/a	$ -	
F04729	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F04730	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Bench		Length	99	Yes					n/a	$ -	
F04731	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Signage		Location	L	Yes					n/a	$ -	
F04732	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F04733	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F04752	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F04753	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F04754	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Bench		Clearance, parallel	32	Yes					n/a	$ -	
F04755	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Bench		Clearance, perpendicular	99	Yes					n/a	$ -	
F04756	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Clearance, pull parallel	60	Yes					n/a	$ -	
F04757	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Clearance, pull parallel	80	Yes					n/a	$ -	
F04758	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Clearance, pull perpendicular	60	Yes					n/a	$ -	
F04759	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Clearance, pull perpendicular	70	Yes					n/a	$ -	
F04760	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Clearance, push parallel	72	Yes					n/a	$ -	
F04761	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F04762	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Clearance, push perpendicular	68	Yes					n/a	$ -	
F04763	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F04764	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Clearance, vertical	82	Yes					n/a	$ -	
F04765	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Clearance, vertical	82	Yes					n/a	$ -	
F04766	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Closing speed	5	Yes					n/a	$ -	
F04767	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Signage		Dimension, characters	4.75	Yes					n/a	$ -	
F04768	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F04769	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F04770	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Bench		Height	17.75	Yes					n/a	$ -	
F04771	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Signage		Height, bottom	58	Yes					n/a	$ -	
F04772	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Signage		Height, bottom	55.75	Yes					n/a	$ -	
F04773	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F04774	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F04775	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Signage		ISA?	Y	Yes					n/a	$ -	
F04776	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Bench		Length	96	Yes					n/a	$ -	
F04777	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Signage		Location	L	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F04778	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Signage		Location	L	Yes					n/a	$ -	
F04779	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F04780	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F04781	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F04782	Justice Center		Interior	Owned	Locker Room	Women's - #S010	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F04783	Justice Center		Interior	Owned	Locker Room	Men's - #S008	3-Employee Common	Door Gate		Height, threshold	OK	Yes					n/a	$ -	
F05094	Justice Center		5th Floor	Owned	Other Room	Domestic check-in	1-Public Unsupervised	Door Gate		Height, threshold	0	Yes					n/a	$ -	
F05102	Justice Center		5th Floor	Owned	Other Room	#501 - Room 516	2-Public Supervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F05103	Justice Center		5th Floor	Owned	Other Room	#501 - Room 516	2-Public Supervised	Door Gate		Clearance, pull parallel	49	Yes					n/a	$ -	
F05104	Justice Center		5th Floor	Owned	Other Room	#501 - Room 516	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F05105	Justice Center		5th Floor	Owned	Other Room	#501 - Room 516	2-Public Supervised	Door Gate		Clearance, push parallel	50	Yes					n/a	$ -	
F05106	Justice Center		5th Floor	Owned	Other Room	#501 - Room 516	2-Public Supervised	Door Gate		Clearance, push perpendicular	82	Yes					n/a	$ -	
F05107	Justice Center		5th Floor	Owned	Other Room	#501 - Room 516	2-Public Supervised	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F05108	Justice Center		5th Floor	Owned	Other Room	#501 - Room 516	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F05109	Justice Center		5th Floor	Owned	Other Room	#501 - Room 516	2-Public Supervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F05110	Justice Center		5th Floor	Owned	Other Room	#501 - Room 516	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F05111	Justice Center		5th Floor	Owned	Other Room	#501 - Room 516	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F05112	Justice Center		5th Floor	Owned	Other Room	#501 - Room 516	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	
F05113	Justice Center		5th Floor	Owned	Other Room	#501 - Room 516	2-Public Supervised	Door Gate		Opening force	1	Yes					n/a	$ -	
F05114	Justice Center		5th Floor	Owned	Other Room	#501 - Room 516	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F05122	Justice Center		5th Floor	Owned	Other Room	#501 - Room 517	2-Public Supervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F05123	Justice Center		5th Floor	Owned	Other Room	#501 - Room 517	2-Public Supervised	Door Gate		Clearance, pull parallel	49	Yes					n/a	$ -	
F05124	Justice Center		5th Floor	Owned	Other Room	#501 - Room 517	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F05125	Justice Center		5th Floor	Owned	Other Room	#501 - Room 517	2-Public Supervised	Door Gate		Clearance, push parallel	49	Yes					n/a	$ -	
F05126	Justice Center		5th Floor	Owned	Other Room	#501 - Room 517	2-Public Supervised	Door Gate		Clearance, push perpendicular	82	Yes					n/a	$ -	
F05127	Justice Center		5th Floor	Owned	Other Room	#501 - Room 517	2-Public Supervised	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F05128	Justice Center		5th Floor	Owned	Other Room	#501 - Room 517	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F05129	Justice Center		5th Floor	Owned	Other Room	#501 - Room 517	2-Public Supervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F05130	Justice Center		5th Floor	Owned	Other Room	#501 - Room 517	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F05131	Justice Center		5th Floor	Owned	Other Room	#501 - Room 517	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F05132	Justice Center		5th Floor	Owned	Other Room	#501 - Room 517	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	
F05133	Justice Center		5th Floor	Owned	Other Room	#501 - Room 517	2-Public Supervised	Door Gate		Opening force	1	Yes					n/a	$ -	
F05134	Justice Center		5th Floor	Owned	Other Room	#501 - Room 517	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F05136	Justice Center		6th Floor	Owned	Other Room	#S611	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F05137	Justice Center		6th Floor	Owned	Other Room	#S611	1-Public Unsupervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F05147	Justice Center		5th Floor	Owned	Other Room	Domestic check-in	1-Public Unsupervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F05148	Justice Center		5th Floor	Owned	Other Room	Domestic check-in	1-Public Unsupervised	Counter		Clearance, parallel	58	Yes					n/a	$ -	
F05149	Justice Center		5th Floor	Owned	Other Room	Domestic check-in	1-Public Unsupervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F05150	Justice Center		5th Floor	Owned	Other Room	Domestic check-in	1-Public Unsupervised	Door Gate		Clearance, pull parallel	31	Yes					n/a	$ -	
F05151	Justice Center		5th Floor	Owned	Other Room	Domestic check-in	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F05152	Justice Center		5th Floor	Owned	Other Room	Domestic check-in	1-Public Unsupervised	Door Gate		Clearance, push parallel	18	Yes					n/a	$ -	
F05153	Justice Center		5th Floor	Owned	Other Room	Domestic check-in	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F05154	Justice Center		5th Floor	Owned	Other Room	Domestic check-in	1-Public Unsupervised	Door Gate		Clearance, vertical	93	Yes					n/a	$ -	
F05155	Justice Center		5th Floor	Owned	Other Room	Domestic check-in	1-Public Unsupervised	Counter		Dimension, knee clearance	40	Yes					n/a	$ -	
F05156	Justice Center		5th Floor	Owned	Other Room	Domestic check-in	1-Public Unsupervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F05157	Justice Center		5th Floor	Owned	Other Room	Domestic check-in	1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F05158	Justice Center		5th Floor	Owned	Other Room	Domestic check-in	1-Public Unsupervised	Counter		Length	58	Yes					n/a	$ -	
F05164	Justice Center		Interior	Owned	Other Room	Unisex - Holding cells	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F05165	Justice Center		Interior	Owned	Other Room	Unisex - Holding cells	2-Public Supervised	Door Gate		Clearance, pull parallel	60	Yes					n/a	$ -	
F05166	Justice Center		Interior	Owned	Other Room	Unisex - Holding cells	2-Public Supervised	Door Gate		Clearance, pull perpendicular	60	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05167	Justice Center		Interior	Owned	Other Room	Unisex - Holding cells	2-Public Supervised	Door Gate		Clearance, push parallel	60	Yes					n/a	$ -	
F05168	Justice Center		Interior	Owned	Other Room	Unisex - Holding cells	2-Public Supervised	Door Gate		Clearance, push perpendicular	60	Yes					n/a	$ -	
F05169	Justice Center		Interior	Owned	Other Room	Unisex - Holding cells	2-Public Supervised	Door Gate		Clearance, vertical	85	Yes					n/a	$ -	
F05170	Justice Center		Interior	Owned	Other Room	Unisex - Holding cells	2-Public Supervised	Door Gate		Hardware type	Keyed	Yes					n/a	$ -	
F05171	Justice Center		Interior	Owned	Other Room	Unisex - Holding cells	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F05172	Justice Center		Interior	Owned	Other Room	Unisex - Holding cells	2-Public Supervised	Door Gate		Opening force	3	Yes					n/a	$ -	
F06638	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	Row 1 space #1	Access aisle?	Y	Yes					n/a	$ -	
F06639	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	Row 1 space #2	Access aisle?	Y	Yes					n/a	$ -	
F06640	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 1	Access aisle?	Y	Yes					n/a	$ -	
F06641	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 1	Access aisle?	Y	Yes					n/a	$ -	
F06642	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#1 - Row 2	Access aisle?	Y	Yes					n/a	$ -	
F06643	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#2 - Row 2	Access aisle?	Y	Yes					n/a	$ -	
F06644	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 2	Access aisle?	Y	Yes					n/a	$ -	
F06645	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 2	Access aisle?	Y	Yes					n/a	$ -	
F06646	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#5 - Row 2	Access aisle?	Y	Yes					n/a	$ -	
F06647	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	Row 1 space #1	Height, sign	82	Yes					n/a	$ -	
F06648	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	Row 1 space #2	Height, sign	85	Yes					n/a	$ -	
F06649	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 1	Height, sign	85	Yes					n/a	$ -	
F06650	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 1	Height, sign	84	Yes					n/a	$ -	
F06651	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#1 - Row 2	Height, sign	85	Yes					n/a	$ -	
F06652	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#2 - Row 2	Height, sign	85	Yes					n/a	$ -	
F06653	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 2	Height, sign	85	Yes					n/a	$ -	
F06654	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 2	Height, sign	85	Yes					n/a	$ -	
F06655	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#5 - Row 2	Height, sign	85	Yes					n/a	$ -	
F06656	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	Row 1 space #1	Sign?	Y	Yes					n/a	$ -	
F06657	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	Row 1 space #2	Sign?	Y	Yes					n/a	$ -	
F06658	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 1	Sign?	Y	Yes					n/a	$ -	
F06659	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 1	Sign?	Y	Yes					n/a	$ -	
F06660	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#1 - Row 2	Sign?	Y	Yes					n/a	$ -	
F06661	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#2 - Row 2	Sign?	Y	Yes					n/a	$ -	
F06662	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 2	Sign?	Y	Yes					n/a	$ -	
F06663	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 2	Sign?	Y	Yes					n/a	$ -	
F06664	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#5 - Row 2	Sign?	Y	Yes					n/a	$ -	
F06665	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#2	Slope, cross	0.1%	Yes					n/a	$ -	
F06666	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#2	Slope, cross	0.3%	Yes					n/a	$ -	
F06667	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#3	Slope, cross	0.5%	Yes					n/a	$ -	
F06668	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#4	Slope, cross	1.0%	Yes					n/a	$ -	
F06669	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Near curb ramp #11	Slope, cross	1.3%	Yes					n/a	$ -	
F06670	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Row 2	Slope, cross	1.3%	Yes					n/a	$ -	
F06671	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 2	Slope, cross	0.2%	Yes					n/a	$ -	
F06672	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#2 - Row 2	Slope, cross	0.8%	Yes					n/a	$ -	
F06673	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 2	Slope, cross	0.8%	Yes					n/a	$ -	
F06674	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#1 - Row 2	Slope, cross	1.0%	Yes					n/a	$ -	
F06675	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	Row 1 space #1	Slope, cross	1.3%	Yes					n/a	$ -	
F06676	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	Row 1 space #2	Slope, cross	1.3%	Yes					n/a	$ -	
F06677	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 1	Slope, cross	1.6%	Yes					n/a	$ -	
F06678	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 1	Slope, cross	2.0%	Yes					n/a	$ -	
F06679	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#5 - Row 2	Slope, cross	0.3%	Yes					n/a	$ -	
F06680	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#2	Slope, running	1.8%	Yes					n/a	$ -	
F06681	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#3	Slope, running	1.9%	Yes					n/a	$ -	
F06682	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 1	Slope, running	1.9%	Yes					n/a	$ -	
F06683	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Near curb ramp #11	Surface marking?	Y	Yes					n/a	$ -	
F06684	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#2	Surface marking?	Y	Yes					n/a	$ -	
F06685	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#3	Surface marking?	Y	Yes					n/a	$ -	
F06686	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Row 2	Surface marking?	Y	Yes					n/a	$ -	
F06687	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#2	Surface marking?	Y	Yes					n/a	$ -	
F06688	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#3	Surface marking?	Y	Yes					n/a	$ -	
F06689	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#4	Surface marking?	Y	Yes					n/a	$ -	
F06690	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Near curb ramp #11	Surface material	Asphalt	Yes					n/a	$ -	
F06691	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	Row 1 space #2	Surface material	Asphalt	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06692	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 1	Van sign?	N	Yes					n/a	$ -	
F06693	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 1	Van sign?	N	Yes					n/a	$ -	
F06694	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#1 - Row 2	Van sign?	Y	Yes					n/a	$ -	
F06695	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 2	Van sign?	N	Yes					n/a	$ -	
F06696	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#2 - Row 2	Van sign?	Y	Yes					n/a	$ -	
F06697	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#5 - Row 2	Van sign?	N	Yes					n/a	$ -	
F06698	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 2	Van sign?	Y	Yes					n/a	$ -	
F06699	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	Row 1 space #1	Van sign?	N	Yes					n/a	$ -	
F06700	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	Row 1 space #2	Van sign?	N	Yes					n/a	$ -	
F06701	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Near curb ramp #11	Width	84	Yes					n/a	$ -	
F06702	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Row 2	Width	108	Yes					n/a	$ -	
F06703	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#2	Width	60	Yes					n/a	$ -	
F06704	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#2	Width	61	Yes					n/a	$ -	
F06705	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#3	Width	67	Yes					n/a	$ -	
F06706	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#3	Width	122	Yes					n/a	$ -	
F06707	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Access Aisle	#4	Width	120	Yes					n/a	$ -	
F06708	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#1 - Row 2	Width	136	Yes					n/a	$ -	
F06709	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#2 - Row 2	Width	144	Yes					n/a	$ -	
F06710	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 2	Width	145	Yes					n/a	$ -	
F06711	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 1	Width	136	Yes					n/a	$ -	
F06712	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 1	Width	122	Yes					n/a	$ -	
F06713	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 2	Width	142	Yes					n/a	$ -	
F06714	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	#5 - Row 2	Width	108	Yes					n/a	$ -	
F06715	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	Row 1 space #1	Width	132	Yes					n/a	$ -	
F06716	Justice Center		Exterior	Owned	Parking Facility	North Parking Lot	1-Public Unsupervised	Parking Space	Row 1 space #2	Width	136	Yes					n/a	$ -	
F06759	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#1 - Row 1	Access aisle?	Y	Yes					n/a	$ -	
F06760	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#2 - Row 1	Access aisle?	Y	Yes					n/a	$ -	
F06761	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 1	Access aisle?	Y	Yes					n/a	$ -	
F06762	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 1	Access aisle?	Y	Yes					n/a	$ -	
F06763	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#5 - Row 1	Access aisle?	Y	Yes					n/a	$ -	
F06764	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#1 - Row 2	Access aisle?	Y	Yes					n/a	$ -	
F06765	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#2 - Row 2	Access aisle?	Y	Yes					n/a	$ -	
F06766	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 2	Access aisle?	Y	Yes					n/a	$ -	
F06767	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 2	Access aisle?	Y	Yes					n/a	$ -	
F06768	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#5 - Row 2	Access aisle?	Y	Yes					n/a	$ -	
F06769	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#6 - Row 2	Access aisle?	Y	Yes					n/a	$ -	
F06770	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#1 - Row 1	Height, sign	85	Yes					n/a	$ -	
F06771	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#2 - Row 1	Height, sign	84	Yes					n/a	$ -	
F06772	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 1	Height, sign	83	Yes					n/a	$ -	
F06773	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 1	Height, sign	83	Yes					n/a	$ -	
F06774	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#5 - Row 1	Height, sign	83	Yes					n/a	$ -	
F06775	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#1 - Row 2	Height, sign	82	Yes					n/a	$ -	
F06776	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#2 - Row 2	Height, sign	83	Yes					n/a	$ -	
F06777	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 2	Height, sign	81	Yes					n/a	$ -	
F06778	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 2	Height, sign	84	Yes					n/a	$ -	
F06779	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#5 - Row 2	Height, sign	85	Yes					n/a	$ -	
F06780	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#6 - Row 2	Height, sign	83	Yes					n/a	$ -	
F06781	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#1 - Row 1	Sign?	Y	Yes					n/a	$ -	
F06782	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#2 - Row 1	Sign?	Y	Yes					n/a	$ -	
F06783	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 1	Sign?	Y	Yes					n/a	$ -	
F06784	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 1	Sign?	Y	Yes					n/a	$ -	
F06785	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#5 - Row 1	Sign?	Y	Yes					n/a	$ -	
F06786	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#1 - Row 2	Sign?	Y	Yes					n/a	$ -	
F06787	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#2 - Row 2	Sign?	Y	Yes					n/a	$ -	
F06788	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 2	Sign?	Y	Yes					n/a	$ -	
F06789	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 2	Sign?	Y	Yes					n/a	$ -	
F06790	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#5 - Row 2	Sign?	Y	Yes					n/a	$ -	
F06791	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#6 - Row 2	Sign?	Y	Yes					n/a	$ -	
F06792	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#2	Slope, cross	0.1%	Yes					n/a	$ -	
F06793	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#4	Slope, cross	0.2%	Yes					n/a	$ -	
F06794	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Row 1	Slope, cross	1.0%	Yes					n/a	$ -	
F06795	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	Row 1 between spaces #2 & #3	Slope, cross	1.0%	Yes					n/a	$ -	
F06796	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Row 2	Slope, cross	1.4%	Yes					n/a	$ -	
F06797	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	Row 1 between spaces #4 & #5	Slope, cross	1.9%	Yes					n/a	$ -	
F06798	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#1 - Row 2	Slope, cross	0.2%	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06799	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#2 - Row 2	Slope, cross	0.3%	Yes					n/a	$ -	
F06800	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 2	Slope, cross	0.4%	Yes					n/a	$ -	
F06801	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#5 - Row 1	Slope, cross	0.8%	Yes					n/a	$ -	
F06802	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 1	Slope, cross	0.9%	Yes					n/a	$ -	
F06803	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#1 - Row 1	Slope, cross	1.1%	Yes					n/a	$ -	
F06804	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#2 - Row 1	Slope, cross	1.1%	Yes					n/a	$ -	
F06805	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#5 - Row 2	Slope, cross	1.5%	Yes					n/a	$ -	
F06806	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 2	Slope, cross	1.6%	Yes					n/a	$ -	
F06807	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#6 - Row 2	Slope, cross	1.8%	Yes					n/a	$ -	
F06808	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	Row 1 between spaces #4 & #5	Slope, running	1.8%	Yes					n/a	$ -	
F06809	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#2	Slope, running	1.8%	Yes					n/a	$ -	
F06810	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Row 1	Surface marking?	Y	Yes					n/a	$ -	
F06811	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	Row 1 between spaces #2 & #3	Surface marking?	Y	Yes					n/a	$ -	
F06812	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	Row 1 between spaces #4 & #5	Surface marking?	Y	Yes					n/a	$ -	
F06813	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Row 2	Surface marking?	Y	Yes					n/a	$ -	
F06814	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#2	Surface marking?	Y	Yes					n/a	$ -	
F06815	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#3	Surface marking?	Y	Yes					n/a	$ -	
F06816	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#4	Surface marking?	Y	Yes					n/a	$ -	
F06817	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Row 1	Surface material	Asphalt	Yes					n/a	$ -	
F06818	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#2 - Row 1	Surface material	Asphalt	Yes					n/a	$ -	
F06819	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#1 - Row 1	Van sign?	Y	Yes					n/a	$ -	
F06820	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#1 - Row 2	Van sign?	N	Yes					n/a	$ -	
F06821	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#2 - Row 1	Van sign?	Y	Yes					n/a	$ -	
F06822	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 1	Van sign?	Y	Yes					n/a	$ -	
F06823	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 1	Van sign?	Y	Yes					n/a	$ -	
F06824	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#2 - Row 2	Van sign?	Y	Yes					n/a	$ -	
F06825	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 2	Van sign?	Y	Yes					n/a	$ -	
F06826	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#5 - Row 1	Van sign?	N	Yes					n/a	$ -	
F06827	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 2	Van sign?	Y	Yes					n/a	$ -	
F06828	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#5 - Row 2	Van sign?	N	Yes					n/a	$ -	
F06829	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#6 - Row 2	Van sign?	N	Yes					n/a	$ -	
F06830	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Row 1	Width	120	Yes					n/a	$ -	
F06831	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#1 - Row 2	Width	110	Yes					n/a	$ -	
F06832	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#2	Width	96	Yes					n/a	$ -	
F06833	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#3	Width	101	Yes					n/a	$ -	
F06834	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	#4	Width	104	Yes					n/a	$ -	
F06835	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	Row 1 between spaces #4 & #5	Width	94	Yes					n/a	$ -	
F06836	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Access Aisle	Row 1 between spaces #2 & #3	Width	84	Yes					n/a	$ -	
F06837	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#1 - Row 1	Width	123	Yes					n/a	$ -	
F06838	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#1 - Row 2	Width	126	Yes					n/a	$ -	
F06839	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#2 - Row 1	Width	112	Yes					n/a	$ -	
F06840	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#2 - Row 2	Width	119	Yes					n/a	$ -	
F06841	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 1	Width	139	Yes					n/a	$ -	
F06842	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#3 - Row 2	Width	122	Yes					n/a	$ -	
F06843	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 1	Width	125	Yes					n/a	$ -	
F06844	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#4 - Row 2	Width	124	Yes					n/a	$ -	
F06845	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#5 - Row 1	Width	120	Yes					n/a	$ -	
F06846	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#5 - Row 2	Width	122	Yes					n/a	$ -	
F06847	Justice Center		Exterior	Owned	Parking Facility	West Parking Lot	1-Public Unsupervised	Parking Space	#6 - Row 2	Width	122	Yes					n/a	$ -	
F06848	Justice Center		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Cars obstruct pathway	N	Yes					n/a	$ -	
F06849	Justice Center		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, accessible	26	Yes					n/a	$ -	
F06850	Justice Center		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, total spaces	966	Yes					n/a	$ -	
F06851	Justice Center		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, van spaces	10	Yes					n/a	$ -	
F11539	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Alarm System		Height	89.25	Yes					n/a	$ -	
F11540	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11541	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Counter		Dimension, knee clearance	29.25	Yes					n/a	$ -	
F11542	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Dispenser	TP	Dimension from water closet seat	7	Yes					n/a	$ -	
F11543	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Dispenser	TP	Height	20	Yes					n/a	$ -	
F11544	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Dispenser	Soap	Height	42	Yes					n/a	$ -	
F11545	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Dispenser	PT	Height	48	Yes					n/a	$ -	
F11546	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F11547	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Door Gate		Clearance, pull parallel	60	Yes					n/a	$ -	
F11548	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Door Gate		Clearance, pull perpendicular	59	Yes					n/a	$ -	
F11549	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Door Gate		Clearance, push parallel	32	Yes					n/a	$ -	
F11550	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Door Gate		Clearance, push perpendicular	83	Yes					n/a	$ -	
F11551	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Door Gate		Clearance, vertical	83.75	Yes					n/a	$ -	
F11552	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F11553	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F11554	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F11555	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F11556	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Fixture Count		Number, toilet compartments	2	Yes					n/a	$ -	
F11557	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Fixture Count		Number, urinals	1	Yes					n/a	$ -	
F11558	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F11559	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F11560	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F11561	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F11562	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F11563	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Grab Bar	Rear	Height, top	34.75	Yes					n/a	$ -	
F11564	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Grab Bar	Side	Height, top	34.75	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11565	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F11566	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F11567	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Lavatory Sink		Clearance, parallel	OK	Yes					n/a	$ -	
F11568	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Lavatory Sink		Clearance, perpendicular	OK	Yes					n/a	$ -	
F11569	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	29.25	Yes					n/a	$ -	
F11570	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F11571	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F11572	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Mirror		Height, bottom	38.25	Yes					n/a	$ -	
F11573	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Signage		Braille?	Y	Yes					n/a	$ -	
F11574	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F11575	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	
F11576	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F11577	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Toilet Compartment		Clear opening	32.25	Yes					n/a	$ -	
F11578	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Toilet Compartment		Clearance, outside	39.25	Yes					n/a	$ -	
F11579	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Toilet Compartment		Clearance, perpendicular	95	Yes					n/a	$ -	
F11580	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F11581	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F11582	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Water Closet		Clearance, perpendicular	70	Yes					n/a	$ -	
F11583	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Water Closet		Dimension, wide side	41.75	Yes					n/a	$ -	
F11584	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Water Closet		Height, seat	17.75	Yes					n/a	$ -	
F11585	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Men's - Training Room	2-Public Supervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F11610	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F11611	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Toilet Compartment		Clear opening	32.5	Yes					n/a	$ -	
F11612	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Counter		Clearance, parallel	94	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11613	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Toilet Compartment		Clearance, parallel	61	Yes					n/a	$ -	
F11614	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Counter		Clearance, perpendicular	75	Yes					n/a	$ -	
F11615	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Toilet Compartment		Clearance, perpendicular	98	Yes					n/a	$ -	
F11616	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Water Closet		Clearance, perpendicular	73	Yes					n/a	$ -	
F11617	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Door Gate		Clearance, pull parallel	60	Yes					n/a	$ -	
F11618	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Door Gate		Clearance, pull perpendicular	59	Yes					n/a	$ -	
F11619	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Door Gate		Clearance, push parallel	32.5	Yes					n/a	$ -	
F11620	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Door Gate		Clearance, push perpendicular	83	Yes					n/a	$ -	
F11621	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F11622	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F11623	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F11624	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F11625	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F11626	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F11627	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Dispenser	TP	Dimension from water closet seat	8.5	Yes					n/a	$ -	
F11628	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F11629	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Counter		Dimension, knee clearance	29	Yes					n/a	$ -	
F11630	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F11631	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Water Closet		Dimension, wide side	43	Yes					n/a	$ -	
F11632	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F11633	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F11634	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F11635	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F11636	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Alarm System		Height	90	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11637	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Counter		Height	34	Yes					n/a	$ -	
F11638	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Dispenser	TP	Height	20	Yes					n/a	$ -	
F11639	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Dispenser	PT	Height	48	Yes					n/a	$ -	
F11640	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Dispenser	Soap	Height	41	Yes					n/a	$ -	
F11641	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F11642	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Mirror		Height, bottom	38	Yes					n/a	$ -	
F11643	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Signage		Height, bottom	58.25	Yes					n/a	$ -	
F11644	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Water Closet		Height, flush control	28	Yes					n/a	$ -	
F11645	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F11646	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F11647	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F11648	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Grab Bar	Rear	Height, top	34.75	Yes					n/a	$ -	
F11649	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Grab Bar	Side	Height, top	34.75	Yes					n/a	$ -	
F11650	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F11651	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F11652	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	
F11653	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F11654	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F11655	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F11656	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Fixture Count		Number, toilet compartments	3	Yes					n/a	$ -	
F11657	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F11658	Justice Center	Self Help Resource Center	1st Floor	Owned	Restroom	Women's - #157 Training Room	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F11659	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Door Gate		Threshold beveled?	Y	Yes					n/a	$ -	
F11694	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F11695	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Toilet Compartment		Clear opening	32	Yes					n/a	$ -	
F11696	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Toilet Compartment		Clearance, outside	99	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11697	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	36	Yes					n/a	$ -	
F11698	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	50	Yes					n/a	$ -	
F11699	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	61	Yes					n/a	$ -	
F11700	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Urinal		Clearance, parallel	30.75	Yes					n/a	$ -	
F11701	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Water Closet		Clearance, parallel	61	Yes					n/a	$ -	
F11702	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	77	Yes					n/a	$ -	
F11703	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	72	Yes					n/a	$ -	
F11704	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	99	Yes					n/a	$ -	
F11705	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Urinal		Clearance, perpendicular	99	Yes					n/a	$ -	
F11706	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Water Closet		Clearance, perpendicular	78	Yes					n/a	$ -	
F11707	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F11708	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	68.5	Yes					n/a	$ -	
F11709	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	76	Yes					n/a	$ -	
F11710	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F11711	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F11712	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Door Gate		Clearance, vertical	94	Yes					n/a	$ -	
F11713	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Water Closet		Control force	3	Yes					n/a	$ -	
F11714	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Urinal		Depth	15	Yes					n/a	$ -	
F11715	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F11716	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F11717	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	7.5	Yes					n/a	$ -	
F11718	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Signage		Dimension, characters	4.75	Yes					n/a	$ -	
F11719	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	30.5	Yes					n/a	$ -	
F11720	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29.25	Yes					n/a	$ -	
F11721	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Toilet Compartment		Door swing direction	Out	Yes					n/a	$ -	
F11722	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F11723	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F11724	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	Y	Yes					n/a	$ -	
F11725	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F11726	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F11727	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F11728	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Toilet Compartment		Hardware type	PP	Yes					n/a	$ -	
F11729	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Alarm System		Height	90	Yes					n/a	$ -	
F11730	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Dispenser	TP	Height	20	Yes					n/a	$ -	
F11731	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Dispenser	Soap	Height	43	Yes					n/a	$ -	
F11732	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Dispenser	PT	Height	47	Yes					n/a	$ -	
F11733	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Mirror		Height, bottom	38.5	Yes					n/a	$ -	
F11734	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Signage		Height, bottom	58.25	Yes					n/a	$ -	
F11735	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Urinal		Height, flush control	40	Yes					n/a	$ -	
F11736	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Water Closet		Height, flush control	27	Yes					n/a	$ -	
F11737	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Urinal		Height, rim	1.5	Yes					n/a	$ -	
F11738	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F11739	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F11740	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F11741	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Grab Bar	Rear	Height, top	34.75	Yes					n/a	$ -	
F11742	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Grab Bar	Side	Height, top	34.75	Yes					n/a	$ -	
F11743	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F11744	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F11745	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11746	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F11747	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F11748	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Fixture Count		Number, toilet compartments	1	Yes					n/a	$ -	
F11749	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Fixture Count		Number, urinals	2	Yes					n/a	$ -	
F11750	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Lavatory Sink		Other attribute	2nd sink	Yes					n/a	$ -	
F11751	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Mirror		Other attribute	2nd sink	Yes					n/a	$ -	
F11752	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F11753	Justice Center		1st Floor	Owned	Restroom	Men's - #108	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F11778	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F11779	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F11780	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Door Gate		Clearance, pull perpendicular	58	Yes					n/a	$ -	
F11781	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Door Gate		Clearance, push parallel	12.75	Yes					n/a	$ -	
F11782	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Door Gate		Clearance, push perpendicular	86	Yes					n/a	$ -	
F11783	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F11784	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Door Gate		Closing speed	5	Yes					n/a	$ -	
F11785	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Dispenser	TP	Dimension from water closet seat	7.5	Yes					n/a	$ -	
F11786	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Toilet Compartment	Inaccessible	Dimension, door to partition	3.5	Yes					n/a	$ -	
F11787	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Water Closet		Dimension, sidewall	16.5	Yes					n/a	$ -	
F11788	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Toilet Compartment	Inaccessible	Door swing direction	In	Yes					n/a	$ -	
F11789	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F11790	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F11791	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Alarm System		Height	89.75	Yes					n/a	$ -	
F11792	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Dispenser	TP	Height	20	Yes					n/a	$ -	
F11793	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Dispenser	PT	Height	48	Yes					n/a	$ -	
F11794	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Lavatory Sink		Height	31	Yes					n/a	$ -	
F11795	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Mirror		Height, bottom	39	Yes					n/a	$ -	
F11796	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Signage		Height, bottom	58.25	Yes					n/a	$ -	
F11797	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Water Closet		Height, flush control	24.5	Yes					n/a	$ -	
F11798	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Toilet Compartment	Inaccessible	Height, toe clearance	12	Yes					n/a	$ -	
F11799	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F11800	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Fixture Count		Number, toilet compartments	1	Yes					n/a	$ -	
F11801	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Fixture Count		Number, urinals	1	Yes					n/a	$ -	
F11802	Justice Center		1st Floor	Owned	Restroom	Men's - #112	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F11811	Justice Center		2nd Floor	Owned	Restroom	Men's - #224	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F11815	Justice Center		2nd Floor	Owned	Restroom	Men's - #224	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F11816	Justice Center		2nd Floor	Owned	Restroom	Men's - #224	1-Public Unsupervised	Door Gate		Clearance, pull parallel	18	Yes					n/a	$ -	
F11817	Justice Center		2nd Floor	Owned	Restroom	Men's - #224	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F11818	Justice Center		2nd Floor	Owned	Restroom	Men's - #224	1-Public Unsupervised	Door Gate		Clearance, push parallel	22	Yes					n/a	$ -	
F11819	Justice Center		2nd Floor	Owned	Restroom	Men's - #224	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F11820	Justice Center		2nd Floor	Owned	Restroom	Men's - #224	1-Public Unsupervised	Door Gate		Clearance, vertical	93	Yes					n/a	$ -	
F11821	Justice Center		2nd Floor	Owned	Restroom	Men's - #224	1-Public Unsupervised	Signage		Dimension, characters	0.75	Yes					n/a	$ -	
F11822	Justice Center		2nd Floor	Owned	Restroom	Men's - #224	1-Public Unsupervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F11823	Justice Center		2nd Floor	Owned	Restroom	Men's - #224	1-Public Unsupervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F11824	Justice Center		2nd Floor	Owned	Restroom	Men's - #224	1-Public Unsupervised	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F11825	Justice Center		2nd Floor	Owned	Restroom	Men's - #224	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F11826	Justice Center		2nd Floor	Owned	Restroom	Men's - #224	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11827	Justice Center		2nd Floor	Owned	Restroom	Men's - #224	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F11828	Justice Center		3rd Floor	Owned	Restroom	Men's - #314	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F11829	Justice Center		3rd Floor	Owned	Restroom	Men's - #314	1-Public Unsupervised	Signage		Dimension, characters	0.75	Yes					n/a	$ -	
F11830	Justice Center		3rd Floor	Owned	Restroom	Men's - #314	1-Public Unsupervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F11831	Justice Center		3rd Floor	Owned	Restroom	Men's - #314	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F11832	Justice Center		3rd Floor	Owned	Restroom	Men's - #314	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F11833	Justice Center		3rd Floor	Owned	Restroom	Men's - #314	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F11857	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F11858	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F11859	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Toilet Compartment		Clear opening	32	Yes					n/a	$ -	
F11860	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F11861	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	97.5	Yes					n/a	$ -	
F11862	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Door Gate		Clearance, pull parallel	18	Yes					n/a	$ -	
F11863	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F11864	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Door Gate		Clearance, push parallel	18	Yes					n/a	$ -	
F11865	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F11866	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F11867	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F11868	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Door Gate		Clearance, vertical	93	Yes					n/a	$ -	
F11869	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Grab Bar	Side	Diameter	1.25	Yes					n/a	$ -	
F11870	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.25	Yes					n/a	$ -	
F11871	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Dispenser		Dimension from water closet seat	8.5	Yes					n/a	$ -	
F11872	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Signage		Dimension, characters	.75	Yes					n/a	$ -	
F11873	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F11874	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29.25	Yes					n/a	$ -	
F11875	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F11876	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Water Closet		Dimension, wide side	42	Yes					n/a	$ -	
F11877	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F11878	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F11879	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F11880	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F11881	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Toilet Compartment		Hardware type	L	Yes					n/a	$ -	
F11882	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Alarm System		Height	90	Yes					n/a	$ -	
F11883	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Dispenser		Height	19	Yes					n/a	$ -	
F11884	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Dispenser	PT	Height	47	Yes					n/a	$ -	
F11885	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Dispenser	Soap	Height	42.5	Yes					n/a	$ -	
F11886	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Mirror		Height, bottom	38.25	Yes					n/a	$ -	
F11887	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Signage		Height, bottom	58.5	Yes					n/a	$ -	
F11888	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F11889	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F11890	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Grab Bar	Side	Height, top	34.75	Yes					n/a	$ -	
F11891	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F11892	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F11893	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F11894	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F11895	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F11896	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F11897	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Fixture Count		Number, toilet compartments	1	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11898	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Fixture Count		Number, urinals	1	Yes					n/a	$ -	
F11899	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F11900	Justice Center		4th Floor	Owned	Restroom	Men's - #410	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F11925	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F11926	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Toilet Compartment		Clear opening	32.5	Yes					n/a	$ -	
F11927	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	60	Yes					n/a	$ -	
F11928	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	60	Yes					n/a	$ -	
F11929	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	97	Yes					n/a	$ -	
F11930	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Door Gate		Clearance, pull parallel	18	Yes					n/a	$ -	
F11931	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F11932	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Door Gate		Clearance, push parallel	23	Yes					n/a	$ -	
F11933	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F11934	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F11935	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F11936	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Door Gate		Clearance, vertical	93.5	Yes					n/a	$ -	
F11937	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.25	Yes					n/a	$ -	
F11938	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Grab Bar	Side	Diameter	1.25	Yes					n/a	$ -	
F11939	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	7.5	Yes					n/a	$ -	
F11940	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Signage		Dimension, characters	0.75	Yes					n/a	$ -	
F11941	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F11942	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F11943	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F11944	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F11945	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F11946	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F11947	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Toilet Compartment		Hardware type	L	Yes					n/a	$ -	
F11948	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Alarm System		Height	89.75	Yes					n/a	$ -	
F11949	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Dispenser	TP	Height	20	Yes					n/a	$ -	
F11950	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Dispenser	Soap	Height	41	Yes					n/a	$ -	
F11951	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Dispenser	PT	Height	46	Yes					n/a	$ -	
F11952	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F11953	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Mirror		Height, bottom	38	Yes					n/a	$ -	
F11954	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Signage		Height, bottom	58.25	Yes					n/a	$ -	
F11955	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Water Closet		Height, seat	17.5	Yes					n/a	$ -	
F11956	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F11957	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F11958	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F11959	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F11960	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F11961	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F11962	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F11963	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F11964	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Fixture Count		Number, toilet compartments	1	Yes					n/a	$ -	
F11965	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Fixture Count		Number, urinals	1	Yes					n/a	$ -	
F11966	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F11967	Justice Center		4th Floor	Owned	Restroom	Men's - #454	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F11986	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F11987	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Toilet Compartment		Clear opening	32	Yes					n/a	$ -	
F11988	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	99	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F11989	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F11990	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	64	Yes					n/a	$ -	
F11991	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	97	Yes					n/a	$ -	
F11992	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Door Gate		Clearance, pull parallel	19	Yes					n/a	$ -	
F11993	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F11994	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Door Gate		Clearance, push parallel	24	Yes					n/a	$ -	
F11995	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F11996	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F11997	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F11998	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Door Gate		Clearance, vertical	93	Yes					n/a	$ -	
F11999	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Door Gate		Closing speed	6	Yes					n/a	$ -	
F12000	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Water Closet		Control force	3	Yes					n/a	$ -	
F12001	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F12002	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F12003	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	7	Yes					n/a	$ -	
F12004	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Signage		Dimension, characters	0.75	Yes					n/a	$ -	
F12005	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F12006	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F12007	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Water Closet		Dimension, sidewall	17	Yes					n/a	$ -	
F12008	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Water Closet		Dimension, wide side	42.5	Yes					n/a	$ -	
F12009	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F12010	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F12011	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F12012	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F12013	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Toilet Compartment		Hardware type	L	Yes					n/a	$ -	
F12014	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Alarm System		Height	89	Yes					n/a	$ -	
F12015	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Dispenser	PT	Height	46	Yes					n/a	$ -	
F12016	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Dispenser	TP	Height	20	Yes					n/a	$ -	
F12017	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Dispenser	Soap	Height	42	Yes					n/a	$ -	
F12018	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F12019	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Mirror		Height, bottom	39	Yes					n/a	$ -	
F12020	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F12021	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Water Closet		Height, flush control	27	Yes					n/a	$ -	
F12022	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F12023	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F12024	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F12025	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F12026	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F12027	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F12028	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F12029	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F12030	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F12031	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F12032	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Fixture Count		Number, toilet compartments	1	Yes					n/a	$ -	
F12033	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Fixture Count		Number, urinals	1	Yes					n/a	$ -	
F12034	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F12035	Justice Center		5th Floor	Owned	Restroom	Men's - #513	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F12050	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F12051	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Toilet Compartment		Clear opening	32	Yes					n/a	$ -	
F12052	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F12053	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	98	Yes					n/a	$ -	
F12054	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Door Gate		Clearance, pull parallel	18	Yes					n/a	$ -	
F12055	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F12056	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Door Gate		Clearance, push parallel	24	Yes					n/a	$ -	
F12057	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F12058	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F12059	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	8	Yes					n/a	$ -	
F12060	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F12061	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F12062	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Water Closet		Dimension, sidewall	17.5	Yes					n/a	$ -	
F12063	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Water Closet		Dimension, wide side	42.25	Yes					n/a	$ -	
F12064	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F12065	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F12066	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Alarm System		Height	89.5	Yes					n/a	$ -	
F12067	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Dispenser	PT	Height	47	Yes					n/a	$ -	
F12068	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Dispenser	Soap	Height	44	Yes					n/a	$ -	
F12069	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Mirror		Height, bottom	38.5	Yes					n/a	$ -	
F12070	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F12071	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F12072	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F12073	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F12074	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F12075	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F12076	Justice Center		6th Floor	Owned	Restroom	Men's - #616	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F12092	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F12093	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Toilet Compartment		Clear opening	32	Yes					n/a	$ -	
F12094	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	60.75	Yes					n/a	$ -	
F12095	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	97.5	Yes					n/a	$ -	
F12096	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Door Gate		Clearance, pull parallel	18	Yes					n/a	$ -	
F12097	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F12098	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Door Gate		Clearance, push parallel	24	Yes					n/a	$ -	
F12099	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F12100	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F12101	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	7	Yes					n/a	$ -	
F12102	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F12103	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29.25	Yes					n/a	$ -	
F12104	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Water Closet		Dimension, wide side	40.5	Yes					n/a	$ -	
F12105	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F12106	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F12107	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F12108	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Alarm System		Height	89.5	Yes					n/a	$ -	
F12109	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Dispenser	TP	Height	21	Yes					n/a	$ -	
F12110	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Dispenser	PT	Height	47	Yes					n/a	$ -	
F12111	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Dispenser	Soap	Height	44	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F12112	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Mirror		Height, bottom	38.5	Yes					n/a	$ -	
F12113	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Water Closet		Height, flush control	27	Yes					n/a	$ -	
F12114	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Water Closet		Height, seat	17.5	Yes					n/a	$ -	
F12115	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F12116	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F12117	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F12118	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F12119	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F12120	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F12121	Justice Center		6th Floor	Owned	Restroom	Men's - #654	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F12137	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Urinal		Depth	14	Yes					n/a	$ -	
F12145	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F12146	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F12147	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Toilet Compartment		Clearance, outside	62	Yes					n/a	$ -	
F12148	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	60	Yes					n/a	$ -	
F12149	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F12150	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Urinal		Clearance, parallel	32.5	Yes					n/a	$ -	
F12151	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Water Closet		Clearance, parallel	60	Yes					n/a	$ -	
F12152	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	99	Yes					n/a	$ -	
F12153	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	60.5	Yes					n/a	$ -	
F12154	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Urinal		Clearance, perpendicular	99	Yes					n/a	$ -	
F12155	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Water Closet		Clearance, perpendicular	60	Yes					n/a	$ -	
F12156	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Door Gate		Clearance, pull parallel	69	Yes					n/a	$ -	
F12157	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	66	Yes					n/a	$ -	
F12158	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F12159	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	72	Yes					n/a	$ -	
F12160	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F12161	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Grab Bar	Vertical	Clearance, to wall	1.5	Yes					n/a	$ -	
F12162	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F12163	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Door Gate		Clearance, vertical	82	Yes					n/a	$ -	
F12164	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F12165	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Urinal		Control force	OK	Yes					n/a	$ -	
F12166	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Water Closet		Control force	OK	Yes					n/a	$ -	
F12167	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F12168	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Grab Bar	Vertical	Diameter	1.5	Yes					n/a	$ -	
F12169	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F12170	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	9	Yes					n/a	$ -	
F12171	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	40.5	Yes					n/a	$ -	
F12172	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Signage		Dimension, characters	4.75	Yes					n/a	$ -	
F12173	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F12174	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Water Closet		Dimension, wide side	39.5	Yes					n/a	$ -	
F12175	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Toilet Compartment		Door swing direction	Out	Yes					n/a	$ -	
F12176	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F12177	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	Y	Yes					n/a	$ -	
F12178	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F12179	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F12180	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Toilet Compartment		Hardware type	PP	Yes					n/a	$ -	
F12181	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Coat Hook		Height	46	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F12182	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Dispenser	TP	Height	20	Yes					n/a	$ -	
F12183	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Dispenser	Soap	Height	38.75	Yes					n/a	$ -	
F12184	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Dispenser	PT	Height	44.5	Yes					n/a	$ -	
F12185	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Lavatory Sink		Height	32	Yes					n/a	$ -	
F12186	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Mirror		Height, bottom	36	Yes					n/a	$ -	
F12187	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Signage		Height, bottom	56	Yes					n/a	$ -	
F12188	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Urinal		Height, flush control	38	Yes					n/a	$ -	
F12189	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Water Closet		Height, flush control	26	Yes					n/a	$ -	
F12190	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Urinal		Height, rim	15.5	Yes					n/a	$ -	
F12191	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F12192	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	14	Yes					n/a	$ -	
F12193	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F12194	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Grab Bar	Side	Height, top	33.75	Yes					n/a	$ -	
F12195	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Grab Bar	Rear	Height, top	33.75	Yes					n/a	$ -	
F12196	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F12197	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F12198	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Grab Bar	Vertical	Length	18	Yes					n/a	$ -	
F12199	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F12200	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F12201	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F12202	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F12203	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Fixture Count		Number, toilet compartments	2	Yes					n/a	$ -	
F12204	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Fixture Count		Number, urinals	2	Yes					n/a	$ -	
F12205	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F12206	Justice Center		Interior	Owned	Restroom	Men's - #S105	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F12228	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F12229	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F12230	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	59	Yes					n/a	$ -	
F12231	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F12232	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	84	Yes					n/a	$ -	
F12233	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	88.5	Yes					n/a	$ -	
F12234	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Door Gate		Clearance, pull parallel	24	Yes					n/a	$ -	
F12235	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F12236	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Door Gate		Clearance, push parallel	24	Yes					n/a	$ -	
F12237	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F12238	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F12239	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F12240	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Grab Bar	Vertical	Clearance, to wall	1.5	Yes					n/a	$ -	
F12241	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F12242	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Water Closet		Control force	2	Yes					n/a	$ -	
F12243	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F12244	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F12245	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Grab Bar	Vertical	Diameter	1.5	Yes					n/a	$ -	
F12246	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	7	Yes					n/a	$ -	
F12247	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Grab Bar	Vertical	Dimension, between	6.5	Yes					n/a	$ -	
F12248	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	40.5	Yes					n/a	$ -	
F12249	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Signage		Dimension, characters	0.75	Yes					n/a	$ -	
F12250	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F12251	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Water Closet		Dimension, sidewall	17.5	Yes					n/a	$ -	
F12252	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Water Closet		Dimension, wide side	43	Yes					n/a	$ -	
F12253	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F12254	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F12255	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F12256	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Toilet Compartment		Hardware type	L	Yes					n/a	$ -	
F12257	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Coat Hook		Height	42	Yes					n/a	$ -	
F12258	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Dispenser	TP	Height	19.5	Yes					n/a	$ -	
F12259	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Dispenser	Soap	Height	43	Yes					n/a	$ -	
F12260	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Dispenser	PT	Height	44	Yes					n/a	$ -	
F12261	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F12262	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Changing Station		Height	33	Yes					n/a	$ -	
F12263	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Mirror		Height, bottom	38.5	Yes					n/a	$ -	
F12264	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F12265	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Water Closet		Height, flush control	27	Yes					n/a	$ -	
F12266	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Door Gate		Height, hardware	OK	Yes					n/a	$ -	
F12267	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Water Closet		Height, seat	17.5	Yes					n/a	$ -	
F12268	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F12269	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F12270	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Grab Bar	Rear	Height, top	34	Yes					n/a	$ -	
F12271	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Grab Bar	Side	Height, top	34	Yes					n/a	$ -	
F12272	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F12273	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F12274	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F12275	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Grab Bar	Vertical	Length	18	Yes					n/a	$ -	
F12276	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F12277	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F12278	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F12279	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F12280	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Fixture Count		Number, toilet compartments	1	Yes					n/a	$ -	
F12281	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Fixture Count		Number, urinals	1	Yes					n/a	$ -	
F12282	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F12283	Justice Center		4th Floor	Owned	Restroom	Men's - #S403	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F12288	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	40.25	Yes					n/a	$ -	
F12308	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F12309	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Toilet Compartment		Clear opening	34.25	Yes					n/a	$ -	
F12310	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Toilet Compartment		Clearance, outside	OK	Yes					n/a	$ -	
F12311	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Counter		Clearance, parallel	58	Yes					n/a	$ -	
F12312	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	59	Yes					n/a	$ -	
F12313	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Urinal		Clearance, parallel	34.75	Yes					n/a	$ -	
F12314	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Counter		Clearance, perpendicular	84	Yes					n/a	$ -	
F12315	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	84	Yes					n/a	$ -	
F12316	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	87	Yes					n/a	$ -	
F12317	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Urinal		Clearance, perpendicular	99	Yes					n/a	$ -	
F12318	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Water Closet		Clearance, perpendicular	62	Yes					n/a	$ -	
F12319	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Door Gate		Clearance, pull parallel	23.5	Yes					n/a	$ -	
F12320	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F12321	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Door Gate		Clearance, push parallel	23.5	Yes					n/a	$ -	
F12322	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F12323	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F12324	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F12325	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Grab Bar	Vertical	Clearance, to wall	1.5	Yes					n/a	$ -	
F12326	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F12327	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Urinal		Control force	5	Yes					n/a	$ -	
F12328	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Water Closet		Control force	4	Yes					n/a	$ -	
F12329	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Urinal		Depth	14.5	Yes					n/a	$ -	
F12330	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F12331	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F12332	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Grab Bar	Vertical	Diameter	1.5	Yes					n/a	$ -	
F12333	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	8	Yes					n/a	$ -	
F12334	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Signage		Dimension, characters	4.5	Yes					n/a	$ -	
F12335	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4	Yes					n/a	$ -	
F12336	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F12337	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F12338	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Counter		Dimension, knee clearance	29	Yes					n/a	$ -	
F12339	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F12340	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F12341	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Water Closet		Dimension, wide side	42.25	Yes					n/a	$ -	
F12342	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F12343	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F12344	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Door Gate		Firm, stable, slip resistant	Y	Yes					n/a	$ -	
F12345	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F12346	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F12347	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Toilet Compartment		Hardware type	L	Yes					n/a	$ -	
F12348	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Alarm System		Height	Ceiling mount	Yes					n/a	$ -	
F12349	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Coat Hook		Height	46	Yes					n/a	$ -	
F12350	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Counter		Height	34	Yes					n/a	$ -	
F12351	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Dispenser	PT	Height	44	Yes					n/a	$ -	
F12352	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Dispenser	TP	Height	20	Yes					n/a	$ -	
F12353	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Dispenser	Soap	Height	42.25	Yes					n/a	$ -	
F12354	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F12355	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Changing Station		Height	33	Yes					n/a	$ -	
F12356	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Mirror		Height, bottom	38	Yes					n/a	$ -	
F12357	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Signage		Height, bottom	56.25	Yes					n/a	$ -	
F12358	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Urinal		Height, flush control	39.5	Yes					n/a	$ -	
F12359	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Water Closet		Height, flush control	27	Yes					n/a	$ -	
F12360	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Water Closet		Height, seat	18.25	Yes					n/a	$ -	
F12361	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Door Gate		Threshold beveled?	Y	Yes					n/a	$ -	
F12362	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12.5	Yes					n/a	$ -	
F12363	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Grab Bar	Rear	Height, top	33.75	Yes					n/a	$ -	
F12364	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Grab Bar	Side	Height, top	33.5	Yes					n/a	$ -	
F12365	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F12366	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Counter		Length	58	Yes					n/a	$ -	
F12367	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F12368	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F12369	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Grab Bar	Vertical	Length	18	Yes					n/a	$ -	
F12370	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F12371	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F12372	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F12373	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F12374	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Fixture Count		Number, toilet compartments	1	Yes					n/a	$ -	
F12375	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Fixture Count		Number, urinals	1	Yes					n/a	$ -	
F12376	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F12377	Justice Center		5th Floor	Owned	Restroom	Men's - #S503	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F12391	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F12392	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F12393	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F12394	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F12395	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F12396	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	88.5	Yes					n/a	$ -	
F12397	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Door Gate		Clearance, pull parallel	24	Yes					n/a	$ -	
F12398	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F12399	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Door Gate		Clearance, push parallel	24	Yes					n/a	$ -	
F12400	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F12401	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F12402	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Water Closet		Control force	1	Yes					n/a	$ -	
F12403	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	8	Yes					n/a	$ -	
F12404	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	40.25	Yes					n/a	$ -	
F12405	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4	Yes					n/a	$ -	
F12406	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F12407	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	28.75	Yes					n/a	$ -	
F12408	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Water Closet		Dimension, sidewall	17.5	Yes					n/a	$ -	
F12409	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Water Closet		Dimension, wide side	42.5	Yes					n/a	$ -	
F12410	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F12411	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F12412	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F12413	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Dispenser	PT	Height	46	Yes					n/a	$ -	
F12414	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Dispenser	Soap	Height	43	Yes					n/a	$ -	
F12415	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Lavatory Sink		Height	33.25	Yes					n/a	$ -	
F12416	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Mirror		Height, bottom	38	Yes					n/a	$ -	
F12417	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Water Closet		Height, flush control	27	Yes					n/a	$ -	
F12418	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F12419	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F12420	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F12421	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F12422	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F12423	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Grab Bar	Vertical	Length	18	Yes					n/a	$ -	
F12424	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F12425	Justice Center		6th Floor	Owned	Restroom	Men's - #S603	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F12456	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F12457	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Toilet Compartment		Clear opening	32	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F12458	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Coat Hook		Clearance, parallel	OK	Yes					n/a	$ -	
F12459	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F12460	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Dispenser	PT	Clearance, parallel	99	Yes					n/a	$ -	
F12461	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	99	Yes					n/a	$ -	
F12462	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Changing Station		Clearance, parallel	99	Yes					n/a	$ -	
F12463	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Coat Hook		Clearance, perpendicular	OK	Yes					n/a	$ -	
F12464	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Counter		Clearance, perpendicular	60.5	Yes					n/a	$ -	
F12465	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Dispenser	PT	Clearance, perpendicular	62	Yes					n/a	$ -	
F12466	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	60.5	Yes					n/a	$ -	
F12467	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Changing Station		Clearance, perpendicular	61	Yes					n/a	$ -	
F12468	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	97.5	Yes					n/a	$ -	
F12469	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Water Closet		Clearance, perpendicular	65	Yes					n/a	$ -	
F12470	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Door Gate		Clearance, pull parallel	19	Yes					n/a	$ -	
F12471	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F12472	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Door Gate		Clearance, push parallel	24	Yes					n/a	$ -	
F12473	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F12474	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F12475	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F12476	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Door Gate		Clearance, vertical	93	Yes					n/a	$ -	
F12477	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F12478	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Water Closet		Control force	2	Yes					n/a	$ -	
F12479	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F12480	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F12481	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	8	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F12482	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Signage		Dimension, characters	5	Yes					n/a	$ -	
F12483	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4	Yes					n/a	$ -	
F12484	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F12485	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Counter		Dimension, knee clearance	29.5	Yes					n/a	$ -	
F12486	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29.5	Yes					n/a	$ -	
F12487	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Water Closet		Dimension, wide side	42	Yes					n/a	$ -	
F12488	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F12489	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F12490	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F12491	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F12492	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Toilet Compartment		Hardware type	L	Yes					n/a	$ -	
F12493	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Alarm System		Height	87	Yes					n/a	$ -	
F12494	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Dispenser	PT	Height	46	Yes					n/a	$ -	
F12495	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Dispenser	TP	Height	20	Yes					n/a	$ -	
F12496	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Dispenser	Soap	Height	42	Yes					n/a	$ -	
F12497	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Mirror		Height, bottom	39	Yes					n/a	$ -	
F12498	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F12499	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Water Closet		Height, flush control	27	Yes					n/a	$ -	
F12500	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Water Closet		Height, seat	17.75	Yes					n/a	$ -	
F12501	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F12502	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Door Gate		Threshold beveled?	Y	Yes					n/a	$ -	
F12503	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F12504	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Grab Bar	Rear	Height, top	34.5	Yes					n/a	$ -	
F12505	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Grab Bar	Side	Height, top	35.5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F12506	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F12507	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Counter		Length	56.25	Yes					n/a	$ -	
F12508	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F12509	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F12510	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F12511	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F12512	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F12513	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F12514	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Fixture Count		Number, toilet compartments	1	Yes					n/a	$ -	
F12515	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Fixture Count		Number, urinals	1	Yes					n/a	$ -	
F12516	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F12517	Justice Center		5th Floor	Owned	Restroom	Men's - Between Courtrooms #504 & #505	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F12536	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F12537	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Lavatory Sink		Clearance, parallel	60	Yes					n/a	$ -	
F12538	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Lavatory Sink		Clearance, perpendicular	99	Yes					n/a	$ -	
F12539	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Water Closet		Clearance, perpendicular	99	Yes					n/a	$ -	
F12540	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Door Gate		Clearance, pull parallel	89	Yes					n/a	$ -	
F12541	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Door Gate		Clearance, pull perpendicular	89	Yes					n/a	$ -	
F12542	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Door Gate		Clearance, push parallel	72	Yes					n/a	$ -	
F12543	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Door Gate		Clearance, push perpendicular	46	Yes					n/a	$ -	
F12544	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F12545	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F12546	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Grab Bar	Vertical	Clearance, to wall	1.5	Yes					n/a	$ -	
F12547	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Door Gate		Clearance, vertical	83.5	Yes					n/a	$ -	
F12548	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Water Closet		Control force	OK	Yes					n/a	$ -	
F12549	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F12550	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F12551	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Grab Bar	Vertical	Diameter	1.5	Yes					n/a	$ -	
F12552	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Dispenser	TP	Dimension from water closet seat	8.5	Yes					n/a	$ -	
F12553	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	40.25	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F12554	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F12555	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Lavatory Sink		Dimension, knee clearance	30	Yes					n/a	$ -	
F12556	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F12557	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F12558	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F12559	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Dispenser	TP	Height	19	Yes					n/a	$ -	
F12560	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Dispenser	PT	Height	45	Yes					n/a	$ -	
F12561	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Dispenser	Soap	Height	46.5	Yes					n/a	$ -	
F12562	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Lavatory Sink		Height	33.5	Yes					n/a	$ -	
F12563	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Mirror		Height, bottom	39.75	Yes					n/a	$ -	
F12564	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Signage		Height, bottom	57.75	Yes					n/a	$ -	
F12565	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Water Closet		Height, flush control	26.5	Yes					n/a	$ -	
F12566	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Grab Bar	Side	Height, top	34.5	Yes					n/a	$ -	
F12567	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F12568	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Signage		ISA?	Y	Yes					n/a	$ -	
F12569	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F12570	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F12571	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F12572	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Grab Bar	Vertical	Length	18	Yes					n/a	$ -	
F12573	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Signage		Location	L	Yes					n/a	$ -	
F12574	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F12575	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Door Gate		Opening force	0	Yes					n/a	$ -	
F12576	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F12577	Justice Center		Interior	Owned	Restroom	Men's - Locker Room #S009	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F12591	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Signage	At hall before closet	Braille?	Y	Yes					n/a	$ -	
F12592	Justice Center		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F12593	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F12594	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Clearance, parallel	66	Yes					n/a	$ -	
F12595	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Clearance, parallel	90.5	Yes					n/a	$ -	
F12596	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Clearance, perpendicular	56	Yes					n/a	$ -	
F12597	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Clearance, perpendicular	72.75	Yes					n/a	$ -	
F12598	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Clearance, pull perpendicular	90	Yes					n/a	$ -	
F12599	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Clearance, push parallel	30.5	Yes					n/a	$ -	
F12600	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F12601	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F12602	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F12603	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Vertical	Clearance, to wall	1.5	Yes					n/a	$ -	
F12604	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F12605	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Control force	5	Yes					n/a	$ -	
F12606	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Rear	Cross section dimension, maximum	1.5	Yes					n/a	$ -	
F12607	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F12608	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F12609	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Vertical	Diameter	1.5	Yes					n/a	$ -	
F12610	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Dispenser	TP	Dimension from water closet seat	9	Yes					n/a	$ -	
F12611	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Vertical	Dimension, between	6	Yes					n/a	$ -	
F12612	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	40	Yes					n/a	$ -	
F12613	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Signage	At hall before closet	Dimension, characters	4	Yes					n/a	$ -	
F12614	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F12615	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F12616	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F12617	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Dimension, wide side	42.25	Yes					n/a	$ -	
F12618	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F12619	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F12620	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F12621	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Dispenser	TP	Height	20	Yes					n/a	$ -	
F12622	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Dispenser	PT	Height	44	Yes					n/a	$ -	
F12623	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Dispenser	Soap	Height	46.5	Yes					n/a	$ -	
F12624	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Height	32.75	Yes					n/a	$ -	
F12625	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Mirror		Height, bottom	40	Yes					n/a	$ -	
F12626	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Signage	At hall before closet	Height, bottom	56.25	Yes					n/a	$ -	
F12627	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Height, flush control	27	Yes					n/a	$ -	
F12628	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Height, seat	17.5	Yes					n/a	$ -	
F12629	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F12630	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Rear	Height, top	33.5	Yes					n/a	$ -	
F12631	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Side	Height, top	33.75	Yes					n/a	$ -	
F12632	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Signage	At hall before closet	ISA?	Y	Yes					n/a	$ -	
F12633	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F12634	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F12635	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Vertical	Length	18	Yes					n/a	$ -	
F12636	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F12637	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Signage	At hall before closet	Tactile letters?	Y	Yes					n/a	$ -	
F12638	Justice Center		5th Floor	Owned	Restroom	Unisex	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F12658	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F12659	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Water Closet		Clearance, parallel	62.5	Yes					n/a	$ -	
F12660	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Water Closet		Clearance, perpendicular	81.5	Yes					n/a	$ -	
F12661	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F12662	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Door Gate		Clearance, pull perpendicular	94	Yes					n/a	$ -	
F12663	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Door Gate		Clearance, push parallel	15	Yes					n/a	$ -	
F12664	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Door Gate		Clearance, push perpendicular	67	Yes					n/a	$ -	
F12665	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F12666	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F12667	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Door Gate		Clearance, vertical	82.75	Yes					n/a	$ -	
F12668	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F12669	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F12670	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Dispenser	TP	Dimension from water closet seat	7	Yes					n/a	$ -	
F12671	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Signage		Dimension, characters	4.75	Yes					n/a	$ -	
F12672	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F12673	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Lavatory Sink		Dimension, knee clearance	31	Yes					n/a	$ -	
F12674	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Water Closet		Dimension, sidewall	17.75	Yes					n/a	$ -	
F12675	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F12676	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Alarm System		Height	89.5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F12677	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Dispenser	Soap	Height	45	Yes					n/a	$ -	
F12678	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Dispenser	PT	Height	47.75	Yes					n/a	$ -	
F12679	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Dispenser	TP	Height	20	Yes					n/a	$ -	
F12680	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Signage		Height, bottom	58.5	Yes					n/a	$ -	
F12681	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Water Closet		Height, flush control	27	Yes					n/a	$ -	
F12682	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Water Closet		Height, seat	18	Yes					n/a	$ -	
F12683	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F12684	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F12685	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Grab Bar	Side	Height, top	34.25	Yes					n/a	$ -	
F12686	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Signage		ISA?	Y	Yes					n/a	$ -	
F12687	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F12688	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Signage		Location	L	Yes					n/a	$ -	
F12689	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F12690	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F12691	Justice Center		Interior	Owned	Restroom	Unisex - #104	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F12728	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Signage		Braille?	Y	Yes					n/a	$ -	
F12729	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F12730	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F12731	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Water Closet		Clearance, parallel	67	Yes					n/a	$ -	
F12732	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Water Closet		Clearance, perpendicular	81	Yes					n/a	$ -	
F12733	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Door Gate		Clearance, pull parallel	19	Yes					n/a	$ -	
F12734	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Door Gate		Clearance, pull perpendicular	62	Yes					n/a	$ -	
F12735	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Door Gate		Clearance, pull perpendicular	72	Yes					n/a	$ -	
F12736	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F12737	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Door Gate		Clearance, push parallel	14	Yes					n/a	$ -	
F12738	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F12739	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Door Gate		Clearance, push perpendicular	67	Yes					n/a	$ -	
F12740	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F12741	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F12742	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F12743	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F12744	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Grab Bar	Rear	Diameter	1.25	Yes					n/a	$ -	
F12745	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Grab Bar	Side	Diameter	1.25	Yes					n/a	$ -	
F12746	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Dispenser	TP	Dimension from water closet seat	7	Yes					n/a	$ -	
F12747	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Dispenser	TP	Dimension from water closet seat	8	Yes					n/a	$ -	
F12748	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Signage		Dimension, characters	0.75	Yes					n/a	$ -	
F12749	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F12750	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Lavatory Sink		Dimension, knee clearance	30	Yes					n/a	$ -	
F12751	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F12752	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F12753	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F12754	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F12755	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Alarm System		Height	89.5	Yes					n/a	$ -	
F12756	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Alarm System		Height	90	Yes					n/a	$ -	
F12757	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Dispenser	Soap	Height	41	Yes					n/a	$ -	
F12758	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Dispenser	PT	Height	45	Yes					n/a	$ -	
F12759	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Dispenser	TP	Height	17	Yes					n/a	$ -	
F12760	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Dispenser	Soap	Height	40	Yes					n/a	$ -	
F12761	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Dispenser	PT	Height	45	Yes					n/a	$ -	
F12762	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Lavatory Sink		Height	31	Yes					n/a	$ -	
F12763	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Signage		Height, bottom	58	Yes					n/a	$ -	
F12764	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Signage		Height, bottom	58	Yes					n/a	$ -	
F12765	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Water Closet		Height, seat	17.75	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F12766	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F12767	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F12768	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Grab Bar	Rear	Height, top	34.8	Yes					n/a	$ -	
F12769	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Grab Bar	Side	Height, top	34.5	Yes					n/a	$ -	
F12770	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Signage		ISA?	Y	Yes					n/a	$ -	
F12771	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F12772	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Signage		Location	L	Yes					n/a	$ -	
F12773	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Signage		Location	L	Yes					n/a	$ -	
F12774	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F12775	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F12776	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F12777	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F12778	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F12779	Justice Center		4th Floor	Owned	Restroom	Unisex - #405	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F12800	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Door Gate		Clear opening	32	Yes					n/a	$ -	
F12801	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Lavatory Sink		Clearance, parallel	56	Yes					n/a	$ -	
F12802	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Lavatory Sink		Clearance, perpendicular	54	Yes					n/a	$ -	
F12803	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Water Closet		Clearance, perpendicular	58	Yes					n/a	$ -	
F12804	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Door Gate		Clearance, pull parallel	20	Yes					n/a	$ -	
F12805	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Door Gate		Clearance, push parallel	16	Yes					n/a	$ -	
F12806	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Door Gate		Clearance, push perpendicular	64	Yes					n/a	$ -	
F12807	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F12808	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F12809	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F12810	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Water Closet		Control force	2	Yes					n/a	$ -	
F12811	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F12812	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F12813	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Dispenser	TP	Dimension from water closet seat	8	Yes					n/a	$ -	
F12814	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Signage		Dimension, characters	5	Yes					n/a	$ -	
F12815	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F12816	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Lavatory Sink		Dimension, knee clearance	31	Yes					n/a	$ -	
F12817	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F12818	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F12819	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F12820	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Alarm System		Height	87	Yes					n/a	$ -	
F12821	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Dispenser	TP	Height	19	Yes					n/a	$ -	
F12822	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Dispenser	Soap	Height	44	Yes					n/a	$ -	
F12823	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Dispenser	PT	Height	45	Yes					n/a	$ -	
F12824	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Lavatory Sink		Height	34	Yes					n/a	$ -	
F12825	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Signage		Height, bottom	58	Yes					n/a	$ -	
F12826	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Water Closet		Height, flush control	27	Yes					n/a	$ -	
F12827	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Water Closet		Height, seat	18	Yes					n/a	$ -	
F12828	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F12829	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F12830	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F12831	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Signage		ISA?	Y	Yes					n/a	$ -	
F12832	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F12833	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Signage		Location	L	Yes					n/a	$ -	
F12834	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F12835	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Door Gate		Opening force	1	Yes					n/a	$ -	
F12836	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F12837	Justice Center		5th Floor	Owned	Restroom	Unisex - #504	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F12849	Justice Center		6th Floor	Owned	Restroom	Unisex - #603	3-Employee Common	Water Closet		Clearance, parallel	64	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F12850	Justice Center		6th Floor	Owned	Restroom	Unisex - #603	3-Employee Common	Water Closet		Clearance, perpendicular	58.5	Yes					n/a	$ -	
F12851	Justice Center		6th Floor	Owned	Restroom	Unisex - #603	3-Employee Common	Dispenser	TP	Dimension from water closet seat	9	Yes					n/a	$ -	
F12852	Justice Center		6th Floor	Owned	Restroom	Unisex - #603	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F12853	Justice Center		6th Floor	Owned	Restroom	Unisex - #603	3-Employee Common	Alarm System		Height	90	Yes					n/a	$ -	
F12854	Justice Center		6th Floor	Owned	Restroom	Unisex - #603	3-Employee Common	Dispenser	Soap	Height	48	Yes					n/a	$ -	
F12855	Justice Center		6th Floor	Owned	Restroom	Unisex - #603	3-Employee Common	Dispenser	PT	Height	48	Yes					n/a	$ -	
F12856	Justice Center		6th Floor	Owned	Restroom	Unisex - #603	3-Employee Common	Lavatory Sink		Height	31.25	Yes					n/a	$ -	
F12857	Justice Center		6th Floor	Owned	Restroom	Unisex - #603	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F12866	Justice Center		6th Floor	Owned	Restroom	Unisex - #604	3-Employee Common	Water Closet		Clearance, parallel	64	Yes					n/a	$ -	
F12867	Justice Center		6th Floor	Owned	Restroom	Unisex - #604	3-Employee Common	Water Closet		Clearance, perpendicular	82	Yes					n/a	$ -	
F12868	Justice Center		6th Floor	Owned	Restroom	Unisex - #604	3-Employee Common	Dispenser	TP	Dimension from water closet seat	8	Yes					n/a	$ -	
F12869	Justice Center		6th Floor	Owned	Restroom	Unisex - #604	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F12870	Justice Center		6th Floor	Owned	Restroom	Unisex - #604	3-Employee Common	Lavatory Sink		Dimension, knee clearance	30	Yes					n/a	$ -	
F12871	Justice Center		6th Floor	Owned	Restroom	Unisex - #604	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F12872	Justice Center		6th Floor	Owned	Restroom	Unisex - #604	3-Employee Common	Alarm System		Height	90.5	Yes					n/a	$ -	
F12873	Justice Center		6th Floor	Owned	Restroom	Unisex - #604	3-Employee Common	Dispenser	TP	Height	21	Yes					n/a	$ -	
F12874	Justice Center		6th Floor	Owned	Restroom	Unisex - #604	3-Employee Common	Dispenser	Soap	Height	48	Yes					n/a	$ -	
F12875	Justice Center		6th Floor	Owned	Restroom	Unisex - #604	3-Employee Common	Dispenser	PT	Height	48	Yes					n/a	$ -	
F12876	Justice Center		6th Floor	Owned	Restroom	Unisex - #604	3-Employee Common	Water Closet		Height, seat	18.25	Yes					n/a	$ -	
F12877	Justice Center		6th Floor	Owned	Restroom	Unisex - #604	3-Employee Common	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F12878	Justice Center		6th Floor	Owned	Restroom	Unisex - #604	3-Employee Common	Grab Bar	Side	Height, top	35.5	Yes					n/a	$ -	
F12879	Justice Center		6th Floor	Owned	Restroom	Unisex - #604	3-Employee Common	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F12880	Justice Center		6th Floor	Owned	Restroom	Unisex - #604	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F12881	Justice Center		6th Floor	Owned	Restroom	Unisex - #604	3-Employee Common	Mirror		Other attribute	OK	Yes					n/a	$ -	
F12882	Justice Center		6th Floor	Owned	Restroom	Unisex - #604	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F12897	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F12898	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Water Closet		Clearance, parallel	90	Yes					n/a	$ -	
F12899	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Water Closet		Clearance, perpendicular	70	Yes					n/a	$ -	
F12900	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Door Gate		Clearance, pull perpendicular	90	Yes					n/a	$ -	
F12901	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Door Gate		Clearance, push parallel	40	Yes					n/a	$ -	
F12902	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F12903	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F12904	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F12905	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Grab Bar	Vertical	Clearance, to wall	1.5	Yes					n/a	$ -	
F12906	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F12907	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F12908	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F12909	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Grab Bar	Vertical	Diameter	1.5	Yes					n/a	$ -	
F12910	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Dispenser	TP	Dimension from water closet seat	8.5	Yes					n/a	$ -	
F12911	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	40	Yes					n/a	$ -	
F12912	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Signage		Dimension, characters	.75	Yes					n/a	$ -	
F12913	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F12914	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F12915	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Lavatory Sink		Dimension, knee clearance	27	Yes					n/a	$ -	
F12916	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Water Closet		Dimension, sidewall	17.75	Yes					n/a	$ -	
F12917	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Water Closet		Dimension, wide side	42.5	Yes					n/a	$ -	
F12918	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F12919	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F12920	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Dispenser	TP	Height	18	Yes					n/a	$ -	
F12921	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Dispenser	Soap	Height	46	Yes					n/a	$ -	
F12922	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Dispenser	PT	Height	44	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F12923	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Lavatory Sink		Height	33	Yes					n/a	$ -	
F12924	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Mirror		Height, bottom	40	Yes					n/a	$ -	
F12925	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Signage		Height, bottom	56	Yes					n/a	$ -	
F12926	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Water Closet		Height, flush control	27	Yes					n/a	$ -	
F12927	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Water Closet		Height, seat	18.5	Yes					n/a	$ -	
F12928	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F12929	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Grab Bar	Side	Height, top	34	Yes					n/a	$ -	
F12930	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Grab Bar	Rear	Height, top	34	Yes					n/a	$ -	
F12931	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Signage		ISA?	Y	Yes					n/a	$ -	
F12932	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F12933	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F12934	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Grab Bar	Vertical	Length	18	Yes					n/a	$ -	
F12935	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Signage		Location	Hallway wall	Yes					n/a	$ -	
F12936	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F12937	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F12938	Justice Center		4th Floor	Owned	Restroom	Unisex - #S438	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F12947	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Signage		Braille?	Y	Yes					n/a	$ -	
F12948	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F12949	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Water Closet		Clearance, parallel	91	Yes					n/a	$ -	
F12950	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Water Closet		Clearance, perpendicular	73	Yes					n/a	$ -	
F12951	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F12952	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Door Gate		Clearance, push parallel	0	Yes					n/a	$ -	
F12953	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F12954	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Dispenser	TP	Dimension from water closet seat	9	Yes					n/a	$ -	
F12955	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	40	Yes					n/a	$ -	
F12956	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F12957	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Lavatory Sink		Dimension, knee clearance	27.5	Yes					n/a	$ -	
F12958	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F12959	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Water Closet		Dimension, wide side	42	Yes					n/a	$ -	
F12960	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F12961	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F12962	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Dispenser	TP	Height	21	Yes					n/a	$ -	
F12963	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Dispenser	PT	Height	46	Yes					n/a	$ -	
F12964	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Dispenser	Soap	Height	47	Yes					n/a	$ -	
F12965	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Lavatory Sink		Height	33.75	Yes					n/a	$ -	
F12966	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Mirror		Height, bottom	39.25	Yes					n/a	$ -	
F12967	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Signage		Height, bottom	57	Yes					n/a	$ -	
F12968	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Water Closet		Height, flush control	27	Yes					n/a	$ -	
F12969	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Water Closet		Height, seat	17.75	Yes					n/a	$ -	
F12970	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F12971	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F12972	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Signage		ISA?	Y	Yes					n/a	$ -	
F12973	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F12974	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F12975	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Grab Bar	Vertical	Length	18	Yes					n/a	$ -	
F12976	Justice Center		6th Floor	Owned	Restroom	Unisex - #S638	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F12985	Justice Center		Interior	Owned	Restroom	Unisex - Holding cells	2-Public Supervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F12986	Justice Center		Interior	Owned	Restroom	Unisex - Holding cells	2-Public Supervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F12987	Justice Center		Interior	Owned	Restroom	Unisex - Holding cells	2-Public Supervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F12988	Justice Center		Interior	Owned	Restroom	Unisex - Holding cells	2-Public Supervised	Grab Bar	Side	Height, top	35.25	Yes					n/a	$ -	
F12989	Justice Center		Interior	Owned	Restroom	Unisex - Holding cells	2-Public Supervised	Grab Bar	Rear	Height, top	35.25	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F12990	Justice Center		Interior	Owned	Restroom	Unisex - Holding cells	2-Public Supervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F13007	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F13008	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Water Closet		Clearance, parallel	94	Yes					n/a	$ -	
F13009	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Water Closet		Clearance, perpendicular	57	Yes					n/a	$ -	
F13010	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Door Gate		Clearance, pull parallel	18	Yes					n/a	$ -	
F13011	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	80	Yes					n/a	$ -	
F13012	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Door Gate		Clearance, push parallel	18	Yes					n/a	$ -	
F13013	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	52	Yes					n/a	$ -	
F13014	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	8	Yes					n/a	$ -	
F13015	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F13016	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F13017	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Alarm System		Height	89	Yes					n/a	$ -	
F13018	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Dispenser	TP	Height	21.5	Yes					n/a	$ -	
F13019	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Dispenser	Soap	Height	48	Yes					n/a	$ -	
F13020	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Dispenser	PT	Height	48	Yes					n/a	$ -	
F13021	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Dispenser	Toilet seat covers	Height	48	Yes					n/a	$ -	
F13022	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Lavatory Sink		Height	31	Yes					n/a	$ -	
F13023	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Water Closet		Height, flush control	25	Yes					n/a	$ -	
F13024	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Water Closet		Height, seat	17	Yes					n/a	$ -	
F13025	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F13026	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 235	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F13034	Justice Center		2nd Floor	Owned	Restroom	Unisex - Jury Room 239	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F13067	Justice Center		3rd Floor	Owned	Restroom	Unisex - Jury Room 369	2-Public Supervised	Dispenser	TP	Dimension from water closet seat	8	Yes					n/a	$ -	
F13084	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F13085	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Door Gate		Clearance, pull parallel	19	Yes					n/a	$ -	
F13086	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Door Gate		Clearance, pull perpendicular	94	Yes					n/a	$ -	
F13087	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Door Gate		Clearance, push parallel	19	Yes					n/a	$ -	
F13088	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Door Gate		Clearance, push perpendicular	56	Yes					n/a	$ -	
F13089	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F13090	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Dispenser	TP	Dimension from water closet seat	7.5	Yes					n/a	$ -	
F13091	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Water Closet		Dimension, sidewall	16	Yes					n/a	$ -	
F13092	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F13093	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F13094	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Alarm System		Height	89.75	Yes					n/a	$ -	
F13095	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Dispenser	TP	Height	22	Yes					n/a	$ -	
F13096	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Dispenser	Toilet seat covers	Height	48	Yes					n/a	$ -	
F13097	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Dispenser	PT	Height	48	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13098	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Dispenser	Soap	Height	40.5	Yes					n/a	$ -	
F13099	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Lavatory Sink		Height	31.25	Yes					n/a	$ -	
F13100	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 421	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F13111	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 425	2-Public Supervised	Water Closet		Clearance, parallel	94	Yes					n/a	$ -	
F13112	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 425	2-Public Supervised	Water Closet		Clearance, perpendicular	58	Yes					n/a	$ -	
F13113	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 425	2-Public Supervised	Dispenser	TP	Dimension from water closet seat	7	Yes					n/a	$ -	
F13114	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 425	2-Public Supervised	Water Closet		Dimension, sidewall	16.25	Yes					n/a	$ -	
F13115	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 425	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F13116	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 425	2-Public Supervised	Alarm System		Height	90	Yes					n/a	$ -	
F13117	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 425	2-Public Supervised	Dispenser	Soap	Height	40	Yes					n/a	$ -	
F13118	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 425	2-Public Supervised	Dispenser	PT	Height	48	Yes					n/a	$ -	
F13119	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 425	2-Public Supervised	Dispenser	Toilet seat covers	Height	46.5	Yes					n/a	$ -	
F13120	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 425	2-Public Supervised	Dispenser	TP	Height	22	Yes					n/a	$ -	
F13121	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 425	2-Public Supervised	Lavatory Sink		Height	31	Yes					n/a	$ -	
F13122	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 425	2-Public Supervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F13123	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 425	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F13142	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F13143	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Water Closet		Clearance, parallel	92	Yes					n/a	$ -	
F13144	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Water Closet		Clearance, perpendicular	59	Yes					n/a	$ -	
F13145	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Door Gate		Clearance, pull perpendicular	93	Yes					n/a	$ -	
F13146	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Door Gate		Clearance, push parallel	48	Yes					n/a	$ -	
F13147	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Door Gate		Clearance, push perpendicular	58	Yes					n/a	$ -	
F13148	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F13149	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Dispenser	TP	Dimension from water closet seat	8	Yes					n/a	$ -	
F13150	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F13151	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F13152	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Alarm System		Height	80	Yes					n/a	$ -	
F13153	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Dispenser	TP	Height	17	Yes					n/a	$ -	
F13154	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Dispenser	Toilet seat covers	Height	48	Yes					n/a	$ -	
F13155	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Dispenser	PT	Height	46	Yes					n/a	$ -	
F13156	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Dispenser	Soap	Height	43	Yes					n/a	$ -	
F13157	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Lavatory Sink		Height	31.5	Yes					n/a	$ -	
F13158	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F13159	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 465	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F13172	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Dispenser	TP	Dimension from water closet seat	8	Yes					n/a	$ -	
F13173	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F13174	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Water Closet		Clearance, parallel	60	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13175	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Water Closet		Clearance, perpendicular	99	Yes					n/a	$ -	
F13176	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Door Gate		Clearance, pull parallel	19	Yes					n/a	$ -	
F13177	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Door Gate		Clearance, pull perpendicular	94	Yes					n/a	$ -	
F13178	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Door Gate		Clearance, push parallel	19	Yes					n/a	$ -	
F13179	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Door Gate		Clearance, push perpendicular	56	Yes					n/a	$ -	
F13180	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F13181	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F13182	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F13183	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Grab Bar	Side	Diameter	1.25	Yes					n/a	$ -	
F13184	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Grab Bar	Rear	Diameter	1.25	Yes					n/a	$ -	
F13185	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F13186	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	30	Yes					n/a	$ -	
F13187	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F13188	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F13189	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F13190	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F13191	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Alarm System		Height	90	Yes					n/a	$ -	
F13192	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Dispenser	Soap	Height	38	Yes					n/a	$ -	
F13193	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Dispenser	PT	Height	46	Yes					n/a	$ -	
F13194	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Dispenser	Toilet seat covers	Height	47	Yes					n/a	$ -	
F13195	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Water Closet		Height, seat	19	Yes					n/a	$ -	
F13196	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F13197	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F13198	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F13199	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room 470	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F13213	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 524	1-Public Unsupervised	Water Closet		Clearance, parallel	94	Yes					n/a	$ -	
F13214	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 524	1-Public Unsupervised	Water Closet		Clearance, perpendicular	58	Yes					n/a	$ -	
F13215	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 524	1-Public Unsupervised	Water Closet		Control force	3	Yes					n/a	$ -	
F13216	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 524	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	8	Yes					n/a	$ -	
F13217	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 524	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F13218	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 524	1-Public Unsupervised	Alarm System		Height	89	Yes					n/a	$ -	
F13219	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 524	1-Public Unsupervised	Dispenser	Soap	Height	40	Yes					n/a	$ -	
F13220	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 524	1-Public Unsupervised	Dispenser	PT	Height	48	Yes					n/a	$ -	
F13221	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 524	1-Public Unsupervised	Dispenser	TP	Height	19	Yes					n/a	$ -	
F13222	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 524	1-Public Unsupervised	Lavatory Sink		Height	31	Yes					n/a	$ -	
F13223	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 524	1-Public Unsupervised	Water Closet		Height, flush control	25	Yes					n/a	$ -	
F13224	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 524	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13237	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Lavatory Sink		Clearance, parallel	53.5	Yes					n/a	$ -	
F13238	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Lavatory Sink		Clearance, perpendicular	78	Yes					n/a	$ -	
F13239	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Water Closet		Clearance, perpendicular	78	Yes					n/a	$ -	
F13240	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F13241	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F13242	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Water Closet		Control force	3	Yes					n/a	$ -	
F13243	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F13244	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F13245	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Dispenser	TP	Dimension from water closet seat	8	Yes					n/a	$ -	
F13246	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F13247	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	31.5	Yes					n/a	$ -	
F13248	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F13249	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F13250	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F13251	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Alarm System		Height	87	Yes					n/a	$ -	
F13252	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Dispenser	TP	Height	20	Yes					n/a	$ -	
F13253	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Dispenser	Soap	Height	41	Yes					n/a	$ -	
F13254	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Dispenser	PT	Height	46	Yes					n/a	$ -	
F13255	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F13256	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Water Closet		Height, flush control	28	Yes					n/a	$ -	
F13257	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F13258	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F13259	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F13260	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F13261	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Water Closet		Location, flush control	N	Yes					n/a	$ -	
F13262	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room 568	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F13277	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 627	1-Public Unsupervised	Water Closet		Clearance, parallel	94	Yes					n/a	$ -	
F13278	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 627	1-Public Unsupervised	Water Closet		Clearance, perpendicular	61.5	Yes					n/a	$ -	
F13279	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 627	1-Public Unsupervised	Door Gate		Clearance, pull parallel	21	Yes					n/a	$ -	
F13280	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 627	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F13281	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 627	1-Public Unsupervised	Alarm System		Height	90	Yes					n/a	$ -	
F13282	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 627	1-Public Unsupervised	Lavatory Sink		Height	32	Yes					n/a	$ -	
F13283	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 627	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F13295	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 631	1-Public Unsupervised	Water Closet		Clearance, parallel	94	Yes					n/a	$ -	
F13296	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 631	1-Public Unsupervised	Water Closet		Clearance, perpendicular	59	Yes					n/a	$ -	
F13297	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 631	1-Public Unsupervised	Door Gate		Clearance, pull parallel	19.5	Yes					n/a	$ -	
F13298	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 631	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	9	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13299	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 631	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F13300	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 631	1-Public Unsupervised	Alarm System		Height	90	Yes					n/a	$ -	
F13301	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 631	1-Public Unsupervised	Dispenser	Soap	Height	41	Yes					n/a	$ -	
F13302	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 631	1-Public Unsupervised	Dispenser	PT	Height	48	Yes					n/a	$ -	
F13303	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 631	1-Public Unsupervised	Dispenser	Toilet seat covers	Height	48	Yes					n/a	$ -	
F13304	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 631	1-Public Unsupervised	Lavatory Sink		Height	31.5	Yes					n/a	$ -	
F13305	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room 631	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F13320	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Door Gate		Clear opening	33.5	Yes					n/a	$ -	
F13321	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Water Closet		Clearance, parallel	92	Yes					n/a	$ -	
F13322	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Water Closet		Clearance, perpendicular	69	Yes					n/a	$ -	
F13323	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Door Gate		Clearance, pull perpendicular	92	Yes					n/a	$ -	
F13324	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Door Gate		Clearance, push parallel	27	Yes					n/a	$ -	
F13325	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Door Gate		Clearance, push perpendicular	57	Yes					n/a	$ -	
F13326	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F13327	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F13328	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Grab Bar	Vertical	Clearance, to wall	1.5	Yes					n/a	$ -	
F13329	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F13330	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F13331	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F13332	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Grab Bar	Vertical	Diameter	1.5	Yes					n/a	$ -	
F13333	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Dispenser	TP	Dimension from water closet seat	8.5	Yes					n/a	$ -	
F13334	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	40	Yes					n/a	$ -	
F13335	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F13336	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Lavatory Sink		Dimension, knee clearance	27	Yes					n/a	$ -	
F13337	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Water Closet		Dimension, sidewall	17.5	Yes					n/a	$ -	
F13338	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Water Closet		Dimension, wide side	42	Yes					n/a	$ -	
F13339	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F13340	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F13341	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F13342	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Dispenser	TP	Height	18	Yes					n/a	$ -	
F13343	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Dispenser	Soap	Height	46.5	Yes					n/a	$ -	
F13344	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Dispenser	PT	Height	44	Yes					n/a	$ -	
F13345	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Lavatory Sink		Height	33	Yes					n/a	$ -	
F13346	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Other Element	Feminine product disposal	Height	24	Yes					n/a	$ -	
F13347	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Mirror		Height, bottom	39.5	Yes					n/a	$ -	
F13348	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Water Closet		Height, flush control	27.5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13349	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Water Closet		Height, seat	18.5	Yes					n/a	$ -	
F13350	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F13351	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Grab Bar	Rear	Height, top	34	Yes					n/a	$ -	
F13352	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Grab Bar	Side	Height, top	34	Yes					n/a	$ -	
F13353	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F13354	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F13355	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Grab Bar	Vertical	Length	18	Yes					n/a	$ -	
F13356	Justice Center		4th Floor	Owned	Restroom	Unisex - Jury Room S422	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F13387	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F13388	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F13389	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Lavatory Sink		Clearance, parallel	68.5	Yes					n/a	$ -	
F13390	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Lavatory Sink		Clearance, parallel	66	Yes					n/a	$ -	
F13391	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Toilet Compartment		Clearance, parallel	68.5	Yes					n/a	$ -	
F13392	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Water Closet		Clearance, parallel	92.5	Yes					n/a	$ -	
F13393	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Water Closet		Clearance, parallel	92	Yes					n/a	$ -	
F13394	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Lavatory Sink		Clearance, perpendicular	51	Yes					n/a	$ -	
F13395	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Lavatory Sink		Clearance, perpendicular	53	Yes					n/a	$ -	
F13396	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Toilet Compartment		Clearance, perpendicular	92.5	Yes					n/a	$ -	
F13397	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Clearance, pull parallel	26.5	Yes					n/a	$ -	
F13398	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Clearance, pull parallel	18	Yes					n/a	$ -	
F13399	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Clearance, pull perpendicular	92.5	Yes					n/a	$ -	
F13400	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F13401	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Clearance, push parallel	26.5	Yes					n/a	$ -	
F13402	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Clearance, push parallel	28	Yes					n/a	$ -	
F13403	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Clearance, push perpendicular	56	Yes					n/a	$ -	
F13404	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Clearance, push perpendicular	62	Yes					n/a	$ -	
F13405	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F13406	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F13407	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Vertical	Clearance, to wall	1.5	Yes					n/a	$ -	
F13408	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F13409	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F13410	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Vertical	Clearance, to wall	1.5	Yes					n/a	$ -	
F13411	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F13412	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F13413	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Water Closet		Control force	5	Yes					n/a	$ -	
F13414	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Water Closet		Control force	3	Yes					n/a	$ -	
F13415	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13416	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F13417	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Vertical	Diameter	1.5	Yes					n/a	$ -	
F13418	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F13419	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F13420	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Vertical	Diameter	1.5	Yes					n/a	$ -	
F13421	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Dispenser	TP	Dimension from water closet seat	8	Yes					n/a	$ -	
F13422	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Dispenser	TP	Dimension from water closet seat	7	Yes					n/a	$ -	
F13423	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Vertical	Dimension, between	6	Yes					n/a	$ -	
F13424	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	40	Yes					n/a	$ -	
F13425	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	40.25	Yes					n/a	$ -	
F13426	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F13427	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F13428	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F13429	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F13430	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	29.5	Yes					n/a	$ -	
F13431	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Water Closet		Dimension, wide side	42.5	Yes					n/a	$ -	
F13432	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Water Closet		Dimension, wide side	42.25	Yes					n/a	$ -	
F13433	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F13434	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F13435	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F13436	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F13437	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F13438	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F13439	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F13440	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Alarm System		Height	Ceiling mount	Yes					n/a	$ -	
F13441	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Dispenser	TP	Height	20	Yes					n/a	$ -	
F13442	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Dispenser	PT	Height	44	Yes					n/a	$ -	
F13443	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Dispenser	Soap	Height	46.75	Yes					n/a	$ -	
F13444	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Dispenser	PT	Height	45	Yes					n/a	$ -	
F13445	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Dispenser	TP	Height	20	Yes					n/a	$ -	
F13446	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Dispenser	Soap	Height	47.5	Yes					n/a	$ -	
F13447	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Lavatory Sink		Height	32.75	Yes					n/a	$ -	
F13448	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Lavatory Sink		Height	33	Yes					n/a	$ -	
F13449	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Mirror		Height, bottom	40	Yes					n/a	$ -	
F13450	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Mirror		Height, bottom	40	Yes					n/a	$ -	
F13451	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Water Closet		Height, flush control	27	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13452	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Water Closet		Height, flush control	27	Yes					n/a	$ -	
F13453	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Water Closet		Height, seat	17.5	Yes					n/a	$ -	
F13454	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Water Closet		Height, seat	17.75	Yes					n/a	$ -	
F13455	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F13456	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Rear	Height, top	33.75	Yes					n/a	$ -	
F13457	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Side	Height, top	33.75	Yes					n/a	$ -	
F13458	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Rear	Height, top	34	Yes					n/a	$ -	
F13459	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Side	Height, top	34	Yes					n/a	$ -	
F13460	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F13461	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F13462	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F13463	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Vertical	Length	18	Yes					n/a	$ -	
F13464	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F13465	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F13466	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Grab Bar	Vertical	Length	18	Yes					n/a	$ -	
F13467	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F13468	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F13469	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Opening force	1	Yes					n/a	$ -	
F13470	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Door Gate		Opening force	2	Yes					n/a	$ -	
F13471	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F13472	Justice Center		5th Floor	Owned	Restroom	Unisex - Jury Room S522	2-Public Supervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F13477	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Water Closet		Clearance, parallel	97	Yes					n/a	$ -	
F13478	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Water Closet		Clearance, perpendicular	68.5	Yes					n/a	$ -	
F13479	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F13480	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F13481	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	8	Yes					n/a	$ -	
F13482	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	40	Yes					n/a	$ -	
F13483	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F13484	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	27	Yes					n/a	$ -	
F13485	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F13486	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F13487	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F13488	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Dispenser	TP	Height	22	Yes					n/a	$ -	
F13489	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Dispenser	Soap	Height	48	Yes					n/a	$ -	
F13490	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Dispenser	PT	Height	46	Yes					n/a	$ -	
F13491	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Lavatory Sink		Height	33	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13492	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Mirror		Height, bottom	39.5	Yes					n/a	$ -	
F13493	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Water Closet		Height, seat	18.5	Yes					n/a	$ -	
F13494	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Grab Bar	Rear	Height, top	35.5	Yes					n/a	$ -	
F13495	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Grab Bar	Side	Height, top	35.25	Yes					n/a	$ -	
F13496	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F13497	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F13498	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Grab Bar	Vertical	Length	18	Yes					n/a	$ -	
F13499	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F13500	Justice Center		6th Floor	Owned	Restroom	Unisex - Jury Room S622	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F13506	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #1	2-Public Supervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F13507	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #1	2-Public Supervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F13508	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #1	2-Public Supervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F13509	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #1	2-Public Supervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F13510	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #1	2-Public Supervised	Grab Bar	Side	Height, top	34.5	Yes					n/a	$ -	
F13511	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #1	2-Public Supervised	Grab Bar	Rear	Height, top	34.5	Yes					n/a	$ -	
F13512	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #1	2-Public Supervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F13520	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #2	2-Public Supervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F13521	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #2	2-Public Supervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F13522	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #2	2-Public Supervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F13523	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #2	2-Public Supervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F13524	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #2	2-Public Supervised	Grab Bar	Side	Height, top	34.75	Yes					n/a	$ -	
F13525	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #2	2-Public Supervised	Grab Bar	Rear	Height, top	34.5	Yes					n/a	$ -	
F13526	Justice Center		Interior	Owned	Restroom	Unisex - Juvenile Holding cell #2	2-Public Supervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F13544	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F13545	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Lavatory Sink		Clearance, parallel	38	Yes					n/a	$ -	
F13546	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Water Closet		Clearance, parallel	63	Yes					n/a	$ -	
F13547	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Water Closet		Clearance, perpendicular	58	Yes					n/a	$ -	
F13548	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Door Gate		Clearance, pull perpendicular	63	Yes					n/a	$ -	
F13549	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F13550	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Door Gate		Clearance, push perpendicular	55	Yes					n/a	$ -	
F13551	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Door Gate		Clearance, vertical	82.75	Yes					n/a	$ -	
F13552	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Dispenser	TP	Dimension from water closet seat	7	Yes					n/a	$ -	
F13553	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F13554	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F13555	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F13556	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Alarm System		Height	90	Yes					n/a	$ -	
F13557	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Dispenser	Soap	Height	48	Yes					n/a	$ -	
F13558	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Dispenser	PT	Height	47.5	Yes					n/a	$ -	
F13559	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Dispenser	TP	Height	20	Yes					n/a	$ -	
F13560	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Lavatory Sink		Height	31	Yes					n/a	$ -	
F13561	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Water Closet		Height, flush control	25	Yes					n/a	$ -	
F13562	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13563	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F13564	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F13565	Justice Center		Interior	Owned	Restroom	Women's - #103	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F13600	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F13601	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Toilet Compartment	With sink	Clear opening	32.5	Yes					n/a	$ -	
F13602	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Toilet Compartment	With sink	Clearance, outside	99	Yes					n/a	$ -	
F13603	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Counter		Clearance, parallel	60	Yes					n/a	$ -	
F13604	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Lavatory Sink	In toilet compartment	Clearance, parallel	36	Yes					n/a	$ -	
F13605	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	60	Yes					n/a	$ -	
F13606	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Counter		Clearance, perpendicular	77	Yes					n/a	$ -	
F13607	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Lavatory Sink	In toilet compartment	Clearance, perpendicular	76	Yes					n/a	$ -	
F13608	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	77	Yes					n/a	$ -	
F13609	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Toilet Compartment	With sink	Clearance, perpendicular	99	Yes					n/a	$ -	
F13610	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Water Closet		Clearance, perpendicular	79	Yes					n/a	$ -	
F13611	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Door Gate		Clearance, pull parallel	90.5	Yes					n/a	$ -	
F13612	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	69	Yes					n/a	$ -	
F13613	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Door Gate		Clearance, push parallel	19	Yes					n/a	$ -	
F13614	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	75	Yes					n/a	$ -	
F13615	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F13616	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F13617	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Door Gate		Clearance, vertical	94	Yes					n/a	$ -	
F13618	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F13619	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Water Closet		Control force	3	Yes					n/a	$ -	
F13620	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F13621	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F13622	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	7	Yes					n/a	$ -	
F13623	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Signage		Dimension, characters	4.75	Yes					n/a	$ -	
F13624	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Counter		Dimension, knee clearance	29.25	Yes					n/a	$ -	
F13625	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Lavatory Sink	In toilet compartment	Dimension, knee clearance	30	Yes					n/a	$ -	
F13626	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29.25	Yes					n/a	$ -	
F13627	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Toilet Compartment	With sink	Door swing direction	In	Yes					n/a	$ -	
F13628	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Lavatory Sink	In toilet compartment	Drain wrapped?	Y	Yes					n/a	$ -	
F13629	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F13630	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Toilet Compartment	With sink	Hardware both sides?	Y	Yes					n/a	$ -	
F13631	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F13632	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Lavatory Sink	In toilet compartment	Hardware type	L	Yes					n/a	$ -	
F13633	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F13634	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Alarm System		Height	89.5	Yes					n/a	$ -	
F13635	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Dispenser	TP	Height	19	Yes					n/a	$ -	
F13636	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Dispenser	Soap	Height	43	Yes					n/a	$ -	
F13637	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Dispenser	PT	Height	46	Yes					n/a	$ -	
F13638	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Lavatory Sink	In toilet compartment	Height	34	Yes					n/a	$ -	
F13639	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Mirror		Height, bottom	38.75	Yes					n/a	$ -	
F13640	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F13641	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Water Closet		Height, flush control	27	Yes					n/a	$ -	
F13642	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F13643	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F13644	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Toilet Compartment	With sink	Height, toe clearance	12	Yes					n/a	$ -	
F13645	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13646	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F13647	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Counter		Length	60	Yes					n/a	$ -	
F13648	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F13649	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F13650	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F13651	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F13652	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F13653	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Fixture Count		Number, toilet compartments	3	Yes					n/a	$ -	
F13654	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F13655	Justice Center		1st Floor	Owned	Restroom	Women's - #109	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F13675	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F13676	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Water Closet		Clearance, perpendicular	58.5	Yes					n/a	$ -	
F13677	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Door Gate		Clearance, pull parallel	36	Yes					n/a	$ -	
F13678	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Door Gate		Clearance, pull perpendicular	58	Yes					n/a	$ -	
F13679	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Door Gate		Clearance, push parallel	13	Yes					n/a	$ -	
F13680	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Door Gate		Clearance, push perpendicular	88	Yes					n/a	$ -	
F13681	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F13682	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Water Closet		Dimension, sidewall	17.25	Yes					n/a	$ -	
F13683	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F13684	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F13685	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Alarm System		Height	89.75	Yes					n/a	$ -	
F13686	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Dispenser	TP - #1	Height	20	Yes					n/a	$ -	
F13687	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Dispenser	Soap	Height	48	Yes					n/a	$ -	
F13688	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Dispenser	PT	Height	48	Yes					n/a	$ -	
F13689	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Lavatory Sink		Height	31	Yes					n/a	$ -	
F13690	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Mirror		Height, bottom	39	Yes					n/a	$ -	
F13691	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Signage		Height, bottom	58.25	Yes					n/a	$ -	
F13692	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F13693	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F13694	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Fixture Count		Number, toilet compartments	2	Yes					n/a	$ -	
F13695	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F13696	Justice Center		Interior	Owned	Restroom	Women's - #111	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F13697	Justice Center		2nd Floor	Owned	Restroom	Women's - #225	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F13705	Justice Center		3rd Floor	Owned	Restroom	Women's - #314	1-Public Unsupervised	Signage		Dimension, characters	0.75	Yes					n/a	$ -	
F13706	Justice Center		3rd Floor	Owned	Restroom	Women's - #314	1-Public Unsupervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F13707	Justice Center		3rd Floor	Owned	Restroom	Women's - #314	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F13708	Justice Center		3rd Floor	Owned	Restroom	Women's - #314	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F13724	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Toilet Compartment		Clear opening	32.25	Yes					n/a	$ -	
F13725	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Toilet Compartment		Clearance, outside	39.25	Yes					n/a	$ -	
F13726	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F13727	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Water Closet		Clearance, parallel	60	Yes					n/a	$ -	
F13728	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	97.5	Yes					n/a	$ -	
F13729	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Water Closet		Clearance, perpendicular	97.5	Yes					n/a	$ -	
F13730	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F13731	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F13732	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Grab Bar	Side	Diameter	1.25	Yes					n/a	$ -	
F13733	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.25	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13734	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	7.5	Yes					n/a	$ -	
F13735	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Signage		Dimension, characters	0.75	Yes					n/a	$ -	
F13736	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F13737	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29.25	Yes					n/a	$ -	
F13738	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Water Closet		Dimension, wide side	41.5	Yes					n/a	$ -	
F13739	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F13740	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F13741	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Lavatory Sink		Hardware type	Y	Yes					n/a	$ -	
F13742	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Toilet Compartment		Hardware type	L	Yes					n/a	$ -	
F13743	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Dispenser	TP	Height	19	Yes					n/a	$ -	
F13744	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Dispenser	Soap	Height	41.75	Yes					n/a	$ -	
F13745	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Dispenser	PT	Height	46.5	Yes					n/a	$ -	
F13746	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Dispenser	Feminine products	Height	40.5	Yes					n/a	$ -	
F13747	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Mirror		Height, bottom	38.25	Yes					n/a	$ -	
F13748	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Signage		Height, bottom	58.25	Yes					n/a	$ -	
F13749	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F13750	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F13751	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F13752	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F13753	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F13754	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F13755	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F13756	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F13757	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F13758	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F13759	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Fixture Count		Number, toilet compartments	2	Yes					n/a	$ -	
F13760	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Fixture Count		Number, urinals	0	Yes					n/a	$ -	
F13761	Justice Center		4th Floor	Owned	Restroom	Women's - #411	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F13787	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F13788	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Toilet Compartment		Clear opening	32.25	Yes					n/a	$ -	
F13789	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F13790	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	97	Yes					n/a	$ -	
F13791	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F13792	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Door Gate		Clearance, push parallel	22	Yes					n/a	$ -	
F13793	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F13794	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F13795	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F13796	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Door Gate		Clearance, vertical	93	Yes					n/a	$ -	
F13797	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F13798	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Grab Bar	Side	Diameter	1.25	Yes					n/a	$ -	
F13799	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.25	Yes					n/a	$ -	
F13800	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	8.5	Yes					n/a	$ -	
F13801	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Signage		Dimension, characters	0.75	Yes					n/a	$ -	
F13802	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F13803	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29.5	Yes					n/a	$ -	
F13804	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13805	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F13806	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F13807	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F13808	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Alarm System		Height	89.5	Yes					n/a	$ -	
F13809	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Dispenser	TP	Height	19	Yes					n/a	$ -	
F13810	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Dispenser	Feminine products	Height	40.5	Yes					n/a	$ -	
F13811	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Dispenser	PT	Height	46.5	Yes					n/a	$ -	
F13812	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Dispenser	Soap	Height	42	Yes					n/a	$ -	
F13813	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Mirror		Height, bottom	38.5	Yes					n/a	$ -	
F13814	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Water Closet		Height, seat	17.75	Yes					n/a	$ -	
F13815	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F13816	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F13817	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F13818	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Signage		Height, top	58.25	Yes					n/a	$ -	
F13819	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F13820	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F13821	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F13822	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F13823	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F13824	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F13825	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Fixture Count		Number, toilet compartments	2	Yes					n/a	$ -	
F13826	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Fixture Count		Number, urinals	0	Yes					n/a	$ -	
F13827	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F13828	Justice Center		4th Floor	Owned	Restroom	Women's - #455	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F13852	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Door Gate		Approach type, push	Y	Yes					n/a	$ -	
F13853	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F13854	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Toilet Compartment		Clear opening	32.25	Yes					n/a	$ -	
F13855	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Toilet Compartment		Clearance, outside	46.25	Yes					n/a	$ -	
F13856	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Counter		Clearance, parallel	58	Yes					n/a	$ -	
F13857	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F13858	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Counter		Clearance, perpendicular	84	Yes					n/a	$ -	
F13859	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	99	Yes					n/a	$ -	
F13860	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Water Closet		Clearance, perpendicular	62.5	Yes					n/a	$ -	
F13861	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Door Gate		Clearance, pull parallel	23	Yes					n/a	$ -	
F13862	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F13863	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Door Gate		Clearance, push parallel	33	Yes					n/a	$ -	
F13864	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F13865	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F13866	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Grab Bar	Vertical	Clearance, to wall	1.5	Yes					n/a	$ -	
F13867	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F13868	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Water Closet		Control force	5	Yes					n/a	$ -	
F13869	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F13870	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F13871	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Grab Bar	Vertical	Diameter	1.5	Yes					n/a	$ -	
F13872	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	8.5	Yes					n/a	$ -	
F13873	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	40.25	Yes					n/a	$ -	
F13874	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Signage		Dimension, characters	4.75	Yes					n/a	$ -	
F13875	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13876	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F13877	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Counter		Dimension, knee clearance	28.75	Yes					n/a	$ -	
F13878	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	28.75	Yes					n/a	$ -	
F13879	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F13880	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Water Closet		Dimension, wide side	42	Yes					n/a	$ -	
F13881	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F13882	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F13883	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F13884	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F13885	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Toilet Compartment		Hardware type	L	Yes					n/a	$ -	
F13886	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Coat Hook		Height	46	Yes					n/a	$ -	
F13887	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Counter		Height	34	Yes					n/a	$ -	
F13888	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Dispenser	PT	Height	44	Yes					n/a	$ -	
F13889	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Dispenser	TP	Height	19	Yes					n/a	$ -	
F13890	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Dispenser	Soap	Height	41.75	Yes					n/a	$ -	
F13891	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F13892	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Changing Station		Height	33	Yes					n/a	$ -	
F13893	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Mirror		Height, bottom	37.75	Yes					n/a	$ -	
F13894	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Signage		Height, bottom	56.25	Yes					n/a	$ -	
F13895	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Water Closet		Height, flush control	27	Yes					n/a	$ -	
F13896	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F13897	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F13898	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Grab Bar	Rear	Height, top	34	Yes					n/a	$ -	
F13899	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Grab Bar	Side	Height, top	34	Yes					n/a	$ -	
F13900	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F13901	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F13902	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Counter		Length	58	Yes					n/a	$ -	
F13903	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F13904	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F13905	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Grab Bar	Vertical	Length	18	Yes					n/a	$ -	
F13906	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F13907	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F13908	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F13909	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F13910	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Fixture Count		Number, toilet compartments	2	Yes					n/a	$ -	
F13911	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F13912	Justice Center		5th Floor	Owned	Restroom	Women's - #504	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F13921	Justice Center		5th Floor	Owned	Restroom	Women's - #514	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F13922	Justice Center		5th Floor	Owned	Restroom	Women's - #514	1-Public Unsupervised	Door Gate		Clearance, pull parallel	19	Yes					n/a	$ -	
F13923	Justice Center		5th Floor	Owned	Restroom	Women's - #514	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F13924	Justice Center		5th Floor	Owned	Restroom	Women's - #514	1-Public Unsupervised	Door Gate		Clearance, push parallel	24	Yes					n/a	$ -	
F13925	Justice Center		5th Floor	Owned	Restroom	Women's - #514	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F13926	Justice Center		5th Floor	Owned	Restroom	Women's - #514	1-Public Unsupervised	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F13927	Justice Center		5th Floor	Owned	Restroom	Women's - #514	1-Public Unsupervised	Signage		Dimension, characters	0.75	Yes					n/a	$ -	
F13928	Justice Center		5th Floor	Owned	Restroom	Women's - #514	1-Public Unsupervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F13929	Justice Center		5th Floor	Owned	Restroom	Women's - #514	1-Public Unsupervised	Signage		Height, bottom	58	Yes					n/a	$ -	
F13930	Justice Center		5th Floor	Owned	Restroom	Women's - #514	1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F13931	Justice Center		5th Floor	Owned	Restroom	Women's - #514	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F13932	Justice Center		5th Floor	Owned	Restroom	Women's - #514	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F13963	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F13964	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Toilet Compartment		Clear opening	32	Yes					n/a	$ -	
F13965	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Toilet Compartment		Clearance, outside	99	Yes					n/a	$ -	
F13966	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Coat Hook		Clearance, parallel	OK	Yes					n/a	$ -	
F13967	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F13968	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Dispenser	PT	Clearance, parallel	99	Yes					n/a	$ -	
F13969	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	99	Yes					n/a	$ -	
F13970	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Changing Station		Clearance, parallel	99	Yes					n/a	$ -	
F13971	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Water Closet		Clearance, parallel	60	Yes					n/a	$ -	
F13972	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Coat Hook		Clearance, perpendicular	OK	Yes					n/a	$ -	
F13973	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Counter		Clearance, perpendicular	59.5	Yes					n/a	$ -	
F13974	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	59.5	Yes					n/a	$ -	
F13975	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Changing Station		Clearance, perpendicular	60	Yes					n/a	$ -	
F13976	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Water Closet		Clearance, perpendicular	72	Yes					n/a	$ -	
F13977	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Door Gate		Clearance, pull parallel	24	Yes					n/a	$ -	
F13978	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F13979	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Door Gate		Clearance, push parallel	24	Yes					n/a	$ -	
F13980	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F13981	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F13982	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F13983	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Door Gate		Clearance, vertical	93	Yes					n/a	$ -	
F13984	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Water Closet		Control force	5	Yes					n/a	$ -	
F13985	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F13986	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F13987	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	7	Yes					n/a	$ -	
F13988	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Signage		Dimension, characters	5	Yes					n/a	$ -	
F13989	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4	Yes					n/a	$ -	
F13990	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F13991	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Counter		Dimension, knee clearance	29.5	Yes					n/a	$ -	
F13992	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29.5	Yes					n/a	$ -	
F13993	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Water Closet		Dimension, wide side	41.5	Yes					n/a	$ -	
F13994	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F13995	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F13996	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F13997	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F13998	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Toilet Compartment		Hardware type	L	Yes					n/a	$ -	
F13999	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Alarm System		Height	87	Yes					n/a	$ -	
F14000	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Dispenser	PT	Height	46	Yes					n/a	$ -	
F14001	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Dispenser	TP	Height	20	Yes					n/a	$ -	
F14002	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Dispenser	Soap	Height	42.5	Yes					n/a	$ -	
F14003	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Mirror		Height, bottom	39	Yes					n/a	$ -	
F14004	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Signage		Height, bottom	58.5	Yes					n/a	$ -	
F14005	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Water Closet		Height, flush control	26	Yes					n/a	$ -	
F14006	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F14007	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F14008	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F14009	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F14010	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F14011	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14012	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Counter		Length	56.5	Yes					n/a	$ -	
F14013	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F14014	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F14015	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F14016	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F14017	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F14018	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F14019	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Fixture Count		Number, toilet compartments	2	Yes					n/a	$ -	
F14020	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Fixture Count		Number, urinals	0	Yes					n/a	$ -	
F14021	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F14022	Justice Center		5th Floor	Owned	Restroom	Women's - #555	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F14038	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F14039	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Toilet Compartment		Clear opening	32.5	Yes					n/a	$ -	
F14040	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Toilet Compartment		Clearance, outside	39.25	Yes					n/a	$ -	
F14041	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Door Gate		Clearance, pull parallel	18	Yes					n/a	$ -	
F14042	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F14043	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Door Gate		Clearance, push parallel	24	Yes					n/a	$ -	
F14044	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F14045	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Door Gate		Clearance, vertical	93	Yes					n/a	$ -	
F14046	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F14047	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	7.5	Yes					n/a	$ -	
F14048	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F14049	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29.5	Yes					n/a	$ -	
F14050	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F14051	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Water Closet		Dimension, wide side	42.5	Yes					n/a	$ -	
F14052	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F14053	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F14054	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F14055	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Alarm System		Height	89.5	Yes					n/a	$ -	
F14056	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Dispenser	Soap	Height	44	Yes					n/a	$ -	
F14057	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Dispenser	PT	Height	47	Yes					n/a	$ -	
F14058	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Mirror		Height, bottom	38.5	Yes					n/a	$ -	
F14059	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Water Closet		Height, seat	17.25	Yes					n/a	$ -	
F14060	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F14061	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F14062	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F14063	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F14064	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F14065	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F14066	Justice Center		6th Floor	Owned	Restroom	Women's - #617	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F14084	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F14085	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Toilet Compartment		Clear opening	32.25	Yes					n/a	$ -	
F14086	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Toilet Compartment		Clearance, outside	39	Yes					n/a	$ -	
F14087	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	64	Yes					n/a	$ -	
F14088	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	97.5	Yes					n/a	$ -	
F14089	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Door Gate		Clearance, pull parallel	18	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14090	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F14091	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Door Gate		Clearance, push parallel	22	Yes					n/a	$ -	
F14092	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F14093	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Door Gate		Clearance, vertical	93	Yes					n/a	$ -	
F14094	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F14095	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	8.5	Yes					n/a	$ -	
F14096	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F14097	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F14098	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Water Closet		Dimension, wide side	42.75	Yes					n/a	$ -	
F14099	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F14100	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F14101	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Alarm System		Height	89	Yes					n/a	$ -	
F14102	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Dispenser	TP	Height	21	Yes					n/a	$ -	
F14103	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Dispenser	PT	Height	47	Yes					n/a	$ -	
F14104	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Dispenser	Soap	Height	44	Yes					n/a	$ -	
F14105	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Mirror		Height, bottom	38.5	Yes					n/a	$ -	
F14106	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Water Closet		Height, flush control	27	Yes					n/a	$ -	
F14107	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Water Closet		Height, seat	17.5	Yes					n/a	$ -	
F14108	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	13	Yes					n/a	$ -	
F14109	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F14110	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F14111	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F14112	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F14113	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F14114	Justice Center		6th Floor	Owned	Restroom	Women's - #655	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F14126	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Toilet Compartment		Clear opening	32	Yes					n/a	$ -	
F14127	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Toilet Compartment		Clearance, outside	71	Yes					n/a	$ -	
F14128	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	60	Yes					n/a	$ -	
F14129	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	61	Yes					n/a	$ -	
F14130	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Water Closet		Clearance, parallel	61	Yes					n/a	$ -	
F14131	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	60	Yes					n/a	$ -	
F14132	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Water Closet		Clearance, perpendicular	61	Yes					n/a	$ -	
F14133	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F14134	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Grab Bar	Vertical	Clearance, to wall	1.5	Yes					n/a	$ -	
F14135	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F14136	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Water Closet		Control force	OK	Yes					n/a	$ -	
F14137	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F14138	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Grab Bar	Vertical	Diameter	1.5	Yes					n/a	$ -	
F14139	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F14140	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	8.5	Yes					n/a	$ -	
F14141	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	40.5	Yes					n/a	$ -	
F14142	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F14143	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F14144	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	27.25	Yes					n/a	$ -	
F14145	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F14146	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Water Closet		Dimension, wide side	42.25	Yes					n/a	$ -	
F14147	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Toilet Compartment		Door swing direction	Out	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14148	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F14149	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	Y	Yes					n/a	$ -	
F14150	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F14151	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Toilet Compartment		Hardware type	PP	Yes					n/a	$ -	
F14152	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Coat Hook		Height	46	Yes					n/a	$ -	
F14153	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Dispenser	TP	Height	19	Yes					n/a	$ -	
F14154	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Dispenser	Soap	Height	39.5	Yes					n/a	$ -	
F14155	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Dispenser	PT	Height	45	Yes					n/a	$ -	
F14156	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Lavatory Sink		Height	32.5	Yes					n/a	$ -	
F14157	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Mirror		Height, bottom	37	Yes					n/a	$ -	
F14158	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Water Closet		Height, flush control	27	Yes					n/a	$ -	
F14159	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Water Closet		Height, seat	18.5	Yes					n/a	$ -	
F14160	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F14161	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Grab Bar	Vertical	Height, top	40.25	Yes					n/a	$ -	
F14162	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Grab Bar	Side	Height, top	33.75	Yes					n/a	$ -	
F14163	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Grab Bar	Rear	Height, top	33.75	Yes					n/a	$ -	
F14164	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F14165	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Grab Bar	Vertical	Length	18	Yes					n/a	$ -	
F14166	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F14167	Justice Center		Interior	Owned	Restroom	Women's - #S106	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F14188	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F14189	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Toilet Compartment		Clear opening	32	Yes					n/a	$ -	
F14190	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Toilet Compartment		Clearance, outside	46	Yes					n/a	$ -	
F14191	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	58	Yes					n/a	$ -	
F14192	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F14193	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	84	Yes					n/a	$ -	
F14194	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	89	Yes					n/a	$ -	
F14195	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Door Gate		Clearance, pull parallel	24	Yes					n/a	$ -	
F14196	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F14197	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Door Gate		Clearance, push parallel	24	Yes					n/a	$ -	
F14198	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F14199	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F14200	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F14201	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Grab Bar	Vertical	Clearance, to wall	1.5	Yes					n/a	$ -	
F14202	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F14203	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Water Closet		Control force	2	Yes					n/a	$ -	
F14204	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F14205	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F14206	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Grab Bar	Vertical	Diameter	1.5	Yes					n/a	$ -	
F14207	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	9	Yes					n/a	$ -	
F14208	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	3.5	Yes					n/a	$ -	
F14209	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F14210	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F14211	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Water Closet		Dimension, sidewall	17	Yes					n/a	$ -	
F14212	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Water Closet		Dimension, wide side	43	Yes					n/a	$ -	
F14213	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F14214	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F14215	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F14216	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Toilet Compartment		Hardware type	L	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14217	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Coat Hook		Height	42	Yes					n/a	$ -	
F14218	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Dispenser	TP	Height	19.5	Yes					n/a	$ -	
F14219	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Dispenser	PT	Height	43	Yes					n/a	$ -	
F14220	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Dispenser	Soap	Height	42	Yes					n/a	$ -	
F14221	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F14222	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Changing Station		Height	33	Yes					n/a	$ -	
F14223	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Mirror		Height, bottom	39	Yes					n/a	$ -	
F14224	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Signage		Height, bottom	56.5	Yes					n/a	$ -	
F14225	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Water Closet		Height, flush control	27	Yes					n/a	$ -	
F14226	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Door Gate		Height, hardware	OK	Yes					n/a	$ -	
F14227	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F14228	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F14229	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F14230	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Grab Bar	Rear	Height, top	34	Yes					n/a	$ -	
F14231	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Grab Bar	Side	Height, top	34	Yes					n/a	$ -	
F14232	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F14233	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F14234	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F14235	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Grab Bar	Vertical	Length	18	Yes					n/a	$ -	
F14236	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F14237	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F14238	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F14239	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F14240	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Fixture Count		Number, toilet compartments	2	Yes					n/a	$ -	
F14241	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Fixture Count		Number, urinals	0	Yes					n/a	$ -	
F14242	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F14243	Justice Center		4th Floor	Owned	Restroom	Women's - #S404	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F14247	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	40.5	Yes					n/a	$ -	
F14259	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F14260	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Toilet Compartment		Clear opening	32	Yes					n/a	$ -	
F14261	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Toilet Compartment		Clearance, outside	45	Yes					n/a	$ -	
F14262	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F14263	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	89	Yes					n/a	$ -	
F14264	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Door Gate		Clearance, pull parallel	24	Yes					n/a	$ -	
F14265	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F14266	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Door Gate		Clearance, push parallel	24	Yes					n/a	$ -	
F14267	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F14268	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F14269	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Water Closet		Control force	1	Yes					n/a	$ -	
F14270	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	8	Yes					n/a	$ -	
F14271	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	3.25	Yes					n/a	$ -	
F14272	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F14273	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F14274	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F14275	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F14276	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Water Closet		Dimension, wide side	42.25	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14277	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F14278	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F14279	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F14280	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Coat Hook		Height	46	Yes					n/a	$ -	
F14281	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Counter		Height	32.75	Yes					n/a	$ -	
F14282	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Dispenser	PT	Height	45	Yes					n/a	$ -	
F14283	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Dispenser	Soap	Height	43	Yes					n/a	$ -	
F14284	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F14285	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Mirror		Height, bottom	38	Yes					n/a	$ -	
F14286	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Water Closet		Height, flush control	27	Yes					n/a	$ -	
F14287	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F14288	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F14289	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F14290	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F14291	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F14292	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F14293	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Grab Bar	Vertical	Length	18	Yes					n/a	$ -	
F14294	Justice Center		6th Floor	Owned	Restroom	Women's - #S604	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F14313	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F14314	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Lavatory Sink		Clearance, parallel	60	Yes					n/a	$ -	
F14315	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Lavatory Sink		Clearance, perpendicular	84	Yes					n/a	$ -	
F14316	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Water Closet		Clearance, perpendicular	87	Yes					n/a	$ -	
F14317	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	1-Public Unsupervised	Door Gate		Clearance, pull parallel	79	Yes					n/a	$ -	
F14318	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	67.5	Yes					n/a	$ -	
F14319	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	1-Public Unsupervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F14320	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	69.75	Yes					n/a	$ -	
F14321	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F14322	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F14323	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Grab Bar	Vertical	Clearance, to wall	1.5	Yes					n/a	$ -	
F14324	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	1-Public Unsupervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F14325	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	1-Public Unsupervised	Door Gate		Closing speed	6	Yes					n/a	$ -	
F14326	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Water Closet		Control force	OK	Yes					n/a	$ -	
F14327	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F14328	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F14329	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Grab Bar	Vertical	Diameter	1.5	Yes					n/a	$ -	
F14330	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Dispenser	TP	Dimension from water closet seat	8.5	Yes					n/a	$ -	
F14331	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	40	Yes					n/a	$ -	
F14332	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	1-Public Unsupervised	Signage		Dimension, characters	4.75	Yes					n/a	$ -	
F14333	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F14334	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Lavatory Sink		Dimension, knee clearance	30.5	Yes					n/a	$ -	
F14335	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F14336	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14337	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F14338	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Dispenser	Soap	Height	45	Yes					n/a	$ -	
F14339	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Dispenser	PT	Height	45	Yes					n/a	$ -	
F14340	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Dispenser	TP	Height	19	Yes					n/a	$ -	
F14341	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Lavatory Sink		Height	34	Yes					n/a	$ -	
F14342	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	1-Public Unsupervised	Signage		Height, bottom	56.75	Yes					n/a	$ -	
F14343	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Water Closet		Height, flush control	26.5	Yes					n/a	$ -	
F14344	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Water Closet		Height, seat	19	Yes					n/a	$ -	
F14345	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	14.5	Yes					n/a	$ -	
F14346	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Grab Bar	Side	Height, top	34.75	Yes					n/a	$ -	
F14347	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F14348	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F14349	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F14350	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F14351	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Grab Bar	Vertical	Length	18	Yes					n/a	$ -	
F14352	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F14353	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F14354	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F14355	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	1-Public Unsupervised	Fixture Count		Number, toilet compartments	4	Yes					n/a	$ -	
F14356	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F14357	Justice Center		Interior	Owned	Restroom	Women's - Locker Room #S011	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F15682	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F15683	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Counter		Clearance, parallel	31	Yes					n/a	$ -	
F15684	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Public Phone		Clearance, parallel	31	Yes					n/a	$ -	
F15685	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F15686	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Public Phone		Clearance, perpendicular	99	Yes					n/a	$ -	
F15687	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Door Gate		Clearance, pull parallel	62	Yes					n/a	$ -	
F15688	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F15689	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Door Gate		Clearance, push parallel	60	Yes					n/a	$ -	
F15690	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Door Gate		Clearance, push perpendicular	55	Yes					n/a	$ -	
F15691	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Door Gate		Clearance, vertical	85	Yes					n/a	$ -	
F15692	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Counter		Dimension, knee clearance	30.5	Yes					n/a	$ -	
F15693	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Door Gate		Hardware type	Keyed	Yes					n/a	$ -	
F15694	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Counter		Height	32	Yes					n/a	$ -	
F15695	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Public Phone		Height, operable part	47	Yes					n/a	$ -	
F15696	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F15697	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Counter		Length	72	Yes					n/a	$ -	
F15698	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Public Phone		Length, handset cord	32.5	Yes					n/a	$ -	
F15699	Justice Center		Interior	Owned	Visiting Area	Juvenile	2-Public Supervised	Door Gate		Opening force	4	Yes					n/a	$ -	
F16300	Justice Center		Exterior	Owned	Walkway	Main Entrance	1-Public Unsupervised	Door Gate		Threshold beveled?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16329	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#2	Accumulates water?	N	Yes					n/a	$ -	
F16330	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#1	Accumulates water?	N	Yes					n/a	$ -	
F16331	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#3	Accumulates water?	N	Yes					n/a	$ -	
F16332	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#4	Accumulates water?	N	Yes					n/a	$ -	
F16333	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#5	Accumulates water?	N	Yes					n/a	$ -	
F16334	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#6	Accumulates water?	N	Yes					n/a	$ -	
F16335	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#7	Accumulates water?	N	Yes					n/a	$ -	
F16336	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#8	Accumulates water?	N	Yes					n/a	$ -	
F16337	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#9	Accumulates water?	N	Yes					n/a	$ -	
F16338	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#10	Accumulates water?	N	Yes					n/a	$ -	
F16339	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Landing	Curb ramp #10	Clearance, parallel	60	Yes					n/a	$ -	
F16340	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Landing	Curb ramp #10	Clearance, perpendicular	53.5	Yes					n/a	$ -	
F16341	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#1	Landing, parallel dimension	71	Yes					n/a	$ -	
F16342	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#2	Landing, parallel dimension	72	Yes					n/a	$ -	
F16343	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#3	Landing, parallel dimension	72	Yes					n/a	$ -	
F16344	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#4	Landing, parallel dimension	72	Yes					n/a	$ -	
F16345	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#5	Landing, parallel dimension	72	Yes					n/a	$ -	
F16346	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#6	Landing, parallel dimension	72	Yes					n/a	$ -	
F16347	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#7	Landing, parallel dimension	72	Yes					n/a	$ -	
F16348	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#8	Landing, parallel dimension	72	Yes					n/a	$ -	
F16349	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#9	Landing, parallel dimension	72	Yes					n/a	$ -	
F16350	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#10	Landing, parallel dimension	72	Yes					n/a	$ -	
F16351	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#1	Landing, perpendicular dimension	60	Yes					n/a	$ -	
F16352	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#2	Landing, perpendicular dimension	99	Yes					n/a	$ -	
F16353	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#3	Landing, perpendicular dimension	60	Yes					n/a	$ -	
F16354	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#4	Landing, perpendicular dimension	54.5	Yes					n/a	$ -	
F16355	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#5	Landing, perpendicular dimension	61	Yes					n/a	$ -	
F16356	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#6	Landing, perpendicular dimension	61	Yes					n/a	$ -	
F16357	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#7	Landing, perpendicular dimension	69.5	Yes					n/a	$ -	
F16358	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#8	Landing, perpendicular dimension	62	Yes					n/a	$ -	
F16359	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#9	Landing, perpendicular dimension	71	Yes					n/a	$ -	
F16360	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#10	Landing, perpendicular dimension	53.5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16361	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#1	Landing?	Y	Yes					n/a	$ -	
F16362	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#2	Landing?	Y	Yes					n/a	$ -	
F16363	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#3	Landing?	Y	Yes					n/a	$ -	
F16364	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#4	Landing?	Y	Yes					n/a	$ -	
F16365	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#5	Landing?	Y	Yes					n/a	$ -	
F16366	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#6	Landing?	Y	Yes					n/a	$ -	
F16367	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#7	Landing?	Y	Yes					n/a	$ -	
F16368	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#8	Landing?	Y	Yes					n/a	$ -	
F16369	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#9	Landing?	Y	Yes					n/a	$ -	
F16370	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#10	Landing?	Y	Yes					n/a	$ -	
F16371	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#4	Slope, counter	0.6%	Yes					n/a	$ -	
F16372	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#8	Slope, counter	1.0%	Yes					n/a	$ -	
F16373	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#6	Slope, counter	1.4%	Yes					n/a	$ -	
F16374	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#2	Slope, counter	1.8%	Yes					n/a	$ -	
F16375	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#7	Slope, counter	2.5%	Yes					n/a	$ -	
F16376	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#10	Slope, counter	2.8%	Yes					n/a	$ -	
F16377	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#5	Slope, counter	3.6%	Yes					n/a	$ -	
F16378	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#9	Slope, counter	4.2%	Yes					n/a	$ -	
F16379	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#4	Slope, cross	0.0%	Yes					n/a	$ -	
F16380	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#8	Slope, cross	0.3%	Yes					n/a	$ -	
F16381	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#2	Slope, cross	0.7%	Yes					n/a	$ -	
F16382	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#7	Slope, cross	1.1%	Yes					n/a	$ -	
F16383	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#9	Slope, cross	1.1%	Yes					n/a	$ -	
F16384	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#1	Slope, cross	1.4%	Yes					n/a	$ -	
F16385	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#5	Slope, cross	1.4%	Yes					n/a	$ -	
F16386	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#6	Slope, cross	1.8%	Yes					n/a	$ -	
F16387	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#3	Slope, cross	1.9%	Yes					n/a	$ -	
F16388	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#1	Slope, left flare	0.5%	Yes					n/a	$ -	
F16389	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#8	Slope, left flare	1.2%	Yes					n/a	$ -	
F16390	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#6	Slope, left flare	3.8%	Yes					n/a	$ -	
F16391	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#10	Slope, left flare	6.7%	Yes					n/a	$ -	
F16392	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#2	Slope, left flare	8.5%	Yes					n/a	$ -	
F16393	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#4	Slope, left flare	4.9%	Yes					n/a	$ -	
F16394	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#3	Slope, left flare	0.0%	Yes					n/a	$ -	
F16395	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#5	Slope, left flare	0.0%	Yes					n/a	$ -	
F16396	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#7	Slope, left flare	0.0%	Yes					n/a	$ -	
F16397	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#9	Slope, left flare	0.0%	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16398	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#9	Slope, right flare	0.1%	Yes					n/a	$ -	
F16399	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#10	Slope, right flare	3.0%	Yes					n/a	$ -	
F16400	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#7	Slope, right flare	4.5%	Yes					n/a	$ -	
F16401	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#2	Slope, right flare	8.0%	Yes					n/a	$ -	
F16402	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#5	Slope, right flare	2.8%	Yes					n/a	$ -	
F16403	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#3	Slope, right flare	4.0%	Yes					n/a	$ -	
F16404	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#4	Slope, right flare	0.0%	Yes					n/a	$ -	
F16405	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#6	Slope, right flare	0.0%	Yes					n/a	$ -	
F16406	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#8	Slope, right flare	0.0%	Yes					n/a	$ -	
F16407	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#1	Slope, running	2.1%	Yes					n/a	$ -	
F16408	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#7	Slope, running	2.4%	Yes					n/a	$ -	
F16409	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#3	Slope, running	3.1%	Yes					n/a	$ -	
F16410	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#9	Slope, running	5.8%	Yes					n/a	$ -	
F16411	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#2	Slope, running	6.4%	Yes					n/a	$ -	
F16412	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#8	Slope, running	7.3%	Yes					n/a	$ -	
F16413	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#5	Slope, running	7.7%	Yes					n/a	$ -	
F16414	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#4	Slope, running	8.0%	Yes					n/a	$ -	
F16415	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#3	Surface material	Concrete	Yes					n/a	$ -	
F16416	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#4	Surface material	Concrete	Yes					n/a	$ -	
F16417	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#5	Surface material	Concrete	Yes					n/a	$ -	
F16418	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#6	Surface material	Concrete	Yes					n/a	$ -	
F16419	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#7	Surface material	Concrete	Yes					n/a	$ -	
F16420	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#8	Surface material	Concrete	Yes					n/a	$ -	
F16421	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#9	Surface material	Concrete	Yes					n/a	$ -	
F16422	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#10	Surface material	Concrete	Yes					n/a	$ -	
F16423	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#10	Width	60	Yes					n/a	$ -	
F16424	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#1	Width	72	Yes					n/a	$ -	
F16425	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#2	Width	72	Yes					n/a	$ -	
F16426	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#3	Width	72	Yes					n/a	$ -	
F16427	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#4	Width	72	Yes					n/a	$ -	
F16428	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#5	Width	72	Yes					n/a	$ -	
F16429	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#6	Width	72	Yes					n/a	$ -	
F16430	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#7	Width	72	Yes					n/a	$ -	
F16431	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#8	Width	72	Yes					n/a	$ -	
F16432	Justice Center		Exterior	Owned	Walkway	From Bus Stop to main entrance	1-Public Unsupervised	Curb Ramp	#9	Width	72	Yes					n/a	$ -	
F16447	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#1	Accumulates water?	N	Yes					n/a	$ -	
F16448	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#2	Accumulates water?	N	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16449	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#3	Accumulates water?	N	Yes					n/a	$ -	
F16450	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#4	Accumulates water?	N	Yes					n/a	$ -	
F16451	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#12	Accumulates water?	N	Yes					n/a	$ -	
F16452	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#13	Accumulates water?	N	Yes					n/a	$ -	
F16453	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#1	Landing, parallel dimension	72	Yes					n/a	$ -	
F16454	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#2	Landing, parallel dimension	72	Yes					n/a	$ -	
F16455	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#3	Landing, parallel dimension	95	Yes					n/a	$ -	
F16456	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#4	Landing, parallel dimension	95	Yes					n/a	$ -	
F16457	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#12	Landing, parallel dimension	92	Yes					n/a	$ -	
F16458	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#13	Landing, parallel dimension	93	Yes					n/a	$ -	
F16459	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#1	Landing, perpendicular dimension	84	Yes					n/a	$ -	
F16460	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#2	Landing, perpendicular dimension	55.5	Yes					n/a	$ -	
F16461	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#3	Landing, perpendicular dimension	90	Yes					n/a	$ -	
F16462	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#4	Landing, perpendicular dimension	60	Yes					n/a	$ -	
F16463	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#12	Landing, perpendicular dimension	95	Yes					n/a	$ -	
F16464	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#13	Landing, perpendicular dimension	86.5	Yes					n/a	$ -	
F16465	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#1	Landing?	Y	Yes					n/a	$ -	
F16466	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#2	Landing?	Y	Yes					n/a	$ -	
F16467	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#3	Landing?	Y	Yes					n/a	$ -	
F16468	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#4	Landing?	Y	Yes					n/a	$ -	
F16469	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#12	Landing?	Y	Yes					n/a	$ -	
F16470	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#13	Landing?	Y	Yes					n/a	$ -	
F16471	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#13	Slope, counter	1.0%	Yes					n/a	$ -	
F16472	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#12	Slope, counter	1.8%	Yes					n/a	$ -	
F16473	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#1	Slope, counter	2.2%	Yes					n/a	$ -	
F16474	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#2	Slope, counter	2.3%	Yes					n/a	$ -	
F16475	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#3	Slope, counter	4.1%	Yes					n/a	$ -	
F16476	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#3	Slope, cross	0.2%	Yes					n/a	$ -	
F16477	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#1	Slope, cross	0.6%	Yes					n/a	$ -	
F16478	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#12	Slope, cross	1.4%	Yes					n/a	$ -	
F16479	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#2	Slope, cross	1.6%	Yes					n/a	$ -	
F16480	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#4	Slope, cross	2.0%	Yes					n/a	$ -	
F16481	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#13	Slope, cross	2.0%	Yes					n/a	$ -	
F16482	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#12	Slope, left flare	3.8%	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16483	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#13	Slope, left flare	4.6%	Yes					n/a	$ -	
F16484	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#2	Slope, left flare	6.5%	Yes					n/a	$ -	
F16485	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#3	Slope, left flare	8.4%	Yes					n/a	$ -	
F16486	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#1	Slope, left flare	0.0%	Yes					n/a	$ -	
F16487	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#4	Slope, left flare	0.0%	Yes					n/a	$ -	
F16488	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#12	Slope, right flare	5.0%	Yes					n/a	$ -	
F16489	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#13	Slope, right flare	5.9%	Yes					n/a	$ -	
F16490	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#1	Slope, right flare	7.5%	Yes					n/a	$ -	
F16491	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#2	Slope, right flare	0.0%	Yes					n/a	$ -	
F16492	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#4	Slope, right flare	0.0%	Yes					n/a	$ -	
F16493	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#13	Slope, running	5.9%	Yes					n/a	$ -	
F16494	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#2	Slope, running	6.3%	Yes					n/a	$ -	
F16495	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#4	Slope, running	8.0%	Yes					n/a	$ -	
F16496	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#1	Surface material	Concrete	Yes					n/a	$ -	
F16497	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#2	Surface material	Concrete	Yes					n/a	$ -	
F16498	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#3	Surface material	Concrete	Yes					n/a	$ -	
F16499	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#4	Surface material	Concrete	Yes					n/a	$ -	
F16500	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#12	Surface material	Concrete	Yes					n/a	$ -	
F16501	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#13	Surface material	Concrete	Yes					n/a	$ -	
F16502	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#1	Width	72	Yes					n/a	$ -	
F16503	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#2	Width	72	Yes					n/a	$ -	
F16504	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#12	Width	92	Yes					n/a	$ -	
F16505	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#13	Width	92	Yes					n/a	$ -	
F16506	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#3	Width	95	Yes					n/a	$ -	
F16507	Justice Center		Exterior	Owned	Walkway	From West parking lot to entrance	1-Public Unsupervised	Curb Ramp	#4	Width	95	Yes					n/a	$ -	
F16515	Justice Center		Exterior	Owned	Walkway	Main Entrance	1-Public Unsupervised	Door Gate		Clear opening	33.25	Yes					n/a	$ -	
F16516	Justice Center		Exterior	Owned	Walkway	Main Entrance	1-Public Unsupervised	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F16517	Justice Center		Exterior	Owned	Walkway	Main Entrance	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F16518	Justice Center		Exterior	Owned	Walkway	Main Entrance	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	OK	Yes					n/a	$ -	
F16519	Justice Center		Exterior	Owned	Walkway	Main Entrance	1-Public Unsupervised	Door Gate		Clearance, series doors	80	Yes					n/a	$ -	
F16520	Justice Center		Exterior	Owned	Walkway	Main Entrance	1-Public Unsupervised	Door Gate		Clearance, vertical	99	Yes					n/a	$ -	
F16521	Justice Center		Exterior	Owned	Walkway	Main Entrance	1-Public Unsupervised	Door Gate		Closing speed	12	Yes					n/a	$ -	
F16522	Justice Center		Exterior	Owned	Walkway	Main Entrance	1-Public Unsupervised	Door Gate		Hardware type	Auto	Yes					n/a	$ -	
F16523	Justice Center		Exterior	Owned	Walkway	Main Entrance	1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	11.25	Yes					n/a	$ -	
F16524	Justice Center		Exterior	Owned	Walkway	Main Entrance	1-Public Unsupervised	Door Gate		Opening force	Auto	Yes					n/a	$ -	
F16526	Justice Center		Exterior	Owned	Walkway	Same Bus Stop as DA Bldg	1-Public Unsupervised	Walking Surface		Slope, running	3.7%	Yes					n/a	$ -	
F16527	Justice Center		Exterior	Owned	Walkway	Same Bus Stop as DA Bldg	1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F16528	Justice Center		Exterior	Owned	Walkway	Same Bus Stop as DA Bldg	1-Public Unsupervised	Walking Surface		Width	72	Yes					n/a	$ -	
F16809	Justice Center	CASA	Interior	Owned	Work Area	#309 - Office	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16810	Justice Center	CASA	Interior	Owned	Work Area	#309 - Office	1-Public Unsupervised	Door Gate		Clearance, pull parallel	24	Yes					n/a	$ -	
F16811	Justice Center	CASA	Interior	Owned	Work Area	#309 - Office	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	84	Yes					n/a	$ -	
F16812	Justice Center	CASA	Interior	Owned	Work Area	#309 - Office	1-Public Unsupervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F16813	Justice Center	CASA	Interior	Owned	Work Area	#309 - Office	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F16814	Justice Center	CASA	Interior	Owned	Work Area	#309 - Office	1-Public Unsupervised	Door Gate		Clearance, vertical	93	Yes					n/a	$ -	
F16815	Justice Center	CASA	Interior	Owned	Work Area	#309 - Office	1-Public Unsupervised	Signage		Dimension, characters	0.75	Yes					n/a	$ -	
F16816	Justice Center	CASA	Interior	Owned	Work Area	#309 - Office	1-Public Unsupervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F16817	Justice Center	CASA	Interior	Owned	Work Area	#309 - Office	1-Public Unsupervised	Signage		Height, bottom	59	Yes					n/a	$ -	
F16818	Justice Center	CASA	Interior	Owned	Work Area	#309 - Office	1-Public Unsupervised	Signage		ISA?	N	Yes					n/a	$ -	
F16819	Justice Center	CASA	Interior	Owned	Work Area	#309 - Office	1-Public Unsupervised	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F16820	Justice Center	CASA	Interior	Owned	Work Area	#309 - Office	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F16821	Justice Center		3rd Floor	Owned	Work Area	#305 - Staff Area	3-Employee Common	Door Gate		Threshold beveled?	Y	Yes					n/a	$ -	
F16831	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F16832	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Counter		Clearance, parallel	84	Yes					n/a	$ -	
F16833	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Counter	L-shaped	Clearance, parallel	OK	Yes					n/a	$ -	
F16834	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Counter		Clearance, perpendicular	99	Yes					n/a	$ -	
F16835	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Counter	L-shaped	Clearance, perpendicular	OK	Yes					n/a	$ -	
F16836	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Door Gate		Clearance, pull parallel	93	Yes					n/a	$ -	
F16837	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F16838	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F16839	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F16840	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Door Gate		Clearance, vertical	93	Yes					n/a	$ -	
F16841	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F16842	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Counter		Dimension, knee clearance	40.25	Yes					n/a	$ -	
F16843	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Counter	L-shaped	Dimension, knee clearance	40	Yes					n/a	$ -	
F16844	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F16845	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F16846	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Counter		Length	84	Yes					n/a	$ -	
F16847	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Counter	L-shaped	Length	99	Yes					n/a	$ -	
F16848	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Counter	L-shaped	Other attribute	24	Yes					n/a	$ -	
F16849	Justice Center		Interior	Owned	Work Area	#107 - File Room	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F16859	Justice Center		3rd Floor	Owned	Work Area	#305 - Staff Area	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F16860	Justice Center		3rd Floor	Owned	Work Area	#305 - Staff Area	3-Employee Common	Counter		Clearance, parallel	58	Yes					n/a	$ -	
F16861	Justice Center		3rd Floor	Owned	Work Area	#305 - Staff Area	3-Employee Common	Counter		Clearance, perpendicular	72	Yes					n/a	$ -	
F16862	Justice Center		3rd Floor	Owned	Work Area	#305 - Staff Area	3-Employee Common	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F16863	Justice Center		3rd Floor	Owned	Work Area	#305 - Staff Area	3-Employee Common	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F16864	Justice Center		3rd Floor	Owned	Work Area	#305 - Staff Area	3-Employee Common	Door Gate		Clearance, push parallel	22	Yes					n/a	$ -	
F16865	Justice Center		3rd Floor	Owned	Work Area	#305 - Staff Area	3-Employee Common	Door Gate		Clearance, push perpendicular	72	Yes					n/a	$ -	
F16866	Justice Center		3rd Floor	Owned	Work Area	#305 - Staff Area	3-Employee Common	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F16867	Justice Center		3rd Floor	Owned	Work Area	#305 - Staff Area	3-Employee Common	Counter		Dimension, knee clearance	40.5	Yes					n/a	$ -	
F16868	Justice Center		3rd Floor	Owned	Work Area	#305 - Staff Area	3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F16869	Justice Center		3rd Floor	Owned	Work Area	#305 - Staff Area	3-Employee Common	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F16870	Justice Center		3rd Floor	Owned	Work Area	#305 - Staff Area	3-Employee Common	Counter		Length	58	Yes					n/a	$ -	
F16893	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Signage		Braille?	Y	Yes					n/a	$ -	
F16894	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F16895	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate	Into Fire Vestibule	Clear opening	33	Yes					n/a	$ -	
F16896	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Clear opening	33.5	Yes					n/a	$ -	
F16897	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Counter		Clearance, parallel	58	Yes					n/a	$ -	
F16898	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Counter		Clearance, perpendicular	50	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16899	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Clearance, pull parallel	19.5	Yes					n/a	$ -	
F16900	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate	Into Fire Vestibule	Clearance, pull parallel	20	Yes					n/a	$ -	
F16901	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Clearance, pull parallel	30	Yes					n/a	$ -	
F16902	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F16903	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate	Into Fire Vestibule	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F16904	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F16905	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Clearance, push parallel	19.5	Yes					n/a	$ -	
F16906	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate	Into Fire Vestibule	Clearance, push parallel	99	Yes					n/a	$ -	
F16907	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Clearance, push parallel	17	Yes					n/a	$ -	
F16908	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F16909	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate	Into Fire Vestibule	Clearance, push perpendicular	60	Yes					n/a	$ -	
F16910	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Clearance, push perpendicular	50	Yes					n/a	$ -	
F16911	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F16912	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate	Into Fire Vestibule	Clearance, vertical	84	Yes					n/a	$ -	
F16913	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Clearance, vertical	92.5	Yes					n/a	$ -	
F16914	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Closing speed	5	Yes					n/a	$ -	
F16915	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Signage		Dimension, characters	0.75	Yes					n/a	$ -	
F16916	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Counter		Dimension, knee clearance	40.5	Yes					n/a	$ -	
F16917	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Hardware type	Panic bar	Yes					n/a	$ -	
F16918	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F16919	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Signage		Height, bottom	58	Yes					n/a	$ -	
F16920	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Signage		Height, bottom	58	Yes					n/a	$ -	
F16921	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Signage		Height, bottom	58	Yes					n/a	$ -	
F16922	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F16923	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Door Gate	Into Fire Vestibule	Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F16924	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Signage		ISA?	N	Yes					n/a	$ -	
F16925	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Signage		ISA?	N	Yes					n/a	$ -	
F16926	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Counter		Length	58.5	Yes					n/a	$ -	
F16927	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Signage		Location	L	Yes					n/a	$ -	
F16928	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F16929	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F16930	Justice Center		4th Floor	Owned	Work Area	#405 - Staff Area	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F16937	Justice Center		4th Floor	Owned	Work Area	#S426 - Trial Support Center Annex	2-Public Supervised	Door Gate		Clear opening	33.5	Yes					n/a	$ -	
F16938	Justice Center		4th Floor	Owned	Work Area	#S426 - Trial Support Center Annex	2-Public Supervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F16939	Justice Center		4th Floor	Owned	Work Area	#S426 - Trial Support Center Annex	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F16940	Justice Center		4th Floor	Owned	Work Area	#S426 - Trial Support Center Annex	2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F16941	Justice Center		4th Floor	Owned	Work Area	#S426 - Trial Support Center Annex	2-Public Supervised	Door Gate		Clearance, push perpendicular	62	Yes					n/a	$ -	
F16942	Justice Center		4th Floor	Owned	Work Area	#S426 - Trial Support Center Annex	2-Public Supervised	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F16943	Justice Center		4th Floor	Owned	Work Area	#S426 - Trial Support Center Annex	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F16944	Justice Center		4th Floor	Owned	Work Area	#S426 - Trial Support Center Annex	2-Public Supervised	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16953	Justice Center		Interior	Owned	Work Area	Off lobby	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F16954	Justice Center		Interior	Owned	Work Area	Off lobby	3-Employee Common	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F16955	Justice Center		Interior	Owned	Work Area	Off lobby	3-Employee Common	Door Gate		Clearance, push parallel	16.5	Yes					n/a	$ -	
F16956	Justice Center		Interior	Owned	Work Area	Off lobby	3-Employee Common	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F16957	Justice Center		Interior	Owned	Work Area	Off lobby	3-Employee Common	Door Gate		Clearance, vertical	91	Yes					n/a	$ -	
F16958	Justice Center		Interior	Owned	Work Area	Off lobby	3-Employee Common	Door Gate		Hardware type	Secure access	Yes					n/a	$ -	
F16959	Justice Center		Interior	Owned	Work Area	Off lobby	3-Employee Common	Signage		Height, bottom	58.5	Yes					n/a	$ -	
F16960	Justice Center		Interior	Owned	Work Area	Off lobby	3-Employee Common	Door Gate		Height, smooth surface (kick plate)	SD	Yes					n/a	$ -	
F16961	Justice Center		Interior	Owned	Work Area	Off lobby	3-Employee Common	Signage		ISA?	N	Yes					n/a	$ -	
F16962	Justice Center		Interior	Owned	Work Area	Off lobby	3-Employee Common	Signage		Location	L	Yes					n/a	$ -	
F06856	Lowell Street Trailhead		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, accessible	1	Yes					n/a	$ -	
F06857	Lowell Street Trailhead		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Sign?	Y	Yes					n/a	$ -	
F06858	Lowell Street Trailhead		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Slope, cross	0.7%	Yes					n/a	$ -	
F06859	Lowell Street Trailhead		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Slope, running	1.6%	Yes					n/a	$ -	
F06860	Lowell Street Trailhead		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Width	144	Yes					n/a	$ -	
F00700	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Break Room		3-Employee Common	Door Gate		Clear opening	32	Yes					n/a	$ -	
F00701	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Break Room		3-Employee Common	Counter		Clearance, parallel	60	Yes					n/a	$ -	
F00702	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Break Room		3-Employee Common	Counter		Clearance, perpendicular	60	Yes					n/a	$ -	
F00703	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Break Room		3-Employee Common	Door Gate		Clearance, vertical	81	Yes					n/a	$ -	
F00704	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Break Room		3-Employee Common	Counter		Dimension, knee clearance	0	Yes					n/a	$ -	
F00705	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Break Room		3-Employee Common	Door Gate		Height, hardware	38	Yes					n/a	$ -	
F00706	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Break Room		3-Employee Common	Counter		Length	99	Yes					n/a	$ -	
F00707	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Break Room		3-Employee Common	Counter		Length	99	Yes					n/a	$ -	
F00708	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Break Room		3-Employee Common	Door Gate		Opening force	3	Yes					n/a	$ -	
F00716	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Break Room		3-Employee Common	Counter		Clearance, parallel	99	Yes					n/a	$ -	
F00717	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Break Room		3-Employee Common	Lavatory Sink		Other attribute	In Cabinet	Yes					n/a	$ -	
F01562	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Conference Room	Coroner	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F01563	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Conference Room	Coroner	2-Public Supervised	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F01564	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Conference Room	Coroner	2-Public Supervised	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F01565	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Conference Room	Coroner	2-Public Supervised	Door Gate		Clearance, push parallel	OK	Yes					n/a	$ -	
F01566	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Conference Room	Coroner	2-Public Supervised	Door Gate		Clearance, push perpendicular	OK	Yes					n/a	$ -	
F01567	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Conference Room	Coroner	2-Public Supervised	Door Gate		Clearance, vertical	81	Yes					n/a	$ -	
F01568	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Conference Room	Coroner	2-Public Supervised	Door Gate		Hardware type	OK	Yes					n/a	$ -	
F01569	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Conference Room	Coroner	2-Public Supervised	Door Gate		Height, hardware	40	Yes					n/a	$ -	
F01574	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Conference Room		2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F01575	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Conference Room		2-Public Supervised	Door Gate		Clearance, vertical	81.5	Yes					n/a	$ -	
F04079	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Hallway	To exterior Break Area	3-Employee Common	Door Gate		Clear opening	32	Yes					n/a	$ -	
F04080	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Hallway	To exterior Break Area	3-Employee Common	Door Gate		Clearance, pull parallel	24	Yes					n/a	$ -	
F04081	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Hallway	To exterior Break Area	3-Employee Common	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F04082	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Hallway	To exterior Break Area	3-Employee Common	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F04083	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Hallway	To exterior Break Area	3-Employee Common	Door Gate		Clearance, series doors	99	Yes					n/a	$ -	
F04084	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Hallway	To exterior Break Area	3-Employee Common	Door Gate		Clearance, vertical	81	Yes					n/a	$ -	
F04085	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Hallway	To exterior Break Area	3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F04086	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Hallway	To exterior Break Area	3-Employee Common	Door Gate		Height, hardware	38	Yes					n/a	$ -	
F04087	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Hallway	To exterior Break Area	3-Employee Common	Door Gate		Threshold beveled?	Y	Yes					n/a	$ -	
F04092	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Hallway		3-Employee Common	Door Gate		Clear opening	32	Yes					n/a	$ -	
F04093	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Hallway		3-Employee Common	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F04486	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception	Employee entrance	3-Employee Common	Door Gate	To locker/shower area	Clear opening	32	Yes					n/a	$ -	
F04487	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception	Employee entrance	3-Employee Common	Door Gate	To locker/shower area	Clearance, pull parallel	18	Yes					n/a	$ -	
F04488	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception	Employee entrance	3-Employee Common	Door Gate	To locker/shower area	Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F04489	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception	Employee entrance	3-Employee Common	Door Gate	To locker/shower area	Clearance, push parallel	18	Yes					n/a	$ -	
F04490	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception	Employee entrance	3-Employee Common	Door Gate	To locker/shower area	Clearance, push perpendicular	OK	Yes					n/a	$ -	
F04491	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception	Employee entrance	3-Employee Common	Door Gate	To locker/shower area	Clearance, vertical	80	Yes					n/a	$ -	
F04492	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception	Employee entrance	3-Employee Common	Door Gate	To locker/shower area	Hardware type	L	Yes					n/a	$ -	
F04493	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception	Employee entrance	3-Employee Common	Door Gate	To locker/shower area	Height, hardware	38	Yes					n/a	$ -	
F04514	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		3-Employee Common	Door Gate	From shared lobby to Coroner's Office	Clear opening	32	Yes					n/a	$ -	
F04515	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		3-Employee Common	Door Gate	From shared lobby to Coroner's Office	Clear opening	32	Yes					n/a	$ -	
F04516	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F04517	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter	Check-in	Clearance, parallel	OK	Yes					n/a	$ -	
F04518	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter	Check-in	Clearance, parallel	OK	Yes					n/a	$ -	
F04519	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		3-Employee Common	Door Gate	From shared lobby to Coroner's Office	Clearance, pull parallel	18	Yes					n/a	$ -	
F04520	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		3-Employee Common	Door Gate	From shared lobby to Coroner's Office	Clearance, pull parallel	60	Yes					n/a	$ -	
F04521	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		3-Employee Common	Door Gate	From shared lobby to Coroner's Office	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F04522	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		3-Employee Common	Door Gate	From shared lobby to Coroner's Office	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F04523	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		3-Employee Common	Door Gate	From shared lobby to Coroner's Office	Clearance, push parallel	19	Yes					n/a	$ -	
F04524	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		3-Employee Common	Door Gate	From shared lobby to Coroner's Office	Clearance, push perpendicular	99	Yes					n/a	$ -	
F04525	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		3-Employee Common	Door Gate	From shared lobby to Coroner's Office	Clearance, push perpendicular	99	Yes					n/a	$ -	
F04526	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Clearance, series doors	82	Yes					n/a	$ -	
F04527	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Clearance, vertical	86	Yes					n/a	$ -	
F04528	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		3-Employee Common	Door Gate	From shared lobby to Coroner's Office	Clearance, vertical	81	Yes					n/a	$ -	
F04529	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		3-Employee Common	Door Gate	From shared lobby to Coroner's Office	Clearance, vertical	81	Yes					n/a	$ -	
F04530	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Closing speed	10	Yes					n/a	$ -	
F04531	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Drinking Fountain		Control force	3	Yes					n/a	$ -	
F04532	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter	Check-in	Dimension, knee clearance	6.5	Yes					n/a	$ -	
F04533	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Drinking Fountain		Dimension, knee clearance	27	Yes					n/a	$ -	
F04534	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		3-Employee Common	Door Gate	From shared lobby to Coroner's Office	Hardware type	L	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F04535	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		3-Employee Common	Door Gate	From shared lobby to Coroner's Office	Hardware type	L	Yes					n/a	$ -	
F04536	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Drinking Fountain		Height	35.5	Yes					n/a	$ -	
F04537	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Drinking Fountain		Height	42.5	Yes					n/a	$ -	
F04538	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Vending Machine		Height, control	47	Yes					n/a	$ -	
F04539	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		3-Employee Common	Door Gate	From shared lobby to Coroner's Office	Height, hardware	38	Yes					n/a	$ -	
F04540	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter	Check-in	Length	99	Yes					n/a	$ -	
F04541	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter	Check-in	Length	50	Yes					n/a	$ -	
F04542	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		3-Employee Common	Counter		Length	99	Yes					n/a	$ -	
F04543	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Threshold beveled?	Y	Yes					n/a	$ -	
F04788	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Clearance, parallel	OK	Yes					n/a	$ -	
F04789	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Clearance, perpendicular	OK	Yes					n/a	$ -	
F04790	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Control force	OK	Yes					n/a	$ -	
F04791	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Control location	F	Yes					n/a	$ -	
F04792	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Hand spray unit?	Y	Yes					n/a	$ -	
F04793	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Height, shower control	39	Yes					n/a	$ -	
F04794	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Height, threshold	OK	Yes					n/a	$ -	
F04795	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Threshold beveled?	Y	Yes					n/a	$ -	
F04796	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Length, hose	72	Yes					n/a	$ -	
F04797	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Seat location	Back wall	Yes					n/a	$ -	
F04798	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Locker Room	Men's	3-Employee Common	Shower Compartment		Seat type	F	Yes					n/a	$ -	
F06866	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility	Employee parking lot	1-Public Unsupervised	Access Aisle		Adjacent pathway?	Y	Yes					n/a	$ -	
F06867	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility	Employee parking lot	1-Public Unsupervised	Access Aisle		Length	OK	Yes					n/a	$ -	
F06868	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility	Employee parking lot	1-Public Unsupervised	Access Aisle		Pathway behind cars?	N	Yes					n/a	$ -	
F06869	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility	Employee parking lot	1-Public Unsupervised	Access Aisle		Slope, cross	0.8%	Yes					n/a	$ -	
F06870	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility	Employee parking lot	1-Public Unsupervised	Access Aisle		Surface material	Asphalt	Yes					n/a	$ -	
F06871	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility	Employee parking lot	1-Public Unsupervised	Access Aisle		Width	60	Yes					n/a	$ -	
F06879	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Height, sign	83	Yes					n/a	$ -	
F06880	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Sign?	Y	Yes					n/a	$ -	
F06881	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Surface material	Asphalt	Yes					n/a	$ -	
F06882	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Width	96	Yes					n/a	$ -	
F06883	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Access aisle?	Y	Yes					n/a	$ -	
F06884	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Access aisle?	Y	Yes					n/a	$ -	
F06885	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Access aisle?	Y	Yes					n/a	$ -	
F06886	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Adjacent pathway?	Y	Yes					n/a	$ -	
F06887	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Cars obstruct pathway	N	Yes					n/a	$ -	
F06888	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Height, sign	87	Yes					n/a	$ -	
F06889	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Height, sign	83	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06890	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Length	OK	Yes					n/a	$ -	
F06891	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, accessible	2	Yes					n/a	$ -	
F06892	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Pathway behind cars?	N	Yes					n/a	$ -	
F06893	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Sign?	Y	Yes					n/a	$ -	
F06894	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Sign?	Y	Yes					n/a	$ -	
F06895	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Slope, cross	0.2%	Yes					n/a	$ -	
F06896	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Slope, cross	0.6%	Yes					n/a	$ -	
F06897	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Slope, cross	0.7%	Yes					n/a	$ -	
F06898	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Slope, cross	0.0%	Yes					n/a	$ -	
F06899	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Slope, running	1.7%	Yes					n/a	$ -	
F06900	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Slope, running	1.1%	Yes					n/a	$ -	
F06901	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Slope, running	1.1%	Yes					n/a	$ -	
F06902	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Surface marking?	Y	Yes					n/a	$ -	
F06903	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Surface material	Asphalt	Yes					n/a	$ -	
F06904	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Surface material	Asphalt	Yes					n/a	$ -	
F06905	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Surface material	Asphalt	Yes					n/a	$ -	
F06906	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Van sign?	N	Yes					n/a	$ -	
F06907	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Van sign?	N	Yes					n/a	$ -	
F06908	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Width	60	Yes					n/a	$ -	
F06909	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Width	96	Yes					n/a	$ -	
F06910	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Width	111	Yes					n/a	$ -	
F14375	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F14376	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Clear opening	35	Yes					n/a	$ -	
F14377	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Clearance, outside	OK	Yes					n/a	$ -	
F14378	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Coat Hook		Clearance, parallel	OK	Yes					n/a	$ -	
F14379	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	64	Yes					n/a	$ -	
F14380	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	99	Yes					n/a	$ -	
F14381	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Water Closet		Clearance, parallel	OK	Yes					n/a	$ -	
F14382	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Coat Hook		Clearance, perpendicular	OK	Yes					n/a	$ -	
F14383	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	99	Yes					n/a	$ -	
F14384	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	72	Yes					n/a	$ -	
F14385	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Water Closet		Clearance, perpendicular	OK	Yes					n/a	$ -	
F14386	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F14387	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F14388	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	72	Yes					n/a	$ -	
F14389	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F14390	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14391	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F14392	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Cross section dimension, maximum	1.5	Yes					n/a	$ -	
F14393	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Side	Cross section dimension, maximum	1.5	Yes					n/a	$ -	
F14394	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F14395	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F14396	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar		Length	18	Yes					n/a	$ -	
F14397	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	3.5	Yes					n/a	$ -	
F14398	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	67	Yes					n/a	$ -	
F14399	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F14400	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Water Closet		Dimension, wide side	42	Yes					n/a	$ -	
F14401	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Door location	S	Yes					n/a	$ -	
F14402	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F14403	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F14404	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	Y	Yes					n/a	$ -	
F14405	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Lavatory Sink		Hardware type	OK	Yes					n/a	$ -	
F14406	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Hardware type	OK	Yes					n/a	$ -	
F14407	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Coat Hook		Height	41	Yes					n/a	$ -	
F14408	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Lavatory Sink		Height	33.5	Yes					n/a	$ -	
F14409	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Mirror		Height, bottom	40	Yes					n/a	$ -	
F14410	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Water Closet		Height, flush control	28	Yes					n/a	$ -	
F14411	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Water Closet		Height, seat	18.5	Yes					n/a	$ -	
F14412	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F14413	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F14414	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F14415	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F14416	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Side	Length	54	Yes					n/a	$ -	
F14417	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F14422	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Men's - Locker Room	3-Employee Common	Coat Hook		Other attribute	60	Yes					n/a	$ -	
F14433	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F14434	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Dispenser	PT	Clearance, parallel	OK	Yes					n/a	$ -	
F14435	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Dispenser	PT	Clearance, perpendicular	OK	Yes					n/a	$ -	
F14436	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Door Gate		Clearance, pull parallel	72	Yes					n/a	$ -	
F14437	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Door Gate		Clearance, pull parallel	24	Yes					n/a	$ -	
F14438	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F14439	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Door Gate		Clearance, vertical	81	Yes					n/a	$ -	
F14440	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Dispenser	TP	Height	23	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14441	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Unisex - Employee	3-Employee Common	Door Gate		Opening force	3	Yes					n/a	$ -	
F14449	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F14450	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F14451	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Coat Hook		Height	41	Yes					n/a	$ -	
F14452	New Sheriff's & Coroner's Office	Coroner's Office	Interior	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Dispenser	PT	Height	46	Yes					n/a	$ -	
F14463	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F14464	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F14465	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Side	Cross section dimension, maximum	1.25	Yes					n/a	$ -	
F14466	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Side	Diameter	1.25	Yes					n/a	$ -	
F14467	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Rear	Diameter	1.25	Yes					n/a	$ -	
F14468	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Dispenser	TP	Dimension from water closet seat	8.5	Yes					n/a	$ -	
F14469	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F14470	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Lavatory Sink		Dimension, knee clearance	31	Yes					n/a	$ -	
F14471	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Water Closet		Dimension, sidewall	17.5	Yes					n/a	$ -	
F14472	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F14473	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Dispenser	PT	Height	40	Yes					n/a	$ -	
F14474	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Dispenser	TP	Height	26	Yes					n/a	$ -	
F14475	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Water Closet		Height, seat	18	Yes					n/a	$ -	
F14476	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Side	Height, top	35.5	Yes					n/a	$ -	
F14477	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F14478	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Side	Length	54	Yes					n/a	$ -	
F14479	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F14480	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Men's	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F14485	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Clearance, parallel	80	Yes					n/a	$ -	
F14486	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Clearance, perpendicular	76	Yes					n/a	$ -	
F14487	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F14488	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F14489	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Side	Diameter	1.25	Yes					n/a	$ -	
F14490	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F14491	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F14492	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Dimension, knee clearance	30	Yes					n/a	$ -	
F14493	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Dimension, sidewall	16.5	Yes					n/a	$ -	
F14494	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F14495	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Unisex	3-Employee Common	Lavatory Sink		Height	34	Yes					n/a	$ -	
F14496	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Height, seat	19	Yes					n/a	$ -	
F14497	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Side	Height, top	35.5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14498	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F14499	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Side	Length	54	Yes					n/a	$ -	
F14500	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Unisex	3-Employee Common	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F14517	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F14518	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Water Closet		Clearance, parallel	67	Yes					n/a	$ -	
F14519	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Water Closet		Clearance, perpendicular	88	Yes					n/a	$ -	
F14520	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Door Gate		Clearance, pull parallel	26	Yes					n/a	$ -	
F14521	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Door Gate		Clearance, push parallel	26	Yes					n/a	$ -	
F14522	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F14523	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F14524	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Door Gate		Clearance, vertical	81	Yes					n/a	$ -	
F14525	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Diameter	1.25	Yes					n/a	$ -	
F14526	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Diameter	1.25	Yes					n/a	$ -	
F14527	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Lavatory Sink		Dimension, knee clearance	30	Yes					n/a	$ -	
F14528	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Water Closet		Dimension, sidewall	17.5	Yes					n/a	$ -	
F14529	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F14530	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Alarm System		Height	80	Yes					n/a	$ -	
F14531	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Water Closet		Height, seat	18.5	Yes					n/a	$ -	
F14532	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F14533	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F14534	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Length	54	Yes					n/a	$ -	
F14535	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F14536	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F14537	New Sheriff's & Coroner's Office	Sheriff's Office	Interior	Owned	Restroom	Women's	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F16531	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Walkway	From employee parking lot	1-Public Unsupervised	Walking Surface		Slope, cross	1.2%	Yes					n/a	$ -	
F16532	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Walkway	From employee parking lot	1-Public Unsupervised	Landing		Slope, running	0.1%	Yes					n/a	$ -	
F16533	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Walkway	From employee parking lot	1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F16534	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Walkway	From employee parking lot	1-Public Unsupervised	Walking Surface		Width	60	Yes					n/a	$ -	
F16537	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Landing	At base of walkway	Clearance, parallel	57	Yes					n/a	$ -	
F16538	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Landing	At base of walkway	Clearance, perpendicular	70	Yes					n/a	$ -	
F16539	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Walking Surface		Slope, cross	1.3%	Yes					n/a	$ -	
F16540	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Landing	At base of walkway	Slope, running	1.4%	Yes					n/a	$ -	
F16541	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Walking Surface		Slope, running	5.0%	Yes					n/a	$ -	
F16542	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F16543	New Sheriff's & Coroner's Office	Coroner's Office	Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Walking Surface		Width	70	Yes					n/a	$ -	
F00721	Parks Admin Building		1st Floor	Owned	Break Room	Meeting Room	1-Public Unsupervised	Lavatory Sink		Other attribute	In Cabinet	Yes					n/a	$ -	
F00731	Parks Admin Building		2nd Floor	Owned	Break Room		3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00732	Parks Admin Building		1st Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Other attribute	In Cabinet	Yes					n/a	$ -	
F00733	Parks Admin Building		2nd Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Other attribute	In Cabinet	Yes					n/a	$ -	
F00734	Parks Admin Building		2nd Floor	Owned	Break Room		1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F01577	Parks Admin Building		2nd Floor	Owned	Conference Room		1-Public Unsupervised	Lavatory Sink		Other attribute	In Cabinet	Yes					n/a	$ -	
F03411	Parks Admin Building		1st Floor	Owned	Elevator		1-Public Unsupervised	Hoistway Sign		All floors?	Y	Yes					n/a	$ -	
F03412	Parks Admin Building		1st Floor	Owned	Elevator		1-Public Unsupervised	Elevator Car		Audible signal?	Y	Yes					n/a	$ -	
F03413	Parks Admin Building		1st Floor	Owned	Elevator		1-Public Unsupervised	Hoistway Sign		Both jambs?	Y	Yes					n/a	$ -	
F03414	Parks Admin Building		1st Floor	Owned	Elevator		1-Public Unsupervised	Car Controls		Braille instructions	Y	Yes					n/a	$ -	
F03415	Parks Admin Building		1st Floor	Owned	Elevator		1-Public Unsupervised	Hoistway Sign		Braille?	Y	Yes					n/a	$ -	
F03416	Parks Admin Building		1st Floor	Owned	Elevator		1-Public Unsupervised	Elevator Door		Clear opening	36	Yes					n/a	$ -	
F03417	Parks Admin Building		1st Floor	Owned	Elevator		1-Public Unsupervised	Elevator Car		Dimension, back to front	51.25	Yes					n/a	$ -	
F03418	Parks Admin Building		1st Floor	Owned	Elevator		1-Public Unsupervised	Elevator Car		Dimension, gap	1.25	Yes					n/a	$ -	
F03419	Parks Admin Building		1st Floor	Owned	Elevator		1-Public Unsupervised	Elevator Car		Dimension, side to side	68.75	Yes					n/a	$ -	
F03420	Parks Admin Building		1st Floor	Owned	Elevator		1-Public Unsupervised	Car Controls		Height, bottom	31.5	Yes					n/a	$ -	
F03421	Parks Admin Building		1st Floor	Owned	Elevator		1-Public Unsupervised	Call Control		Height, top	41.75	Yes					n/a	$ -	
F03422	Parks Admin Building		1st Floor	Owned	Elevator		1-Public Unsupervised	Car Controls		Height, top	39.25	Yes					n/a	$ -	
F03423	Parks Admin Building		1st Floor	Owned	Elevator		1-Public Unsupervised	Car Controls		Lighted?	Y	Yes					n/a	$ -	
F03424	Parks Admin Building		1st Floor	Owned	Elevator		1-Public Unsupervised	Call Control		Size	1	Yes					n/a	$ -	
F03425	Parks Admin Building		1st Floor	Owned	Elevator		1-Public Unsupervised	Car Controls		Star?	Y	Yes					n/a	$ -	
F03426	Parks Admin Building		1st Floor	Owned	Elevator		1-Public Unsupervised	Hoistway Sign		Tactile letters?	Y	Yes					n/a	$ -	
F03427	Parks Admin Building		1st Floor	Owned	Elevator		1-Public Unsupervised	Car Controls		Tactile?	Y	Yes					n/a	$ -	
F03428	Parks Admin Building		1st Floor	Owned	Elevator		1-Public Unsupervised	Call Control		Up above down?	Y	Yes					n/a	$ -	
F03429	Parks Admin Building		1st Floor	Owned	Elevator		1-Public Unsupervised	Call Control		Visible signal?	Y	Yes					n/a	$ -	
F04096	Parks Admin Building		1st Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near restrooms	Dimension, knee clearance	27	Yes					n/a	$ -	
F04097	Parks Admin Building		1st Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near restrooms	Height	33	Yes					n/a	$ -	
F04098	Parks Admin Building		1st Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near restrooms	Height	38.5	Yes					n/a	$ -	
F04545	Parks Admin Building		1st Floor	Owned	Lobby Reception		1-Public Unsupervised	Counter		Height	29.5	Yes					n/a	$ -	
F04546	Parks Admin Building		1st Floor	Owned	Lobby Reception		1-Public Unsupervised	Counter		Length	30.5	Yes					n/a	$ -	
F06913	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North of Park Admin building	1-Public Unsupervised	Parking Space	#2	Access aisle?	Y	Yes					n/a	$ -	
F06914	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North of Park Admin building	1-Public Unsupervised	Parking Space	#2	Height, sign	72	Yes					n/a	$ -	
F06915	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North of Park Admin building	1-Public Unsupervised	Parking Space	#2	Slope, cross	0.4%	Yes					n/a	$ -	
F06916	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North of Park Admin building	1-Public Unsupervised	Parking Space	#2	Slope, running	0.4%	Yes					n/a	$ -	
F06917	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North of Park Admin building	1-Public Unsupervised	Parking Space	#2	Van sign?	Y	Yes					n/a	$ -	
F06918	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North of Park Admin building	1-Public Unsupervised	Parking Space	#2	Width	144	Yes					n/a	$ -	
F06925	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Parking Space	#1	Access aisle?	Y	Yes					n/a	$ -	
F06926	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Parking Space	#1	Height, sign	72	Yes					n/a	$ -	
F06927	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Parking Space	#3	Height, sign	72	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06928	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Access Aisle	#1	Pathway behind cars?	N	Yes					n/a	$ -	
F06929	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Parking Space	#1	Sign?	Y	Yes					n/a	$ -	
F06930	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Parking Space	#2	Sign?	Y	Yes					n/a	$ -	
F06931	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Parking Space	#3	Sign?	Y	Yes					n/a	$ -	
F06932	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Access Aisle	#1	Slope, cross	1.7%	Yes					n/a	$ -	
F06933	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Parking Space	#3	Slope, cross	0.7%	Yes					n/a	$ -	
F06934	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Parking Space	#2	Slope, cross	0.8%	Yes					n/a	$ -	
F06935	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Parking Space	#1	Slope, cross	1.3%	Yes					n/a	$ -	
F06936	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Access Aisle	#1	Slope, running	0.6%	Yes					n/a	$ -	
F06937	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Parking Space	#1	Slope, running	1.0%	Yes					n/a	$ -	
F06938	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Parking Space	#3	Slope, running	2.0%	Yes					n/a	$ -	
F06939	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Parking Space	#2	Slope, running	1.5%	Yes					n/a	$ -	
F06940	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Access Aisle	#1	Surface marking?	Y	Yes					n/a	$ -	
F06941	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Parking Space	#1	Van sign?	N	Yes					n/a	$ -	
F06942	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Parking Space	#2	Van sign?	N	Yes					n/a	$ -	
F06943	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Parking Space	#3	Van sign?	N	Yes					n/a	$ -	
F06944	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Access Aisle	#1	Width	94	Yes					n/a	$ -	
F06945	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Parking Space	#1	Width	132	Yes					n/a	$ -	
F06946	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Parking Space	#2	Width	132	Yes					n/a	$ -	
F06947	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	North side of North parking lot	1-Public Unsupervised	Parking Space	#3	Width	132	Yes					n/a	$ -	
F06954	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	West side of North parking lot	1-Public Unsupervised	Parking Space	#1	Access aisle?	Y	Yes					n/a	$ -	
F06955	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	West side of North parking lot	1-Public Unsupervised	Parking Space	#2	Access aisle?	Y	Yes					n/a	$ -	
F06956	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	West side of North parking lot	1-Public Unsupervised	Parking Space	#1	Height, sign	72	Yes					n/a	$ -	
F06957	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	West side of North parking lot	1-Public Unsupervised	Parking Space	#2	Height, sign	72	Yes					n/a	$ -	
F06958	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	West side of North parking lot	1-Public Unsupervised	Parking Space	#1	Sign?	Y	Yes					n/a	$ -	
F06959	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	West side of North parking lot	1-Public Unsupervised	Parking Space	#2	Sign?	Y	Yes					n/a	$ -	
F06960	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	West side of North parking lot	1-Public Unsupervised	Access Aisle	#1	Slope, cross	0.3%	Yes					n/a	$ -	
F06961	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	West side of North parking lot	1-Public Unsupervised	Parking Space	#1	Slope, cross	0.3%	Yes					n/a	$ -	
F06962	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	West side of North parking lot	1-Public Unsupervised	Parking Space	#2	Slope, cross	0.7%	Yes					n/a	$ -	
F06963	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	West side of North parking lot	1-Public Unsupervised	Parking Space	#2	Slope, running	1.8%	Yes					n/a	$ -	
F06964	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	West side of North parking lot	1-Public Unsupervised	Parking Space	#1	Slope, running	1.9%	Yes					n/a	$ -	
F06965	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	West side of North parking lot	1-Public Unsupervised	Access Aisle	#1	Surface marking?	Y	Yes					n/a	$ -	
F06966	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	West side of North parking lot	1-Public Unsupervised	Parking Space	#1	Van sign?	N	Yes					n/a	$ -	
F06967	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	West side of North parking lot	1-Public Unsupervised	Parking Space	#2	Van sign?	N	Yes					n/a	$ -	
F06968	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	West side of North parking lot	1-Public Unsupervised	Parking Space	#1	Width	132	Yes					n/a	$ -	
F06969	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility	West side of North parking lot	1-Public Unsupervised	Parking Space	#2	Width	133	Yes					n/a	$ -	
F06974	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Access aisle?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F06975	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Adjacent pathway?	Y	Yes					n/a	$ -	
F06976	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, accessible	7	Yes					n/a	$ -	
F06977	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, total spaces	69	Yes					n/a	$ -	
F06978	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, van spaces	1	Yes					n/a	$ -	
F06979	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Pathway behind cars?	N	Yes					n/a	$ -	
F06980	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Slope, cross	0.6%	Yes					n/a	$ -	
F06981	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Slope, cross	0.8%	Yes					n/a	$ -	
F06982	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Slope, running	1.5%	Yes					n/a	$ -	
F06983	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Slope, running	1.9%	Yes					n/a	$ -	
F06984	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Surface marking?	Y	Yes					n/a	$ -	
F06985	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Surface material	Asphalt	Yes					n/a	$ -	
F06986	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Surface material	Asphalt	Yes					n/a	$ -	
F06987	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Van sign?	N	Yes					n/a	$ -	
F06988	Parks Admin Building	North Parking Area	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Width	134	Yes					n/a	$ -	
F06989	Parks Admin Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Access aisle?	Y	Yes					n/a	$ -	
F06990	Parks Admin Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Access aisle?	Y	Yes					n/a	$ -	
F06991	Parks Admin Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Adjacent pathway?	Y	Yes					n/a	$ -	
F06992	Parks Admin Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Height, sign	60	Yes					n/a	$ -	
F06993	Parks Admin Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Height, sign	60	Yes					n/a	$ -	
F06994	Parks Admin Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, accessible	2	Yes					n/a	$ -	
F06995	Parks Admin Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, total spaces	12	Yes					n/a	$ -	
F06996	Parks Admin Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, van spaces	1	Yes					n/a	$ -	
F06997	Parks Admin Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Sign?	Y	Yes					n/a	$ -	
F06998	Parks Admin Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Sign?	Y	Yes					n/a	$ -	
F06999	Parks Admin Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Slope, cross	1.9%	Yes					n/a	$ -	
F07000	Parks Admin Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Slope, cross	1.6%	Yes					n/a	$ -	
F07001	Parks Admin Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Slope, cross	2.0%	Yes					n/a	$ -	
F07002	Parks Admin Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Slope, running	1.7%	Yes					n/a	$ -	
F07003	Parks Admin Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Slope, running	1.3%	Yes					n/a	$ -	
F07004	Parks Admin Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Slope, running	2.0%	Yes					n/a	$ -	
F07005	Parks Admin Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Van sign?	Y	Yes					n/a	$ -	
F07006	Parks Admin Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Width	61	Yes					n/a	$ -	
F07007	Parks Admin Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Width	153	Yes					n/a	$ -	
F07008	Parks Admin Building		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Width	133	Yes					n/a	$ -	
F14555	Parks Admin Building		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F14556	Parks Admin Building		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Clearance, perpendicular	60	Yes					n/a	$ -	
F14557	Parks Admin Building		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	56	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14558	Parks Admin Building		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, sidewall	17.5	Yes					n/a	$ -	
F14559	Parks Admin Building		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Height, seat	18.5	Yes					n/a	$ -	
F14560	Parks Admin Building		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F14576	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F14577	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F14578	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F14579	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Signage		Dimension, characters	0.5	Yes					n/a	$ -	
F14580	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	30	Yes					n/a	$ -	
F14581	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Water Closet		Dimension, sidewall	17.5	Yes					n/a	$ -	
F14582	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Water Closet		Dimension, wide side	43.5	Yes					n/a	$ -	
F14583	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F14584	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Alarm System		Height	84	Yes					n/a	$ -	
F14585	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Signage		Height, bottom	56	Yes					n/a	$ -	
F14586	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Water Closet		Height, seat	18.5	Yes					n/a	$ -	
F14587	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F14588	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F14589	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F14590	Parks Admin Building		1st Floor	Owned	Restroom	Men's - West Hall	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F14600	Parks Admin Building		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, sidewall	16.5	Yes					n/a	$ -	
F14601	Parks Admin Building		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, wide side	60	Yes					n/a	$ -	
F14602	Parks Admin Building		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F14624	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F14625	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F14626	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Toilet Compartment		Clear opening	33	Yes					n/a	$ -	
F14627	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	61	Yes					n/a	$ -	
F14628	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	99	Yes					n/a	$ -	
F14629	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F14630	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F14631	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Grab Bar	Side	Diameter	1.25	Yes					n/a	$ -	
F14632	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.25	Yes					n/a	$ -	
F14633	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Signage		Dimension, characters	0.5	Yes					n/a	$ -	
F14634	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	3	Yes					n/a	$ -	
F14635	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	30	Yes					n/a	$ -	
F14636	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Toilet Compartment		Door swing direction	Out	Yes					n/a	$ -	
F14637	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F14638	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F14639	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Alarm System		Height	83.5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14640	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Signage		Height, bottom	56.5	Yes					n/a	$ -	
F14641	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F14642	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Grab Bar	Side	Length	51	Yes					n/a	$ -	
F14643	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F14644	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F14645	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Fixture Count		Number, accessible compartments	1	Yes					n/a	$ -	
F14646	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Fixture Count		Number, toilet compartments	3	Yes					n/a	$ -	
F14647	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F14648	Parks Admin Building		1st Floor	Owned	Restroom	Women's - West Hall	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F16546	Parks Admin Building	North Parking Area	Exterior	Owned	Walkway	From 'New' North parking lot	1-Public Unsupervised	Curb Ramp		Accumulates water?	N	Yes					n/a	$ -	
F16547	Parks Admin Building	North Parking Area	Exterior	Owned	Walkway	From 'New' North parking lot	1-Public Unsupervised	Curb Ramp		Landing, parallel dimension	60	Yes					n/a	$ -	
F16548	Parks Admin Building	North Parking Area	Exterior	Owned	Walkway	From 'New' North parking lot	1-Public Unsupervised	Curb Ramp		Landing, perpendicular dimension	64	Yes					n/a	$ -	
F16549	Parks Admin Building	North Parking Area	Exterior	Owned	Walkway	From 'New' North parking lot	1-Public Unsupervised	Curb Ramp		Landing?	Y	Yes					n/a	$ -	
F16550	Parks Admin Building	North Parking Area	Exterior	Owned	Walkway	From 'New' North parking lot	1-Public Unsupervised	Curb Ramp		Slope, cross	1.6%	Yes					n/a	$ -	
F16551	Parks Admin Building	North Parking Area	Exterior	Owned	Walkway	From 'New' North parking lot	1-Public Unsupervised	Curb Ramp		Slope, left flare	7.0%	Yes					n/a	$ -	
F16552	Parks Admin Building	North Parking Area	Exterior	Owned	Walkway	From 'New' North parking lot	1-Public Unsupervised	Curb Ramp		Slope, running	0.4%	Yes					n/a	$ -	
F16553	Parks Admin Building	North Parking Area	Exterior	Owned	Walkway	From 'New' North parking lot	1-Public Unsupervised	Curb Ramp		Surface material	Concrete	Yes					n/a	$ -	
F16554	Parks Admin Building	North Parking Area	Exterior	Owned	Walkway	From 'New' North parking lot	1-Public Unsupervised	Curb Ramp		Width	64	Yes					n/a	$ -	
F16558	Parks Admin Building		Exterior	Owned	Walkway	From parking lot	1-Public Unsupervised	Curb Ramp		Accumulates water?	N	Yes					n/a	$ -	
F16559	Parks Admin Building		Exterior	Owned	Walkway	From parking lot	1-Public Unsupervised	Curb Ramp		Slope, cross	0.1%	Yes					n/a	$ -	
F16560	Parks Admin Building		Exterior	Owned	Walkway	From parking lot	1-Public Unsupervised	Curb Ramp		Slope, left flare	6.2%	Yes					n/a	$ -	
F16561	Parks Admin Building		Exterior	Owned	Walkway	From parking lot	1-Public Unsupervised	Curb Ramp		Slope, right flare	7.1%	Yes					n/a	$ -	
F16562	Parks Admin Building		Exterior	Owned	Walkway	From parking lot	1-Public Unsupervised	Curb Ramp		Slope, running	1.2%	Yes					n/a	$ -	
F16569	Parks Admin Building		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F16570	Parks Admin Building		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Closing speed	9	Yes					n/a	$ -	
F16571	Parks Admin Building		Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Opening force	Auto	Yes					n/a	$ -	
F00748	Public Works and Fleet		1st Floor	Owned	Break Room		1-Public Unsupervised	Operable Part	Soap dispenser	Depth, obstruction	20	Yes					n/a	$ -	
F00749	Public Works and Fleet		1st Floor	Owned	Break Room		1-Public Unsupervised	Operable Part	PT	Depth, obstruction	19	Yes					n/a	$ -	
F00750	Public Works and Fleet		1st Floor	Owned	Break Room		1-Public Unsupervised	Operable Part	Soap dispenser	Height	43	Yes					n/a	$ -	
F00751	Public Works and Fleet		1st Floor	Owned	Break Room		1-Public Unsupervised	Lavatory Sink		Other attribute	In Cabinet	Yes					n/a	$ -	
F00752	Public Works and Fleet		2nd Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Other attribute	In Cabinet	Yes					n/a	$ -	
F00753	Public Works and Fleet		1st Floor	Owned	Break Room		1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F03431	Public Works and Fleet		1st Floor	Owned	Elevator		1-Public Unsupervised	Hoistway Sign		All floors?	Y	Yes					n/a	$ -	
F03432	Public Works and Fleet		1st Floor	Owned	Elevator		1-Public Unsupervised	Hoistway Sign		Both jambs?	Y	Yes					n/a	$ -	
F03433	Public Works and Fleet		1st Floor	Owned	Elevator		1-Public Unsupervised	Hoistway Sign		Braille?	Y	Yes					n/a	$ -	
F03434	Public Works and Fleet		1st Floor	Owned	Elevator		1-Public Unsupervised	Elevator Car		Dimension, back to front	51	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F03435	Public Works and Fleet		1st Floor	Owned	Elevator		1-Public Unsupervised	Elevator Car		Dimension, side to side	69	Yes					n/a	$ -	
F03436	Public Works and Fleet		1st Floor	Owned	Elevator		1-Public Unsupervised	Elevator Door		Distance to door	11	Yes					n/a	$ -	
F03437	Public Works and Fleet		1st Floor	Owned	Elevator		1-Public Unsupervised	Car Controls		Height, bottom	35	Yes					n/a	$ -	
F03438	Public Works and Fleet		1st Floor	Owned	Elevator		1-Public Unsupervised	Car Controls		Height, emergency control	35	Yes					n/a	$ -	
F03439	Public Works and Fleet		1st Floor	Owned	Elevator		1-Public Unsupervised	Call Control		Height, top	43	Yes					n/a	$ -	
F03440	Public Works and Fleet		1st Floor	Owned	Elevator		1-Public Unsupervised	Car Controls		Height, top	42	Yes					n/a	$ -	
F03441	Public Works and Fleet		1st Floor	Owned	Elevator		1-Public Unsupervised	Elevator Car		Other attribute	Side opening	Yes					n/a	$ -	
F03442	Public Works and Fleet		1st Floor	Owned	Elevator		1-Public Unsupervised	Elevator Door		Reopen device?	Y	Yes					n/a	$ -	
F03443	Public Works and Fleet		1st Floor	Owned	Elevator		1-Public Unsupervised	Call Control		Visible signal?	Y	Yes					n/a	$ -	
F04548	Public Works and Fleet		2nd Floor	Owned	Lobby Reception		1-Public Unsupervised	Counter		Height	29.5	Yes					n/a	$ -	
F04549	Public Works and Fleet		2nd Floor	Owned	Lobby Reception		1-Public Unsupervised	Counter		Length	36	Yes					n/a	$ -	
F07014	Public Works and Fleet		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Access aisle?	Y	Yes					n/a	$ -	
F07015	Public Works and Fleet		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Adjacent pathway?	Y	Yes					n/a	$ -	
F07016	Public Works and Fleet		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Height, sign	74	Yes					n/a	$ -	
F07017	Public Works and Fleet		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Height, sign	70	Yes					n/a	$ -	
F07018	Public Works and Fleet		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, van spaces	2	Yes					n/a	$ -	
F07019	Public Works and Fleet		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Slope, cross	1.4%	Yes					n/a	$ -	
F07020	Public Works and Fleet		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Slope, cross	0.0%	Yes					n/a	$ -	
F07021	Public Works and Fleet		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Slope, cross	0.1%	Yes					n/a	$ -	
F07022	Public Works and Fleet		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Slope, running	1.1%	Yes					n/a	$ -	
F07023	Public Works and Fleet		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Slope, running	1.5%	Yes					n/a	$ -	
F07024	Public Works and Fleet		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Slope, running	1.9%	Yes					n/a	$ -	
F07025	Public Works and Fleet		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Van sign?	Y	Yes					n/a	$ -	
F07026	Public Works and Fleet		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Width	112	Yes					n/a	$ -	
F07027	Public Works and Fleet		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Width	133	Yes					n/a	$ -	
F07028	Public Works and Fleet		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Width	141	Yes					n/a	$ -	
F14703	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F14704	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F14705	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clear opening	32.5	Yes					n/a	$ -	
F14706	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clearance, outside	47	Yes					n/a	$ -	
F14707	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F14708	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	59.5	Yes					n/a	$ -	
F14709	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	99	Yes					n/a	$ -	
F14710	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	59	Yes					n/a	$ -	
F14711	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F14712	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F14713	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, vertical	80	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14714	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	8	Yes					n/a	$ -	
F14715	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	27	Yes					n/a	$ -	
F14716	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F14717	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, wide side	42.5	Yes					n/a	$ -	
F14718	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	Soap	Height	44	Yes					n/a	$ -	
F14719	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F14720	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Height	32	Yes					n/a	$ -	
F14721	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Mirror		Height, bottom	36	Yes					n/a	$ -	
F14722	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Mirror		Height, bottom	37.5	Yes					n/a	$ -	
F14723	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Mirror		Height, bottom	34	Yes					n/a	$ -	
F14724	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Height, seat	19	Yes					n/a	$ -	
F14725	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F14726	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Height, top	36	Yes					n/a	$ -	
F14727	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Height, top	36	Yes					n/a	$ -	
F14728	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Height, top	36	Yes					n/a	$ -	
F14729	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Height, top	57.5	Yes					n/a	$ -	
F14730	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F14731	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F14732	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F14733	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F14734	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F14735	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F14736	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Fixture Count		Number, toilet compartments	1	Yes					n/a	$ -	
F14737	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Fixture Count		Number, urinals	2	Yes					n/a	$ -	
F14738	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Self-closing?	Y	Yes					n/a	$ -	
F14739	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F14740	Public Works and Fleet		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F14741	Public Works and Fleet		2nd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F14751	Public Works and Fleet		1st Floor	Owned	Restroom	Men's - Fleet Break Room	3-Employee Common	Toilet Compartment		Clearance, perpendicular	56	Yes					n/a	$ -	
F14752	Public Works and Fleet		1st Floor	Owned	Restroom	Men's - Fleet Break Room	3-Employee Common	Lavatory Sink		Dimension, knee clearance	27	Yes					n/a	$ -	
F14753	Public Works and Fleet		1st Floor	Owned	Restroom	Men's - Fleet Break Room	3-Employee Common	Lavatory Sink		Height	32.5	Yes					n/a	$ -	
F14754	Public Works and Fleet		1st Floor	Owned	Restroom	Men's - Fleet Break Room	3-Employee Common	Fixture Count		Number, ambulatory compartments	0	Yes					n/a	$ -	
F14755	Public Works and Fleet		1st Floor	Owned	Restroom	Men's - Fleet Break Room	3-Employee Common	Fixture Count		Number, toilet compartments	2	Yes					n/a	$ -	
F14756	Public Works and Fleet		1st Floor	Owned	Restroom	Men's - Fleet Break Room	3-Employee Common	Fixture Count		Number, urinals	2	Yes					n/a	$ -	
F14757	Public Works and Fleet		1st Floor	Owned	Restroom	Men's - Fleet Break Room	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F14767	Public Works and Fleet		1st Floor	Owned	Restroom	Unisex - Fleet Area	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14768	Public Works and Fleet		1st Floor	Owned	Restroom	Unisex - Fleet Area	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	59	Yes					n/a	$ -	
F14769	Public Works and Fleet		1st Floor	Owned	Restroom	Unisex - Fleet Area	1-Public Unsupervised	Door Gate		Clearance, vertical	81	Yes					n/a	$ -	
F14770	Public Works and Fleet		1st Floor	Owned	Restroom	Unisex - Fleet Area	1-Public Unsupervised	Urinal		Depth	16	Yes					n/a	$ -	
F14771	Public Works and Fleet		1st Floor	Owned	Restroom	Unisex - Fleet Area	1-Public Unsupervised	Water Closet		Dimension, wide side	17	Yes					n/a	$ -	
F14772	Public Works and Fleet		1st Floor	Owned	Restroom	Unisex - Fleet Area	1-Public Unsupervised	Lavatory Sink		Height	27	Yes					n/a	$ -	
F14773	Public Works and Fleet		1st Floor	Owned	Restroom	Unisex - Fleet Area	1-Public Unsupervised	Fixture Count		Number, toilet compartments	1	Yes					n/a	$ -	
F14774	Public Works and Fleet		1st Floor	Owned	Restroom	Unisex - Fleet Area	1-Public Unsupervised	Fixture Count		Number, urinals	2	Yes					n/a	$ -	
F14775	Public Works and Fleet		1st Floor	Owned	Restroom	Unisex - Fleet Area	1-Public Unsupervised	Lavatory Sink		Other attribute	Round	Yes					n/a	$ -	
F14823	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F14824	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F14825	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F14826	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	99	Yes					n/a	$ -	
F14827	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	59	Yes					n/a	$ -	
F14828	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F14829	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F14830	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, vertical	80	Yes					n/a	$ -	
F14831	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F14832	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F14833	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	8.5	Yes					n/a	$ -	
F14834	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	7	Yes					n/a	$ -	
F14835	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4	Yes					n/a	$ -	
F14836	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F14837	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	28	Yes					n/a	$ -	
F14838	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F14839	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, wide side	42	Yes					n/a	$ -	
F14840	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment	Ambulatory	Door swing direction	Out	Yes					n/a	$ -	
F14841	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Soap	Height	45.5	Yes					n/a	$ -	
F14842	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Feminine products	Height	48	Yes					n/a	$ -	
F14843	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Height	33	Yes					n/a	$ -	
F14844	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Mirror		Height, bottom	37	Yes					n/a	$ -	
F14845	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Mirror		Height, bottom	37	Yes					n/a	$ -	
F14846	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Mirror		Height, bottom	38	Yes					n/a	$ -	
F14847	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F14848	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Height, top	36	Yes					n/a	$ -	
F14849	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Height, top	36	Yes					n/a	$ -	
F14850	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Height, top	59	Yes					n/a	$ -	
F14851	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14852	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F14853	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F14854	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F14855	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F14856	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F14857	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Fixture Count		Number, toilet compartments	1	Yes					n/a	$ -	
F14858	Public Works and Fleet		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment	Ambulatory	Self-closing?	Y	Yes					n/a	$ -	
F14859	Public Works and Fleet		2nd Floor	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F15587	Public Works and Fleet		2nd Floor	Owned	Shower Room	Men's	3-Employee Common	Bench		Height	19	Yes					n/a	$ -	
F15588	Public Works and Fleet		2nd Floor	Owned	Shower Room	Men's	3-Employee Common	Other Element	Bench	Other attribute	No back	Yes					n/a	$ -	
F15596	Public Works and Fleet		2nd Floor	Owned	Shower Room	Women's	3-Employee Common	Door Gate		Clear opening	33.5	Yes					n/a	$ -	
F07033	Rotella Park		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#1	Access aisle?	Y	Yes					n/a	$ -	
F07034	Rotella Park		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#2	Access aisle?	Y	Yes					n/a	$ -	
F07035	Rotella Park		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	#1	Adjacent pathway?	Y	Yes					n/a	$ -	
F07036	Rotella Park		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Facility Specifications		Cars obstruct pathway	N	Yes					n/a	$ -	
F07037	Rotella Park		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#1	Height, sign	77	Yes					n/a	$ -	
F07038	Rotella Park		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#2	Height, sign	79	Yes					n/a	$ -	
F07039	Rotella Park		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	#1	Length	OK	Yes					n/a	$ -	
F07040	Rotella Park		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Facility Specifications		Number, accessible	2	Yes					n/a	$ -	
F07041	Rotella Park		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#1	Sign?	Y	Yes					n/a	$ -	
F07042	Rotella Park		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	#1	Slope, cross	0.2%	Yes					n/a	$ -	
F07043	Rotella Park		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#1	Slope, cross	0.3%	Yes					n/a	$ -	
F07044	Rotella Park		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#2	Slope, cross	0.7%	Yes					n/a	$ -	
F07045	Rotella Park		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	#1	Slope, running	0.6%	Yes					n/a	$ -	
F07046	Rotella Park		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#2	Slope, running	1.1%	Yes					n/a	$ -	
F07047	Rotella Park		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#1	Slope, running	1.5%	Yes					n/a	$ -	
F07048	Rotella Park		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	#1	Surface material	Concrete	Yes					n/a	$ -	
F07049	Rotella Park		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#1	Van sign?	N	Yes					n/a	$ -	
F07050	Rotella Park		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#2	Van sign?	N	Yes					n/a	$ -	
F07051	Rotella Park		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Access Aisle	#1	Width	93	Yes					n/a	$ -	
F07052	Rotella Park		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#1	Width	107	Yes					n/a	$ -	
F07053	Rotella Park		Exterior	Owned	Parking Facility	West parking lot	1-Public Unsupervised	Parking Space	#2	Width	110	Yes					n/a	$ -	
F07062	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Access aisle?	Y	Yes					n/a	$ -	
F07063	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Access aisle?	Y	Yes					n/a	$ -	
F07064	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Access aisle?	Y	Yes					n/a	$ -	
F07065	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Access aisle?	Y	Yes					n/a	$ -	
F07066	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Adjacent pathway?	Y	Yes					n/a	$ -	
F07067	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Adjacent pathway?	Y	Yes					n/a	$ -	
F07068	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Cars obstruct pathway	N	Yes					n/a	$ -	
F07069	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Height, sign	79	Yes					n/a	$ -	
F07070	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Height, sign	79	Yes					n/a	$ -	
F07071	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Height, sign	78	Yes					n/a	$ -	
F07072	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Height, sign	79	Yes					n/a	$ -	
F07073	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Height, sign	80	Yes					n/a	$ -	
F07074	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Length	OK	Yes					n/a	$ -	
F07075	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Length	OK	Yes					n/a	$ -	
F07076	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #3 & #4	Length	OK	Yes					n/a	$ -	
F07077	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Length	OK	Yes					n/a	$ -	
F07078	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, accessible	5	Yes					n/a	$ -	
F07079	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, van spaces	1	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07080	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Pathway behind cars?	N	Yes					n/a	$ -	
F07081	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Sign?	Y	Yes					n/a	$ -	
F07082	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Sign?	Y	Yes					n/a	$ -	
F07083	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Slope, cross	0.7%	Yes					n/a	$ -	
F07084	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Slope, cross	0.7%	Yes					n/a	$ -	
F07085	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Slope, cross	1.1%	Yes					n/a	$ -	
F07086	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #3 & #4	Slope, cross	1.5%	Yes					n/a	$ -	
F07087	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Slope, cross	0.4%	Yes					n/a	$ -	
F07088	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Slope, cross	0.5%	Yes					n/a	$ -	
F07089	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Slope, cross	1.1%	Yes					n/a	$ -	
F07090	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Slope, cross	1.2%	Yes					n/a	$ -	
F07091	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Slope, cross	1.6%	Yes					n/a	$ -	
F07092	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Slope, running	0.1%	Yes					n/a	$ -	
F07093	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #3 & #4	Slope, running	0.4%	Yes					n/a	$ -	
F07094	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Slope, running	0.7%	Yes					n/a	$ -	
F07095	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Slope, running	1.0%	Yes					n/a	$ -	
F07096	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Slope, running	1.0%	Yes					n/a	$ -	
F07097	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Slope, running	0.6%	Yes					n/a	$ -	
F07098	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Slope, running	0.8%	Yes					n/a	$ -	
F07099	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Slope, running	1.4%	Yes					n/a	$ -	
F07100	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Surface material	Concrete	Yes					n/a	$ -	
F07101	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #3 & #4	Surface material	Concrete	Yes					n/a	$ -	
F07102	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Surface material	Concrete	Yes					n/a	$ -	
F07103	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Surface material	Concrete	Yes					n/a	$ -	
F07104	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Surface material	Concrete	Yes					n/a	$ -	
F07105	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Width	92	Yes					n/a	$ -	
F07106	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #2 & #3	Width	97	Yes					n/a	$ -	
F07107	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #3 & #4	Width	60	Yes					n/a	$ -	
F07108	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #4 & #5	Width	60	Yes					n/a	$ -	
F07109	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Width	97	Yes					n/a	$ -	
F07110	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Width	132	Yes					n/a	$ -	
F07111	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Width	132	Yes					n/a	$ -	
F07112	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Width	150	Yes					n/a	$ -	
F07113	Rotella Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Width	97	Yes					n/a	$ -	
F07438	Rotella Park		Exterior	Owned	Play Area		1-Public Unsupervised	Transfer		Clearance, parallel	99	Yes					n/a	$ -	
F07439	Rotella Park		Exterior	Owned	Play Area		1-Public Unsupervised	Transfer		Clearance, perpendicular	99	Yes					n/a	$ -	
F07440	Rotella Park		Exterior	Owned	Play Area		1-Public Unsupervised	Transfer		Depth, platform/step	24	Yes					n/a	$ -	
F07441	Rotella Park		Exterior	Owned	Play Area		1-Public Unsupervised	Transfer		Height, platform/step	14.5	Yes					n/a	$ -	
F07442	Rotella Park		Exterior	Owned	Play Area		1-Public Unsupervised	Transfer		Transfer support?	Y	Yes					n/a	$ -	
F07443	Rotella Park		Exterior	Owned	Play Area		1-Public Unsupervised	Transfer		Width, platform/step	28	Yes					n/a	$ -	
F14863	Rotella Park		Exterior	Owned	Restroom	Accessible Porta-Potty	1-Public Unsupervised	Water Closet		Clearance, parallel	99	Yes					n/a	$ -	
F14864	Rotella Park		Exterior	Owned	Restroom	Accessible Porta-Potty	1-Public Unsupervised	Water Closet		Clearance, perpendicular	99	Yes					n/a	$ -	
F14865	Rotella Park		Exterior	Owned	Restroom	Accessible Porta-Potty	1-Public Unsupervised	Water Closet		Control force	OK	Yes					n/a	$ -	
F14866	Rotella Park		Exterior	Owned	Restroom	Accessible Porta-Potty	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F14867	Rotella Park		Exterior	Owned	Restroom	Accessible Porta-Potty	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F15629	Rotella Park		Exterior	Owned	Sport Area	Basketball court	1-Public Unsupervised	Circulation Path		Both sides of court?	Y	Yes					n/a	$ -	
F15630	Rotella Park		Exterior	Owned	Sport Area	Basketball court	1-Public Unsupervised	Circulation Path		Width	OK	Yes					n/a	$ -	
F15633	Rotella Park		Exterior	Owned	Sport Area	Volleyball Court	1-Public Unsupervised	Circulation Path		Both sides of court?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15634	Rotella Park		Exterior	Owned	Sport Area	Volleyball Court	1-Public Unsupervised	Circulation Path		Connects to all elements?	Y	Yes					n/a	$ -	
F15635	Rotella Park		Exterior	Owned	Sport Area	Volleyball Court	1-Public Unsupervised	Circulation Path		Width	OK	Yes					n/a	$ -	
F16577	Rotella Park		Exterior	Owned	Walkway	To play area #2 and Pavilion	1-Public Unsupervised	Ramp		Edge protection?	Y	Yes					n/a	$ -	
F16578	Rotella Park		Exterior	Owned	Walkway	To play area #2 and Pavilion	1-Public Unsupervised	Ramp		Slope, cross	0.3%	Yes					n/a	$ -	
F16579	Rotella Park		Exterior	Owned	Walkway	To play area #2 and Pavilion	1-Public Unsupervised	Walking Surface		Slope, cross	0.3%	Yes					n/a	$ -	
F16580	Rotella Park		Exterior	Owned	Walkway	To play area #2 and Pavilion	1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F16581	Rotella Park		Exterior	Owned	Walkway	To play area #2 and Pavilion	1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F16582	Rotella Park		Exterior	Owned	Walkway	To play area #2 and Pavilion	1-Public Unsupervised	Ramp		Width	72	Yes					n/a	$ -	
F16583	Rotella Park		Exterior	Owned	Walkway	To play area #2 and Pavilion	1-Public Unsupervised	Walking Surface		Width	72	Yes					n/a	$ -	
F16584	Rotella Park		Exterior	Owned	Walkway	To play area #2 and Pavilion	1-Public Unsupervised	Walking Surface		Width	72	Yes					n/a	$ -	
F07120	Steele Street Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Access aisle?	Y	Yes					n/a	$ -	
F07121	Steele Street Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Adjacent pathway?	Y	Yes					n/a	$ -	
F07122	Steele Street Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Height, sign	79	Yes					n/a	$ -	
F07123	Steele Street Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Length	OK	Yes					n/a	$ -	
F07124	Steele Street Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, accessible	1	Yes					n/a	$ -	
F07125	Steele Street Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Pathway behind cars?	N	Yes					n/a	$ -	
F07126	Steele Street Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Sign?	Y	Yes					n/a	$ -	
F07127	Steele Street Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Slope, cross	0.4%	Yes					n/a	$ -	
F07128	Steele Street Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Slope, cross	1.5%	Yes					n/a	$ -	
F07129	Steele Street Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Surface material	Asphalt	Yes					n/a	$ -	
F07130	Steele Street Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle		Width	79	Yes					n/a	$ -	
F07131	Steele Street Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space		Width	118	Yes					n/a	$ -	
F16585	Steele Street Park		Exterior	Owned	Walkway		1-Public Unsupervised	Walking Surface		Slope, cross	0.0%	Yes					n/a	$ -	
F16586	Steele Street Park		Exterior	Owned	Walkway		1-Public Unsupervised	Walking Surface		Slope, running	0.0%	Yes					n/a	$ -	
F16587	Steele Street Park		Exterior	Owned	Walkway		1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F16588	Steele Street Park		Exterior	Owned	Walkway		1-Public Unsupervised	Walking Surface		Width	60	Yes					n/a	$ -	
F00760	Strasburg Facility	Sheriff's Office	Interior	Owned	Break Room	North End	2-Public Supervised	Appliance	Stove/Oven	Clearance, parallel	OK	Yes					n/a	$ -	
F00761	Strasburg Facility	Sheriff's Office	Interior	Owned	Break Room	North End	2-Public Supervised	Counter		Clearance, parallel	OK	Yes					n/a	$ -	
F00762	Strasburg Facility	Sheriff's Office	Interior	Owned	Break Room	North End	2-Public Supervised	Lavatory Sink		Clearance, parallel	OK	Yes					n/a	$ -	
F00763	Strasburg Facility	Sheriff's Office	Interior	Owned	Break Room	North End	2-Public Supervised	Appliance	Stove/Oven	Clearance, perpendicular	OK	Yes					n/a	$ -	
F00764	Strasburg Facility	Sheriff's Office	Interior	Owned	Break Room	North End	2-Public Supervised	Counter		Clearance, perpendicular	OK	Yes					n/a	$ -	
F00765	Strasburg Facility	Sheriff's Office	Interior	Owned	Break Room	North End	2-Public Supervised	Lavatory Sink		Clearance, perpendicular	OK	Yes					n/a	$ -	
F00766	Strasburg Facility	Sheriff's Office	Interior	Owned	Break Room	North End	2-Public Supervised	Lavatory Sink		Drain wrapped?	In cabinet	Yes					n/a	$ -	
F00767	Strasburg Facility	Sheriff's Office	Interior	Owned	Break Room	North End	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F00768	Strasburg Facility	Sheriff's Office	Interior	Owned	Break Room	North End	2-Public Supervised	Appliance	Stove/Oven	Height	36.75	Yes					n/a	$ -	
F00769	Strasburg Facility	Sheriff's Office	Interior	Owned	Break Room	North End	2-Public Supervised	Counter		Length	99	Yes					n/a	$ -	
F00770	Strasburg Facility	Sheriff's Office	Interior	Owned	Break Room	North End	2-Public Supervised	Appliance	Stove/Oven	Other attribute	OK	Yes					n/a	$ -	
F03500	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F03501	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Exercise Equipment	Free weight storage	Clearance, parallel	OK	Yes					n/a	$ -	
F03502	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Exercise Equipment	Free weight storage	Clearance, perpendicular	OK	Yes					n/a	$ -	
F03503	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F03504	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Door Gate		Clearance, pull parallel	39	Yes					n/a	$ -	
F03505	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Door Gate		Clearance, push parallel	OK	Yes					n/a	$ -	
F03506	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Door Gate		Clearance, push perpendicular	OK	Yes					n/a	$ -	
F03507	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Door Gate		Clearance, vertical	83.25	Yes					n/a	$ -	
F03508	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F03509	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Signage		Height, bottom	59.25	Yes					n/a	$ -	
F03510	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Signage		ISA?	N	Yes					n/a	$ -	
F03511	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F03512	Strasburg Facility	Sheriff's Office	Interior	Owned	Exercise Room		3-Employee Common	Signage		Location	L	Yes					n/a	$ -	
F04212	Strasburg Facility	Sheriff's Office	Interior	Owned	Holding Cell	Left of main entry	2-Public Supervised	Bench		Back support?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F04213	Strasburg Facility	Sheriff's Office	Interior	Owned	Holding Cell	Left of main entry	2-Public Supervised	Bench		Clearance, parallel	72	Yes					n/a	$ -	
F04214	Strasburg Facility	Sheriff's Office	Interior	Owned	Holding Cell	Left of main entry	2-Public Supervised	Water Closet	Combination lav/toilet	Dimension, wide side	57	Yes					n/a	$ -	
F04215	Strasburg Facility	Sheriff's Office	Interior	Owned	Holding Cell	Left of main entry	2-Public Supervised	Lavatory Sink	Combination lav/toilet	Drain wrapped?	Y	Yes					n/a	$ -	
F04216	Strasburg Facility	Sheriff's Office	Interior	Owned	Holding Cell	Left of main entry	2-Public Supervised	Lavatory Sink	Combination lav/toilet	Hardware type	Button	Yes					n/a	$ -	
F04217	Strasburg Facility	Sheriff's Office	Interior	Owned	Holding Cell	Left of main entry	2-Public Supervised	Lavatory Sink	Combination lav/toilet	Height	32.75	Yes					n/a	$ -	
F04218	Strasburg Facility	Sheriff's Office	Interior	Owned	Holding Cell	Left of main entry	2-Public Supervised	Water Closet	Combination lav/toilet	Height, flush control	24.5	Yes					n/a	$ -	
F04219	Strasburg Facility	Sheriff's Office	Interior	Owned	Holding Cell	Left of main entry	2-Public Supervised	Bench		Length	72	Yes					n/a	$ -	
F04220	Strasburg Facility	Sheriff's Office	Interior	Owned	Holding Cell	Left of main entry	2-Public Supervised	Water Closet	Combination lav/toilet	Location, flush control	W	Yes					n/a	$ -	
F04553	Strasburg Facility	Sheriff's Office	Interior	Owned	Lobby Reception	Within hallway at North side of building	2-Public Supervised	Vending Machine	Soda	Clearance, parallel	OK	Yes					n/a	$ -	
F04554	Strasburg Facility	Sheriff's Office	Interior	Owned	Lobby Reception	Within hallway at North side of building	2-Public Supervised	Vending Machine	Soda	Clearance, perpendicular	OK	Yes					n/a	$ -	
F04587	Strasburg Facility	Public Works Shops	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Clearance, parallel	OK	Yes					n/a	$ -	
F04588	Strasburg Facility	Public Works Shops	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Clearance, perpendicular	OK	Yes					n/a	$ -	
F04810	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Off weight room	3-Employee Common	Shower Compartment		Clearance, perpendicular	52.5	Yes					n/a	$ -	
F04811	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Off weight room	3-Employee Common	Shower Compartment		Control location	S	Yes					n/a	$ -	
F04812	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Off weight room	3-Employee Common	Shower Compartment		Hand spray unit?	Y	Yes					n/a	$ -	
F04813	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Off weight room	3-Employee Common	Shower Compartment		Height, shower control	40	Yes					n/a	$ -	
F04815	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Off weight room	3-Employee Common	Shower Compartment		Length, hose	60	Yes					n/a	$ -	
F04816	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Off weight room	3-Employee Common	Shower Compartment		Seat location	S	Yes					n/a	$ -	
F04817	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Off weight room	3-Employee Common	Shower Compartment		Seat type	F	Yes					n/a	$ -	
F04821	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Shower	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F04822	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Shower	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F04823	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Shower	3-Employee Common	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F04824	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Shower	3-Employee Common	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F04825	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Shower	3-Employee Common	Grab Bar	Side	Height, top	36	Yes					n/a	$ -	
F04826	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Shower	3-Employee Common	Grab Bar	Rear	Height, top	36	Yes					n/a	$ -	
F04827	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Shower	3-Employee Common	Grab Bar	Side	Length	29	Yes					n/a	$ -	
F04828	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Shower	3-Employee Common	Grab Bar	Rear	Length	16	Yes					n/a	$ -	
F04829	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room	Shower	3-Employee Common	Grab Bar	Rear	Perimeter	1.5	Yes					n/a	$ -	
F04843	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room		3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F04844	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room		3-Employee Common	Bench		Clearance, parallel	84	Yes					n/a	$ -	
F04845	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room		3-Employee Common	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F04846	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room		3-Employee Common	Door Gate		Clearance, pull parallel	39.5	Yes					n/a	$ -	
F04847	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room		3-Employee Common	Door Gate		Clearance, push parallel	OK	Yes					n/a	$ -	
F04848	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room		3-Employee Common	Door Gate		Clearance, push perpendicular	OK	Yes					n/a	$ -	
F04849	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room		3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F04850	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room		3-Employee Common	Bench		Height	18	Yes					n/a	$ -	
F04851	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room		3-Employee Common	Mirror		Height, bottom	17	Yes					n/a	$ -	
F04852	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room		3-Employee Common	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F04853	Strasburg Facility	Sheriff's Office	Interior	Owned	Locker Room		3-Employee Common	Bench		Slip resistant?	N	Yes					n/a	$ -	
F05182	Strasburg Facility	Sheriff's Office	Interior	Owned	Other Room	Processing/Intoxilyzer	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F05183	Strasburg Facility	Sheriff's Office	Interior	Owned	Other Room	Processing/Intoxilyzer	2-Public Supervised	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F05184	Strasburg Facility	Sheriff's Office	Interior	Owned	Other Room	Processing/Intoxilyzer	2-Public Supervised	Door Gate		Clearance, push parallel	OK	Yes					n/a	$ -	
F05185	Strasburg Facility	Sheriff's Office	Interior	Owned	Other Room	Processing/Intoxilyzer	2-Public Supervised	Door Gate		Clearance, push perpendicular	OK	Yes					n/a	$ -	
F05186	Strasburg Facility	Sheriff's Office	Interior	Owned	Other Room	Processing/Intoxilyzer	2-Public Supervised	Signage		Height, bottom	55.25	Yes					n/a	$ -	
F05187	Strasburg Facility	Sheriff's Office	Interior	Owned	Other Room	Processing/Intoxilyzer	2-Public Supervised	Door Gate		Height, hardware	OK	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05188	Strasburg Facility	Sheriff's Office	Interior	Owned	Other Room	Processing/Intoxilyzer	2-Public Supervised	Signage		ISA?	N	Yes					n/a	$ -	
F05189	Strasburg Facility	Sheriff's Office	Interior	Owned	Other Room	Processing/Intoxilyzer	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	
F07137	Strasburg Facility	Sheriff's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Access aisle?	Y	Yes					n/a	$ -	
F07138	Strasburg Facility	Sheriff's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Access aisle?	Y	Yes					n/a	$ -	
F07139	Strasburg Facility	Sheriff's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Cars obstruct pathway	N	Yes					n/a	$ -	
F07140	Strasburg Facility	Sheriff's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Height, sign	78	Yes					n/a	$ -	
F07141	Strasburg Facility	Sheriff's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Height, sign	70	Yes					n/a	$ -	
F07142	Strasburg Facility	Sheriff's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, accessible	2	Yes					n/a	$ -	
F07143	Strasburg Facility	Sheriff's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Sign?	Y	Yes					n/a	$ -	
F07144	Strasburg Facility	Sheriff's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Sign?	Y	Yes					n/a	$ -	
F07145	Strasburg Facility	Sheriff's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Slope, cross	0.6%	Yes					n/a	$ -	
F07146	Strasburg Facility	Sheriff's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Slope, cross	0.6%	Yes					n/a	$ -	
F07147	Strasburg Facility	Sheriff's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Slope, cross	0.6%	Yes					n/a	$ -	
F07148	Strasburg Facility	Sheriff's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Slope, running	1.2%	Yes					n/a	$ -	
F07149	Strasburg Facility	Sheriff's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Slope, running	1.2%	Yes					n/a	$ -	
F07150	Strasburg Facility	Sheriff's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Surface marking?	Y	Yes					n/a	$ -	
F07151	Strasburg Facility	Sheriff's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Surface material	Asphalt	Yes					n/a	$ -	
F07152	Strasburg Facility	Sheriff's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Van sign?	N	Yes					n/a	$ -	
F07153	Strasburg Facility	Sheriff's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Van sign?	N	Yes					n/a	$ -	
F07154	Strasburg Facility	Sheriff's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Width	64	Yes					n/a	$ -	
F07155	Strasburg Facility	Sheriff's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Width	128	Yes					n/a	$ -	
F07156	Strasburg Facility	Sheriff's Office	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Width	132	Yes					n/a	$ -	
F14877	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	39.5	Yes					n/a	$ -	
F14898	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F14899	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Lavatory Sink		Clearance, parallel	OK	Yes					n/a	$ -	
F14900	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Water Closet		Clearance, parallel	90	Yes					n/a	$ -	
F14901	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Lavatory Sink		Clearance, perpendicular	OK	Yes					n/a	$ -	
F14902	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Water Closet		Clearance, perpendicular	94.5	Yes					n/a	$ -	
F14903	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F14904	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F14905	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F14906	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F14907	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F14908	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Vertical	Clearance, to wall	1.5	Yes					n/a	$ -	
F14909	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F14910	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F14911	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Vertical	Diameter	1.5	Yes					n/a	$ -	
F14912	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Dispenser	TP	Dimension from water closet seat	7	Yes					n/a	$ -	
F14913	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Vertical	Dimension, between	3.25	Yes					n/a	$ -	
F14914	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F14915	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	29.25	Yes					n/a	$ -	
F14916	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Water Closet		Dimension, sidewall	17.25	Yes					n/a	$ -	
F14917	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F14918	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F14919	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F14920	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Dispenser	PT	Height	40	Yes					n/a	$ -	
F14921	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Dispenser	Soap	Height	42.5	Yes					n/a	$ -	
F14922	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F14923	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Mirror		Height, bottom	39.25	Yes					n/a	$ -	
F14924	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Signage		Height, bottom	59.5	Yes					n/a	$ -	
F14925	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Water Closet		Height, seat	19	Yes					n/a	$ -	
F14926	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Side	Height, top	36	Yes					n/a	$ -	
F14927	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Rear	Height, top	35.5	Yes					n/a	$ -	
F14928	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Door Gate		Kick plate?	SD	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F14929	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F14930	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F14931	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Grab Bar	Vertical	Length	18	Yes					n/a	$ -	
F14932	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Men's	2-Public Supervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F14955	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F14956	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Dispenser	PT	Clearance, parallel	OK	Yes					n/a	$ -	
F14957	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Water Closet		Clearance, parallel	95	Yes					n/a	$ -	
F14958	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Dispenser	PT	Clearance, perpendicular	OK	Yes					n/a	$ -	
F14959	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Water Closet		Clearance, perpendicular	94	Yes					n/a	$ -	
F14960	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F14961	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F14962	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F14963	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F14964	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F14965	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Grab Bar	Vertical	Clearance, to wall	1.5	Yes					n/a	$ -	
F14966	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F14967	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Grab Bar	Vertical	Diameter	1.5	Yes					n/a	$ -	
F14968	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Dispenser	TP	Dimension from water closet seat	9	Yes					n/a	$ -	
F14969	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Grab Bar	Vertical	Dimension, between	4	Yes					n/a	$ -	
F14970	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	40.5	Yes					n/a	$ -	
F14971	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F14972	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F14973	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Lavatory Sink		Dimension, knee clearance	29.25	Yes					n/a	$ -	
F14974	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Water Closet		Dimension, wide side	44	Yes					n/a	$ -	
F14975	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F14976	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F14977	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F14978	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Dispenser	PT	Height	46	Yes					n/a	$ -	
F14979	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Dispenser	Soap	Height	42.5	Yes					n/a	$ -	
F14980	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F14981	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Mirror		Height, bottom	39.5	Yes					n/a	$ -	
F14982	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Signage		Height, bottom	59.5	Yes					n/a	$ -	
F14983	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Water Closet		Height, seat	19	Yes					n/a	$ -	
F14984	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Grab Bar	Side	Height, top	36	Yes					n/a	$ -	
F14985	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Grab Bar	Rear	Height, top	35.75	Yes					n/a	$ -	
F14986	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Door Gate		Kick plate?	SD	Yes					n/a	$ -	
F14987	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F14988	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F14989	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Grab Bar	Vertical	Length	18	Yes					n/a	$ -	
F14990	Strasburg Facility	Sheriff's Office	Interior	Owned	Restroom	Women's	2-Public Supervised	Signage		Location	L	Yes					n/a	$ -	
F16589	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Threshold beveled?	Y	Yes					n/a	$ -	
F16612	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp		Accumulates water?	N	Yes					n/a	$ -	
F16613	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		2-Public Supervised	Door Gate	Secured double door entrance	Clear opening	32.5	Yes					n/a	$ -	
F16614	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F16615	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Landing		Clearance, parallel	96	Yes					n/a	$ -	
F16616	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Landing		Clearance, perpendicular	99	Yes					n/a	$ -	
F16617	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F16618	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		2-Public Supervised	Door Gate	Secured double door entrance	Clearance, pull parallel	OK	Yes					n/a	$ -	
F16619	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16620	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		2-Public Supervised	Door Gate	Secured double door entrance	Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F16621	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Clearance, push parallel	OK	Yes					n/a	$ -	
F16622	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		2-Public Supervised	Door Gate	Secured double door entrance	Clearance, push parallel	OK	Yes					n/a	$ -	
F16623	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Clearance, push perpendicular	OK	Yes					n/a	$ -	
F16624	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		2-Public Supervised	Door Gate	Secured double door entrance	Clearance, push perpendicular	OK	Yes					n/a	$ -	
F16625	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Clearance, vertical	81.5	Yes					n/a	$ -	
F16626	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		2-Public Supervised	Door Gate	Secured double door entrance	Clearance, vertical	82.5	Yes					n/a	$ -	
F16627	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F16628	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	10	Yes					n/a	$ -	
F16629	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		2-Public Supervised	Door Gate	Secured double door entrance	Kick plate?	SD	Yes					n/a	$ -	
F16630	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp		Landing?	Y	Yes					n/a	$ -	
F16631	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp		Slope, counter	1.5%	Yes					n/a	$ -	
F16632	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp		Surface material	Concrete	Yes					n/a	$ -	
F16633	Strasburg Facility	Sheriff's Office	Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp		Width	96	Yes					n/a	$ -	
F07166	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Access aisle?	Y	Yes					n/a	$ -	
F07167	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Access aisle?	Y	Yes					n/a	$ -	
F07168	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Access aisle?	Y	Yes					n/a	$ -	
F07169	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Access aisle?	Y	Yes					n/a	$ -	
F07170	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Adjacent pathway?	Y	Yes					n/a	$ -	
F07171	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #3 & #4	Adjacent pathway?	Y	Yes					n/a	$ -	
F07172	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Cars obstruct pathway	N	Yes					n/a	$ -	
F07173	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Height, sign	61	Yes					n/a	$ -	
F07174	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Height, sign	65	Yes					n/a	$ -	
F07175	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Height, sign	78	Yes					n/a	$ -	
F07176	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Height, sign	79	Yes					n/a	$ -	
F07177	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Height, sign	79	Yes					n/a	$ -	
F07178	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Length	OK	Yes					n/a	$ -	
F07179	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #3 & #4	Length	OK	Yes					n/a	$ -	
F07180	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#5	Length	OK	Yes					n/a	$ -	
F07181	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, accessible	5	Yes					n/a	$ -	
F07182	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Pathway behind cars?	N	Yes					n/a	$ -	
F07183	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Sign?	Y	Yes					n/a	$ -	
F07184	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Sign?	Y	Yes					n/a	$ -	
F07185	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Sign?	Y	Yes					n/a	$ -	
F07186	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #3 & #4	Slope, cross	0.6%	Yes					n/a	$ -	
F07187	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#5	Slope, cross	0.8%	Yes					n/a	$ -	
F07188	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Slope, cross	1.1%	Yes					n/a	$ -	
F07189	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Slope, cross	0.3%	Yes					n/a	$ -	
F07190	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Slope, cross	0.7%	Yes					n/a	$ -	
F07191	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Slope, cross	1.4%	Yes					n/a	$ -	
F07192	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Slope, cross	0.5%	Yes					n/a	$ -	
F07193	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #3 & #4	Slope, running	1.0%	Yes					n/a	$ -	
F07194	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#5	Slope, running	0.3%	Yes					n/a	$ -	
F07195	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Slope, running	0.5%	Yes					n/a	$ -	
F07196	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Slope, running	0.4%	Yes					n/a	$ -	
F07197	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Slope, running	0.1%	Yes					n/a	$ -	
F07198	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Slope, running	0.8%	Yes					n/a	$ -	
F07199	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Slope, running	0.8%	Yes					n/a	$ -	
F07200	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Slope, running	0.0%	Yes					n/a	$ -	
F07201	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Surface marking?	Y	Yes					n/a	$ -	
F07202	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #3 & #4	Surface material	Asphalt	Yes					n/a	$ -	
F07203	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Surface material	Asphalt	Yes					n/a	$ -	
F07204	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Van sign?	N	Yes					n/a	$ -	
F07205	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Van sign?	N	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07206	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Van sign?	N	Yes					n/a	$ -	
F07207	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Width	62	Yes					n/a	$ -	
F07208	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	Between parking spaces #3 & #4	Width	80	Yes					n/a	$ -	
F07209	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#5	Width	62	Yes					n/a	$ -	
F07210	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Width	106	Yes					n/a	$ -	
F07211	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Width	111	Yes					n/a	$ -	
F07212	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Width	107	Yes					n/a	$ -	
F07213	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Width	112	Yes					n/a	$ -	
F07214	Twin Lakes Park		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#5	Width	108	Yes					n/a	$ -	
F14998	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F14999	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clear opening	32	Yes					n/a	$ -	
F15000	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	OK	Yes					n/a	$ -	
F15001	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	OK	Yes					n/a	$ -	
F15002	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar		Clearance, to wall	1.5	Yes					n/a	$ -	
F15003	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar		Diameter	1.5	Yes					n/a	$ -	
F15004	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	8	Yes					n/a	$ -	
F15005	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Dimension, characters	4.5	Yes					n/a	$ -	
F15006	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F15007	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F15008	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	Y	Yes					n/a	$ -	
F15009	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F15010	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Hardware type	PP	Yes					n/a	$ -	
F15011	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Height	43	Yes					n/a	$ -	
F15012	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Height	33	Yes					n/a	$ -	
F15013	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Height, bottom	55.75	Yes					n/a	$ -	
F15014	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Height, seat	18.75	Yes					n/a	$ -	
F15015	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar		Height, top	34.5	Yes					n/a	$ -	
F15016	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F15017	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar		Length	OK	Yes					n/a	$ -	
F15018	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Self-closing?	Y	Yes					n/a	$ -	
F15019	Twin Lakes Park		Exterior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F15039	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F15040	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F15041	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Clearance, parallel	99	Yes					n/a	$ -	
F15042	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Clearance, parallel	41	Yes					n/a	$ -	
F15043	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	99	Yes					n/a	$ -	
F15044	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Clearance, parallel	99	Yes					n/a	$ -	
F15045	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Clearance, perpendicular	60	Yes					n/a	$ -	
F15046	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Clearance, perpendicular	OK	Yes					n/a	$ -	
F15047	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	53	Yes					n/a	$ -	
F15048	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Clearance, perpendicular	85	Yes					n/a	$ -	
F15049	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, pull parallel	24	Yes					n/a	$ -	
F15050	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F15051	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F15052	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F15053	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F15054	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, vertical	80.5	Yes					n/a	$ -	
F15055	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Closing speed	5	Yes					n/a	$ -	
F15056	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F15057	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F15058	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Dimension, characters	5	Yes					n/a	$ -	
F15059	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	28	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15060	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, sidewall	16	Yes					n/a	$ -	
F15061	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F15062	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F15063	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Height	42	Yes					n/a	$ -	
F15064	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Height	43.5	Yes					n/a	$ -	
F15065	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Height	32	Yes					n/a	$ -	
F15066	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Height, top	34.5	Yes					n/a	$ -	
F15067	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F15068	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F15069	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F15070	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Opening force	4	Yes					n/a	$ -	
F15071	Twin Lakes Park		Exterior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F16634	Twin Lakes Park		Exterior	Owned	Walkway	Parking lot to play area	1-Public Unsupervised	Walking Surface		Slope, cross	1.2%	Yes					n/a	$ -	
F16635	Twin Lakes Park		Exterior	Owned	Walkway	Parking lot to play area	1-Public Unsupervised	Walking Surface		Slope, running	4.6%	Yes					n/a	$ -	
F16636	Twin Lakes Park		Exterior	Owned	Walkway	Parking lot to play area	1-Public Unsupervised	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F16637	Twin Lakes Park		Exterior	Owned	Walkway	Parking lot to play area	1-Public Unsupervised	Walking Surface		Width	60	Yes					n/a	$ -	
F16644	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	#1	Accumulates water?	N	Yes					n/a	$ -	
F16645	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	#2	Accumulates water?	N	Yes					n/a	$ -	
F16646	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp		Accumulates water?	N	Yes					n/a	$ -	
F16647	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	#2	Landing, parallel dimension	99	Yes					n/a	$ -	
F16648	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp		Landing, parallel dimension	99	Yes					n/a	$ -	
F16649	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	#2	Landing, perpendicular dimension	48	Yes					n/a	$ -	
F16650	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp		Landing, perpendicular dimension	60	Yes					n/a	$ -	
F16651	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	#2	Landing?	Y	Yes					n/a	$ -	
F16652	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp		Slope, counter	1.0%	Yes					n/a	$ -	
F16653	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	#1	Slope, counter	1.6%	Yes					n/a	$ -	
F16654	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	#2	Slope, counter	0.4%	Yes					n/a	$ -	
F16655	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp		Slope, cross	0.5%	Yes					n/a	$ -	
F16656	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	#2	Slope, cross	0.3%	Yes					n/a	$ -	
F16657	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	#1	Slope, cross	0.9%	Yes					n/a	$ -	
F16658	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	#2	Slope, left flare	7.1%	Yes					n/a	$ -	
F16659	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	#1	Slope, running	0.0%	Yes					n/a	$ -	
F16660	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp		Slope, running	4.5%	Yes					n/a	$ -	
F16661	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	#2	Slope, running	0.6%	Yes					n/a	$ -	
F16662	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	#1	Surface material	Concrete	Yes					n/a	$ -	
F16663	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	#2	Surface material	Concrete	Yes					n/a	$ -	
F16664	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	#1	Width	60	Yes					n/a	$ -	
F16665	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	#2	Width	61	Yes					n/a	$ -	
F16666	Twin Lakes Park		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp		Width	62	Yes					n/a	$ -	
F00773	Western Service Center	ACED	1st Floor	Owned	Break Room		3-Employee Common	Counter		Height	34	Yes					n/a	$ -	
F00774	Western Service Center	ACED	1st Floor	Owned	Break Room		3-Employee Common	Counter		Height	34	Yes					n/a	$ -	
F00775	Western Service Center	ACED	1st Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Height	34	Yes					n/a	$ -	
F00776	Western Service Center	ACED	1st Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Height	34	Yes					n/a	$ -	
F00777	Western Service Center	ACED	1st Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Other attribute	In Cabinet	Yes					n/a	$ -	
F00778	Western Service Center	ACED	1st Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Other attribute	In Cabinet	Yes					n/a	$ -	
F00779	Western Service Center	ACED	1st Floor	Owned	Break Room		3-Employee Common	Turning Space		T-space provided?	Y	Yes					n/a	$ -	
F00783	Western Service Center	DMV	1st Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Other attribute	In Cabinet	Yes					n/a	$ -	
F00794	Western Service Center		3rd Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Other attribute	In Cabinet	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00795	Western Service Center		2nd Floor	Owned	Break Room		3-Employee Common	Lavatory Sink		Other attribute	In Cabinet	Yes					n/a	$ -	
F03452	Western Service Center		1st Floor	Owned	Elevator		1-Public Unsupervised	Hoistway Sign		All floors?	Y	Yes					n/a	$ -	
F03453	Western Service Center		1st Floor	Owned	Elevator		1-Public Unsupervised	Elevator Car		Audible signal?	Y	Yes					n/a	$ -	
F03454	Western Service Center		1st Floor	Owned	Elevator		1-Public Unsupervised	Elevator Door		Clear opening	40	Yes					n/a	$ -	
F03455	Western Service Center		1st Floor	Owned	Elevator		1-Public Unsupervised	Elevator Car		Dimension, back to front	58	Yes					n/a	$ -	
F03456	Western Service Center		1st Floor	Owned	Elevator		1-Public Unsupervised	Elevator Car		Dimension, gap	1.25	Yes					n/a	$ -	
F03457	Western Service Center		1st Floor	Owned	Elevator		1-Public Unsupervised	Elevator Car		Dimension, side to side	78	Yes					n/a	$ -	
F03458	Western Service Center		1st Floor	Owned	Elevator		1-Public Unsupervised	Car Controls		Height, bottom	36	Yes					n/a	$ -	
F03459	Western Service Center		1st Floor	Owned	Elevator		1-Public Unsupervised	Call Control		Height, top	47	Yes					n/a	$ -	
F03460	Western Service Center		1st Floor	Owned	Elevator		1-Public Unsupervised	Car Controls		Height, top	48	Yes					n/a	$ -	
F03461	Western Service Center		1st Floor	Owned	Elevator		1-Public Unsupervised	Car Controls		Lighted?	Y	Yes					n/a	$ -	
F03462	Western Service Center		1st Floor	Owned	Elevator		1-Public Unsupervised	Position Indicators		Location	Above door	Yes					n/a	$ -	
F03463	Western Service Center		1st Floor	Owned	Elevator		1-Public Unsupervised	Emergency Communications		Provided?	Y	Yes					n/a	$ -	
F03464	Western Service Center		1st Floor	Owned	Elevator		1-Public Unsupervised	Elevator Door		Reopen device?	Y	Yes					n/a	$ -	
F03465	Western Service Center		1st Floor	Owned	Elevator		1-Public Unsupervised	Call Control		Size	1	Yes					n/a	$ -	
F03466	Western Service Center		1st Floor	Owned	Elevator		1-Public Unsupervised	Emergency Communications		Tactile?	Y	Yes					n/a	$ -	
F03467	Western Service Center		1st Floor	Owned	Elevator		1-Public Unsupervised	Call Control		Up above down?	Y	Yes					n/a	$ -	
F03468	Western Service Center		1st Floor	Owned	Elevator		1-Public Unsupervised	Call Control		Visible signal?	Y	Yes					n/a	$ -	
F03706	Western Service Center	DMV	Interior	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near restrooms	Clearance, parallel	OK	Yes					n/a	$ -	
F03707	Western Service Center	DMV	Interior	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near restrooms	Clearance, perpendicular	OK	Yes					n/a	$ -	
F03708	Western Service Center	DMV	Interior	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near restrooms	Height	35	Yes					n/a	$ -	
F03709	Western Service Center	DMV	Interior	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near restrooms	Height, water flow	4.5	Yes					n/a	$ -	
F03710	Western Service Center	DMV	Interior	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near restrooms	Spout location	2.5	Yes					n/a	$ -	
F04104	Western Service Center		2nd Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near Restrooms	Dimension, knee clearance	27	Yes					n/a	$ -	
F04105	Western Service Center		1st Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near rear restrooms	Height	35.5	Yes					n/a	$ -	
F04106	Western Service Center		1st Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near rear restrooms	Height	41	Yes					n/a	$ -	
F04107	Western Service Center		1st Floor	Owned	Hallway		1-Public Unsupervised	Drinking Fountain	Near rear restrooms	Height, water flow	4	Yes					n/a	$ -	
F04297	Western Service Center	DMV	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Clearance, parallel	OK	Yes					n/a	$ -	
F04298	Western Service Center	DMV	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Clearance, perpendicular	OK	Yes					n/a	$ -	
F04299	Western Service Center	DMV	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Dimension, knee clearance	29.25	Yes					n/a	$ -	
F04300	Western Service Center	DMV	Interior	Owned	Lobby Reception		1-Public Unsupervised	Counter		Height	33.75	Yes					n/a	$ -	
F04557	Western Service Center	DMV	1st Floor	Owned	Lobby Reception		1-Public Unsupervised	Counter		Height	33.5	Yes					n/a	$ -	
F04561	Western Service Center		3rd Floor	Owned	Lobby Reception	Diversion	1-Public Unsupervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F04562	Western Service Center		3rd Floor	Owned	Lobby Reception	Diversion	1-Public Unsupervised	Counter		Height	35	Yes					n/a	$ -	
F04567	Western Service Center		2nd Floor	Owned	Lobby Reception	Probation	1-Public Unsupervised	Door Gate		Clear opening	32	Yes					n/a	$ -	
F04568	Western Service Center		2nd Floor	Owned	Lobby Reception	Probation	1-Public Unsupervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F04569	Western Service Center		2nd Floor	Owned	Lobby Reception	Probation	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F04570	Western Service Center		2nd Floor	Owned	Lobby Reception	Probation	1-Public Unsupervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F04571	Western Service Center		2nd Floor	Owned	Lobby Reception	Probation	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F04572	Western Service Center		2nd Floor	Owned	Lobby Reception	Probation	1-Public Unsupervised	Counter		Height	30	Yes					n/a	$ -	
F04573	Western Service Center		2nd Floor	Owned	Lobby Reception	Probation	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F04863	Western Service Center		2nd Floor	Owned	Locker Room	Employee Showers	3-Employee Common	Door Gate		Clear opening	32	Yes					n/a	$ -	
F04864	Western Service Center		2nd Floor	Owned	Locker Room	Employee Showers	3-Employee Common	Lavatory Sink		Clearance, perpendicular	99	Yes					n/a	$ -	
F04865	Western Service Center		2nd Floor	Owned	Locker Room	Employee Showers	3-Employee Common	Lavatory Sink		Dimension, knee clearance	34	Yes					n/a	$ -	
F04866	Western Service Center		2nd Floor	Owned	Locker Room	Employee Showers	3-Employee Common	Bench		Height	18	Yes					n/a	$ -	
F04867	Western Service Center		2nd Floor	Owned	Locker Room	Employee Showers	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F05695	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Access aisle?	Y	Yes					n/a	$ -	
F05696	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Access aisle?	Y	Yes					n/a	$ -	
F05697	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Access aisle?	Y	Yes					n/a	$ -	
F05698	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Access aisle?	Y	Yes					n/a	$ -	
F05699	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Adjacent pathway?	Y	Yes					n/a	$ -	
F05700	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#2	Adjacent pathway?	Y	Yes					n/a	$ -	
F05701	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Height, sign	95	Yes					n/a	$ -	
F05702	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Height, sign	95	Yes					n/a	$ -	
F05703	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Height, sign	96	Yes					n/a	$ -	
F05704	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Pathway behind cars?	N	Yes					n/a	$ -	
F05705	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#2	Pathway behind cars?	N	Yes					n/a	$ -	
F05706	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Sign?	Y	Yes					n/a	$ -	
F05707	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Sign?	Y	Yes					n/a	$ -	
F05708	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Slope, cross	0.8%	Yes					n/a	$ -	
F05709	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Slope, cross	0.1%	Yes					n/a	$ -	
F05710	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Slope, cross	0.6%	Yes					n/a	$ -	
F05711	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Slope, cross	0.7%	Yes					n/a	$ -	
F05712	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Slope, cross	1.3%	Yes					n/a	$ -	
F05713	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#2	Slope, running	2.0%	Yes					n/a	$ -	
F05714	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Slope, running	1.1%	Yes					n/a	$ -	
F05715	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Surface marking?	Y	Yes					n/a	$ -	
F05716	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#2	Surface marking?	Y	Yes					n/a	$ -	
F05717	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Van sign?	N	Yes					n/a	$ -	
F05718	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Van sign?	N	Yes					n/a	$ -	
F05719	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Van sign?	N	Yes					n/a	$ -	
F05720	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#1	Width	66	Yes					n/a	$ -	
F05721	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Access Aisle	#2	Width	102	Yes					n/a	$ -	
F05722	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Width	103	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F05723	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#2	Width	102	Yes					n/a	$ -	
F05724	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#3	Width	102	Yes					n/a	$ -	
F05725	Western Service Center	DMV	Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#4	Width	102	Yes					n/a	$ -	
F07218	Western Service Center	ACED	Exterior	Owned	Parking Facility	Underground parking	5-Tenant Common	Facility Specifications		Number, total spaces	18	Yes					n/a	$ -	
F07225	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Parking Space	#2	Access aisle?	Y	Yes					n/a	$ -	
F07226	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Parking Space	#4	Access aisle?	Y	Yes					n/a	$ -	
F07227	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Access Aisle	#2	Adjacent pathway?	Y	Yes					n/a	$ -	
F07228	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Parking Space	#2	Height, sign	72	Yes					n/a	$ -	
F07229	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Parking Space	#3	Height, sign	76	Yes					n/a	$ -	
F07230	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Parking Space	#4	Height, sign	77	Yes					n/a	$ -	
F07231	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Access Aisle	#2	Pathway behind cars?	N	Yes					n/a	$ -	
F07232	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Parking Space	#2	Sign?	Y	Yes					n/a	$ -	
F07233	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Parking Space	#3	Sign?	Y	Yes					n/a	$ -	
F07234	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Parking Space	#4	Sign?	Y	Yes					n/a	$ -	
F07235	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Access Aisle	#2	Slope, cross	1.0%	Yes					n/a	$ -	
F07236	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Access Aisle	Left space	Slope, cross	1.9%	Yes					n/a	$ -	
F07237	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Parking Space	#4	Slope, cross	0.7%	Yes					n/a	$ -	
F07238	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Parking Space	#3	Slope, cross	1.5%	Yes					n/a	$ -	
F07239	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Parking Space	#2	Slope, cross	1.9%	Yes					n/a	$ -	
F07240	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Access Aisle	Left space	Surface marking?	Y	Yes					n/a	$ -	
F07241	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Access Aisle	#2	Surface marking?	Y	Yes					n/a	$ -	
F07242	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Parking Space	#2	Van sign?	Y	Yes					n/a	$ -	
F07243	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Parking Space	#3	Van sign?	Y	Yes					n/a	$ -	
F07244	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Parking Space	#4	Van sign?	Y	Yes					n/a	$ -	
F07245	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Access Aisle	#2	Width	60	Yes					n/a	$ -	
F07246	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Access Aisle	Left space	Width	104	Yes					n/a	$ -	
F07247	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Parking Space	#2	Width	115	Yes					n/a	$ -	
F07248	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Parking Space	#3	Width	108	Yes					n/a	$ -	
F07249	Western Service Center		Exterior	Owned	Parking Facility	At building walk	1-Public Unsupervised	Parking Space	#4	Width	114	Yes					n/a	$ -	
F07252	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#3 South	Access aisle?	Y	Yes					n/a	$ -	
F07253	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#1	Height, sign	78	Yes					n/a	$ -	
F07254	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#2	Height, sign	78	Yes					n/a	$ -	
F07255	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#3 South	Height, sign	77	Yes					n/a	$ -	
F07256	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#3 South	Height, sign	77	Yes					n/a	$ -	
F07257	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#4 South	Height, sign	77	Yes					n/a	$ -	
F07258	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#1	Sign?	Y	Yes					n/a	$ -	
F07259	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#2	Sign?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07260	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#3 South	Sign?	Y	Yes					n/a	$ -	
F07261	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#3 South	Sign?	Y	Yes					n/a	$ -	
F07262	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#4 South	Sign?	Y	Yes					n/a	$ -	
F07263	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Access Aisle		Slope, cross	0.0%	Yes					n/a	$ -	
F07264	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Access Aisle		Slope, cross	0.7%	Yes					n/a	$ -	
F07265	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#2	Slope, cross	0.1%	Yes					n/a	$ -	
F07266	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#1	Slope, cross	0.3%	Yes					n/a	$ -	
F07267	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#4 South	Slope, cross	0.3%	Yes					n/a	$ -	
F07268	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#3 South	Slope, cross	0.8%	Yes					n/a	$ -	
F07269	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#3 South	Slope, cross	0.8%	Yes					n/a	$ -	
F07270	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Access Aisle		Slope, running	1.4%	Yes					n/a	$ -	
F07271	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Access Aisle		Slope, running	1.8%	Yes					n/a	$ -	
F07272	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#2	Slope, running	1.3%	Yes					n/a	$ -	
F07273	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#1	Slope, running	1.5%	Yes					n/a	$ -	
F07274	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#4 South	Slope, running	1.8%	Yes					n/a	$ -	
F07275	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#3 South	Slope, running	2.0%	Yes					n/a	$ -	
F07276	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#3 South	Slope, running	2.0%	Yes					n/a	$ -	
F07277	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Access Aisle		Surface marking?	Y	Yes					n/a	$ -	
F07278	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Access Aisle		Surface marking?	Y	Yes					n/a	$ -	
F07279	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#2	Van sign?	N	Yes					n/a	$ -	
F07280	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#1	Van sign?	N	Yes					n/a	$ -	
F07281	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#3 South	Van sign?	N	Yes					n/a	$ -	
F07282	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#3 South	Van sign?	N	Yes					n/a	$ -	
F07283	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#4 South	Van sign?	N	Yes					n/a	$ -	
F07284	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Access Aisle		Width	108	Yes					n/a	$ -	
F07285	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Access Aisle		Width	108	Yes					n/a	$ -	
F07286	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#2	Width	108	Yes					n/a	$ -	
F07287	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#1	Width	108	Yes					n/a	$ -	
F07288	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#3 South	Width	108	Yes					n/a	$ -	
F07289	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#3 South	Width	108	Yes					n/a	$ -	
F07290	Western Service Center		Exterior	Owned	Parking Facility	Parking lot West of building entrance	1-Public Unsupervised	Parking Space	#4 South	Width	108	Yes					n/a	$ -	
F07294	Western Service Center		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Access aisle?	Y	Yes					n/a	$ -	
F07295	Western Service Center		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Cars obstruct pathway	N	Yes					n/a	$ -	
F07296	Western Service Center		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Height, sign	71	Yes					n/a	$ -	
F07297	Western Service Center		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, accessible	8	Yes					n/a	$ -	
F07298	Western Service Center		Exterior	Owned	Parking Facility		1-Public Unsupervised	Facility Specifications		Number, van spaces	2	Yes					n/a	$ -	
F07299	Western Service Center		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Sign?	Y	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F07300	Western Service Center		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Surface material	Asphalt	Yes					n/a	$ -	
F07301	Western Service Center		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Van sign?	Y	Yes					n/a	$ -	
F07302	Western Service Center		Exterior	Owned	Parking Facility		1-Public Unsupervised	Parking Space	#1	Width	108	Yes					n/a	$ -	
F09339	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F09340	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clear opening	32.5	Yes					n/a	$ -	
F09341	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Clearance, parallel	63	Yes					n/a	$ -	
F09342	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Clearance, perpendicular	75	Yes					n/a	$ -	
F09343	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, push parallel	OK	Yes					n/a	$ -	
F09344	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	OK	Yes					n/a	$ -	
F09345	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F09346	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F09347	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, vertical	95	Yes					n/a	$ -	
F09348	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F09349	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F09350	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	7	Yes					n/a	$ -	
F09351	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Dimension, characters	.75	Yes					n/a	$ -	
F09352	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F09353	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F09354	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F09355	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F09356	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F09357	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	Soap	Height	39.5	Yes					n/a	$ -	
F09358	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Dispenser	PT	Height	48	Yes					n/a	$ -	
F09359	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Height	32.5	Yes					n/a	$ -	
F09360	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Mirror		Height, bottom	37.5	Yes					n/a	$ -	
F09361	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Height, bottom	57.5	Yes					n/a	$ -	
F09362	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F09363	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Height, top	36	Yes					n/a	$ -	
F09364	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Height, top	36	Yes					n/a	$ -	
F09365	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F09366	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F09367	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Perimeter	42	Yes					n/a	$ -	
F09368	Western Service Center	DMV	Interior	Owned	Restroom	Men's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F09390	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F09391	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F09392	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Clearance, parallel	OK	Yes					n/a	$ -	
F09393	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Clearance, parallel	63	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F09394	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Clearance, perpendicular	OK	Yes					n/a	$ -	
F09395	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Clearance, perpendicular	75	Yes					n/a	$ -	
F09396	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, push parallel	OK	Yes					n/a	$ -	
F09397	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	OK	Yes					n/a	$ -	
F09398	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F09399	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F09400	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, vertical	95	Yes					n/a	$ -	
F09401	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F09402	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F09403	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	TP	Dimension from water closet seat	7	Yes					n/a	$ -	
F09404	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Dimension, characters	0.75	Yes					n/a	$ -	
F09405	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F09406	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	28	Yes					n/a	$ -	
F09407	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, sidewall	17.5	Yes					n/a	$ -	
F09408	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F09409	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Door Gate		Hardware type	L	Yes					n/a	$ -	
F09410	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	PT	Height	46	Yes					n/a	$ -	
F09411	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Dispenser	Soap	Height	39.5	Yes					n/a	$ -	
F09412	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Height	31.25	Yes					n/a	$ -	
F09413	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Mirror		Height, bottom	35.75	Yes					n/a	$ -	
F09414	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Height, bottom	57.5	Yes					n/a	$ -	
F09415	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Water Closet		Height, seat	18.5	Yes					n/a	$ -	
F09416	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F09417	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F09418	Western Service Center	DMV	Interior	Owned	Restroom	Women's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F15085	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Signage		Braille?	Y	Yes					n/a	$ -	
F15086	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F15087	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F15088	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Lavatory Sink	In stall	Clearance, parallel	42	Yes					n/a	$ -	
F15089	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Toilet Compartment		Clearance, parallel	82	Yes					n/a	$ -	
F15090	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Water Closet		Clearance, parallel	OK	Yes					n/a	$ -	
F15091	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Lavatory Sink	In stall	Clearance, perpendicular	48	Yes					n/a	$ -	
F15092	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Toilet Compartment		Clearance, perpendicular	60	Yes					n/a	$ -	
F15093	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Water Closet		Clearance, perpendicular	OK	Yes					n/a	$ -	
F15094	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F15095	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F15096	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15097	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F15098	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F15099	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F15100	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Vertical	Diameter	1.5	Yes					n/a	$ -	
F15101	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	40.5	Yes					n/a	$ -	
F15102	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F15103	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F15104	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Lavatory Sink	In stall	Dimension, knee clearance	29	Yes					n/a	$ -	
F15105	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F15106	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Water Closet		Dimension, wide side	42	Yes					n/a	$ -	
F15107	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Toilet Compartment		Door swing direction	Out	Yes					n/a	$ -	
F15108	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Lavatory Sink	In stall	Drain wrapped?	Y	Yes					n/a	$ -	
F15109	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Toilet Compartment		Hardware both sides?	Y	Yes					n/a	$ -	
F15110	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F15111	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Toilet Compartment		Hardware type	PP	Yes					n/a	$ -	
F15112	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Lavatory Sink	In stall	Height	33	Yes					n/a	$ -	
F15113	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Signage		Height, bottom	57.5	Yes					n/a	$ -	
F15114	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Water Closet		Height, seat	17	Yes					n/a	$ -	
F15115	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Toilet Compartment		Height, toe clearance	11	Yes					n/a	$ -	
F15116	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Side	Height, top	35.75	Yes					n/a	$ -	
F15117	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Rear	Height, top	35.75	Yes					n/a	$ -	
F15118	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F15119	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F15120	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Grab Bar	Vertical	Length	18	Yes					n/a	$ -	
F15121	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F15122	Western Service Center	ACED	1st Floor	Owned	Restroom	Men's	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F15129	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Signage		Braille?	Y	Yes					n/a	$ -	
F15130	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F15131	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F15132	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Toilet Compartment		Clearance, perpendicular	99	Yes					n/a	$ -	
F15133	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F15134	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F15135	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F15136	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F15137	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Dispenser	TP	Dimension from water closet seat	8	Yes					n/a	$ -	
F15138	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	40	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15139	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Toilet Compartment		Dimension, door to partition	4	Yes					n/a	$ -	
F15140	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F15141	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F15142	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F15143	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F15144	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Water Closet		Dimension, wide side	42	Yes					n/a	$ -	
F15145	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F15146	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Lavatory Sink		Height	33	Yes					n/a	$ -	
F15147	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Signage		Height, bottom	58	Yes					n/a	$ -	
F15148	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Water Closet		Height, seat	18	Yes					n/a	$ -	
F15149	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F15150	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Height, top	36	Yes					n/a	$ -	
F15151	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Signage		ISA?	Y	Yes					n/a	$ -	
F15152	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F15153	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F15154	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Grab Bar	Vertical	Length	18	Yes					n/a	$ -	
F15155	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F15156	Western Service Center	ACED	1st Floor	Owned	Restroom	Women's	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F15161	Western Service Center	DMV	1st Floor	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F15162	Western Service Center	DMV	1st Floor	Owned	Restroom	Unisex	3-Employee Common	Water Closet		Dimension, wide side	42	Yes					n/a	$ -	
F15174	Western Service Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F15175	Western Service Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F15176	Western Service Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F15177	Western Service Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, push parallel	22	Yes					n/a	$ -	
F15178	Western Service Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F15179	Western Service Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Door swing direction	Out	Yes					n/a	$ -	
F15180	Western Service Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Hardware both sides?	Y	Yes					n/a	$ -	
F15181	Western Service Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F15182	Western Service Center		3rd Floor	Owned	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Other attribute	3.5	Yes					n/a	$ -	
F15183	Western Service Center		1st Floor	Owned	Restroom	Men's	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F15203	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F15204	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	99	Yes					n/a	$ -	
F15205	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F15206	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F15207	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F15208	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F15209	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Door Gate		Closing speed	5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15210	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F15211	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F15212	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	11.5	Yes					n/a	$ -	
F15213	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Door swing direction	Out	Yes					n/a	$ -	
F15214	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F15215	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Alarm System		Height	88	Yes					n/a	$ -	
F15216	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F15217	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Mirror		Height, bottom	38.5	Yes					n/a	$ -	
F15218	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Water Closet		Height, seat	19	Yes					n/a	$ -	
F15219	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F15220	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Side	Height, top	34.5	Yes					n/a	$ -	
F15221	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F15222	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Toilet Compartment		Self-closing?	Y	Yes					n/a	$ -	
F15223	Western Service Center		1st Floor	Owned	Restroom	Men's - Lobby	1-Public Unsupervised	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F15225	Western Service Center		2nd Floor	Owned	Restroom	Unisex - Drug Screening Area	3-Employee Common	Water Closet		Clearance, parallel	88	Yes					n/a	$ -	
F15226	Western Service Center		2nd Floor	Owned	Restroom	Unisex - Drug Screening Area	3-Employee Common	Water Closet		Clearance, perpendicular	84	Yes					n/a	$ -	
F15227	Western Service Center		2nd Floor	Owned	Restroom	Unisex - Drug Screening Area	3-Employee Common	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F15228	Western Service Center		2nd Floor	Owned	Restroom	Unisex - Drug Screening Area	3-Employee Common	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F15229	Western Service Center		2nd Floor	Owned	Restroom	Unisex - Drug Screening Area	3-Employee Common	Dispenser	TP	Dimension from water closet seat	9	Yes					n/a	$ -	
F15230	Western Service Center		2nd Floor	Owned	Restroom	Unisex - Drug Screening Area	3-Employee Common	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	40	Yes					n/a	$ -	
F15231	Western Service Center		2nd Floor	Owned	Restroom	Unisex - Drug Screening Area	3-Employee Common	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F15232	Western Service Center		2nd Floor	Owned	Restroom	Unisex - Drug Screening Area	3-Employee Common	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F15233	Western Service Center		2nd Floor	Owned	Restroom	Unisex - Drug Screening Area	3-Employee Common	Lavatory Sink		Dimension, knee clearance	27	Yes					n/a	$ -	
F15234	Western Service Center		2nd Floor	Owned	Restroom	Unisex - Drug Screening Area	3-Employee Common	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F15235	Western Service Center		2nd Floor	Owned	Restroom	Unisex - Drug Screening Area	3-Employee Common	Water Closet		Dimension, wide side	46	Yes					n/a	$ -	
F15236	Western Service Center		2nd Floor	Owned	Restroom	Unisex - Drug Screening Area	3-Employee Common	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F15237	Western Service Center		2nd Floor	Owned	Restroom	Unisex - Drug Screening Area	3-Employee Common	Lavatory Sink		Height	34	Yes					n/a	$ -	
F15238	Western Service Center		2nd Floor	Owned	Restroom	Unisex - Drug Screening Area	3-Employee Common	Mirror		Height, bottom	40	Yes					n/a	$ -	
F15239	Western Service Center		2nd Floor	Owned	Restroom	Unisex - Drug Screening Area	3-Employee Common	Water Closet		Height, seat	17	Yes					n/a	$ -	
F15240	Western Service Center		2nd Floor	Owned	Restroom	Unisex - Drug Screening Area	3-Employee Common	Grab Bar	Side	Height, top	36	Yes					n/a	$ -	
F15241	Western Service Center		2nd Floor	Owned	Restroom	Unisex - Drug Screening Area	3-Employee Common	Grab Bar	Rear	Height, top	36	Yes					n/a	$ -	
F15242	Western Service Center		2nd Floor	Owned	Restroom	Unisex - Drug Screening Area	3-Employee Common	Grab Bar	Side	Length	48	Yes					n/a	$ -	
F15243	Western Service Center		2nd Floor	Owned	Restroom	Unisex - Drug Screening Area	3-Employee Common	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F15244	Western Service Center		2nd Floor	Owned	Restroom	Unisex - Drug Screening Area	3-Employee Common	Grab Bar	Vertical	Length	18	Yes					n/a	$ -	
F15245	Western Service Center		2nd Floor	Owned	Restroom	Unisex - Drug Screening Area	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F15255	Western Service Center		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clear opening	33	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15256	Western Service Center		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	99	Yes					n/a	$ -	
F15257	Western Service Center		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Door swing direction	Out	Yes					n/a	$ -	
F15258	Western Service Center		1st Floor	Owned	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F15267	Western Service Center		2nd Floor	Owned	Restroom	Women's - Employee	3-Employee Common	Door Gate		Clear opening	32	Yes					n/a	$ -	
F15268	Western Service Center		2nd Floor	Owned	Restroom	Women's - Employee	3-Employee Common	Door Gate		Clearance, pull perpendicular	60	Yes					n/a	$ -	
F15269	Western Service Center		2nd Floor	Owned	Restroom	Women's - Employee	3-Employee Common	Mirror		Other attribute	Full length	Yes					n/a	$ -	
F15270	Western Service Center		2nd Floor	Owned	Restroom	Women's - Employee	3-Employee Common	Alarm System		Visible alarm	Y	Yes					n/a	$ -	
F15286	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F15287	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F15288	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	97	Yes					n/a	$ -	
F15289	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	66	Yes					n/a	$ -	
F15290	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F15291	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F15292	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F15293	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F15294	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F15295	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	27	Yes					n/a	$ -	
F15296	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F15297	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Water Closet		Dimension, wide side	80.5	Yes					n/a	$ -	
F15298	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Toilet Compartment		Door swing direction	Out	Yes					n/a	$ -	
F15299	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F15300	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Coat Hook		Height	48	Yes					n/a	$ -	
F15301	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Dispenser		Height	21	Yes					n/a	$ -	
F15302	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Lavatory Sink		Height	32	Yes					n/a	$ -	
F15303	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Mirror		Height, bottom	36	Yes					n/a	$ -	
F15304	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F15305	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Grab Bar	Side	Height, top	34.5	Yes					n/a	$ -	
F15306	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Height, top	34	Yes					n/a	$ -	
F15307	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F15308	Western Service Center		1st Floor	Owned	Restroom	Women's - Lobby	1-Public Unsupervised	Toilet Compartment		Self-closing?	Y	Yes					n/a	$ -	
F15867	Western Service Center	DMV	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Clear opening	33.5	Yes					n/a	$ -	
F15868	Western Service Center	DMV	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Clearance, pull parallel	OK	Yes					n/a	$ -	
F15869	Western Service Center	DMV	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	OK	Yes					n/a	$ -	
F15870	Western Service Center	DMV	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Clearance, push parallel	OK	Yes					n/a	$ -	
F15871	Western Service Center	DMV	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Clearance, push perpendicular	OK	Yes					n/a	$ -	
F15872	Western Service Center	DMV	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Clearance, vertical	80.5	Yes					n/a	$ -	
F15873	Western Service Center	DMV	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Closing speed	5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15874	Western Service Center	DMV	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Kick plate?	N	Yes					n/a	$ -	
F15875	Western Service Center	DMV	Exterior	Owned	Walkway		1-Public Unsupervised	Door Gate		Opening force	6	Yes					n/a	$ -	
F16676	Western Service Center	DMV	Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate		Clear opening	32.25	Yes					n/a	$ -	
F16677	Western Service Center	DMV	Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F16678	Western Service Center	DMV	Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F16679	Western Service Center	DMV	Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F16680	Western Service Center	DMV	Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate		Clearance, vertical	81.5	Yes					n/a	$ -	
F16681	Western Service Center	DMV	Exterior	Owned	Walkway	From parking lot to Main entrance	1-Public Unsupervised	Door Gate		Height, smooth surface (kick plate)	10	Yes					n/a	$ -	
F16684	Western Service Center		Exterior	Owned	Walkway	From East parking lot to entrance	3-Employee Common	Walking Surface		Surface material	Concrete	Yes					n/a	$ -	
F16685	Western Service Center		Exterior	Owned	Walkway	From East parking lot to entrance	3-Employee Common	Walking Surface		Width	48	Yes					n/a	$ -	
F16692	Western Service Center		Exterior	Owned	Walkway	From nearest Bus Stop to entrance	1-Public Unsupervised	Curb Ramp	At 122nd & Pecos	Slope, counter	0.9%	Yes					n/a	$ -	
F16693	Western Service Center		Exterior	Owned	Walkway	From nearest Bus Stop to entrance	1-Public Unsupervised	Curb Ramp	At 122nd & Pecos	Slope, left flare	1.0%	Yes					n/a	$ -	
F16694	Western Service Center		Exterior	Owned	Walkway	From nearest Bus Stop to entrance	1-Public Unsupervised	Curb Ramp	At 122nd & Pecos	Slope, right flare	7.9%	Yes					n/a	$ -	
F16695	Western Service Center		Exterior	Owned	Walkway	From nearest Bus Stop to entrance	1-Public Unsupervised	Curb Ramp	At 122nd & Pecos	Slope, running	3.2%	Yes					n/a	$ -	
F16696	Western Service Center		Exterior	Owned	Walkway	From nearest Bus Stop to entrance	1-Public Unsupervised	Walking Surface	Sidewalk	Slope, running	4.1%	Yes					n/a	$ -	
F16697	Western Service Center		Exterior	Owned	Walkway	From nearest Bus Stop to entrance	1-Public Unsupervised	Curb Ramp	At 122nd & Pecos	Surface material	Concrete	Yes					n/a	$ -	
F16698	Western Service Center		Exterior	Owned	Walkway	From nearest Bus Stop to entrance	1-Public Unsupervised	Walking Surface	Sidewalk	Surface material	Concrete	Yes					n/a	$ -	
F16699	Western Service Center		Exterior	Owned	Walkway	From nearest Bus Stop to entrance	1-Public Unsupervised	Curb Ramp	At 122nd & Pecos	Width	60	Yes					n/a	$ -	
F16700	Western Service Center		Exterior	Owned	Walkway	From nearest Bus Stop to entrance	1-Public Unsupervised	Walking Surface	Sidewalk	Width	73	Yes					n/a	$ -	
F16706	Western Service Center		Exterior	Owned	Walkway	From North parking lot to East entrance	1-Public Unsupervised	Walking Surface	From drive to sidewalk	Slope, running	1.6%	Yes					n/a	$ -	
F16707	Western Service Center		Exterior	Owned	Walkway	From North parking lot to East entrance	1-Public Unsupervised	Walking Surface	From drive to sidewalk	Width	48	Yes					n/a	$ -	
F16708	Western Service Center		Exterior	Owned	Walkway	From North parking lot to East entrance	1-Public Unsupervised	Walking Surface	At East entrance	Width	99	Yes					n/a	$ -	
F16714	Western Service Center		Exterior	Owned	Walkway	Ramp to entrance	1-Public Unsupervised	Handrail		Cross section dimension, maximum	1.5	Yes					n/a	$ -	
F16715	Western Service Center		Exterior	Owned	Walkway	Ramp to entrance	1-Public Unsupervised	Handrail		Height, top	34	Yes					n/a	$ -	
F16719	Western Service Center		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	At accessible parking spaces	Accumulates water?	N	Yes					n/a	$ -	
F16720	Western Service Center		Exterior	Owned	Walkway		1-Public Unsupervised	Ramp		Slope, cross	1.2%	Yes					n/a	$ -	
F16721	Western Service Center		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	At accessible parking spaces	Slope, left flare	0.0%	Yes					n/a	$ -	
F16722	Western Service Center		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	At accessible parking spaces	Slope, right flare	0.0%	Yes					n/a	$ -	
F16723	Western Service Center		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	At accessible parking spaces	Slope, running	6.3%	Yes					n/a	$ -	
F16724	Western Service Center		Exterior	Owned	Walkway		1-Public Unsupervised	Ramp		Slope, running	7.7%	Yes					n/a	$ -	
F16725	Western Service Center		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	At accessible parking spaces	Surface material	Concrete	Yes					n/a	$ -	
F16726	Western Service Center		Exterior	Owned	Walkway		1-Public Unsupervised	Ramp		Surface material	Concrete	Yes					n/a	$ -	
F16727	Western Service Center		Exterior	Owned	Walkway		1-Public Unsupervised	Curb Ramp	At accessible parking spaces	Width	65	Yes					n/a	$ -	
F16728	Western Service Center		Exterior	Owned	Walkway		1-Public Unsupervised	Ramp		Width	60	Yes					n/a	$ -	
F00801	Westminster Motor Vehicle		Interior	Leased	Break Room		3-Employee Common	Lavatory Sink		Dimension, knee clearance	28	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F00802	Westminster Motor Vehicle		Interior	Leased	Break Room		3-Employee Common	Lavatory Sink		Other attribute	In Cabinet	Yes					n/a	$ -	
F00803	Westminster Motor Vehicle		Interior	Leased	Break Room		3-Employee Common	Alarm System		Visible alarm	N	Yes					n/a	$ -	
F04110	Westminster Motor Vehicle		Interior	Leased	Hallway	Near Public Restroom	1-Public Unsupervised	Drinking Fountain		Clearance, parallel	99	Yes					n/a	$ -	
F04111	Westminster Motor Vehicle		Interior	Leased	Hallway	Near Public Restroom	1-Public Unsupervised	Drinking Fountain		Clearance, perpendicular	99	Yes					n/a	$ -	
F04112	Westminster Motor Vehicle		Interior	Leased	Hallway	Near Public Restroom	1-Public Unsupervised	Drinking Fountain		Control force	2	Yes					n/a	$ -	
F04113	Westminster Motor Vehicle		Interior	Leased	Hallway	Near Public Restroom	1-Public Unsupervised	Drinking Fountain		Height	34	Yes					n/a	$ -	
F04114	Westminster Motor Vehicle		Interior	Leased	Hallway	Near Public Restroom	1-Public Unsupervised	Drinking Fountain		Height, water flow	5	Yes					n/a	$ -	
F04115	Westminster Motor Vehicle		Interior	Leased	Hallway	Near Public Restroom	1-Public Unsupervised	Drinking Fountain		Spout location	3	Yes					n/a	$ -	
F04576	Westminster Motor Vehicle		Interior	Leased	Lobby Reception		1-Public Unsupervised	Counter		Height	33.5	Yes					n/a	$ -	
F07308	Westminster Motor Vehicle		Exterior	Leased	Parking Facility		1-Public Unsupervised	Parking Space		Access aisle?	Y	Yes					n/a	$ -	
F07309	Westminster Motor Vehicle		Exterior	Leased	Parking Facility		1-Public Unsupervised	Parking Space		Height, sign	61	Yes					n/a	$ -	
F07310	Westminster Motor Vehicle		Exterior	Leased	Parking Facility		1-Public Unsupervised	Access Aisle		Slope, cross	0.0%	Yes					n/a	$ -	
F07311	Westminster Motor Vehicle		Exterior	Leased	Parking Facility		1-Public Unsupervised	Parking Space		Slope, cross	0.0%	Yes					n/a	$ -	
F07312	Westminster Motor Vehicle		Exterior	Leased	Parking Facility		1-Public Unsupervised	Access Aisle		Slope, running	0.0%	Yes					n/a	$ -	
F07313	Westminster Motor Vehicle		Exterior	Leased	Parking Facility		1-Public Unsupervised	Parking Space		Slope, running	0.0%	Yes					n/a	$ -	
F07314	Westminster Motor Vehicle		Exterior	Leased	Parking Facility		1-Public Unsupervised	Access Aisle		Surface marking?	Y	Yes					n/a	$ -	
F07315	Westminster Motor Vehicle		Exterior	Leased	Parking Facility		1-Public Unsupervised	Access Aisle		Surface material	Asphalt	Yes					n/a	$ -	
F07316	Westminster Motor Vehicle		Exterior	Leased	Parking Facility		1-Public Unsupervised	Parking Space		Surface material	Asphalt	Yes					n/a	$ -	
F07317	Westminster Motor Vehicle		Exterior	Leased	Parking Facility		1-Public Unsupervised	Parking Space		Width	112	Yes					n/a	$ -	
F15324	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F15325	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F15326	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clear opening	34	Yes					n/a	$ -	
F15327	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	60	Yes					n/a	$ -	
F15328	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	99	Yes					n/a	$ -	
F15329	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	52	Yes					n/a	$ -	
F15330	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F15331	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Door Gate		Clearance, vertical	84	Yes					n/a	$ -	
F15332	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F15333	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F15334	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Signage		Dimension, characters	.75	Yes					n/a	$ -	
F15335	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4	Yes					n/a	$ -	
F15336	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F15337	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F15338	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F15339	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F15340	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Water Closet		Dimension, wide side	46	Yes					n/a	$ -	
F15341	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15342	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F15343	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Mirror		Height, bottom	39	Yes					n/a	$ -	
F15344	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Signage		Height, bottom	57	Yes					n/a	$ -	
F15345	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Water Closet		Height, seat	17	Yes					n/a	$ -	
F15346	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	
F15347	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F15348	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Height, top	36	Yes					n/a	$ -	
F15349	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F15350	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F15351	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F15352	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F15353	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F15354	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Door Gate		Opening force	5	Yes					n/a	$ -	
F15355	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F15363	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F15364	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F15365	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Water Closet		Clearance, parallel	83.5	Yes					n/a	$ -	
F15366	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Water Closet		Clearance, perpendicular	90	Yes					n/a	$ -	
F15367	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F15368	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F15369	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Grab Bar	Vertical	Clearance, to wall	1.5	Yes					n/a	$ -	
F15370	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Door Gate		Clearance, vertical	80	Yes					n/a	$ -	
F15371	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F15372	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	40	Yes					n/a	$ -	
F15373	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Signage		Dimension, characters	.75	Yes					n/a	$ -	
F15374	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F15375	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F15376	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F15377	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Water Closet		Dimension, wide side	41.5	Yes					n/a	$ -	
F15378	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Mirror		Height, bottom	38	Yes					n/a	$ -	
F15379	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Signage		Height, bottom	52	Yes					n/a	$ -	
F15380	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F15381	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Grab Bar	Side	Height, top	36	Yes					n/a	$ -	
F15382	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Grab Bar	Rear	Height, top	36	Yes					n/a	$ -	
F15383	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F15384	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15385	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F15386	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Signage		Location	L	Yes					n/a	$ -	
F15387	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F15388	Westminster Motor Vehicle		Interior	Leased	Restroom	Men's - Election Facility	1-Public Unsupervised	Alarm System		Visible alarm	N	Yes					n/a	$ -	
F15399	Westminster Motor Vehicle		Interior	Leased	Restroom	Unisex	3-Employee Common	Signage		Braille?	Y	Yes					n/a	$ -	
F15400	Westminster Motor Vehicle		Interior	Leased	Restroom	Unisex	3-Employee Common	Door Gate		Clear opening	33	Yes					n/a	$ -	
F15401	Westminster Motor Vehicle		Interior	Leased	Restroom	Unisex	3-Employee Common	Water Closet		Clearance, parallel	60	Yes					n/a	$ -	
F15402	Westminster Motor Vehicle		Interior	Leased	Restroom	Unisex	3-Employee Common	Water Closet		Clearance, perpendicular	84	Yes					n/a	$ -	
F15403	Westminster Motor Vehicle		Interior	Leased	Restroom	Unisex	3-Employee Common	Door Gate		Clearance, vertical	80	Yes					n/a	$ -	
F15404	Westminster Motor Vehicle		Interior	Leased	Restroom	Unisex	3-Employee Common	Lavatory Sink		Dimension, knee clearance	28	Yes					n/a	$ -	
F15405	Westminster Motor Vehicle		Interior	Leased	Restroom	Unisex	3-Employee Common	Door Gate		Hardware type	L	Yes					n/a	$ -	
F15406	Westminster Motor Vehicle		Interior	Leased	Restroom	Unisex	3-Employee Common	Lavatory Sink		Height	32	Yes					n/a	$ -	
F15407	Westminster Motor Vehicle		Interior	Leased	Restroom	Unisex	3-Employee Common	Signage		Height, bottom	57	Yes					n/a	$ -	
F15408	Westminster Motor Vehicle		Interior	Leased	Restroom	Unisex	3-Employee Common	Water Closet		Height, seat	19	Yes					n/a	$ -	
F15409	Westminster Motor Vehicle		Interior	Leased	Restroom	Unisex	3-Employee Common	Signage		ISA?	Y	Yes					n/a	$ -	
F15410	Westminster Motor Vehicle		Interior	Leased	Restroom	Unisex	3-Employee Common	Signage		Location	L	Yes					n/a	$ -	
F15411	Westminster Motor Vehicle		Interior	Leased	Restroom	Unisex	3-Employee Common	Fixture Count		Number, toilet compartments	1	Yes					n/a	$ -	
F15412	Westminster Motor Vehicle		Interior	Leased	Restroom	Unisex	3-Employee Common	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F15428	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F15429	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F15430	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clear opening	35	Yes					n/a	$ -	
F15431	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, parallel	65	Yes					n/a	$ -	
F15432	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Clearance, perpendicular	99	Yes					n/a	$ -	
F15433	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Door Gate		Clearance, vertical	80	Yes					n/a	$ -	
F15434	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F15435	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F15436	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Dimension, door to partition	4	Yes					n/a	$ -	
F15437	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F15438	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F15439	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	28	Yes					n/a	$ -	
F15440	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F15441	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Water Closet		Dimension, wide side	42	Yes					n/a	$ -	
F15442	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Door swing direction	In	Yes					n/a	$ -	
F15443	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Door Gate		Hardware type	PP	Yes					n/a	$ -	
F15444	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Signage		Height, bottom	57	Yes					n/a	$ -	
F15445	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Water Closet		Height, seat	17.5	Yes					n/a	$ -	
F15446	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Toilet Compartment		Height, toe clearance	12	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15447	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F15448	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F15449	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F15450	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Door Gate		Opening force	4	Yes					n/a	$ -	
F15451	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F15461	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Signage		Braille?	Y	Yes					n/a	$ -	
F15462	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Door Gate		Clear opening	33.5	Yes					n/a	$ -	
F15463	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Water Closet		Clearance, parallel	92.5	Yes					n/a	$ -	
F15464	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Water Closet		Clearance, perpendicular	83	Yes					n/a	$ -	
F15465	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Grab Bar	Side	Clearance, to wall	1.5	Yes					n/a	$ -	
F15466	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F15467	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Door Gate		Clearance, vertical	80	Yes					n/a	$ -	
F15468	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F15469	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F15470	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Grab Bar	Vertical	Diameter	1.5	Yes					n/a	$ -	
F15471	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	40	Yes					n/a	$ -	
F15472	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Signage		Dimension, characters	.75	Yes					n/a	$ -	
F15473	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F15474	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	29	Yes					n/a	$ -	
F15475	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Water Closet		Dimension, wide side	50.5	Yes					n/a	$ -	
F15476	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F15477	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F15478	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F15479	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Mirror		Height, bottom	38	Yes					n/a	$ -	
F15480	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Signage		Height, bottom	53	Yes					n/a	$ -	
F15481	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Water Closet		Height, seat	18	Yes					n/a	$ -	
F15482	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Grab Bar	Side	Height, top	35	Yes					n/a	$ -	
F15483	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Grab Bar	Rear	Height, top	35	Yes					n/a	$ -	
F15484	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Signage		ISA?	Y	Yes					n/a	$ -	
F15485	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F15486	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F15487	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Grab Bar	Vertical	Length	18	Yes					n/a	$ -	
F15488	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F15489	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Signage		Tactile letters?	Y	Yes					n/a	$ -	
F15490	Westminster Motor Vehicle		Interior	Leased	Restroom	Women's - Election Facility	1-Public Unsupervised	Alarm System		Visible alarm	N	Yes					n/a	$ -	
F16733	Westminster Motor Vehicle		Exterior	Leased	Walkway	To employee entrance	3-Employee Common	Door Gate		Clear opening	32.5	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16734	Westminster Motor Vehicle		Exterior	Leased	Walkway	To employee entrance	3-Employee Common	Door Gate		Clearance, vertical	83	Yes					n/a	$ -	
F16741	Westminster Motor Vehicle		Exterior	Leased	Walkway		1-Public Unsupervised	Curb Ramp		Accumulates water?	N	Yes					n/a	$ -	
F16742	Westminster Motor Vehicle		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate	Main entrance	Clear opening	37	Yes					n/a	$ -	
F16743	Westminster Motor Vehicle		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate	Main entrance	Clearance, vertical	83	Yes					n/a	$ -	
F16744	Westminster Motor Vehicle		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate	Main entrance	Closing speed	10	Yes					n/a	$ -	
F16745	Westminster Motor Vehicle		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate	Main entrance	Hardware type	Auto	Yes					n/a	$ -	
F16746	Westminster Motor Vehicle		Exterior	Leased	Walkway		1-Public Unsupervised	Curb Ramp		Landing?	Y	Yes					n/a	$ -	
F16747	Westminster Motor Vehicle		Exterior	Leased	Walkway		1-Public Unsupervised	Curb Ramp		Slope, counter	1.5%	Yes					n/a	$ -	
F16748	Westminster Motor Vehicle		Exterior	Leased	Walkway		1-Public Unsupervised	Curb Ramp		Slope, cross	1.0%	Yes					n/a	$ -	
F16749	Westminster Motor Vehicle		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate	Main entrance	Slope, cross	1.0%	Yes					n/a	$ -	
F16750	Westminster Motor Vehicle		Exterior	Leased	Walkway		1-Public Unsupervised	Curb Ramp		Slope, running	7.1%	Yes					n/a	$ -	
F16751	Westminster Motor Vehicle		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate	Main entrance	Slope, running	1.0%	Yes					n/a	$ -	
F16752	Westminster Motor Vehicle		Exterior	Leased	Walkway		1-Public Unsupervised	Curb Ramp		Surface material	Concrete	Yes					n/a	$ -	
F16753	Westminster Motor Vehicle		Exterior	Leased	Walkway		1-Public Unsupervised	Door Gate	Main entrance	Threshold beveled?	Y	Yes					n/a	$ -	
F00805	Whittier Public Works Support Facility		Interior	Owned	Break Room		1-Public Unsupervised	Appliance	Microwave	Height	42	Yes					n/a	$ -	
F00806	Whittier Public Works Support Facility		Interior	Owned	Break Room		1-Public Unsupervised	Appliance	Refrigerator	Height	48	Yes					n/a	$ -	
F00807	Whittier Public Works Support Facility		Interior	Owned	Break Room		1-Public Unsupervised	Lavatory Sink		Height	34	Yes					n/a	$ -	
F00808	Whittier Public Works Support Facility		Interior	Owned	Break Room		1-Public Unsupervised	Lavatory Sink		Other attribute	In Cabinet	Yes					n/a	$ -	
F04579	Whittier Public Works Support Facility		Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F04580	Whittier Public Works Support Facility		Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F04581	Whittier Public Works Support Facility		Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F04582	Whittier Public Works Support Facility		Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	
F04583	Whittier Public Works Support Facility		Interior	Owned	Lobby Reception		1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F15496	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Clear opening	33	Yes					n/a	$ -	
F15497	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Water Closet		Clearance, parallel	99	Yes					n/a	$ -	
F15498	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Water Closet		Clearance, perpendicular	85	Yes					n/a	$ -	
F15499	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Clearance, pull parallel	99	Yes					n/a	$ -	
F15500	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Clearance, pull perpendicular	99	Yes					n/a	$ -	
F15501	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Clearance, push parallel	99	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F15502	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Door Gate		Clearance, push perpendicular	99	Yes					n/a	$ -	
F15503	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Grab Bar	Rear	Clearance, to wall	1.5	Yes					n/a	$ -	
F15504	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Grab Bar	Side	Diameter	1.5	Yes					n/a	$ -	
F15505	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Grab Bar	Rear	Diameter	1.5	Yes					n/a	$ -	
F15506	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Grab Bar	Vertical	Dimension, centerline to wall (vertical)	40	Yes					n/a	$ -	
F15507	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Grab Bar	Side	Dimension, end to wall	12	Yes					n/a	$ -	
F15508	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Grab Bar	Rear	Dimension, end to wall	6	Yes					n/a	$ -	
F15509	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Lavatory Sink		Dimension, knee clearance	28	Yes					n/a	$ -	
F15510	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Water Closet		Dimension, sidewall	18	Yes					n/a	$ -	
F15511	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Water Closet		Dimension, wide side	42	Yes					n/a	$ -	
F15512	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Lavatory Sink		Drain wrapped?	Y	Yes					n/a	$ -	
F15513	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Lavatory Sink		Hardware type	L	Yes					n/a	$ -	
F15514	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Lavatory Sink		Height	32	Yes					n/a	$ -	
F15515	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Mirror		Height, bottom	39	Yes					n/a	$ -	
F15516	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Water Closet		Height, seat	17.5	Yes					n/a	$ -	
F15517	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Grab Bar	Side	Height, top	36	Yes					n/a	$ -	
F15518	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Grab Bar	Rear	Height, top	36	Yes					n/a	$ -	
F15519	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Grab Bar	Side	Length	42	Yes					n/a	$ -	
F15520	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Grab Bar	Rear	Length	36	Yes					n/a	$ -	
F15521	Whittier Public Works Support Facility		Interior	Owned	Restroom	Unisex	1-Public Unsupervised	Water Closet		Location, flush control	W	Yes					n/a	$ -	
F16758	Whittier Public Works Support Facility		Exterior	Owned	Walkway		3-Employee Common	Door Gate	Main entrance	Clear opening	32.75	Yes					n/a	$ -	
F16759	Whittier Public Works Support Facility		Exterior	Owned	Walkway		3-Employee Common	Door Gate	Main entrance	Clearance, pull parallel	99	Yes					n/a	$ -	
F16760	Whittier Public Works Support Facility		Exterior	Owned	Walkway		3-Employee Common	Door Gate	Main entrance	Clearance, pull perpendicular	99	Yes					n/a	$ -	
F16761	Whittier Public Works Support Facility		Exterior	Owned	Walkway		3-Employee Common	Door Gate	Main entrance	Clearance, push perpendicular	99	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments
F16762	Whittier Public Works Support Facility		Exterior	Owned	Walkway		3-Employee Common	Door Gate	Main entrance	Clearance, vertical	83	Yes					n/a	$ -	

Record Number	Facility	Facility Description	Area	Owned/ Leased	Room/Space	Room/Space Description	Room/Space Type	Element	Element Description	Attribute	On-Site Value	Compliant	Finding	Priority	Recommendation	Recomm Value	Planned Year of Completion	Estimate Cost (ROM)	Notes / Comments

Compliant	
10655	Yes
61	Not best practice
2970	N/A
3280	No
16966	Totals

Total Counts of Deficiencies

Total Estimates for Transition Plan	575	2016	$ 20,100.00	
	774	2017	$ 1,233,105.00	$ 2,709,955.00
	292	2018	$ 376,550.00	
Total Addressed:	341	2019	$ 435,900.00	
2177	195	2020	$ 644,300.00	
Total Deferred:	612	None	$ 267,150.00	
1141	529	When Renovated	$ -	$ 269,650.00
Total N/A:	**13635**	n/a	$ 2,500.00	
12/28/2015	16953	Totals	$ 2,979,605.00	

ADAMS COUNTY
COLORADO

Americans with Disabilities Act (ADA) Transition Plan for Public Right-of-Way in Unincorporated Adams County, Colorado

Original Plan Prepared in 2015

This publication has been prepared by Alfred Benesch & Company in partnership with the Adams County Transportation Department.

All information contained herein is expressly prepared for the sole use of Adams County. Should any portion of this publication be duplicated elsewhere, we request appropriate attribution for such usage.

TABLE OF CONTENTS

Executive Summary 1

Transition Plan 2

I. Introduction & Project Background 2
II. ADA Coordinator Role & Responsibilities 2
III. Self-Evaluation 3
IV. Public Involvement 4
V. Public Information Sharing & Grievance Procedure 5
VI. Design Standards & Specifications 5
VII. Prioritize and Identify Goals, Strategies, & Schedules 6
VIII. Monitoring & Updating Plan 8

Appendices

A. Definitions
B. County Policy Regarding the ADA
C. ADA Coordinator Contact Info
D. Inventory of Public Facilities Assessed
E. Overview of Assessment Attributes/Parameters
F. Assessment Findings
G. Public Involvement Documentation
H. Complaint & Grievance Procedure
I. ADA Design and Construction Exception Form
J. Example Summary of Work Completed towards Transition Plan Implementation

EXECUTIVE SUMMARY

Adams County has prepared this Americans with Disabilities Act (ADA) Transition Plan based upon self-evaluation findings, public outreach, and collaboration with citizens, stakeholders, and partners throughout the County. This plan establishes guidance for addressing and improving accessibility with the County's transportation system. The success of making our transportation system fully accessible will require a coordinated effort by the County and other public sector, private sector, and citizen partners to utilize the guidelines and strategies outlined in this plan. Beyond this plan, Adams County is committed to identifying and enacting opportunities to involve citizens, stakeholders and partners in the implementation of this plan, future updates to the plan, and in policy decisions affecting accessibility with the goal of achieving a better, more accessible, safe, efficient, and sustainable transportation network for all users.

ADAMS COUNTY ADA TRANSITION PLAN

I. Introduction & Project Background

The purpose of this Transition Plan is to identify facilities, guidelines, standards, policies, procedures, and/or practices currently utilized or recommended for use to minimize or eliminate barriers to accessibility within unincorporated Adams County's transportation network. The Plan is a living document to be reviewed and updated periodically.

The Americans with Disabilities Act (ADA), enacted on July 26, 1990, is a civil rights law prohibiting discrimination against individuals on the basis of disability. The ADA consists of five titles outlining protections in the following areas:

- Employment
- State and local government services
- Public accommodations
- Telecommunications
- Miscellaneous Provisions

Title II of ADA pertains to the programs, activities and services public entities provide and extends the application of the ADA to include those provided by all state and local government entities. As such, public transportation services and programs, including those provided by Adams County, must comply with the appropriate sections of the ADA. The ADA requires the ADA Transition Plan be submitted for public review before final approval and adoption.

Title II of ADA, 28 CFR. Part 35 Sec. 35.105 and Sec. 35.150 requires agencies to conduct a self-evaluation of its facilities and develop a Transition Plan to outline how reasonable accessibility improvements for individuals, when needed, will be addressed for facilities, services, programs and activities. This plan includes the findings of the self-evaluation and addresses areas of potential improvement as they pertain to the County's transportation network. This Plan also identifies alternative methods of service delivery permissible under 28 CFR Part 35. l 50(a) and (b). While the ADA requires agencies to provide accessibility to all of its services, it is not required to remove all architectural barriers in all of its facilities.

The Plan also addresses training provided regarding guidelines, standards, policies, procedures, and/or practices to minimize or eliminate barriers to access within Adams County's transportation network.

II. ADA Coordinator Role & Responsibilities

The ADA requires public entities with fifty (50) or more employees to designate one or more individuals as responsible employees for monitoring compliance with and investigating potential violations of the ADA. This individual(s) is the primary point of contact for individuals with disabilities to:

- Request auxiliary aids and services, policy modifications, and other accommodations;
- File a complaint with the County regarding accessibility to County programs, activities and services; and/or
- Address ADA concerns from the general public and from other departments and employees of the public entity.

Appendix C identifies the office, address, and telephone number of the ADA Coordinator(s) for unincorporated Adams County.

III. Self-Evaluation

The County's transportation network is defined as all roadways, sidewalks, on-system shared-use trails, curb ramps, bridges, and other pathways designated for public transportation within the unincorporated limits and ROW of the County. This plan is intended to address accessibility adjacent to or crossing roadways and bridges and accessibility on facilities designated for shared-use or non-vehicular public transportation. The transportation network does not include facilities maintained by or owned by other agencies or private entities within the jurisdictional boundaries of the County.

The County has identified a comprehensive evaluation plan consisting of physical review and measurement of sidewalks and other pedestrian transportation assets adjacent to or crossing roadways and bridges. Specifically, the County has evaluated:

- Curb Ramps
- Sidewalks
- Pedestrian Push Buttons

This evaluation is based on the 2011 Proposed Guidelines for Pedestrian Facilities in the Public Right-of-Way (PROWAG) published by the United States Access Board. The PROWAG document has not been adopted or approved. PROWAG is recognized as a best practice and has been recommended for use by the Federal Highway Administration (FHWA). Compliance or non-compliance as noted herein, is in reference to PROWAG, assuming it is the standard by which accessibility should be measured.

Adams County has a step by step process of how different aspects of accessibility within the County's transportation network are measured and captured.

In determining the compliancy of the existing assets addressed under this plan, the County inventoried each location within the urbanized or sub-urbanized, unincorporated areas of the County in 2015 and documented the following:

- Curb ramp presence, configuration, geometry, grades, and condition
- Detectable warnings panel presence, geometry, contrast, and condition
- Maneuvering area clearance from parallel vehicle traffic
- Landing area presence, configuration, geometry, grades, and condition
- Pedestrian push button presence, location, and accessibility
- Sidewalk presence, width, cross slope, and condition

To be compliant under PROWAG, these features must satisfy established criteria specific to each asset type and purpose. If one criteria of an asset is non-compliant, the asset technically does not meet accessibility requirements even though it may be substantially compliant. Appendix D, E, and F provide information related to the assets surveyed, summary of findings, and detailed findings. This information has been added to the County's GIS database for easy reference and query for internal staff. It should be noted, all information related to the findings is based upon the self-assessment performed in 2015.

The County has approximately 2,900 locations with curb ramps present and constructed to old or non-compliant standards. These locations, while not fully compliant, provide some degree of accessibility. Based upon the self-assessment survey, approximately 2% of the curb ramp locations were fully compliant and provided compliant accessibility. Of the locations assessed, 327 need curb ramps added to provide full accessibility at those locations. Approximately 1,900 locations did not have an acceptable detectable warning panel present. [1] The most prevalent issues with non-compliant curb ramps included improper landing slopes and/or dimensions; improper cross slope or geometry along the ramp or at the curb drop; and/or vertical obstructions in the travel path.

The County has approximately 314 miles of existing sidewalk in the 4,400 sidewalk segments along the transportation network in the unincorporated area. Based on the self-assessment, over 90% of the segments meet running slope requirement and are free of obstructions. The most prevalent issues encountered on non-compliant sidewalk segments included improper width, excessive cross slope at driveway crossings, and/or faulted or separated joints and cracks in the travel path. These issues either singularly or in combination were present on 50-75% of the segments assessed. Approximately 150 sidewalk segments did not provide connectivity to another sidewalk along the transportation network. The majority of these were located in corridors with undeveloped pedestrian features where future development should provide connectivity.

It should be noted for locations with non-compliant curb ramp and/or sidewalk segments, an accessible route may exist within reasonable proximity to some of these locations.

Based on the self-assessment, approximately 75% of the locations with pedestrian push buttons have the buttons mounted properly in accessible locations. For those non-compliant mountings, the most prevalent issues are improper mounting height and/or being mounted in an inaccessible location on the pole.

The ADA requires the County to evaluate current policies and practices to identify and correct any barriers inconsistent with the intent of the law. County representatives have examined current practices and policies related to the ADA and identified gaps in information or training to address as part of this Transition Plan. To further refine and understand accessibility issues needing addressed, the County plans on continuing to meet with staff to review policies, practices, and institutional knowledge regarding the following:

- The nature of programs,
- Forms and methods to advertise and communicate program's services or activities,
- Level of staff training, and
- Accommodations made for individuals with disabilities to access these services.

IV. Public Involvement Used in Transition Plan Development

The self-assessment phase included creating and distributing information about the development of the Plan to encourage the public, advocacy groups, and other stakeholders to provide input and identify areas of concern. In addition to providing traditional means of communication (e.g., paper informational handouts, press releases, targeted communications), a Transition Plan Development webpage was provided within the County's website specifically intended for providing updates and soliciting input. The

[1] NOTE: Detectable warning panels were not introduced as a requirement until 2001 and ramps constructed before 2001 without detectable warning panels are not considered non-compliant until the alterations threshold is met.

primary means of soliciting input for the Plan occurred using a public survey made available in a variety of formats. Appendix G contains a copy of the survey materials and responses received.

A public open house was held at the Adams County Government Conference Center, a fully accessible facility, on August 6, 2015. Notifications for the event followed standard County procedures. The open house included a presentation regarding the Plan goals and an update on the progress to date. The open house also provided an opportunity for interested parties to visit with the Plan development team and provide input on areas of concern.

The input received from the survey and meeting initiatives was evaluated and included in the Plan. A draft version of the Plan was made available to the public and feedback was evaluated and the Plan modified as deemed appropriate by the Plan development team.

A second public open house was held at the same Adams County Government Conference Center facility, on December 8, 2015. Notifications for the event were sent out via standard County public notice procedures, the County's project website, and on the Adams County Facebook page. The open house included a presentation of the Transition Plan draft and findings from the self-evaluation. The open house also provided an opportunity for interested parties to visit with the Plan development team and provide input on the draft Transition Plan.

The Plan will continuously be available by contacting the ADA Coordinator or on the County's website http://www.adcogov.org (keyword search "ADA Transition Plan").

V. Public Information Sharing & Grievance Procedure

Adams County will make available to all applicants, participants, beneficiaries, and interested persons information regarding the provisions of the ADA and its applicability to the services, programs or activities of the County.

Adams County is committed to sharing information with the public regarding efforts to improve accessibility within the County's jurisdiction. Information sharing occurs through contact with the ADA Coordinator, the County's webpage on ADA Compliance located at http://www.adcogov.org (keyword search "ADA Coordinator"); public meetings and town hall sessions, press releases and other public notifications; and other typical methodologies used by the County and the County's Public Information Office.

Appendix B identifies the process for requesting auxiliary aid or service at public meetings.

Appendix H identifies complaints and grievances procedures and responsibilities towards filing, investigating, and initiating a response.

VI. Design Standards & Specifications

The ADA Standards and Specifications described in this section are intended to apply to all construction within unincorporated Adams County public Right-of-Way required to adhere to County requirements.

The County maintains standard details and construction specifications for transportation assets intended to provide accessibility within the transportation network. The County standards are available at http://www.adcogov.org (keyword search "Engineering Road Standards")

For assets constructed not specifically addressed by those details and specifications, the County typically utilizes Colorado Department of Transportation requirements. CDOT standards are available at:

> https://www.codot.gov/business/designsupport/standard-plans/2012-m-standards-plans/2012-m-standards-pdfs/ or https://www.codot.gov (keyword search "Standard Plans")

In an effort to account for construction tolerances and to avoid exceeding listed thresholds, designers and construction crews shall use specified slopes and dimensions below the maximum or are above the minimum requirements stated in these standards while maintaining positive drainage.

In alterations to existing facilities, where compliance with applicable standards and specifications is technically infeasible or result in undue burden, the alteration shall conform to standards to the maximum extent possible.

Such exceptions shall be documented on the ADA Design and Construction Exception Form contained in Appendix I and submitted to the ADA Coordinator for documentation.

VII. Prioritize and Identify Goals, Strategies, & Schedules

The overall goal of the Transition Plan is to improve accessibility for all users within unincorporated Adams County. In order to achieve this goal, the County continuously prioritizes the list of identified barriers, identifies strategies and methods to be used to remove barriers achievable within fiscal constraints, provides guidance to County staff and the public on the requirements of the ADA and the County's approach to improve accessibility, develops a realistic schedule based on available budget for the removal of barriers, and identifies potential funding sources and opportunities to remove barriers.

When determining the manner and options for providing accessibility, the County considers many factors including the volume of pedestrian traffic, population density, and the roadway average daily vehicle traffic volume. Considering these factors along with funding challenges, the County anticipates using the following criteria to assist in prioritizing implementation of accessibility improvements as funds become available (in order of priority).

1. Locations where adjacent roadway or infrastructure improvements are taking place
2. Locations in close proximity to public facilities and high pedestrian traffic areas such as schools, hospitals, recreation facilities, parks, etc.
3. Locations in targeted neighborhood zones
4. Locations having a higher degree of non-compliance or more significant barriers to accessibility
5. All other locations not listed above as funding and resources are available

Where possible, out-of-direction travel may be utilized to provide an accessible path, for short or long periods of time until a more direct accessible path can be provided. The County endeavors to improve accessibility annually on a priority basis considering the criteria presented above with an overall goal to have accessible paths in nearly all of these corridors in the next 30-50 years.

Locations identified from the grievance process will be addressed and prioritized on a case-by-case basis.

In general, accessibility improvements along the transportation network addressing curb ramps and sidewalks occur as part of contracted and self-performed construction projects and activities. The County has legal authority to require repairs and to order new sidewalks and accessible ramps be constructed within County Right-of-Way along properties where facilities have degraded or do not exist.

It is anticipated the majority of the accessibility improvement will be performed in conjunction with other projects and activities occurring within the County. The following illustrates the most anticipated efforts and how each may improve accessibility:

New Construction Projects: Work involving creating new public Right-of-Way and/or constructing new pedestrian or transportation features in locations within current or future public Right-of-Way shall provide accessible features in the project that meet current ADA design standards.

New Improvements Projects: Work involving improving existing public Right-of-Way transportation features will provide new or necessary upgrades to existing accessible features in the project area to meet current ADA design standards. Such projects may include road widenings as part of the Capital Improvement Program with associated sidewalk improvements.

Major Maintenance and Rehabilitation Projects: Work involving any alteration or major maintenance activity performed on transportation assets in the existing public Right-of-Way shall provide or upgrade accessible features in, or immediately adjacent to, the project to meet current ADA design standards. Such projects shall include any project requiring pavement reconstruction, major pavement rehabilitation, sidewalk improvements, or the reconstruction of accessibility facilities caused by permitees. Minor or routine maintenance activities (patching, sealing, etc.) will include accessibility improvements when required by the ADA or when such improvements are consistent with the scope of the activity being performed.

Routine Maintenance Projects: Work that is limited to specifically repairing spot areas in the public Right-of-Way directly affecting accessibility shall provide new or necessary upgrades to impacted existing accessible features to meet current ADA design standards.

Training & Education Projects: The County may provide training, formal or informal, to staff, contractors, engineers, developers, partners, and the general public as deemed appropriate for the purpose of educating and training individuals and entities on ADA requirements, construction standards and processes, and County expectations for projects within the transportation network.

Funding is an important component for improving accessibility within the transportation network. Adams County endeavors to responsibly fund efforts to improve accessibility whenever possible. It is anticipated funding for improvements and mechanisms for project delivery may come from the following sources:

- Annual Capital Improvement Program Projects
- Federal Aid or Grants[2] – State Transportation Improvement Program (STIP), Highway Safety Improvement Program (HSIP), Safe Routes To Schools (SRTS), Congestion Mitigation and Air Quality Improvement (CMAQ), Surface Transportation Program (STP), Colorado Office of Transportation Safety (OTS) grants, Centers for Disease Control and Prevention (CDC), Community Development Block Grant (CDBG), Road Diet Projects, Multi-Modal Transportation Programs, Transportation Enhancement Activities (TEA), Transportation Alternatives (TA), Railway-Highway Crossing Program (RHC), and other pedestrian, mobility, development grants
- Intergovernmental Agreement (IGA) with neighboring jurisdictions

[2] NOTE: Many of these programs or types of programs are competitive type grants, therefore, agencies aren't guaranteed to receive these funds. The County will need to monitor these programs and decide whether to pursue the funds.

- Bonding
- Reallocation of departmental budgets
- Creation of Taxing Districts - Tax Increment Financing District (TIF), Community Improvement District (CID), Tax Allocation District (TAD)
- Adoption of Fees to fund an Enterprise associated with Accessibility

The ADA does not require the County to undertake any action that would result in a fundamental alteration in the intent of its program or activity, would create a hazardous condition, or would represent an undue financial and administrative burden. This determination shall include concurrence of the ADA Coordinator and must be accompanied by a statement citing the reasons for reaching the conclusion. The determination that undue burdens would result must be based on an evaluation of all resources available for use in the programs.

The following outlines the anticipated process for addressing accessibility barriers within the County's transportation network:

Coordinated/Included with another Project(s):

1. Annually review planned projects and compare project locations to locations of known accessibility issues.
2. Review project areas to identify or confirm and quantify accessibility barriers.
3. Identify available funding to allocate towards accessibility improvements.
4. Develop necessary Contract Document changes to incorporate proposed improvements into the overall project.
5. Inspect constructed improvements and document resolution of accessibility barrier(s).

Standalone Project(s):

1. Review documented accessibility barriers and identify locations without undue burdens to target, consistent with the Plan priorities, construction economics and other environmental factors, and available funding.
2. Identify available funding to allocate towards accessibility improvements.
3. Develop necessary Contract Document changes to incorporate proposed improvements into the overall project.
4. Inspect constructed improvements and document resolution of accessibility barrier(s).

Years prior to initiating the formal development of the Plan, the County commenced efforts to improve accessibility. These efforts are ongoing and will be re-focused as needed to maintain consistency with the vision of the Plan.

During the implementation of this Transition Plan, the County will base programming costs of the different project components based upon an Engineer's Estimate of Probable Costs on a per ramp, per linear foot of sidewalk or curb and gutter, and per each pedestrian push button basis. These programming costs should include an allowance for different elements typically associated with the specific improvements. Examples of these components include additional adjacent sidewalk or curb and gutter required to construct curb ramp, retaining walls, landscaping, pavement patching, and ROW. This estimated programming costs should also include contingencies for design and construction engineering and surveying. Because of the unknown nature of future capital improvement program projects and budgets,

development and re-development, federal grants, and general operating budgets; the County cannot accurately predict available future annual spending towards improving accessibility. An estimate of costs and potential timeline to address the findings of the self-assessment is provided in Appendix F.

As stated above, in an effort to provide a better understanding of the ADA and its requirements, the County is developing and will be providing two different ADA training measures. The first training measure will address County specific items such as the ADA Coordinator, requirements for public meetings, standardized language for public outreach and correspondence, and ADA support provided by the County. The second training measure will address issues more technical in nature such as current ADA standards and specifications and details; requirements for providing an accessible route; reasonable accommodations; and the design, construction, and inspection of accessible improvements. The measures provided may focus on a combination of these elements or single elements depending on the intended specific purpose or audience.

VIII. Monitoring & Updating Plan

The County will review the Plan on a periodic basis and update it as deemed appropriate to address progress towards improving accessibility and provide for any Plan modifications. The ADA Coordinator will work with the different County departments and appropriate staff during this review to identify updates and incorporate new information pertaining to accessibility and the ADA into the Plan. Public comments or suggestions received will be incorporated as deemed appropriate.

APPENDICES

APPENDIX A – DEFINITIONS

Accessible Route – a continuous, unobstructed path connecting all accessible elements and spaces including public transportation facilities, parking access aisles, curb ramps, crosswalks at vehicular ways, walks, ramps and lifts.

ADA – means and refers to the Americans with Disabilities Act as contained and explained in Title 42, Chapter 126 of the United States Code.

ADAAG – Americans with Disabilities Act Accessibility Guidelines, codified at Appendix A to 28 Code of Federal Regulations Part 36 and at Appendix A to 49 Code of Federal Regulations part 37.

Auxiliary Aids and Services – services and devices promoting effective communication or allowing access to goods and services as defined by Titles II and III of the ADA.

Curb Ramp – a short ramp cutting through a curb or built up to it.

Detectable Warning – truncated domes, typically pre-fabricated and installed or stamped into a walkway, providing a tactile surface at the transition from a curb and the street or other hazardous vehicular crossings, assisting pedestrians with vision disabilities in determining when they enter the street.

Disability – a physical or mental impairment substantially limiting one or more of the major life activities of an individual as defined by the ADA.

Impairment – any physiological disorder, or condition, cosmetic disfigurement, or anatomical loss affecting one or more body systems or any mental or psychological disorder, such as mental retardation, organic brain syndrome, emotional or mental illness, and specific learning disabilities.

Pedestrian Rights-of-Way (PROW) – sidewalks, curb ramps, crosswalks serving such sidewalks, and any other designated routes or pathways used by pedestrians along public rights of way.

PROWAG – Proposed Guidelines for Pedestrian Facilities in the Public Right-of-Way. At the time of this Initial Plan the most current version of the PROWAG is the 2011 Proposed Guidelines for Pedestrian Facilities in the Public Right-of-Way published by the United States Access Board. This document provides guidelines for public rights-of-way addressing various issues, including access for blind pedestrians at street crossings, wheelchair access to on-street parking, and various constraints posed by space limitations, roadway design practices, slope, and terrain.

Reasonable Accommodation – changes or adjustments providing, without undue burden, means for an individual with a disability to perform the duties or tasks required. Where existing physical constraints make it impractical for altered elements, spaces, or facilities to fully comply with new construction requirements, compliance is required to the extent practicable within the scope of the project. Existing physical constraints include, but are not limited to, underlying terrain, right-of-way availability, underground structures, adjacent developed facilities, drainage, or the presence of a notable natural or historic feature. See 2011 PROWAG and 28 C.F.R. § 35.130(b)(7).

Undue Burden – excessive or disproportionate financial and administrative burdens associated with modifying an existing facility and incurred by a covered entity, likely due to factors including, but not limited to, the nature and cost of the action; the overall financial resources of the owner(s); the number

of persons employed at the site; the effect on expenses and resources; legitimate safety requirements necessary for safe operation, including crime prevention measures; or any other impact of the action on the operation of the site; the geographic separateness, and the administrative or fiscal relationship of the site or sites in question to any parent corporation or entity; if applicable, the overall financial resources of any parent corporation or entity; the overall size of the parent corporation or entity with respect to the number of its employees; the number, type, and location of its facilities; and if applicable, the type of operation or operations of any parent corporation or entity, including the composition, structure, and functions of the workforce of the parent corporation or entity.

APPENDIX B – COUNTY POLICY REGARDING THE ADA

NOTICE UNDER THE AMERICANS WITH DISABILITIES ACT

In accordance with the requirements of Title II of the Americans with Disabilities Act of 1990 ("ADA"), Adams County will not intentionally discriminate against qualified individuals with disabilities on the basis of disability in its services, programs, or activities.

Anyone desiring or requiring an auxiliary aid or service for effective communication, or a modification of policies or procedures to participate in a program, service, or activity of Adams County should contact the ADA Coordinator identified in Appendix C of the Plan as soon as possible but no later than 48 hours before the scheduled event.

Adams County Board of County Commissioners has to budget and appropriate on an annual basis. While Adams County intends to make services available for auxiliary aid or service for effective communication such as translators, the company contracted for those services may be temporarily unavailable. If other service needs of the County, such as emergency responders/response, becomes a priority, then the service for effective communication may be delayed.

The ADA does not require Adams County to take any action that would fundamentally alter the nature of its programs or services, or impose an undue financial or administrative burden.

APPENDIX C – ADA COORDINATOR CONTACT INFO

Adams County ADA Coordinator

County Attorney's Office
4430 S. Adams County Pkwy.
5th Floor, Suite C5000B
Brighton, CO 80601-8206

Ph: 720.523.6116
Fax: 720.523.6114

http://www.adcogov.org/

Hours
Monday - Friday
8:00 a.m. - 4:30 p.m.
(Excluding County holidays)

APPENDIX D – INVENTORY OF PUBLIC FACILITIES ASSESSED


W 68th Ave
W 67th Ave
W 66th Ave
W 65th Ave
W 64th Ave
W 63rd Ave
W 62nd Ave
W 61st Pl
W 66th Ave
W 65th Pl
W 65th Ct
W 63rd Pl
W 63rd Ave
W 62nd Pl
W 62nd Pl
W 62nd Ave
W 62nd Ave
Lowell Blvd
King St
Knox St
Julian St
Stuart Ct
Quitman Ct
Perry Ct
Osceola Ct
Newton Ct
Meade Ct
Stuart St
Raleigh St
Quitman St
Perry St
Osceola St
Newton St
Knox Ct
Julian St
Osceola Way
Newton Ct
Stuart St
Raleigh St
Quitman St
Perry St
Tennyson St
BAKER
N
LEGEND
Sidewalk
Neighborhood


W 62nd Pl
Stuart St
Quitman St
Perry St
W 61st Pl
W 62nd Ave
W 62nd Ave
W 62nd Ave
Lowell Blvd
W 58th Ave
W 58th Way
W 58th Ave
Unknown
Hooker St
Tennyson St
76
W 55th Pl
287
W 55th Ave
W 54th Ave
W 54th Ave
King Ct
Julian St
Irving St
Grove St
W 53rd Pl
W 53rd Ave
King St
Regis Rdg
St Clair Pl
W 52nd Pl
W 52nd Ave
Stuart St
Raleigh St
Quitman St
Perry St
Osceola St
Newton St
Meade St
W 53rd Pl
70
N
LEGEND
Sidewalk
Neighborhood

BERKELEY


W 72nd Ave
Ruth Way
Zuni St
Warren Dr
Morrison Dr
Jordan Dr
Fern Dr
N Zuni St
W 68th Ave
W 70th Ave
W 69th Ave
Mosko Ct
W 68th Pl
W 68th Ave
Little Dry Creek
Lowell Blvd
King St
Knox St
Julian St
Hooker St
Grove St
Green St
W 67th Ave
W 67th Pl
Decatur St
287
W 66th Pl
W 66th Ave
W 65th Pl
Longfellow Pl
Irving St
W 65th Ave
Clay St
W 65th Ave
Hawthorne Pl
W 64th Ave
Knox Ct
Julian St
Clay St
Beach St
W 63rd Ave
W 62nd Ct
W 62nd Ave
W 62nd Ave
W 62nd Ave
Clear Creek
Lake Sangraco
GOAT HILL
N
LEGEND
Sidewalk
Neighborhood



MONACO/ DUPONT



NORTH PERL MACK

N

LEGEND

Sidewalk Neighborhood



NORTH WASHINGTON INDUSTRIAL



SE ARVADA

N

LEGEND

Sidewalk Neighborhood



SHAW HEIGHTS



SOUTH FEDERAL

N

LEGEND

Sidewalk Neighborhood


Kalcevic Reservoir
W 80th Pl
W 80th Ave
Sherrelwood Dr
Valley View Dr
Crestview Ln
Cottonwood Dr
Fairview Ave
Greenleaf Ln
Applewood Ln
Elmwood Pl
Zuni St
Wyandot St
Vallejo St
Umatilla St
Elmwood Ln
Cyd Dr
Quivas Way
W 78th Cir
Meadowbrook Dr
Westchester Dr
Zane St
Tejon St
Shoshone St
Raritan St
Turner Dr
Quivas St
W 76th Ave
Osage St
Navajo St
Mariposa Dr
Hilltop Cir
Ember St
Elder St
Ebony St
El Paso Blvd
Elbert St
Erie St
Elder Cir
Linda Cir
W 79th Pl
Elmwood Dr
W 78th Pl
Conifer Rd
Granada Rd
Greenwood Blvd
Dakin St
Drake St
Delta St
Del Norte St
Cuchara St
Cragmore St
Cortez St
Campo St
Bountiful Ct
Bowie Ct
Bronco Rd
Bannock St
Broadway St
Durango St
Mona Ct
Grace Ct
Sherman Way
Sherman St
Joan Dr
Ellen Ln
Grace Pl
Linda Ln
W 74th Way
Del Norte St
Samuel Dr
W 74th Ave
W 73rd Pl
W 73rd Ave
Cortez St
Dakin St
Worley Dr
Navajo St
Quivas St
Alan Dr
Avrum Dr
Larsh Dr
Ruth Way
Raritan St
W 72nd Ave
Inca St
Jennie Dr
W 71st Pl
Kalamath St
Santa Fe Dr
Joan St
Huron St
Galapago St
Fox St
Elati St
Lipan St
Masey St
W 70th Pl
Zuni St
Sheldon Ave
Warren Dr
Morrison Dr
Jordan Dr
W 70th Ave
Pecos St
Osage St
Navajo St
W 69th Ave
Santa Fe Dr
N Huron St
Fox Way
Elati Way
Kidder Dr
Clark Ct
Broadway St
N Zuni St
Fern Dr
W 68th Ave
Little Dry Creek
W 67th Pl
W 66th Pl
W 65th Pl
Clay St
W 65th Ave
W 64th Ave
Clear Creek
Gordon Lake
Beach St
W 63rd Ave
W 62nd Ct
W 62nd Ave
Delaware Way
W 66th Ave
Delaware St
Huron St
E 64th Ave
E 62nd Ave
62nd
Lipan St
W 60th Pl
W 60th Ave
Pecos
Osage
36
25
76
N
SOUTH PERL MACK
LEGEND
Sidewalk
Neighborhood



STRASBURG

N

LEGEND

Sidewalk

Neighborhood



UTAH JUNCTION


Dawson St
De Soto St
Edison St
Essex St
Faraday St
Galen Ct
Evelyn Ct
Hopkins Dr
Cheryl Dr
Rainbow Dr
Devonshire Blvd
Welby Rd
Emerson Ct
Ogden St
Sheldon Dr
E 86th Pl
Mc Elwain Blvd
Richard Rd
Mc Dougal St
E 86th Ave
E 85th Pl
Corona St
Dawson Dr
Franklin St
Rainbow Ave
Hope Ct
Jolene Dr
City View Dr
Franklin Dr
York St
Clarkson St
Mable Ave
Essex Dr
E 84th Ave
E 83rd Pl
E 83rd Pl
Harris St
Gaylord St
Emerson St
Ogden St
E 83rd Dr
E 83rd Ave
Vine St
Clayton Ct
Steele St
Race St
E 81st Pl
High St
E 82nd Pl
Grant Way
E 83rd Dr
Downing Dr
Quivira Dr
Solana Dr
Coronado Pkwy
Explorador Calle Ave
Nueva Vista Dr
Cleo St
Welby Rd
E 82nd Dr
Clarkson Ct
Washington St
Lafayette St
E 81st Pl
Pearl St
Downing St
Coronado Pkwy
E 80th Ave
Downing Way
Marion Cir
Lafayette Way
Humboldt Cir
Patricia Dr
Grant St
Logan St
Pennsylvania St
Pearl St
Sherman St
E 79th Ave
Cleveland St
E 78th Pl
E 78th Pl
E 78th Dr
E 78th Ave
Grant St
E 77th Dr
E 77th Pl
E 77th Ave
South Platte River
Pennsylvania Ct
E 76th Ave
E 75th Pl
Lafayette St
York St
Clayton St
E 75th Ave
E 75th Ave
E 74th Pl
25
E 74th Ave
E 74th Ave
Race St
E Brannan Pl
E 73rd Ave
Gilpin Way
36
E 71st Ave
Clear Creek
W 70th Ave
76
E 70th Ave
270
E 69th Ave
E 68th Pl
Columbine St
E 68th Ave
N
WELBY
LEGEND
Sidewalk
Neighborhood


Bachman Dr
Quince St
Uinta St
Valentia St
Verbena St
E 124th Pl
Brighton Rd
E 123rd Ave
Riverdale Rd
E 123rd Dr
E 123rd Pl
Ivanhoe St
Ivanhoe Ct
Jasmine St
Krameria St
Locust St
Niagara St
E 121st Dr
E 120th Pl
E 120th Pkwy
South Platte River
E 120th Ave
Quebec St
Riverdale Rd
E 112th Ave
Mc Kay Rd
Belle Creek Blvd
85
E 104th Way
E 105th Ct
76
Brighton Blvd
WRIGHT FARMS/
HOLLY CROSSING
N
LEGEND
Sidewalk
Neighborhood

APPENDIX E – OVERVIEW OF ASSESSMENT ATTRIBUTES/PARAMETERS

I. Curb Ramp Assessment Elements

1. **Number of Curb Ramps Present?**
   - o 0
   - o 1
   - o 2

2. **What type of curb ramp configuration is present?**
   - o Single
   - o Double
   - o Diagonal
   - o Midblock
   - o Median
   - o Railroad
   - o N/A

3. **What type of curb ramp arrangement is present?**
   - o Parallel
   - o Perpendicular
   - o Blended Transition
   - o N/A

4. **Number of Curb Ramp(s) Needing to be Added?**
   - o 0
   - o 1
   - o 2

5. **What will be the ultimate curb ramp configuration?**
   - o Single
   - o Double
   - o Diagonal
   - o Midblock
   - o Median
   - o Railroad
   - o N/A

6. **Is the ramp free of any vertical discontinuities >0.5" from the curb lip to the top of the ramp?** (Yes – No)

7. **Is the area at the base of the ramp clear of parallel vehicle traffic?** (Yes – No)

8. **What is the ramp width?**
   - o <4'
   - o 4'-5'
   - o 5'-6'
   - o >6'

9. **Does the ramp have a max cross slope of <2% near the top of the ramp?** (Yes – No)

10. **What is the running slope of the ramp?**
    - o 0 - 5.0%
    - o 5.0 - 8.3%
    - o 8.3 - 12.0 %
    - o > 12.0%

11. **Are compliant flared sides present?** (Yes – No)

12. **Are all joints or cracks with gaps present <0.5"?** (Yes – No)

13. **Are there prefabricated domes or dome panel(s) present?** (Yes – No)

14. **Does the dome panel have the correct placement and orientation?** (Yes – No)

15. **Does the dome panel color contrast with the surrounding material?** (Yes – No)

16. **Is the dome panel 2' long and the full width of the ramp?** (Yes – No)

17. **Does the defined landing have a max slope less than 2%?** (Yes – No)

18. **Is there a defined landing with the proper minimum dimensions?** (Yes – No)

II. Sidewalk Assessment Elements

1. **Does a sidewalk need to be constructed to establish a pedestrian route?** (Yes – No)

2. **Existing sidewalk surface type?**
   - Concrete
   - Concrete Integral with Curb and Gutter
   - Asphalt
   - Brick/Pavers
   - Aggregate
   - Wood chip
   - Other
   - None Present

3. **Is the running slope generally consistent with the adjacent street?** (Yes – No)

4. **What is the width of sidewalk?**
   - <3'
   - 3'-4'
   - 4'-5'
   - >5'

5. **How many obstructions are present restricting the sidewalk width?**
   - 0
   - 1-5
   - 6-10
   - >10

6. **What is the predominant cross slope of sidewalk?**
   - < 2%
   - 2 - 3%
   - 3 - 4%
   - > 4%

7. **What is the maximum cross slope of sidewalk?**
   - < 2%
   - 2 - 3%
   - 3 - 4%
   - > 4%

8. **How many driveway crossings have a cross slope greater than 2%?**
   - 0
   - 1-5
   - 6-10
   - >10

9. **How many trip hazards or faulted panels are present?**
   - 0
   - 1-5
   - 6-10
   - 10-20

10. **How many horizontal gaps at on-plane joints and cracks >0.5" are present?**
    - 0
    - 1-5
    - 6-10
    - >10

III. Pedestrian Pushbutton Assessment Elements

1. **Are pedestrian pushbuttons in an accessible location on the pole or mounted surface?** (Yes – No - N/A)

2. **Are pedestrian pushbutton located above a compliant sidewalk area?** (Yes – No - N/A)

APPENDIX F – ASSESSMENT FINDINGS

CURB RAMPS

Presently, there are 3,163 corner, midblock or median crossing locations within unincorporated Adams County where curb ramps either exist or could exist. The following identifies the existing ramp configuration present. The (X%) indicates the likely ultimate configuration.

No Ramps..... 8% (4%)	Double Ramp 1% (8%)
Single Ramp 78% (78%)	Midblock Ramp.....6% (8%)
Diagonal Ramp..... 6% (2%)	Median Ramp .....<1% (<1%)

Of the 2,902 existing curb ramps, most (77%) are orientated parallel with the direction of travel. The remaining ramps (23%) are orientated perpendicular to the back of curb. The following provides other data on the existing curb ramps present.

RUNNING SLOPE OF RAMPS

< 5.0%..... 64%	8.3 –12.0% 17%
5.0 – 8.3%..... 15%	> 12.0% 4%

WIDTH OF RAMPS

< 4' 51%	5' – 6' 6%
4' – 5' 40%	> 6' 3%

OTHER CURB RAMP PROPERTIES	**YES**	**NO**
Ramp is Fully Compliant.....	2%	98%
Vertical Profile is Free of Obstructions	75%	25%
Base of Ramp Clear of Parallel Traffic.....	90%	10%
Maximum Cross Slope is <2%	29%	71%
Compliant Flared Sides	76%	24%
Compliant Dome Panel(s)	35%	65%
Compliant Landing Area.....	12%	88%

Of the locations surveyed currently without a ramp, 140 would not improve accessibility with the addition of a curb ramp. For locations with an existing ramp(s), 260 would improve accessibility with the addition of a ramp to provide a crossing in another direction.

SIDEWALK

Presently there are 4,396 sidewalk locations where sidewalk either exists or could exist. These locations total approximately 316 miles of sidewalk. 4,339 locations, or 313 miles, currently have sidewalk constructed. The following details the breakdown of types of sidewalk present in the unincorporated portions of Adam County.

Concrete..... 11%	Brick ..... < 1%
Asphalt .....< 1%	Aggregate.....1%
Concrete Integral ..... 88% w/ Curb & Gutter	Other.....<1%

Only 1% of the existing sidewalks are fully compliant. 4% of the constructed sidewalks have gaps preventing continuity. Approximately 12 miles of sidewalk is needed to connect existing sidewalk segments with nearby sidewalk segments to provide connectivity within the sidewalk network.

SIDEWALK ISSUES	0	1 – 5	6 –10	> 10
Obstructions	92%	7%	< 1%	< 1%
Cross Slope > 2% @ Driveways	30%	45%	14%	11%
Trip hazards / Faulted Panels	46%	48%	5%	2%
Joints / Cracks > 0.5" Wide	25%	57%	12%	6%

CROSS SLOPE OF SIDEWALK	< 2%	2% – 3%	3% – 4%	> 4%
Typical	29%	40%	22%	9%
Maximum	18%	32%	27%	23%

PEDESTRIAN PUSH BUTTONS

Pedestrian push buttons are currently installed at 3% of the curb ramp locations. For the locations having pedestrian push buttons, 75% are in accessible locations.

ESTIMATED COSTS TO CORRECT ACCESSIBILITY CHALLENGES[3]

The following provides present day cost estimates and annual budgets to construct or reconstruct pedestrian transportation assets to improve accessibility. Market forces and packaging may result in these costs varying.

ASSET ELEMENTS	ESTIMATED COST	YEARS 1 – 20	YEARS 21 – 30	YEARS 31 – 50
Curb Ramps	$8.3 million	$275,000	$275,000	$0
Sidewalk	$38.0 million	$690,000	$700,000	$975,00
Pedestrian Push Buttons	$0.2 million	$10,000	$0	$0
Total	**$46.5 million**	**$975,000**	**$975,000**	**$975,000**

[3] Estimated costs include planning, engineering, and construction costs. Due to the large volume of sidewalk infrastructure and the need to prioritize funds, it is not reasonable or feasible to remove and replace all sidewalk segments with global, linear issues as a targeted standalone project or projects. Because of this, when considering a long term strategy to improve accessibility, targeting single point or small area issues initially and address linear issues under a future initiative or as part of other infrastructure improvement projects as opportunities become available is recommended.

APPENDIX G – PUBLIC INVOLVEMENT DOCUMENTATION (WEBSITE, PRESS RELEASE, USER SURVEY, ETC.)

Engage your community - connect to news, events and information you care about. View more information... Sign In

Americans With Disabilities
Animal Shelter / Adoption Center
Assessor
Board of Commissioners
Budget Office
Citizen Advisory Boards and Commissions
Clerk & Recorder
Coroner
Community and Economic Development
Community Corrections
County Attorney
County Manager
County Ordinances
Criminal Justice Coordinating Committee- CJCC
Deputy County Manager - External Services
Deputy County Manager - Internal Services
District Attorney
Elected Officials
Elections
Emergency Management
Facility Operations
Finance Department
Finance Reports
Fleet Management
Front Range Airport
GIS/Business Solutions
Heart at Work
Human Resources
Human Services

ADAMS COUNTY COLORADO

Americans With Disabilities

Adams County is committed to ensuring individuals with disabilities have an equal opportunity to participate in our programs, services, and activities. Please refer to our Disability Rights Notice for more information.

SECTION 504 OF THE REHABILITATION ACT OF 1973 (Section 504) is a federal law protecting qualified individuals with disabilities from discrimination. This law applies to entities receiving federal assistance.

TITLE II OF THE AMERICANS WITH DISABILTIES ACT OF 1990, AS AMENDED (ADA) is a federal law protecting qualified individuals with disabilities from discrimination. This law applies to all state and local government agencies.

DISABILITY is defined as a person with a physical or mental impairment that substantially limits one or more of the major life activities; a record of such an impairment; or being regarded as having such an impairment. Major life activities include caring for one's self, walking, seeing, hearing, speaking, breathing, working, and learning.

QUALIFIED INDIVIDUAL WITH A DISABILITY is defined in Title II ADA as "an individual with a disability who, with or without reasonable modifications to rules, policies, or practices, the removal of architectural, communication, or transportation barriers, or the provision of auxiliary aids and services, meets the essential eligibility requirements for the receipt of services or the participation in programs or activities provided by a public entity."

More Information

If you have questions, please contact the ADA Coordinator:
Valerie Fennell
ADA & CORA Coordinator
County Attorney's Office
4430 S. Adams County Parkway, Suite C5000B
Brighton, CO 80601-8206
Phone: 720.523.6882 | Fax: 720.523.6114 | Email

Engage your community - connect to news, events and information you care about. View more information... Sign In

ADAMS COUNTY
COLORADO

- Information Technology
- Liquor Licensing
- Motor Vehicle
- Long Range Strategic Planning
- Open Adams
- Parks & Open Space
- PIO/Communications
- Public Trustee
- Retirement Administration
- Sheriff
- Surveyor
- Sustainability
- Transparency Hotline
- Transportation Department
- Treasurer
- Workforce & Business Center

SERVICE·CENTER
CODES & ORDINANCES
CONTACT ADAMS COUNTY
PUBLIC RECORDS/MAPS
DEVELOPMENT STANDARDS & REGULATIONS
CONNECT WITH US

Engage your community - connect to news, events and information you care about. View more information... Sign In

ADA Transition Plan

About the Project

As required by Title II of the ADA and 28 CFR 35.105, the Adams County is developing a Transition Plan to improve access compliance to pedestrian facilities within the county's jurisdiction. As part of this effort, the county has retained an engineering consultant, Alfred Benesch & Company, to assist county staff in developing the Transition Plan.

The county has developed a process for creating and implementing the Transition Plan. The first step in this process is to conduct self-evaluation by inventorying and assessing existing pedestrian facilities to identify access barriers to persons with disabilities within the public Right-of-Way. The inventory will assess pedestrian facilities along roadways, primarily sidewalks and curb ramps, to document what facilities are present and in compliance with the applicable standards or need to be constructed or improved to be compliant.

What's Happening

Currently, the inventory and assessment activities are underway. It is anticipated a public meeting will be scheduled and special interest groups will be contacted to start gathering additional information.

Part of the self-evaluation process includes a public outreach program to gain public input and help identify particular existing areas of concern. The self-evaluation findings will provide the framework for developing the county's ADA Transition Plan. Besides identifying the results of the self-evaluation, the Transition Plan will prioritize addressing the identified existing barriers and identify strategies for addressing them. It will also provide standards and guidelines for future improvements to the pedestrian network within the county's public right-of-ways

Contact

Anna Sparks, PE
Adams County Project Manager
asparks@adcogov.org
720.523.6859

Jess Hastings, PE
Project Manager
jhastings@benesch.com
7979 E. Tufts Avenue, Suite 800
Denver, CO 80210
303.771.6868

Transportation Department
4430 South Adams County Parkway
1st Floor, Suite W2000B
Brighton, CO 80601-8218
PHONE 720.523.6875
FAX 720.523.6996
www.adcogov.org

ADA Transition Plan Survey

Adams County, Colorado - ADA Transition Plan Survey

Adams County, Colorado is performing a public outreach program toward the development of an Americans with Disabilities Act (ADA) Transition Plan (Plan). The purpose of this Plan is to eliminate pedestrian facilities barriers within public right-of-ways in unincorporated Adams County (County). Barriers are typically eliminated by adding or correcting sidewalks and curb ramps. One component of the public outreach program is this survey. It will be used to help document concerns and locations of needed improvements to accommodate disabled users of pedestrian facilities in the County. While efforts won't immediately result in improvements, the resulting Plan will provide the County a document that will provide guidance to making ADA related improvements, as funding allows.

It is the County's preference that this survey be taken online at www.surveymonkey.com/s/adamsadatransitionplan to help reduce misinterpretation of information and data entry errors. However, if you require this survey in an alternate format (paper, large font, audio), please contact Jess Hastings at 720-473-7576; or jhastings@benesch.com.

We would like your contact information to allow the ADA Transition Plan team to keep you up to date via email on Plan progress and follow up. Any information provided will remain confidential and will not be posted, shared, or otherwise made available to anyone outside the ADA Transition Plan team. Only comment summaries will be documented in the ADA Transition Plan. Thank you for your input!

First Name*: Last Name*:

and/or Business Name*:

Street Address:

City: State: Zip: Phone Number:

Email Address*: (BCC distribution emails only)

1. Have you experienced physical barriers or constraints on a pedestrian path you currently use or would like to use?

   Yes ○ No ○

   If yes, please provide more information relating to your experiences by answering the next 4 questions.
   If no, jump to question 6.

Adams County, Colorado - ADA Transition Plan Survey (continued)

Name:

2. Have you encountered street segments or locations where sidewalks are missing, inaccessible, or in poor condition?

   Yes ◯ No ◯

   If yes, please provide the street name(s), segment(s) of street, side(s) of street, and describe your concerns:

   (For Example: Washington Street between 58th and 60th, east side – sidewalk has heaved and settled making it difficult to use.)

3. Have you encountered locations where curb ramps are missing, inaccessible, or in poor condition?

   Yes ◯ No ◯

   If yes, please provide intersecting street names, location(s) and describe your concerns:

   (For Example: Washington Street and E 58th Avenue, southwest and southeast corners – missing curb ramps.)

4. Have you encountered intersections or mid-block crossings, where medians or traffic signals affect your ability to cross the street?

   Yes ◯ No ◯

   If yes, please provide intersecting street names, location(s) and describe your concerns:

   (For Example: Pedestrian traffic signal on E 72nd Avenue, just west of Cherry Street. A concrete pad is needed at the north push button.)

5. Have you encountered any physical obstructions like roots, trees, branches, bushes, retaining walls, signs, fire hydrants or other?

   Yes ◯ No ◯

   If yes, please provide street name(s), segment(s) of street, side(s) of street, and describe your concerns:

   (For Example: Tree roots in front of 7401 Broadway Street have created a sidewalk displacement of more than one-half an inch.)

6. Do you have any more specific or general comments that you feel the ADA Transition Plan team should consider related to pedestrian facilities?

Thank you for participating in this survey!

Print Submit

benesch

If you prefer not to provide the required personal information above, but have comments for consideration, please click Print and mail a hard copy to Jess Hastings at 7979 E. Tufts Avenue, Suite 800, Denver, Colorado 80237

Engage your community - connect to news, events and information you care about. View more information... Sign In

Contact Adams County
Boards & Commissions Public Hearings
BOCC Public Hearings
BOCC Public Study Sessions
Department Directory
Meet the Elected Officials
Stay Connected
Stormwater Utility
Transparency Hotline
Transparency Portal
YourGOV: Report an Issue

SERVICE·CENTER
CODES & ORDINANCES
CONTACT ADAMS COUNTY
PUBLIC RECORDS/MAPS
DEVELOPMENT STANDARDS & REGULATIONS

News Flash Home

The original item was published from 7/21/2015 3:54:26 PM to 8/7/2015 12:00:00 AM.

County News Releases

Posted on: July 21, 2015

[ARCHIVED] Adams County Seeking Input on ADA Transition Plan

As required by Title II of the Americans with Disabilities Act (ADA) and 28 CFR 35.105, Adams County is developing a transition plan to improve access compliance to pedestrian facilities within the county's jurisdiction. Alfred Benesch & Company is assisting county staff in developing the transition plan.

Existing pedestrian facilities within the public right-of-way are currently being inventoried and analyzed to gain relevant data. In conjunction with this effort, Adams County would like public input to help identify specific areas of concern. A brief survey to provide the desired input can be accessed through the county's website, www.co.adams.co.us (search keyword ADA), or at www.surveymonkey.com/r/adamsadatransitionplan.

This brief survey will take approximately five minutes to complete and will be available through September 30, 2015. A public open house will be held on Thursday, Aug. 6, 2015, starting at 5 p.m. at the Adams County Government Conference Center, Platte River Room B and C, 4430 South Adams County Parkway, Brighton, Colorado 80601. Interested parties will learn about transition plan progress and will have the opportunity to visit with project staff and provide input on areas of concern. Findings from data collection and input provided will help develop the county's ADA Transition Plan.

Survey and transition plan information can be made available in alternative accessible formats upon request. For information about obtaining an alternative format, contact Jess Hastings at Alfred Benesch & Co. 7979 E. Tufts Avenue, Suite 800, Denver, Colorado 80237, 402.479.2493, or jhastings@benesch.com.

ADA Transition Plan Survey

Search

All categories

Tools
RSS
Notify Me

Categories
- All Categories
- County News Releases

Other News in County News Releases

Gov. Hickenlooper Orders flags Lowered for Colorado State Patrol Trooper Jaimie Jursevics
Posted on: November 20, 2015

Absolutely Adams - Fall 2015
Posted on: November 6, 2015

Adams County Videos
Posted on: October 21, 2014

Voters in Adams County, Denver Approve Ballot Question Related to Development at DIA
Posted on: November 3, 2015

ADAMS COUNTY
COLORADO

WELCOME

Please take a moment to sign in.

ADA Transition Plan

PUBLIC OPEN HOUSE

benesch

Adams County
ADA Transition Plan
PUBLIC OPEN HOUSE

Adams County Government
Conference Center
Platte River Room B and C
4430 South Adams County Parkway
Brighton, CO 80601

August 6, 2015 | 5:00 p.m.

Thank you for your interest in the development of the Adams County Americans with Disabilities Act (ADA) Transition Plan Project. The County strives to provide an accessible environment for all of its citizens and visitors. Early in 2015, the County contracted with Alfred Benesch & Company through a qualifications-based selection process to assist with the development of an ADA Transition Plan for the transportation network within the County's Public Right-of-Way. This open house is intended to provide information about the plan development process and goals, answer questions about the Transition Plan, and provide interested parties means of providing input towards plan development or prioritization of addressing existing accessibility challenges or issues.

This project is primarily focusing on existing sidewalks and locations where curb ramps exist or should be constructed to create an accessible path. To develop the Transition Plan, we are:

- Documenting Existing Pedestrian Facilities within the County's Transportation Public Right of Way
- Soliciting Input from Interested Parties
- Categorizing Accessibility Challenges
- Identifying Potential Standards, Guidelines, and Training Programs to Improve Accessibility
- Identifying Potential Strategies to Address Accessibility Challenges

Currently, field personnel are documenting the existing sidewalk and curb ramps throughout the County. For sidewalks the primary data being captured or confirmed includes:

Sidewalks

- Width
- Longitudinal and Transverse (Cross) Slope
- Presence of Tripping or Navigation Hazards

Pedestrian Push Buttons

- Location Relative to Sidewalk/ Curb Ramp
- Compliant Sidewalk Area Adjacent to Button

Curb Ramps

- Configuration and Orientation
- Dimensions and Slopes
- Landing Dimensions
- Presence of Tripping or Navigation Hazards
- Presence of Compliant Dome Panels



Adams County ADA Transition Plan
PUBLIC OPEN HOUSE

The County has established an initial program for providing information to and accepting input from its citizens and other interested parties. This program includes:

- Transition Plan Website
- Public Meetings
- Targeted Outreach
- Formal Accessibility Concern/Complaint Reporting and Tracking Process

A key component of the Transition Plan will be analyzing the information gathered on the existing facilities and developing potential strategies to improve accessibility. These strategies may include improvements constructed as part of future projects; additional training and education of design and construction personnel; and/or modification of County ordinances, policies, or requirements.

Any interested party may provide input on this process or areas of concern. It is the County's preference that this survey be taken online at **www.surveymonkey.com/s/adamsadatransitionplan** to help reduce misinterpretation of information and data entry errors. However, if you require this survey in an alternate format (paper, large font, audio), please contact Jess Hastings at 720-473-7576; or jhastings@benesch.com.

We thank you again for your interest in this important project. We look forward to hearing your thoughts and concerns.



Contact

Anna Sparks, PE
Adams County
Project Manager
asparks@adcogov.org
4430 South Adams County Parkway
Brighton, CO 80601-8218
(720) 523-6859

Jess Hastings, PE
Benesch
Project Manager
jhastings@benesch.com
7979 E. Tufts Avenue, Suite 800
Denver, CO 80210
(303) 771-6868

ADAMS COUNTY COLORADO

benesch

Visit the website for updates and ongoing information:
http://www.co.adams.co.us/index.aspx?nid=1409

ADA Transition Plan

PUBLIC OPEN HOUSE

AUGUST 2015

Introductions

ADAMS COUNTY REPRESENTATIVES

Anna Sparks, PE

Russell Nelson, PE

ALFRED BENESCH & CO REPRESENTATIVES

Jess Hastings, PE

Steve Banks, PE

Jeff Sockel, PE

Project Overview

- Goal: Improve Accessibility within Public Right of Way
- Establish a Framework to Guide Future Activities Affecting Accessibility
- Provide a Means for Identifying Areas of Concern & Process to Review & Address As Appropriate

Transition Plan Overview

- Documenting Existing Pedestrian Facilities within the County's Transportation Public Right of Way
- Soliciting Input from Interested Parties
- Categorizing Accessibility Challenges
- Identifying Potential Standards, Guidelines, and Training Programs to Improve Accessibility
- Identifying Potential Strategies to Address Accessibility Challenges

Documentation - Sidewalks

- Width
- Longitudinal and Transverse (Cross) Slope
- Presence of Tripping or Navigation Hazards

benesch

Documentation – Curb Ramps

- Configuration and Orientation
- Dimensions and Slopes
- Landing Dimensions
- Presence of Tripping or Navigation Hazards
- Presence of Compliant Dome Panels

benesch

Documentation – Push Buttons

- Location Relative to Sidewalk/Curb Ramp
- Compliant Sidewalk Area Adjacent to Button

benesch

Information Sharing

- Transition Plan Website
- Public Meetings
- Targeted Outreach
- Formal Accessibility Concern/Complaint Reporting and Tracking Process



benesch

Potential Strategies

- Improvements Constructed as Part of Future Projects
- Additional Training and Education of Design and Construction Personnel
- Modification of County Ordinances, Policies, or Requirements

benesch

Thank You

Please Visit the County's Website for Additional Information or to Provide any Input or Suggestions

http://www.co.adams.co.us/index.aspx?nid=1409

benesch

Engage your community - connect to news, events and information you care about.

View more information...

ADA Transition Plan

About the Project

As required by Title II of the ADA and 28 CFR 35.105, the Adams County is developing a Transition Plan to improve access compliance to pedestrian facilities within the county's jurisdiction. As part of this effort, the county has retained an engineering consultant, Alfred Benesch & Company, to assist county staff in developing the Transition Plan.

The county has developed a process for creating and implementing the Transition Plan. The first step in this process is to conduct self-evaluation by inventorying and assessing existing pedestrian facilities to identify access barriers to persons with disabilities within the public Right-of-Way. The inventory will assess pedestrian facilities along roadways, primarily sidewalks and curb ramps, to document what facilities are present and in compliance with the applicable standards or need to be constructed or improved to be compliant.

Public Open House

A public open house will be held on Tuesday, December 8, 2015, from 6:00 – 7:30 p.m. at the Adams County Government Conference Center, Platte River Room B and C (4430 South Adams County Parkway, Brighton, Colorado 80601). At this event, interested parties will learn about transition plan development, have the opportunity to visit with project staff and review the plan. All comments and questions should be directed to either Jess Hastings or Anna Sparks, Project Managers.

Contact

Anna Sparks, PE, CFM
Adams County Project Manager
asparks@adcogov.org
720.523.6859

Jess Hastings, PE
Project Manager
jhastings@benesch.com
7979 E. Tufts Avenue, Suite 800
Denver, CO 80210
303.771.6868

Adams County Government, CO
December 7, 2015 ·

Join us for a public forum on Tuesday, December 8, 2015, from 6:00 – 7:30 p.m. at the Adams County Government Conference Center, 4430 South Adams County Parkway in Brighton, to discuss a mandatory plan on how to improve access and mobility for all residents within the county. For more information about the plan visit: adcogov.org/adaplan.

Like · Comment · Share

3 Top Comments ▾

Write a comment...

Vicente Eddie Blea Need to flatten the curbs for wheel chairs.
Like · Reply · December 7, 2015 at 3:13pm

Contacts:
Jim Siedlecki, Director of Public Information
O: 720. 523.6793 M: 402.203.5498
jsiedlecki@adcogov.org

Rich Neumann, Communications Manager
O: 720. 523.6112 M: 302.299.6797
rneumann@adcogov.org

December 4, 2015

Adams County News & Information

Adams County Seeks Public Input on Improving Access and Mobility within County Facilities

Public Forum on December 8 to help ensure compliance with American Disabilities Act (ADA)

Adams County will host a public forum at the Adams County Government Center on Tuesday, Dec. 8, 6–7:30 p.m., to gather feedback on the county's plan to ensure access and mobility for all visitors to county facilities. The Adams County Government Center is located at 4430 South Adams County Parkway in Brighton.

"Adams County wants to ensure that all residents enjoy equal, unimpeded access to county facilities—regardless of their level of mobility," said Anna Sparks, ADA Transition Plan project manager. "To that end, we've developed a plan that takes a comprehensive look at potential challenges in each of our properties as well as strategies for addressing any problem areas we've identified. We encourage the public to share their feedback on our plan."

For more information about the plan, visit: www.adcogov.org/adaplan. If you are unable to attend the public forum but wish to share your feedback or ask questions, please contact Anna Sparks at 720.523.6859 or asparks@adcogov.org. Comments will be accepted through Dec. 23, 2015.

--END--

ADA Transition Plan

DRAFT PLAN PRESENTATION TO THE PUBLIC

DECEMBER 2015

Introductions

ADAMS COUNTY REPRESENTATIVES

Anna Sparks, PE, CFM

Valerie Fennell, PHR
(ADA Coordinator)

ALFRED BENESCH & CO REPRESENTATIVES

Jess Hastings, PE

Jeff Sockel, PE

Transition Plan Goals

- Comply with Title II for Pedestrian Facilities in the Public Right-of-Way in Unincorporated Adams County
- Document Existing Conditions
- Establish a Framework for Receiving, Evaluating, and Addressing Grievances
- Establish Standards, Guidelines, and Training Mechanisms to Improve Accessibility
- Identify Project Strategies to Improve Accessibility

Transition Plan Overview

- ADA Coordinator
- Self Evaluation Process & Findings
- Public Involvement
- Public Information Sharing & Grievance Procedure
- Design Standards & Specifications
- Prioritize and Identify Goals, Strategies, & Schedules
- Monitoring & Updating Plan

ADA Coordinator Role

- Monitoring Compliance & Implementation
- Investigating Grievance Complaints
- Addressing ADA Concerns & Questions
- Accessing Undue Burden & Reasonable Accommodations
- Updating Plan

ADAMS COUNTY
COLORADO

benesch

Self Evaluation Components

- Curb Ramp Configuration & Slopes
- Detectable Warning Panel Location & Contrast
- Maneuvering Area Clearance
- Landing Area Configuration & Slopes
- Sidewalk Width & Cross Slope
- Pedestrian Push Button Location & Accessibility

benesch

Curb Ramp Findings

- 2,900 Curb Ramps Locations
- 2% are Fully Compliant
- 65% have Improper Landings
- 78% have Improper Cross Slope or Geometry Along the Ramp or at the Curb Drop
- 25% have Vertical Obstructions

benesch

Sidewalk Findings

- 314 Miles of Sidewalk
- 90% Meet Running Slope Requirement Without Any Obstructions
- 75% have a Width <4’
- Several Segments have Excessive Cross Slope at Driveway Crossings and Faulted or Separated Joints and Cracks in the Travel Path

benesch

Push Button Findings

- 100 Push Button Locations
- 25% are in an Inaccessible Location on the Pole or at an Improper Height

benesch

Public Outreach

- Transition Plan Website
- User Survey
- Public Meetings
- Targeted Contact
- Formal Accessibility Concern/Complaint Reporting and Tracking Process



benesch

Potential Strategies - Programs

- Training and Education of Design and Construction Personnel
- Modification of County Policies or Construction Requirements

benesch

Potential Strategies - Projects

- Routine Maintenance Projects
- Targeted Accessibility Improvement Projects
- Address as Part of Other Projects
  - New Construction Projects
  - Reconstruction Projects
  - Major Rehabilitation Projects

benesch

Grievance Process

1. Complaint filed by an Affected Individual or Their Designated Representative
2. Investigation by the County ADA Coordinator or Designee
3. Follow-up Contact with the Affected Individual or Designated Representative to Explain the Findings and/or Measures Being Taken

NOTE: Compliant Dismissal Guidelines are also Identified

Implementation Priorities

1. Locations Where Adjacent Roadway or Infrastructure Improvements are Taking Place
2. Locations in Close Proximity to Public Facilities and High Pedestrian Traffic Areas (e.g., Schools, Hospitals, Rec. Facilities, Parks, etc.)
3. Locations in Targeted Neighborhood Zones
4. Locations Having a Higher Degree of Non-compliance or More Significant Barriers to Accessibility
5. All Other Locations Not Listed Above as Funding and Resources are Available

NOTE: Locations Identified from the Grievance Process Will Be Prioritized on a Case-by-Case Basis

Potential Funding Options

- Annual Capital Improvement Plan & Maintenance Projects
- Federal Aid or Grants (e.g., STIP, HSIP, SRTS, CDBG, TEA)
- Intergovernmental Agreement (IGA)
- Bonding

Going Forward…

- Proactively Improve Accessibility
- Address Grievances when Identified
- Periodic Review and Update of the Plan



Thank You

Questions?

ADA Transition Plan
Public Open House

Adams County Government Conference Center
4430 South Adams County Parkway, Brighton, CO 80601
Tuesday, December 8, 2015

Comment Form

Do you have any comments or questions about the ADA Transition Plan?

If so, we would like to hear from you.
Please write your comments in the space below and return them to Alfred Benesch & Company.
You can drop this form off on your way out, or you may take it with you and mail it later.

Thank you for your participation!

Jess Hastings, PE
Alfred Benesch & Company
7979 E. Tufts Avenue, Suite 800
Denver, CO 80237
phone: 303-771-6868
email: jhastings@benesch.com

Anna Sparks, PE, CFM
Adams County
4430 South Adams Parkway
Brighton, CO 80601
phone: 720-523-6859
email: asparks@adcogov.org

If you are willing, please provide your complete contact information to allow us to follow-up with you on any questions or concerns:	Name Street City, Zip Email Phone

Thank you for your interest and participation!

Place
Stamp
Here

Jess Hastings, PE
Alfred Benesch & Company
7979 E. Tufts Avenue, Suite 800
Denver, CO 80237

Fold

Adams County
ADA Transition Plan
PUBLIC OPEN HOUSE

Adams County Government
Conference Center
Platte River Room B and C
4430 South Adams County Parkway
Brighton, CO 80601

December 8, 2015 | 6:00 p.m.

Thank you for your interest in the development of the Adams County Americans with Disabilities Act (ADA) Transition Plan Project. The County strives to provide an accessible environment for all of its citizens and visitors. Early in 2015, the County contracted with Alfred Benesch & Company through a qualifications-based selection process to assist with the development of an ADA Transition Plan for the transportation network within the County's Public Right-of-Way. This open house is intended to provide information about the plan development process and goals, answer questions about the Transition Plan, and provide interested parties means of providing input towards plan development or prioritization of addressing existing accessibility challenges or issues.

This project is primarily focusing on existing sidewalks and locations where curb ramps exist or should be constructed to create an accessible path. To develop the Transition Plan, we are:

- Documented Existing Pedestrian Facilities within the County's Transportation Public Right of Way
- Solicited Input from Interested Parties
- Quantified Accessibility Challenges
- Identified Potential Standards, Guidelines, and Training Programs to Improve Accessibility
- Identified Potential Strategies to Address Accessibility Challenges

During the existing condition surveys, crews documented the following accessibility characteristics along target roadways throughout the County.

Sidewalks

- 314 Miles of Sidewalk
- 90% Meet Running Slope Requirement Without Any Obstructions
- 75% have a Width <4'
- Several Segments have Excessive Cross Slope at Driveway Crossings and Faulted or Separated Joints and Cracks in the Travel Path

Pedestrian Push Buttons

- 100 Push Buttons Locations
- 25% are in an Inaccessible Location on the Pole or at an Improper Height

Curb Ramps

- 2,900 Curb Ramp Locations
- 2% are Fully Compliant
- 65% have Improper Landings
- 78% have Improper Cross Slope or Geometry Along the Ramp or at the Curb Drop
- 25% have Vertical Obstructions

Adams County **ADA Transition Plan**
PUBLIC OPEN HOUSE

The County has established a program for providing information to and accepting input from its citizens and other interested parties. This program includes:

- Transition Plan Website
- Public Meetings
- Targeted Outreach
- Formal Accessibility Concern/Complaint Reporting and Tracking Process

A key component of the Transition Plan includes identifying potential strategies to improve accessibility. These strategies include improvements constructed as part of future projects; additional training and education of design and construction personnel; and/or modification of County ordinances, policies, or requirements.

Any interested party may provide input on the draft Plan or areas of concern. The County has established a website to share information and a Grievance Process to allow individuals or their representative to identify areas of concern for the County to investigate and remedy as appropriate. Please feel free to contact Jess Hastings, Anna Sparks, or the County ADA Coordinator directly with any concerns, questions, or comments. Their contact information is provided below.

We thank you again for your interest in this important project. We look forward to hearing your thoughts and concerns.



Contact

Anna Sparks, PE, CFM
Adams County
Project Manager
asparks@adcogov.org
4430 South Adams County Parkway
Brighton, CO 80601-8218
(720) 523-6859

Jess Hastings, PE
Benesch
Project Manager
jhastings@benesch.com
7979 E. Tufts Avenue, Suite 800
Denver, CO 80210
(303) 771-6868

ADA Coordinator
County Attorney's Office
4430 South Adams County Parkway
5th Floor, Suite C5000B
Brighton, CO 80601-8206
(720) 523-6116

Visit the website for updates and ongoing information:
http://www.adcogov.org/ keyword: ADA Transition

benesch

ADAMS COUNTY
COLORADO

In addition to the County's standard public notification process, the following were specifically requested to review and provide comment on the Plan.

City of Arvada
8101 Ralston Road
P.O. Box 8101
Arvada, CO 80001-8101

City of Aurora
15151 E. Alameda Pkwy.
Aurora CO 80012

Town of Bennett
355 4th St.
Bennett, CO 80102

City of Brighton
22 S. 4th Ave.
Brighton, CO 80601

City of Commerce City
7887 E. 60th Ave.
Commerce City,CO 80022

City of Federal Heights
2380 W 90th Avenue
Federal Heights, CO 80260

City of Northglenn
11701 Community Center Drive
P.O. Box 330061
Northglenn, CO 80233

City of Thornton
9500 Civic Center Drive
Thornton, CO 80229

City of Westminster
4800 W. 92nd Ave.
Westminster, Co 80031

Rocky Mountain ADA Center
3630 Sinton Road, Suite 103
Colorado Springs, CO 80907

#1

INCOMPLETE

Collector: Web L nk 1 (Web L nk)
Started: Tuesday, Ju y 21, 2015 9:12:49 PM
Last Modified: Tuesday, Ju y 21, 2015 9:13:15 PM
Time Spent: 00:00:26
IP Address: 67.172.157.233

PAGE 2

Q1: **Have you experienced physical barriers or constraints on a pedestrian path you currently use or would like to use?**	Yes

PAGE 3

Q2: **Have you encountered street segments or locations where sidewalks are missing, inaccessible, or in poor condition?**	Yes

PAGE 4

Q3: **Please provide the street name(s), segment(s) of street, side(s) of street, and describe your concerns. (For Example: Washington Street between 58th and 60th, east side – sidewalk has heaved and settled making it difficult to use.)**	*Respondent skipped this question*

PAGE 5

Q4: **Have you encountered locations where curb ramps are missing, inaccessible, or in poor condition?**	*Respondent skipped this question*

PAGE 6

Q5: **Please provide intersecting street names, location(s) and describe your concerns (For Example: Washington Street and E 58th Avenue, southwest and southeast corners – missing curb ramps.)**	*Respondent skipped this question*

PAGE 7

Q6: Have you encountered intersections or mid-block crossings, where medians or traffic signals affect your ability to cross the street?

Respondent skipped this question

PAGE 8

Q7: Please provide intersecting street names, location(s) and describe your concerns. (For Example: Pedestrian traffic signal on E 72nd Avenue, just west of Cherry Street. A concrete pad is needed at the north push button.)

Respondent skipped this question

PAGE 9

Q8: Have you encountered any physical obstructions like roots, trees, branches, bushes, retaining walls, signs, fire hydrants or other?

Respondent skipped this question

PAGE 10

Q9: Please provide intersecting street names, location(s) and describe your concerns. (For Example: Tree roots in front of 7401 Broadway Street have created a sidewalk displacement of more than one-half an inch.)

Respondent skipped this question

PAGE 11

Q10: Do you have any more specific or general comments that you feel the ADA Transition Plan team should consider related to pedestrian facilities?

Respondent skipped this question

PAGE 12

Q11: Please provide your contact information to allow the ADA Transition Plan team to keep you up to date on plan progress and follow up if there are questions related to your concerns. Any information shared will remain confidential and will not be posted, shared, or otherwise made available to anyone outside the ADA Transition Plan team. Thank you for your input!

Respondent skipped this question



#2

COMPLETE

Collector: Web L nk 1 (Web L nk)
Started: Wednesday, Ju y 22, 2015 7:45:57 AM
Last Modified: Wednesday, Ju y 22, 2015 7:46:26 AM
Time Spent: 00:00:29
IP Address: 73.153.165.102

PAGE 2

Q1: **Have you experienced physical barriers or constraints on a pedestrian path you currently use or would like to use?**	No

PAGE 3

Q2: Have you encountered street segments or locations where sidewalks are missing, inaccessible, or in poor condition?	*Respondent skipped this question*

PAGE 4

Q3: Please provide the street name(s), segment(s) of street, side(s) of street, and describe your concerns. (For Example: Washington Street between 58th and 60th, east side – sidewalk has heaved and settled making it difficult to use.)	*Respondent skipped this question*

PAGE 5

Q4: Have you encountered locations where curb ramps are missing, inaccessible, or in poor condition?	*Respondent skipped this question*

PAGE 6

Q5: Please provide intersecting street names, location(s) and describe your concerns (For Example: Washington Street and E 58th Avenue, southwest and southeast corners – missing curb ramps.)	*Respondent skipped this question*

PAGE 7

Q6: Have you encountered intersections or mid-block crossings, where medians or traffic signals affect your ability to cross the street?

Respondent skipped this question

PAGE 8

Q7: Please provide intersecting street names, location(s) and describe your concerns. (For Example: Pedestrian traffic signal on E 72nd Avenue, just west of Cherry Street. A concrete pad is needed at the north push button.)

Respondent skipped this question

PAGE 9

Q8: Have you encountered any physical obstructions like roots, trees, branches, bushes, retaining walls, signs, fire hydrants or other?

Respondent skipped this question

PAGE 10

Q9: Please provide intersecting street names, location(s) and describe your concerns. (For Example: Tree roots in front of 7401 Broadway Street have created a sidewalk displacement of more than one-half an inch.)

Respondent skipped this question

PAGE 11

Q10: Do you have any more specific or general comments that you feel the ADA Transition Plan team should consider related to pedestrian facilities?

Respondent skipped this question

PAGE 12

Q11: Please provide your contact information to allow the ADA Transition Plan team to keep you up to date on plan progress and follow up if there are questions related to your concerns. Any information shared will remain confidential and will not be posted, shared, or otherwise made available to anyone outside the ADA Transition Plan team. Thank you for your input!

Respondent skipped this question



#3

INCOMPLETE

Collector: Web L nk 1 (Web L nk)
Started: Wednesday, Ju y 22, 2015 8:35:37 AM
Last Modified: Wednesday, Ju y 22, 2015 8:35:58 AM
Time Spent: 00:00:21
IP Address: 67.230.204.5

PAGE 2

Q1: **Have you experienced physical barriers or constraints on a pedestrian path you currently use or would like to use?**	Yes

PAGE 3

Q2: **Have you encountered street segments or locations where sidewalks are missing, inaccessible, or in poor condition?**	Yes

PAGE 4

Q3: **Please provide the street name(s), segment(s) of street, side(s) of street, and describe your concerns. (For Example: Washington Street between 58th and 60th, east side – sidewalk has heaved and settled making it difficult to use.)**	*Respondent skipped this question*

PAGE 5

Q4: **Have you encountered locations where curb ramps are missing, inaccessible, or in poor condition?**	*Respondent skipped this question*

PAGE 6

Q5: **Please provide intersecting street names, location(s) and describe your concerns (For Example: Washington Street and E 58th Avenue, southwest and southeast corners – missing curb ramps.)**	*Respondent skipped this question*

PAGE 7

Q6: Have you encountered intersections or mid-block crossings, where medians or traffic signals affect your ability to cross the street?	*Respondent skipped this question*

PAGE 8

Q7: Please provide intersecting street names, location(s) and describe your concerns. (For Example: Pedestrian traffic signal on E 72nd Avenue, just west of Cherry Street. A concrete pad is needed at the north push button.)	*Respondent skipped this question*

PAGE 9

Q8: Have you encountered any physical obstructions like roots, trees, branches, bushes, retaining walls, signs, fire hydrants or other?	*Respondent skipped this question*

PAGE 10

Q9: Please provide intersecting street names, location(s) and describe your concerns. (For Example: Tree roots in front of 7401 Broadway Street have created a sidewalk displacement of more than one-half an inch.)	*Respondent skipped this question*

PAGE 11

Q10: Do you have any more specific or general comments that you feel the ADA Transition Plan team should consider related to pedestrian facilities?	*Respondent skipped this question*

PAGE 12

Q11: Please provide your contact information to allow the ADA Transition Plan team to keep you up to date on plan progress and follow up if there are questions related to your concerns. Any information shared will remain confidential and will not be posted, shared, or otherwise made available to anyone outside the ADA Transition Plan team. Thank you for your input!	*Respondent skipped this question*



#4

COMPLETE

Collector: Web L nk 1 (Web L nk)
Started: Wednesday, August 05, 2015 1:34:50 PM
Last Modified: Wednesday, August 05, 2015 1:35:00 PM
Time Spent: 00:00:10
IP Address: 65.113.226.130

PAGE 2

Q1: **Have you experienced physical barriers or constraints on a pedestrian path you currently use or would like to use?**	No

PAGE 3

Q2: Have you encountered street segments or locations where sidewalks are missing, inaccessible, or in poor condition?	*Respondent skipped this question*

PAGE 4

Q3: Please provide the street name(s), segment(s) of street, side(s) of street, and describe your concerns. (For Example: Washington Street between 58th and 60th, east side – sidewalk has heaved and settled making it difficult to use.)	*Respondent skipped this question*

PAGE 5

Q4: Have you encountered locations where curb ramps are missing, inaccessible, or in poor condition?	*Respondent skipped this question*

PAGE 6

Q5: Please provide intersecting street names, location(s) and describe your concerns (For Example: Washington Street and E 58th Avenue, southwest and southeast corners – missing curb ramps.)	*Respondent skipped this question*

PAGE 7

Q6: Have you encountered intersections or mid-block crossings, where medians or traffic signals affect your ability to cross the street?

Respondent skipped this question

PAGE 8

Q7: Please provide intersecting street names, location(s) and describe your concerns. (For Example: Pedestrian traffic signal on E 72nd Avenue, just west of Cherry Street. A concrete pad is needed at the north push button.)

Respondent skipped this question

PAGE 9

Q8: Have you encountered any physical obstructions like roots, trees, branches, bushes, retaining walls, signs, fire hydrants or other?

Respondent skipped this question

PAGE 10

Q9: Please provide intersecting street names, location(s) and describe your concerns. (For Example: Tree roots in front of 7401 Broadway Street have created a sidewalk displacement of more than one-half an inch.)

Respondent skipped this question

PAGE 11

Q10: Do you have any more specific or general comments that you feel the ADA Transition Plan team should consider related to pedestrian facilities?

Respondent skipped this question

PAGE 12

Q11: Please provide your contact information to allow the ADA Transition Plan team to keep you up to date on plan progress and follow up if there are questions related to your concerns. Any information shared will remain confidential and will not be posted, shared, or otherwise made available to anyone outside the ADA Transition Plan team. Thank you for your input!

Respondent skipped this question



#5

INCOMPLETE

Collector: Web L nk 1 (Web L nk)
Started: Wednesday, August 12, 2015 10:33:06 AM
Last Modified: Wednesday, August 12, 2015 10:36:04 AM
Time Spent: 00:02:58
IP Address: 104.218.81.9

PAGE 2

Q1: **Have you experienced physical barriers or constraints on a pedestrian path you currently use or would like to use?**	No

PAGE 3

Q2: **Have you encountered street segments or locations where sidewalks are missing, inaccessible, or in poor condition?**	Yes

PAGE 4

Q3: **Please provide the street name(s), segment(s) of street, side(s) of street, and describe your concerns. (For Example: Washington Street between 58th and 60th, east side – sidewalk has heaved and settled making it difficult to use.)**	*Respondent skipped this question*

PAGE 5

Q4: **Have you encountered locations where curb ramps are missing, inaccessible, or in poor condition?**	Yes

PAGE 6

Q5: **Please provide intersecting street names, location(s) and describe your concerns (For Example: Washington Street and E 58th Avenue, southwest and southeast corners – missing curb ramps.)**	*Respondent skipped this question*

PAGE 7

Q6: Have you encountered intersections or mid-block crossings, where medians or traffic signals affect your ability to cross the street?

Respondent skipped this question

PAGE 8

Q7: Please provide intersecting street names, location(s) and describe your concerns. (For Example: Pedestrian traffic signal on E 72nd Avenue, just west of Cherry Street. A concrete pad is needed at the north push button.)

Respondent skipped this question

PAGE 9

Q8: Have you encountered any physical obstructions like roots, trees, branches, bushes, retaining walls, signs, fire hydrants or other?

Respondent skipped this question

PAGE 10

Q9: Please provide intersecting street names, location(s) and describe your concerns. (For Example: Tree roots in front of 7401 Broadway Street have created a sidewalk displacement of more than one-half an inch.)

Respondent skipped this question

PAGE 11

Q10: Do you have any more specific or general comments that you feel the ADA Transition Plan team should consider related to pedestrian facilities?

Respondent skipped this question

PAGE 12

Q11: Please provide your contact information to allow the ADA Transition Plan team to keep you up to date on plan progress and follow up if there are questions related to your concerns. Any information shared will remain confidential and will not be posted, shared, or otherwise made available to anyone outside the ADA Transition Plan team. Thank you for your input!

Respondent skipped this question



COMPLETE

Collector: Web L nk 1 (Web L nk)
Started: Monday, August 17, 2015 9:04:34 AM
Last Modified: Monday, August 17, 2015 9:07:58 AM
Time Spent: 00:03:24
IP Address: 75.166.176.108

PAGE 2

Q1: **Have you experienced physical barriers or constraints on a pedestrian path you currently use or would like to use?**

Yes

PAGE 3

Q2: **Have you encountered street segments or locations where sidewalks are missing, inaccessible, or in poor condition?**

Yes

PAGE 4

Q3: **Please provide the street name(s), segment(s) of street, side(s) of street, and describe your concerns. (For Example: Washington Street between 58th and 60th, east side – sidewalk has heaved and settled making it difficult to use.)**

5235 Newton 80221

PAGE 5

Q4: **Have you encountered locations where curb ramps are missing, inaccessible, or in poor condition?**

Yes

PAGE 6

Q5: **Please provide intersecting street names, location(s) and describe your concerns (For Example: Washington Street and E 58th Avenue, southwest and southeast corners – missing curb ramps.)**

Carl Park area. Newton is my street

PAGE 7

Q6: Have you encountered intersections or mid-block crossings, where medians or traffic signals affect your ability to cross the street?

Yes

PAGE 8

Q7: Please provide intersecting street names, location(s) and describe your concerns. (For Example: Pedestrian traffic signal on E 72nd Avenue, just west of Cherry Street. A concrete pad is needed at the north push button.)

52nd and Lowell

PAGE 9

Q8: Have you encountered any physical obstructions like roots, trees, branches, bushes, retaining walls, signs, fire hydrants or other?

No

PAGE 10

Q9: Please provide intersecting street names, location(s) and describe your concerns. (For Example: Tree roots in front of 7401 Broadway Street have created a sidewalk displacement of more than one-half an inch.)

Respondent skipped this question

PAGE 11

Q10: Do you have any more specific or general comments that you feel the ADA Transition Plan team should consider related to pedestrian facilities?

Respondent skipped this question

PAGE 12

Q11: Please provide your contact information to allow the ADA Transition Plan team to keep you up to date on plan progress and follow up if there are questions related to your concerns. Any information shared will remain confidential and will not be posted, shared, or otherwise made available to anyone outside the ADA Transition Plan team. Thank you for your input!

Name:	[redacted]
Address:	[redacted]
City/Town:	Denver
State:	CO
ZIP:	[redacted]
Country:	United States
Email Address:	[redacted]
Phone Number:	[redacted]



#7

INCOMPLETE

Collector: Web L nk 1 (Web L nk)
Started: Fr day, August 21, 2015 7:55:08 AM
Last Modified: Fr day, August 21, 2015 7:59:43 AM
Time Spent: 00:04:35
IP Address: 65.114.219.190

PAGE 2

Q1: Have you experienced physical barriers or constraints on a pedestrian path you currently use or would like to use?

Respondent skipped this question

PAGE 3

Q2: Have you encountered street segments or locations where sidewalks are missing, inaccessible, or in poor condition?

Respondent skipped this question

PAGE 4

Q3: Please provide the street name(s), segment(s) of street, side(s) of street, and describe your concerns. (For Example: Washington Street between 58th and 60th, east side – sidewalk has heaved and settled making it difficult to use.)

Respondent skipped this question

PAGE 5

Q4: Have you encountered locations where curb ramps are missing, inaccessible, or in poor condition?

Respondent skipped this question

PAGE 6

Q5: Please provide intersecting street names, location(s) and describe your concerns (For Example: Washington Street and E 58th Avenue, southwest and southeast corners – missing curb ramps.)

Respondent skipped this question

PAGE 7

Q6: Have you encountered intersections or mid-block crossings, where medians or traffic signals affect your ability to cross the street?

Respondent skipped this question

PAGE 8

Q7: Please provide intersecting street names, location(s) and describe your concerns. (For Example: Pedestrian traffic signal on E 72nd Avenue, just west of Cherry Street. A concrete pad is needed at the north push button.)

Respondent skipped this question

PAGE 9

Q8: Have you encountered any physical obstructions like roots, trees, branches, bushes, retaining walls, signs, fire hydrants or other?

Respondent skipped this question

PAGE 10

Q9: Please provide intersecting street names, location(s) and describe your concerns. (For Example: Tree roots in front of 7401 Broadway Street have created a sidewalk displacement of more than one-half an inch.)

Respondent skipped this question

PAGE 11

Q10: Do you have any more specific or general comments that you feel the ADA Transition Plan team should consider related to pedestrian facilities?

Respondent skipped this question

PAGE 12

Q11: Please provide your contact information to allow the ADA Transition Plan team to keep you up to date on plan progress and follow up if there are questions related to your concerns. Any information shared will remain confidential and will not be posted, shared, or otherwise made available to anyone outside the ADA Transition Plan team. Thank you for your input!

Respondent skipped this question



#8

INCOMPLETE

Collector: Web L nk 1 (Web L nk)
Started: Monday, September 21, 2015 4:10:25 PM
Last Modified: Monday, September 21, 2015 4:10:48 PM
Time Spent: 00:00:23
IP Address: 198.239.83.187

PAGE 2

Q1: **Have you experienced physical barriers or constraints on a pedestrian path you currently use or would like to use?**	No

PAGE 3

Q2: Have you encountered street segments or locations where sidewalks are missing, inaccessible, or in poor condition?	*Respondent skipped this question*

PAGE 4

Q3: Please provide the street name(s), segment(s) of street, side(s) of street, and describe your concerns. (For Example: Washington Street between 58th and 60th, east side – sidewalk has heaved and settled making it difficult to use.)	*Respondent skipped this question*

PAGE 5

Q4: Have you encountered locations where curb ramps are missing, inaccessible, or in poor condition?	*Respondent skipped this question*

PAGE 6

Q5: Please provide intersecting street names, location(s) and describe your concerns (For Example: Washington Street and E 58th Avenue, southwest and southeast corners – missing curb ramps.)	*Respondent skipped this question*

PAGE 7

Q6: Have you encountered intersections or mid-block crossings, where medians or traffic signals affect your ability to cross the street?

Respondent skipped this question

PAGE 8

Q7: Please provide intersecting street names, location(s) and describe your concerns. (For Example: Pedestrian traffic signal on E 72nd Avenue, just west of Cherry Street. A concrete pad is needed at the north push button.)

Respondent skipped this question

PAGE 9

Q8: Have you encountered any physical obstructions like roots, trees, branches, bushes, retaining walls, signs, fire hydrants or other?

Respondent skipped this question

PAGE 10

Q9: Please provide intersecting street names, location(s) and describe your concerns. (For Example: Tree roots in front of 7401 Broadway Street have created a sidewalk displacement of more than one-half an inch.)

Respondent skipped this question

PAGE 11

Q10: Do you have any more specific or general comments that you feel the ADA Transition Plan team should consider related to pedestrian facilities?

Respondent skipped this question

PAGE 12

Q11: Please provide your contact information to allow the ADA Transition Plan team to keep you up to date on plan progress and follow up if there are questions related to your concerns. Any information shared will remain confidential and will not be posted, shared, or otherwise made available to anyone outside the ADA Transition Plan team. Thank you for your input!

Respondent skipped this question

Transportation Department
4430 South Adams County Parkway
1st Floor, Suite W2000B
Brighton, CO 80601-8218
PHONE 720.523.6875
FAX 720.523.6996
www.adcogov.org

ADA Transition Plan Survey

Adams County, Colorado - ADA Transition Plan Survey

Adams County, Colorado is performing a public outreach program toward the development of an Americans with Disabilities Act (ADA) Transition Plan (Plan). The purpose of this Plan is to eliminate pedestrian facilities barriers within public right-of-ways in unincorporated Adams County (County). Barriers are typically eliminated by adding or correcting sidewalks and curb ramps. One component of the public outreach program is this survey. It will be used to help document concerns and locations of needed improvements to accommodate disabled users of pedestrian facilities in the County. While efforts won't immediately result in improvements, the resulting Plan will provide the County a document that will provide guidance to making ADA related improvements, as funding allows.

We would like your contact information to allow the ADA Transition Plan team to keep you up to date via email on Plan progress and follow up. Any information provided will remain confidential and will not be posted, shared, or otherwise made available to anyone outside the ADA Transition Plan team. Only comment summaries will be documented in the ADA Transition Plan. Thank you for your input!

Title: First Name*: [redacted] Last Name*: [redacted]

and/or Business Name*: [redacted]

Street Address: [redacted]

City: Welby State: CO Zip: [redacted] Phone Number: [redacted]

Email Address*: [redacted] (BCC distribution emails only)

1. Have you experienced physical barriers or constraints on a pedestrian path you currently use or would like to use?

   Yes ◉ No

   If yes, please provide more information relating to your experiences by answering the next 4 questions. If no, jump to question 6.

Roads in our bussiness area are hardly wide enough for 2 cars to pass side. Employees are afraid to walk or ride bikes. Side walks or bike lanes are needed.

benesch

Adams County, Colorado - ADA Transition Plan Survey (continued)

2. Have you encountered street segments or locations where sidewalks are missing, inaccessible, or in poor condition?

   Yes ● No

   If yes, please provide the street name(s), segment(s) of street, side(s) of street, and describe your concerns:

   there are no sidewalks in our community
   It is a safety & access concern for our employees

3. Have you encountered locations where curb ramps are missing, inaccessible, or in poor condition?

   Yes ● No

   If yes, please provide intersecting street names, location(s) and describe your concerns:

   we have no curbs

4. Have you encountered intersections or mid-block crossings, where medians or traffic signals affect your ability to cross the street?

   Yes ● No

   If yes, please provide intersecting street names, location(s) and describe your concerns:

   It is not safe for our employees that take public transportation to cross the street

5. Have you encountered any physical obstructions like roots, trees, branches, bushes, retaining walls, signs, fire hydrants or other?

   Yes ● No

   If yes, please provide street name(s), segment(s) of street, side(s) of street, and describe your concerns:

   there are trees/bushes that stick out. Cars must pull half way through intersection

6. Do you have any more specific or general comments that you feel the ADA Transition Plan team should consider related to pedestrian facilities?

   I also think that m[redacted]
   addition to sidewalks + curb cuts
   lighting / safety & access are also
   very important

Thank you for participating in this survey!

Please mail hard copies to Jess Hastings at 7979 E. Tufts Avenue, Suite 800, Denver, Colorado 80237

benesch

ADAMS COUNTY
COLORADO

Transportation Department
4430 South Adams County Parkway
1st Floor, Suite W2000B
Brighton, CO 80601-8218
PHONE 720.523.6875
FAX 720.523.6996
www.adcogov.org

ADA Transition Plan Survey

Adams County, Colorado - ADA Transition Plan Survey

Adams County, Colorado is performing a public outreach program toward the development of an Americans with Disabilities Act (ADA) Transition Plan (Plan). The purpose of this Plan is to eliminate pedestrian facilities barriers within public right-of-ways in unincorporated Adams County (County). Barriers are typically eliminated by adding or correcting sidewalks and curb ramps. One component of the public outreach program is this survey. It will be used to help document concerns and locations of needed improvements to accommodate disabled users of pedestrian facilities in the County. While efforts won't immediately result in improvements, the resulting Plan will provide the County a document that will provide guidance to making ADA related improvements, as funding allows.

We would like your contact information to allow the ADA Transition Plan team to keep you up to date via email on Plan progress and follow up. Any information provided will remain confidential and will not be posted, shared, or otherwise made available to anyone outside the ADA Transition Plan team. Only comment summaries will be documented in the ADA Transition Plan. Thank you for your input!

Title: [redacted] First Name*: [redacted] Last Name*: [redacted]

and/or Business Name*:

Street Address: [redacted]

City: Denver State: Co Zip: [redacted] Phone Number: [redacted]

Email Address*: [redacted] (BCC distribution emails only)

1. Have you experienced physical barriers or constraints on a pedestrian path you currently use or would like to use?

   Yes Ø No

   If yes, please provide more information relating to your experiences by answering the next 4 questions. If no, jump to question 6.

   It is very difficult to get onto path from York to Washington Street.

benesch

Adams County, Colorado - ADA Transition Plan Survey (continued)

2. Have you encountered street segments or locations where sidewalks are missing, inaccessible, or in poor condition?

   Yes X No

   If yes, please provide the street name(s), segment(s) of street, side(s) of street, and describe your concerns:

   73rd Avenue
   74th Avenue
   Race Street
   Road designed back in early 1900's and has not been widened. We cannot walk or ride a bike or actually drive safely down those streets.

3. Have you encountered locations where curb ramps are missing, inaccessible, or in poor condition?

   Yes X No

   If yes, please provide intersecting street names, location(s) and describe your concerns:

   Cross walks on York & 72nd as well as Washington. Very dangerous.

4. Have you encountered intersections or mid-block crossings, where medians or traffic signals affect your ability to cross the street?

   Yes No

   If yes, please provide intersecting street names, location(s) and describe your concerns:

5. Have you encountered any physical obstructions like roots, trees, branches, bushes, retaining walls, signs, fire hydrants or other?

   Yes X No

   If yes, please provide street name(s), segment(s) of street, side(s) of street, and describe your concerns:

   Ditches - 73rd
   74th
   Race

6. Do you have any more specific or general comments that you feel the ADA Transition Plan team should consider related to pedestrian facilities?

   A very timely study. Be it residential or business people should feel safe when walking on the streets.
   Create a partnership with CDOT.

Thank you for participating in this survey!

Please mail hard copies to Jess Hastings at 7979 E. Tufts Avenue, Suite 800, Denver, Colorado 80237

benesch

APPENDIX H – COMPLAINT & GRIEVANCE PROCEDURES

2. COMPLAINT PROCEDURE

ADA/Section 504 Complaint Procedure

If you feel that you have not been able to access an Adams County program or service because of lack of accessibility, or that you have been discriminated against because of your disability, please fill out a written ADA Complaint Form.

Step 1: An ADA Complaint Form may be filed in writing to:

Adams County ADA/504 Coordinator
4430 South Adams County Parkway, Suite C5000B
Brighton, CO 80601-8206
720-523-6882 (phone)
720-523-6114 (fax)
Email: ADA504@adcogov.org

Complaints should contain the name and address of the person filing the complaint and describe the alleged violation of Title II of the Americans with Disabilities Act or Section 504 of the Rehabilitation Act, if appropriate, and the remedy the person believes is appropriate. A complaint must be filed within 30 calendar days after the complainant becomes aware, or should have become aware, of the alleged violation. Assistance with and/or a modification to filling out the ADA Complaint Form will be provided to those persons with disabilities requesting such assistance and/or modification.

Step 2: An investigation will follow the filing of a complaint. The ADA/504 Coordinator shall conduct the investigation unless such complaint alleges misconduct on the part of the ADA/504 Coordinator.

Step 3: Upon conclusion of the investigation a written determination shall issue within forty-five (45) working days of the filing of the ADA Complaint Form as to the validity of the complaint and description of the resolution. A copy of the written determination will be forwarded to the complainant and the affected division director.

Filed Complaints:
The ADA/504 Coordinator shall maintain the confidentiality of all files and records of any complaint, unless disclosure is authorized or required by law. The entire record shall be maintained for a period of three years.

Filing a complaint with the ADA/504 Coordinator does not preclude a complainant from filing a complaint or seeking relief from any other federal or state agency with jurisdiction over such matters.

ADA/504 Coordinator
4430 South Adams County Pkwy
County Attorney's Office, C5000B
Brighton, CO 80601-8206
Phone: 720-523-6882
Fax: 720-523-6114
Email: ADA504@adcogov.org

ADA Complaint Form

If you feel that you have not been able to access an Adams County program or service because of lack of accessibility, or that you have been discriminated against because of your disability, please fill out this form completely in print or type. Sign and return to the ADA Coordinator via email, fax, mail or in person within 30 days of the alleged incident. Complaints are processed as quickly as possible – please refer to the ADA Complaint Procedure for more information. If you require assistance completing this form, please contact the ADA Coordinator.

Complainant Information:

FIRST NAME	LAST NAME
DAYTIME PHONE (Please include area code)	ALTERNATE PHONE (Please include area code)
MAILING ADDRESS	CITY

STATE	ZIP CODE	EMAIL ADDRESS (If available)

How would you like us to contact you?

◯ Email ◯ Mail ◯ Telephone ◯ Other (specify) _____

Who do you believe discriminated against you?

NAME OF PERSON(S) COMPLAINT IS ABOUT	DATE(S) DISCRIMINATION OCCURRED
DEPARTMENT/OFFICE	PHONE (Please include area code)

BUILDING/LOCATION OF WHERE INCIDENT(S) OCCURED

Describe briefly the reason for the complaint. How and why do you believe that you have been (or someone else has been) discriminated against? Please be as specific as possible. Attach additional documentation if needed.

_____

_____

_____

_____

_____

_____

Have efforts been made to resolve this complaint directly through the applicable department/office?

◯ Yes ◯ No

If yes, what is the status of the complaint?

Has the complaint been filed with or do you intend to file the complaint with any Federal, State, or local civil rights agency or court?

◯ Yes, a complaint has been filed ◯ Yes, I intend to file a complaint ◯ No

If yes:

Agency or Court name | Date filed

Mailing Address, City, State, ZIP Code | Agency contact

Agency phone number | Other phone number | Email address

Please sign and date this request. You do not need to sign if submitting this form by email, just type your name.

Signature **Date**

Parent or Legal Guardian may sign on behalf of minor child.
Legal Guardian, Power of Attorney, or equivalent may sign on behalf of adult documentation is required.

For Administrative Use Only:

Action taken: **Date received**

ADA/504 Coordinator signature **Date**

APPENDIX I – ADA DESIGN AND CONSTRUCTION EXCEPTION FORM

ADA Design and Construction Exception Form

ADAMS COUNTY
COLORADO

Please fill out this form completely if an element of new construction or alteration to an existing facility seemingly cannot meet the ADA requirements or creates undue financial or administrative burden and return to the County Attorney's Office at:

4430 S. Adams County Pkwy.
5th Floor, Suite C5000B
Brighton, CO 80601-8206

This form applies to facilities located in public right-of-way of unincorporated Adams County or property owned by Adams County.

Project:_____

County Project No.:_____ **Location/Intersection:**_____

New Construction: ☐ **Alteration to Existing Facility:** ☐

ADA requirement seemingly not being satisfied or creating undue burden: _____

_____

_____

Reason for perceived non-compliance: _____

_____

_____

_____

Reasonable accommodation provided: _____

_____

_____

Sketch of area (if needed) or indicate if attached ☐

County Representative/Title:_____ **Date:** _____

If you have questions about this form please contact the ADA Coordinator at (720) 523-6116.

APPENDIX J – EXAMPLE SUMMARY OF WORK COMPLETED TOWARDS TRANSITION PLAN IMPLEMENTATION

CURB RAMPS

Year	# of Curb Ramps (each)

SIDEWALK

Year	Sidewalk (LF)

PEDESTRIAN PUSH BUTTONS

Year	# of Push Buttons (each)